



CSA
Group

ANSI/CSA HGV 4.1-2012

Standard for Hydrogen dispensing systems

Currently in preview, click buy full version

Legal Notice for Standards

Canadian Standards Association and CSA America, Inc. (operating as "CSA Group") develop standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use or apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and other documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Preface

This publication represents a standard for safe operation, substantial and durable construction and performance testing of the mechanical and electrical features of newly manufactured hydrogen gas dispensing systems for vehicles, intended primarily to dispense fuel directly into the vehicle fuel storage container.

This standard is based on engineering principles, research and the combined expertise of manufacturers, users, and others having specialized experience.

Nothing in this standard is to be considered in any way as indicating a measure of quality beyond compliance with the provisions it contains. It is designed to allow compliance of products which may exceed that specified in the provisions herein. In its preparation, full recognition has been given to possibilities of improvement through ingenuity of design. This standard is subject to revision as further experience and investigation may show it is necessary and desirable.

CSA Group, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. CSA Group shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of or reliance upon this standard.

Users of this American National Standard are advised that the devices/product activities within its scope may be subject to regulation at the federal, state, or local levels. Users are strongly urged to investigate this possibility through appropriate channels. In the event of a conflict with this standard, the federal, state, or local regulations should be followed.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute, Inc., require that action be taken to reaffirm, revise or withdraw this standard no later than five (5) years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute, Inc., 25 West 43rd Street, Fourth Floor, New York, N.Y. 10036, (212) 642-4900.

EFFECTIVE DATE: An organization using this standard for product evaluation as a part of its certification program will normally establish the date by which all products certified by that organization should comply with this standard.

History Of The Development Of ANSI/CSA HGV 4.1

(This History is informative and is not part of the standard.)

NOTE: This is the first edition of ANSI/CSA America HGV 4.1.

In September 2002, CSA met with the U.S. Department of Energy, Renewable Fuels Group in Washington, D.C. to discuss standards development opportunities in the hydrogen technology area. During this meeting, DOE requested that CSA provide a proposal relating to the development of hydrogen technology standards and codes in the United States.

Industry recognized that an important consideration in the successful commercialization of hydrogen gas as a vehicle fuel was the issue of codes and standards, pertaining to both fueling stations and vehicle fuel system components. CSA undertook the goal of establishing a program for the development of an organized family of coordinated standards that addresses hydrogen gas vehicles and fueling stations.

Industry and CSA recognized there was no standard that addressed safety requirements for hydrogen dispensing systems. The development of such a standard was necessary based on industry needs and feedback:

- (1) There were no standards available for hydrogen dispenser applications at the 700 bar pressure levels.
- (2) Automotive OEMs driving the application of hydrogen as a fuel for vehicles expressed concern over solutions in demonstration projects in the field.

The focus of the hydrogen dispensing system standard established performance based requirements for the mechanical and electrical features and construction of newly manufactured systems that dispense hydrogen gas for vehicles, intended primarily to dispense fuel directly into the vehicle fuel storage container.

CSA has positioned itself as a leader in the fuel cell, hydrogen and natural gas sectors as a Standards Developing Organization (SDO). CSA is aggressively updating and developing national standards, and is playing a major role in the promulgation of US technologies nationally. As US TAG Administrator to IEC TC 105 for Fuel Cell Technologies and as US TAG members of ISO TC 197 and ISO TC 22 / SC 25, CSA is facilitating US technology internationally. CSA organized committees to address technical issues in the development of standards which would affect future expansion of the hydrogen industry.

The HGV 4.1 hydrogen dispensing systems standard was processed as an American National Standard in accordance with procedures of the American National Standards Institute (ANSI).

This is the first edition of the HGV 4.1 hydrogen dispensing systems standard, and was approved by the American National Standards Institute, Inc. on March 20, 2012.

Joint Automotive Technical Committee

Livio Gambone	Powertech Labs Inc.	<i>(Chairman)</i>
Joe Cohen	Air Products and Chemicals Inc.	
Douglas Horne	Clean Vehicle Education Foundation	
John Jordan	Fab Enterprises, LLC	
Susana Katz	S. Katz and Associates Inc.	
Norman Newhouse	Lincoln Composites Inc.	
Gini Sage	General Motors of Canada Limited	
Stan Sinclair	Southern California Gas Company	
Neel Sirosh	Quantum Fuel Systems Technologies Worldwide, Inc.	
Mike Spears	SSP Fittings Corp.	
Rhoads Stephenson	Motor Vehicle Fire Research Institute	

Currently in preview, click buy full version

NGV/HGV 4.1 Technical Advisory Committee

Robert Boyd	Boyd Hydrogen LLC	
Joe Cohen	Air Products and Chemicals Inc.	
Ron Czischke	Underwriters Laboratories	
John Dimmick	Clean Vehicle Education Foundation	
Hajime Fukumoto	Japan Automobile Research Institute	
Bryan Gordon	Nuvera Fuel Cells, Inc.	
Karen Hall	Fuel Cell and Hydrogen Energy Association	
Aaron Harris	Nuvera Fuel Cells, Inc.	
Douglas Horne	Clean Vehicle Education Foundation	<i>(Alternate)</i>
Terry Jackson	Accuflex Industrial Hose Limited	
Susana Katz	S. Katz and Associates Inc.	
Samuel Lam	Ministry of Transportation	
Steven Mathison	Honda R&D Americas, Inc.	
Angela Nanalal	Powertech Labs Inc.	
Brian Nowicki	Nuvera Fuel Cell Inc	<i>(Alternate)</i>
Dev Patel	Kraus Global Inc.	
Darryl Pollica	Nuvera Fuel Cells Inc	<i>(Alternate)</i>
Brian Powers	Clean Energy Cells	
Spencer Quong	Quong & Associates, Inc.	
Volker Rothe	General Motors Corp.	<i>(Alternate)</i>
Gini Sage	General Motors of Canada Limited	
Eugene Steele	General Motors	<i>(Alternate)</i>
Perry Wage	Alberta Municipal Affairs Safety	
Matthew Weaver	PDC Machines, Inc.	
Robert Wichert	Robert P. Wichert Professional Engineering Inc.	

ANSI/CSA HGV 4.1-2012
Hydrogen dispensing systems



™A trade-mark of the Canadian Standards Association, operating as "CSA Group"

Published in May 2012 by CSA Group
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6
1-800-463-6727 • 416-747-4044

Visit our Online Store at shop.csa.ca

Currently in preview, click buy full version

To purchase standards and related publications, visit our Online Store at shop.csa.ca or call toll-free 1-800-463-6727 or 416-747-4044.

ISBN 978-1-55491-980-2

© 2012 CSA Group

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

Contents

Page

Part I Construction

1.1	Scope	3
1.2	General Construction and Assembly	4
1.3	Housing	6
1.4	Pressure Relief Valves	7
1.5	Filters	7
1.6	Valves	8
1.7	Venting	8
1.8	Piping and Fittings	8
1.9	Hoses and Nozzles	9
1.10	Pressure Indicating Devices	10
1.11	Overfill Protection	10
1.12	Automatic Temperature Compensation	10
1.13	Electrical Equipment and Wiring	11
1.14	Emergency Shutdown Systems	11
1.15	Installation, Service And Operating Instructions	12
1.16	Marking	13

Part II Performance

2.1	General	16
2.2	Leakage	16
2.3	Impact	17
2.4	Dispenser Shut-down	17
2.5	Hose Rupture	18
2.6	Hose Breakaway	18
2.7	Purging System Failure	18
2.8	Vehicle-Dispenser Interface	19
2.9	Dispenser Ground Continuity	19
2.10	Dielectric Voltage-Withstand Test	19
2.11	Rain	20
2.12	Protection Parameters	21
2.13	Marking Material Adhesion And Legibility	21

Tables

Table I	24
---------	-------	----

Figures

Figure 1.	Method of Test for Hose Rupture (Also See Section 2.5, Hose Ruptures)	26
Figure 2.	Arrangement of Spray Heads and Associated Piping for Simulated Rainstorm Test	27
Figure 3.	Spray Head Assembly and Detail of Construction	27

Contents (Continued)

	Page
Part III Manufacturing And Production Tests	28
Part IV Definitions	29
EXHIBIT A List Of Reference Standards	32
EXHIBIT B Reference List Of All CSA America HGV Series Of Documents1	33

NOTE

This standard contains SI (Metric) equivalents to the yard/pound quantities, the purpose being to allow the standard to be used in SI (Metric) units. (Standard for use of the International System of Units (SI): The Modern Metric System, IEEE/ASTM SI 10 or Metric Practice Guide, CAN/CSA Z234.1 are used as a guide in making metric conversion from yard/pound quantities.) If a value for a measurement and an equivalent value in other units, the first stated is to be regarded as the requirement. The given equivalent value may be approximate. If a value for a measurement and an equivalent value in other units, are both specified as a quoted marking requirement, the first stated unit, or both shall be provided.

ANSI/CSA HGV 4.1-2012

Hydrogen Dispensing Systems

Part I: Construction

1.1 Scope

1.1.1

This standard applies to:

- a. The mechanical and electrical features of newly manufactured systems that dispense compressed hydrogen gas for vehicles (HGV) where such systems are intended primarily to dispense the fuel directly into the fuel storage container of the vehicle.
- b. HGV dispensers that integrate in a single unit multiple dispensing functions (e.g., fuel metering, registering, control and management devices, vehicle fuel cylinder overfill and over pressure protection with listed hoses with nozzles).
- c. The following service pressures are applicable, 25MPa, 35MPa, 50MPa, 70MPa:

Each dispenser may have the capability of independently fueling more than one vehicle simultaneously

1.1.2

HGV dispensers covered by this standard are intended for use with gas composition specified by the *Hydrogen Fuel Quality for Fuel Cell Vehicles, SAE J2719*.

1.1.3

This standard applies to dispensers that include fuel metering, registering, control and management devices, vehicle fuel cylinder overfill and vehicle fuel cylinder over pressure protection.

1.1.4

This standard does not apply to dispensers that are part of a modular fueling station with remote fuel metering, registering, control and management devices, vehicle fuel cylinder overfill and over pressure protection included in an integrated fueling station control system. For these applications refer to *CSA America HGV 4.9, Hydrogen Fueling Station Safety Guideline*.

1.1.5

Installation of a dispensing system is intended to be in accordance with the, *Hydrogen Motor Fuel Dispensing and Generating Facilities Standards, ICC 2006 International Fire Code, Section 2209, or Hydrogen Technologies Code, ANSI/NFPA 2*, as applicable, and the requirements of the authority having jurisdiction.

1.1.6

All dimensions used in this standard are in metric units [International System of Units (SI)], unless otherwise specified. If a value for a measurement, as given in this standard, is followed by an equivalent value in other units, the first stated is to be regarded as the specification

1.1.7

All references to pressure throughout this document are to be considered gauge pressures unless otherwise specified.