



**CSA
Group**

N1600-14

General requirements for nuclear emergency management programs

Currently in preview, click buy full versi

Legal Notice for Standards

Canadian Standards Association (operating as "CSA Group") develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group's and/or others' intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or PDF form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way, or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

N1600-14

May 2014

Title: *General requirements for nuclear emergency management programs*

To register for e-mail notification about any updates to this publication

- go to shop.csa.ca
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **242278**

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at csagroup.org/legal to find out how we protect your personal information.

N1600-14

***General requirements for nuclear
emergency management programs***



™A trade-mark of the Canadian Standards Association, operating as "CSA Group"

*Published in May 2014 by CSA Group
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6*

*To purchase standards and related publications, visit our Online Store at shop.csa.ca
or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-77139-413-0

*© 2014 CSA Group
All rights reserved. No part of this publication may be reproduced in any form whatsoever without
the prior permission of the publisher.*

Contents

Technical Committee on General Requirements for Nuclear Emergency Management Programs 5

Preface 8

0 Introduction 9

0.1 General 9

0.2 Plan-do-check-act (PDCA) cycle 9

0.3 Components of emergency management 10

0.3.1 Prevention and mitigation 10

0.3.2 Preparedness 11

0.3.3 Response 11

0.3.4 Recovery 11

1 Scope 12

2 Reference publications 13

3 Definitions 15

4 Nuclear emergency management program (NEMP) 22

4.1 General 22

4.1.1 NEMP overview 22

4.1.2 NEMP elements 22

4.1.3 Integration 23

4.1.4 Alternatives 24

4.2 Planning basis 24

4.2.1 Hazards identification 24

4.2.2 Risk assessment 24

4.2.3 Impact analysis 25

4.2.4 NPP planning basis requirements 25

4.2.5 Off-site planning basis requirements 26

4.2.6 Review frequency 26

4.3 Communication 26

4.3.1 General 26

4.3.2 Communication needs analysis 27

4.3.3 Process for external communication 27

4.3.4 Data and information needs for effective communication 28

4.3.5 Data and information transmittal requirements for NPPs 28

4.3.6 Communications plan establishment 29

4.3.7 Communications plan scope 29

4.3.8 Communication procedures 29

4.3.9 Testing of communication systems 30

4.4 Program management 30

4.4.1 Planning cycle for the NEMP 30

4.4.2 Leadership and commitment 31

4.4.3 Program coordination 31

4.4.4 NEMP review committee 32

4.4.5	NEMP administration	32
4.4.6	Laws and authorities	34
4.4.7	Financial management	34
4.4.8	NEMP maintenance	35
4.5	Nuclear emergency response plan	35
4.5.1	General	35
4.5.2	Nuclear emergency response plan development	36
4.5.3	Response organizational requirements	38
4.5.4	Nuclear emergency categorization and notification	40
4.5.5	Emergency assessment	41
4.5.6	Protective actions	42
4.5.7	Interface and support between response organizations	45
4.5.8	Emergency personnel protection	47
4.5.9	Critical facilities and support resources	49
4.5.10	Communication, information flow, and public alerting systems	52
4.5.11	Continuity of nuclear emergency response operations	54
4.5.12	Deviation from the nuclear emergency response plan	54
4.5.13	Validation of the nuclear emergency response plan and procedures	54
4.5.14	Nuclear emergency response plan maintenance	55
4.6	Nuclear emergency recovery plan	55
4.6.1	Nuclear emergency recovery plan development	55
4.6.2	Transition from response to recovery	56
4.6.3	Plan implementation authority	56
4.6.4	Technical resource needs	56
4.6.5	Scope of the nuclear emergency recovery plan	56
4.6.6	Recovery organizational requirements	57
4.6.7	Other resource requirements	58
4.6.8	Communications and information flow	58
4.6.9	Continuity of nuclear emergency recovery operations	59
4.6.10	Deviation from the nuclear emergency recovery plan	59
4.6.11	Nuclear emergency recovery plan accessibility	59
4.6.12	Validation of the nuclear emergency recovery plan and procedures	59
4.6.13	Nuclear emergency recovery plan maintenance	60
4.7	Training	60
4.7.1	General	60
4.7.2	Levels of training	60
4.7.3	Training requirements	60
4.7.4	Competencies	60
4.7.5	Training design	61
4.7.6	Systematic approach to training	61
4.7.7	Frequency and scope	61
4.7.8	Qualification maintenance	61
4.7.9	On-site and off-site emergency response	61
4.7.10	Record retention	61
4.8	Facilities and equipment maintenance	61
4.8.1	Working condition assurance	61
4.8.2	Functionality inspections and tests	61
4.8.3	System testing	62
4.8.4	Gaps and limitations	62

4.8.5	Corrective action plans	62
4.9	Public awareness and education	62
4.9.1	General	62
4.9.2	Program requirements	62
4.9.3	Capabilities	63
4.9.4	Accountability	63
4.10	Exercises	63
4.10.1	Exercise program	63
4.10.2	Exercise schedule	66
4.10.3	Exercise design	66
4.10.4	Exercise facilitator qualifications	66
4.10.5	Exercise preparation	67
4.10.6	Exercise conduct	68
4.10.7	Post-exercise activities	69
4.10.8	Exercise evaluation	70
5	Response	71
5.1	Activation of the nuclear emergency response plan	71
5.2	Inter-organizational emergency response coordination	71
5.3	Assessment of the response needs	71
5.4	Deviation from the nuclear emergency response plan	71
5.5	Termination of the emergency response phase	72
5.6	Response evaluation	72
5.6.1	General	72
5.6.2	Evaluation considerations	72
6	Recovery	72
6.1	Activation of the nuclear emergency recovery plan	72
6.2	Inter-organizational nuclear emergency recovery coordination	72
6.3	Assessment of the recovery needs	72
6.4	Deviation from the nuclear emergency recovery plan	73
6.5	Termination of the recovery operation	73
6.6	Recovery evaluation	73
6.6.1	General	73
6.6.2	Evaluation considerations	73
7	NEMP evaluation, audit and review	73
7.1	NEMP evaluation	73
7.1.1	NEMP review committee	73
7.1.2	Development of an evaluation plan	74
7.1.3	Review plan processes	74
7.1.4	Currency and completeness	74
7.1.5	Consideration of interfaces	75
7.1.6	Corrective actions	75
7.2	NEMP audit	75
7.3	NEMP review	75
7.3.1	Continuous improvement process	75
7.3.2	Corrective action process	75

8	Management oversight	76
8.1	Senior management oversight	76
8.1.1	General	76
8.1.2	Oversight considerations	76
8.1.3	Frequency of review	76
8.2	Continual improvement	76
8.2.1	Review process	76
8.2.2	Assessments and benchmarking	76
8.2.3	Lessons learned	76

Annex A (informative)	— Introduction figures	77
Annex B (informative)	— Nuclear emergency management program overview	79
Annex C (informative)	— Conversion equivalence table	80

Technical Committee on General Requirements for Nuclear Emergency Management Programs

J. Coles	Ontario Power Generation Inc., Darlington Nuclear, Bowmanville, Ontario <i>Representing User Interest</i>	<i>Chair</i>
R. Kinchlea	Centennial College, Toronto, Ontario <i>Representing General Interest</i>	<i>Vice Chair</i>
N. Ali	Environment Canada, Toronto, Ontario	<i>Associate</i>
D. Beaton	Health Canada Radiation Protection Bureau, Ottawa, Ontario	<i>Associate</i>
K. Bleyer	Emergency Management Ontario, Toronto, Ontario	<i>Associate</i>
J. Byard	The Regional Municipality of Durham, Whitby, Ontario <i>Representing Public Safety Interest</i>	
K. Charles	Canadian Red Cross, Waterloo, Ontario <i>Representing General Interest</i>	
L. Crevier-McKenna	Public Safety Canada, Ottawa, Ontario <i>Representing Government and/or Regulatory Authority</i>	
Y. Dadash	Candesco, Toronto, Ontario <i>Representing Professional Services</i>	
C. Fisher	Atomic Energy of Canada Ltd. (AECL), Chalk River, Ontario <i>Representing User Interest</i>	

L. Gilbert	Bruce Power, Tiverton, Ontario	<i>Associate</i>
D. Gration	Environment Canada Meteorological Service of Canada, Toronto, Ontario	<i>Associate</i>
J. Hagg	City of Pickering, Pickering, Ontario <i>Representing Public Safety Interest</i>	
M. Hand	Newmarket, Ontario <i>Representing General Interest</i>	
T.P. Harkness	Pat Harkness and Associates, Chilliwack, British Columbia <i>Representing Professional Services</i>	
C.N. Hickman	NB Power Corporation, Fredericton, New Brunswick <i>Representing User Interest</i>	
D. Kozak	Ontario Power Generation Inc., Pickering, Ontario	<i>Associate</i>
M. Mantha	Atomic Energy of Canada Ltd. (AECL), Chalk River, Ontario	<i>Associate</i>
D. McArthur	Bruce Power, Tiverton, Ontario <i>Representing User Interest</i>	
T. Nguyen	Canadian Nuclear Safety Commission (CNSC), Ottawa, Ontario	<i>Associate</i>
D. Nodwell	Emergency Management Ontario, Toronto, Ontario <i>Representing Government and/or Regulatory Authority</i>	
D. Payne	Health Canada Radiation Protection Bureau, Ottawa, Ontario <i>Representing Government and/or Regulatory Authority</i>	

L. Sigouin	Canadian Nuclear Safety Commission (CNSC), Ottawa, Ontario <i>Representing Government and/or Regulatory Authority</i>	
W. Summach	Cameco Corporation, Saskatoon, Saskatchewan	<i>Associate</i>
F. Tourneur	University Health Network, Toronto, Ontario <i>Representing General Interest</i>	
G. Weir	Municipality of Clarington, Clarington Emergency & Fire Services, Bowmanville, Ontario <i>Representing Public Safety Interest</i>	
R. Wheeler	Shearwater Environmental Emergency Solutions Inc., Toronto, Ontario <i>Representing Professional Services</i>	
C. Sellar	CSA Group, Mississauga, Ontario	<i>Project Manager</i>

Preface

This is the first edition of CSA N1600, *General requirements for nuclear emergency management programs*.

This Standard provides requirements for a comprehensive nuclear emergency management (EM) program embracing the EM components (prevention/mitigation, preparedness, response, and recovery) in keeping with international EM practice, with a predominant focus on preparedness, response, and recovery. It establishes the elements of a continuous improvement process to develop, implement, maintain, and evaluate the EM functions of nuclear facilities and their surrounding communities.

Users of this Standard are reminded that the site selection, design, manufacture, construction, installation, commissioning, operation, and decommissioning of nuclear facilities in Canada are subject to the *Nuclear Safety and Control Act* and its *Regulations*. The Canadian Nuclear Safety Commission might impose additional requirements to those specified in this Standard.

The CSA N-Series Standards provide an interlinked set of requirements for the management of nuclear facilities and activities. The CSA N286 Standard provides overall direction to management to develop and implement sound management practices and controls, while the other CSA nuclear Standards provide technical requirements and guidance that support the management system. This Standard works in harmony with CSA N286 and does not duplicate the generic requirements of CSA N286; however, it might provide more specific direction for those requirements.

This Standard was prepared by the Technical Committee on General Requirements for Nuclear Emergency Management Programs, under the jurisdiction of the Strategic Steering Committee on Nuclear Standards, and has been formally approved by the Technical Committee.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This publication was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.
- 5) *This Standard is subject to review five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

N1600-14

General requirements for nuclear emergency management programs

0 Introduction

Note: Words that appear in bold throughout the Standard (with the exception of clause titles) are defined in Clause 3, Definitions.

0.1 General

This Standard establishes criteria for the **emergency management** programs of on- and **off-site** organizations to address nuclear emergencies at Canadian **nuclear power plants (NPPs)**. The approach taken is aimed at the protection of health and safety, property, and the environment from nuclear emergencies through a risk-based program of **prevention, mitigation, preparedness, response, and recovery** (see Clause 0.3). This Standard reflects the convergence seen over the past several years of public and private sector **emergency management** efforts.

This Standard has been developed to help organizations that might be involved in or affected by a potential **nuclear emergency** to establish and implement a **nuclear emergency management program (NEMP)** that is appropriate to its needs. These needs could be shaped by legal, regulatory, organizational, and industry requirements, the products and services, the processes employed, the size and structure of the **organization**, and the needs and requirements of its **stakeholders**.

To facilitate its use and adoption, this Standard is aligned with the plan-do-check-act (PDCA) cycle (see Clause 0.2) referred to in other standards as a continual improvement model. This supports consistent and integrated implementation and operation within and between organizations' management systems. This Standard also supports the components of **emergency management** (see Clause 0.3) developed by the federal, provincial, and territorial governments in their document *An Emergency Management Framework for Canada* (Public Safety Canada), which not only establishes a common approach for the various **emergency management** initiatives but also enables consolidation of collaborative work and ensures more coherent, complementary actions among the different **stakeholders**.

This Standard is applicable to all types and sizes of organizations, regardless of whether or not a formal management system is in place.

0.2 Plan-do-check-act (PDCA) cycle

As indicated in Clause 0.1, this Standard is aligned with the PDCA cycle (see Annex A, Figure A.1).

The first phase of the PDCA cycle is the “plan” phase. During this phase, a plan is developed. In this Standard, the “plan” phase is reflected in Clause 4, **Nuclear emergency management program**, specifically Clause 4.2, Planning basis, Clause 4.4, Program management, Clause 4.5, Nuclear emergency response plan, and Clause 4.6, Nuclear emergency recovery plan.

The second phase of the PDCA cycle is the “do” phase. In this phase, the plan is carried out. In this Standard, the “do” phase is reflected in Clause 4.7, Training, Clause 4.8, Facilities and equipment,

Clause 4.9, Public awareness and education building, Clause 4.10, Exercises, Clause 5, **Response**, and Clause 6, **Recovery**.

The third phase of the PDCA cycle is the “check” phase. In this phase, a review takes place of what was intended and what was observed in the previous step (the “do” phase). It is focused on measuring effectiveness and analyzing for improvement. In this Standard, the “check” phase is covered in Clause 4.10, Exercises, and Clause 7, NEMP evaluation, audit, and review.

In the last phase of the PDCA cycle, “act”, action is taken on the causal system to effect the desired change. It is focused on fully implementing the improved solution. In this Standard, the “act” phase is addressed in Clause 7.3, NEMP review, and Clause 8, Management oversight.

0.3 Components of emergency management

Note: See Annex A, Figure A.2, for examples on how PDCA relates to the **emergency management** components.

0.3.1 Prevention and mitigation

0.3.1.1 Prevention

Preventing nuclear emergencies from occurring at Canadian **NPPs** is the responsibility of the **NPP** operators. Through the authority of the *Nuclear Safety and Control Act*, the CNSC regulates the Canadian nuclear industry in order to prevent unreasonable risk to the environment, the health and safety of persons, and national security.

In addition to the regulatory requirements of the *Nuclear Safety and Control Act*, CSA nuclear standards promote the safe and reliable operation of the nuclear power industry in Canada, and subsequently support the **prevention** of nuclear emergencies. This includes, but is not limited to, CSA nuclear standards addressing requirements for systems, structures, and components (SSCs); periodic and in-service inspections; fire protection; and environmental qualification. CSA nuclear standards capture leading practices for industry, document operating experience in order to capture and transfer knowledge, benchmark and harmonize with internationally accepted requirements and practices, and are frequently referenced in Licence and Licence Condition Handbooks of **NPPs** across Canada.

Given this comprehensive approach to the **prevention** of nuclear emergencies in Canada, **prevention** is not addressed in depth in this Standard because it is addressed through the requirements of the **AHJ**.

Notes:

- 1) **“Prevention”** is defined as actions taken to ensure that a **nuclear emergency** does not occur in the first place, or to reduce its likelihood of occurring.
- 2) A **“prevention strategy”** refers to measures taken by an **organization** which aim to prevent a **nuclear emergency** from occurring or completely avoiding the impacts of such a **nuclear emergency**.
- 3) Examples of **prevention** measures include
 - a) design of systems, operations, and infrastructure;
 - b) location of systems, operations, and infrastructure;
 - c) use of appropriate materials, systems, operations, and infrastructure;
 - d) institution of controls; and
 - e) institution of protection and security measures such as controlled access, quarantine, permits, and clearances.

0.3.1.2 Mitigation

On-site **mitigation** of nuclear emergencies is the responsibility of the **NPP** operators. **Off-site mitigation** of nuclear emergencies tends to be driven by local authorities, and may comprise structural measures (e.g., dykes, building reinforcements, etc.) or non-structural measures (e.g., land use planning and

building codes, public awareness, etc.). It is worth noting that Public Safety Canada's National Disaster Mitigation Strategy (NDMS) promotes **mitigation** as an important component of a robust **emergency management** framework.

The NDMS also emphasizes that it is important for all **stakeholders** to commit to working together to support **mitigation** activities in Canada. The development of this Standard is a reflection of this commitment and one avenue through which the integration of nuclear emergency **mitigation** strategies can occur. **Mitigation** is directly touched upon in Clauses 4.1.1 and 4.6.1.5 of this Standard. It is important to note that **mitigation** is not addressed in depth in this Standard.

Note: *Examples of mitigation strategies include*

- a) *recognizing, removing, or reducing the potential consequence of the hazard;*
- b) *integrating risk mitigation strategies into the design of program initiatives for those assumptions with the highest risk rating;*
- c) *integrating continuity management strategies into the design of the program such as duplicating or reallocating resources to deal with these strategies;*
- d) *establishing hazard warning and communications systems;*
- e) *protecting proprietary information and vital records;*
- f) *providing protective systems to safeguard information technology; and*
- g) *adopting current building and appropriate land-use practices.*

0.3.2 Preparedness

"Preparedness" is defined as actions taken prior to a **nuclear emergency** to be ready to respond to it and manage its consequences (Public Works and Government Services Canada, *Emergency Management Vocabulary*). **Preparedness** for nuclear emergencies is a multi-jurisdictional responsibility that is shared by **NPPs** and all levels of government in Canada (i.e., federal government, provincial or territorial governments, and local governments). This is reflected in the number, variety, and integration of plans at all levels (see Annex B).

Nuclear emergency **preparedness** is addressed in Clause 4, **Nuclear emergency management program**, and includes the following:

- a) development of nuclear emergency response and recovery plans (see Clauses 4.5 and 4.6);
- b) training workers who would be engaged in **response/recovery** efforts (see Clause 4.7);
- c) testing of emergency **response/recovery** equipment (see Clause 4.8);
- d) public awareness and education (see Clause 4.9); and
- e) exercising the implementation of emergency plans (see Clause 4.10).

0.3.3 Response

"Response" is defined as actions taken during a **nuclear emergency** to reduce the magnitude of the hazard and manage its consequences, including the impact of the hazard on people, property, and the environment. **Response** actions include, but are not limited to, emergency public communication, search and rescue, emergency medical assistance, and **shelter-in-place** or evacuation to minimize suffering and losses associated with nuclear emergencies. In addition, nuclear emergency response planning, training, and exercising often occur as part of the **preparedness** efforts. Nuclear emergency response planning (including development, validation, and maintenance) is therefore addressed in Clause 4.5, Nuclear emergency response plan, and the active **response** phase requirements (including plan activation, needs assessment, plan deviation, **response** termination) are defined in Clause 5, **Response**.

0.3.4 Recovery

"Recovery" can be defined as the short-term and long-term actions taken in order to restore, to an acceptable level, both the organizations involved in, and the communities affected by, the **nuclear**

emergency and its associated **response** activities. The level of restoration would typically be determined by the authorities having jurisdiction (**AHJ**), in consultation with the **stakeholders** affected by the **nuclear emergency**. Note that there is a strong relationship between long-term sustainable **recovery** and **prevention** and **mitigation** of future nuclear emergencies. Consequently, **recovery** efforts should be conducted with a view towards risk reduction. Examples of **recovery** efforts include, but are not limited to, environmental monitoring and remediation, containment and disposal of contaminants, psychological and psychosocial support, reconstruction, economic **recovery**, financial assistance, and long-term medical follow-up.

The implementation of **mitigation** strategies can occur in parallel with **recovery** functions. In addition, nuclear emergency **recovery** planning, training, and exercising could occur as part of the **preparedness** efforts. Nuclear emergency **recovery** planning (including development, validation, and maintenance) is therefore addressed in Clause 4.6, Nuclear emergency recovery plan, and the active **recovery** phase requirements (including plan activation, inter-organizational nuclear emergency **recovery** coordination, needs assessment, plan deviation, and termination of the **recovery** operation) are defined in Clause 6, **Recovery**.

1 Scope

1.1

This Standard establishes criteria for the **emergency management** programs of on- and **off-site** organizations to address nuclear emergencies at Canadian nuclear power plants (**NPPs**).

Notes:

- 1) *This Standard may provide guidance for nuclear facilities other than **NPPs**. The operators of these facilities may, together with the **authorities having jurisdiction (AHJs)**, determine the applicability and suitability of the guidance provided by this Standard.*
- 2) *The requirements in this Standard are applied in accordance with the jurisdictional responsibilities of the **organization**.*

1.2

This Standard provides the unique requirements to develop, implement, evaluate, maintain, and continuously improve a **nuclear emergency management program (NEMP)** for **prevention, mitigation, preparedness, response, and recovery** from a **nuclear emergency** at an **NPP**.

1.3

This Standard does not apply to nuclear emergencies at

- a) **Class IB nuclear facilities;**
- b) **Class II nuclear facilities;** and
- c) uranium mines and mills.

1.4

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

2 Reference publications

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below.

CSA Group

N286-05 (withdrawn)

Management system requirements for nuclear power plants

N286-12

Management system requirements for nuclear facilities

N288.6-12

Environmental risk assessments at class I nuclear facilities and uranium mines and mills

N292.0-14

General principles for the management of radioactive waste

N292.3-14

Management of low- and intermediate-level radioactive waste

N294-09

Decommissioning of facilities containing nuclear substances

Z764-96 (R2012)

A guide to public involvement

CNSC (Canadian Nuclear Safety Commission)

CNSC RD/GD-99.3 (2012)

Public Information and Disclosure

CNSC Regulatory Guide G-306 (2006)

Severe Accident Management Programs for Nuclear Reactors

Government of Canada

Nuclear Liability Act, R.S.C. 1985, c. N-28

Nuclear Safety and Control Act, S.C. 1997, c. 9

Class I Nuclear Facilities Regulations (SOR/2000-204)

Class II Nuclear Facilities and Prescribed Equipment Regulations (SOR/2000-205)

Security Regulations (SOR/2000-209)