

Workplace electrical safety



Legal Notice for Standards

Canadian Standards Association (CSA) standards are developed through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

CSA is a private not-for-profit company that publishes voluntary standards and related documents. CSA has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Important notice and disclaimer concerning the NFPA standard from which this document has been adapted

This document is adapted by the Canadian Standards Association (CSA), from an NFPA document originally developed and promulgated by the National Fire Protection Association (NFPA). The NFPA 70E standard contained within this NFPA document in its original format, like all NFPA codes and standards, is developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards. All commentary, other than the promulgated standard, has been developed by the NFPA or the CSA.

The NFPA and the CSA disclaim liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA and the CSA also make no guarantee or warranty as to the accuracy or completeness of any information published in these documents.

In issuing and making this document available, the NFPA and the CSA are not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA or CSA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Neither the NFPA nor the CSA has any power, nor do they undertake, to police or enforce compliance with the contents of this document. Nor do the NFPA or CSA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of these documents shall not be attributable to the NFPA or CSA and is solely the responsibility of the certifier or maker of the statement.

For additional notices and disclaimers concerning NFPA codes and standards see www.nfpa.org/disclaimers.

Intellectual property rights and ownership

This document is a derivative work adapted by the Canadian Standards Association (CSA) from NFPA 70E, *Standard for Electrical Safety in the Workplace* (2018 edition), the rights to which were licensed to CSA by the National Fire Protection Association®. Copyright to this document is held by the National Fire Protection Association®. CSA is the owner of all trademarks (except as otherwise noted to the contrary). Without limitation, the unauthorized use, modification, copying, or distribution of this document may violate laws that protect NFPA and CSA, as authorized licensee, and may give rise to a right in NFPA and/or CSA to seek legal redress for such use, modification, copying, or distribution. To the extent permitted by license or law, CSA and the NFPA reserve all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.



Standards Update Service

CSA Z462:21 January 2021

Title: *Workplace electrical safety*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **24285-7**

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada



A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada



Standards Council of Canada
Conseil canadien des normes

Cette Norme Nationale du Canada n'est disponible qu'en anglais.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

**A trademark of the Canadian Standards Association, operating as “CSA Group”*

National Standard of Canada

CSA Z462:21
Workplace electrical safety



®A trademark of the Canadian Standards Association,
operating as "CSA Group."



Published in January 2021 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3

To purchase standards and related publications, visit our Online Store at store.csagroup.org
or call toll-free 1-800-463-6727 or 416-747-4044.

ICS 13.260
ISBN 978-1-4883-3240-1

All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.

Currently in preview, click buy full version

Copyright © 2018 National Fire Protection Association®

Certain clauses and annexes are Copyright © 2021 Canadian Standards Association

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior written permission of CSA Group, as authorized licensee of the National Fire Protection Association.

National Fire Protection Association and NFPA are registered trademarks of the National Fire Protection Association, Quincy, Massachusetts, USA.

Contents

Technical Committee on Workplace Electrical Safety	5
Preface	9
1 Scope	11
1.1 General	11
1.2 Application	11
1.3 Suitability	11
1.4 Use with related standards and regulations	11
1.5 Organization of this Standard	11
1.6 Measurements	12
1.7 Terminology	12
2 Reference publications	12
3 Definitions	22
4 Safety-related work practices	32
4.1 General requirements for electrical-safety-related work practices and procedures	32
4.1.1 General	32
4.1.2 Purpose	32
4.1.3 Responsibility	33
4.1.4 Organization	33
4.1.5 Electrical safety policy	33
4.1.6 Electrically safe work condition	33
4.1.7 Electrical safety program	34
4.1.8 Training	38
4.1.9 Host and contract employer's responsibilities	41
4.1.10 Electrical equipment	42
4.1.11 Test instruments and equipment	42
4.1.12 Portable (cord-and-plug connected) electric equipment	42
4.1.13 Ground-fault circuit interrupter (GFCI) protection	44
4.1.14 Overcurrent protection modification	45
4.2 Establishing an electrically safe work condition	45
4.2.1 Lockout program	45
4.2.2 Lockout principles	45
4.2.3 Lockout equipment	46
4.2.4 Lockout procedures	47
4.2.5 Process for establishing and verifying an electrically safe work condition	51
4.2.6 Temporary protective grounding equipment	52
4.3 Work involving electrical hazards	53
4.3.1 General	53
4.3.2 Energized electrical work permit	53
4.3.3 [Reserved for future use]	54
4.3.4 Shock risk assessment	54
4.3.5 Arc flash risk assessment	57

4.3.6	[Reserved for future use]	63
4.3.7	Personal and other protective equipment	63
4.3.8	Other precautions for personnel activities	81
4.3.9	Work within the limited approach boundary of overhead lines	83
4.3.10	Underground electrical lines and equipment	84
4.3.11	Cutting or drilling	84
4.3.12	Cutting, removing, or rerouting of conductors	85
5	Safety-related maintenance requirements	86
5.1	General	86
5.2	Maintenance program	86
5.3	General maintenance requirements	86
5.3.1	Equipment maintenance	86
5.3.2	Qualified persons	87
5.3.3	Single-line diagram	87
5.3.4	Identification of components	87
5.3.5	Identification of circuits	87
5.3.6	Warning signs	87
5.3.7	Spaces about electrical equipment	87
5.3.8	Grounding and bonding	87
5.3.9	Safety equipment	88
5.3.10	Life safety systems	88
5.3.11	Electrical cables and single and multiple conductors	88
5.3.12	Overhead line clearances	88
5.4	Specific maintenance requirements	88
5.4.1	Protective devices	88
5.4.2	Overcurrent relays	88
5.4.3	Fuses	89
5.4.4	Arc flash relays	89
5.4.5	Ground fault devices and system	89
5.4.6	Disconnecting means	89
5.4.7	Capacitors	90
5.4.8	Control equipment	90
5.4.9	Equipment in hazardous locations	90
5.4.10	Batteries and battery rooms	90
6	Safety requirements for special equipment	91
6.1	General	91
6.1.1	Organization of Clause 6	91
6.1.2	Responsibility	91
6.2	Safety-related work practices for electrolytic cells	91
6.2.1	General	91
6.2.2	Safety training	91
6.2.3	Worker training	91
6.2.4	Safeguarding of workers in the cell line working zone	92
6.2.5	Portable tools and equipment	95
6.2.6	Maintenance of electrolytic cells	96
6.3	Safety requirements related to batteries and battery rooms or battery enclosures	96
6.3.1	General	96

6.3.2	Safety procedures	96
6.3.3	Electrolyte hazards	98
6.3.4	Tools and equipment	98
6.3.5	Cell flame arresters and cell ventilation	98
6.4	Safety-related work practices for use of lasers	99
6.4.1	General	99
6.4.2	Hazardous energy	99
6.4.3	Electrical safety training	99
6.4.4	Safeguarding of persons from electrical hazards associated with lasers and laser systems	99
6.4.5	Responsibility for electrical safety	100
6.5	Safety-related work practices for power electronic equipment	100
6.5.1	General	100
6.5.2	Hazards associated with power electronic equipment	100
6.5.3	Specific measures for personnel safety	101
6.6	Safety-related work requirements for research and development laboratories	101
6.6.1	General	101
6.6.2	Applicability of this Standard	102
6.6.3	Competent person	102
6.6.4	Establishment of an electrical safety authority	102
6.6.5	Specific measures and controls for personnel safety	102
6.6.6	Approval	103
6.6.7	Custom built, non-approved research equipment, 1000 V or less, ac or dc	103
6.6.8	Custom built, unlisted research equipment, greater than 1000 V, ac or dc	104
6.6.9	Energy thresholds	104
6.6.10	Establishing an electrically safe work condition	104

Annex A (informative)	— Aligning implementation of this Standard with CSA Z45001	105
Annex B (informative)	— Safety-related electrical maintenance	111
Annex C (informative)	— Limits of approach	114
Annex D (informative)	— Incident energy and arc flash boundary calculation methods	118
Annex E (informative)	— Electrical safety program	126
Annex F (informative)	— Risk assessment and risk control	128
Annex G (informative)	— Sample lockout policy and program and sample general lockout procedure (individual lockout)	133
Annex H (informative)	— Guidance on selection of protective clothing and other personal protective equipment	142
Annex I (informative)	— Sample job briefing and planning checklists	147
Annex J (informative)	— Sample energized electrical work permit	151
Annex K (informative)	— General categories of electrical hazards	154
Annex L (informative)	— Typical application of safeguards in the cell line working zone	157
Annex M (informative)	— Layering of protective clothing and total system arc rating	158
Annex N (informative)	— Example of industrial procedures and policies for working within the limited approach boundary of overhead or buried electrical power lines and equipment	160
Annex O (informative)	— Safety-related design	164
Annex P (informative)	— Electrical switching and isolation	168
Annex Q (informative)	— Arc flash and shock warning equipment labels	173
Annex R (informative)	— Substation systems and equipment	176

Annex S (informative) — Guidance for preventing shock injuries from electrostatic discharges in manufacturing operations	185
Annex T (informative) — Temporary protective grounding	187
Annex U (informative) — Human performance and workplace electrical safety	191
Annex V (normative) — Arc flash PPE categories	202
Annex W (informative) — Bibliography	208
Annex X (informative) — Requests for amendments to CSA Z462	210

Technical Committee on Workplace Electrical Safety

C. M. Black	IFR Workwear Inc, Red Deer, Alberta, Canada <i>Category: Producer Interest</i>	<i>Chair</i>
V. Balitski	Magna IV Engineering, Edmonton, Alberta, Canada <i>Category: User Management</i>	<i>Vice-Chair</i>
T. W. Becker	TW Becker Electrical Safety Consulting, Calgary, Alberta, Canada <i>Category: General Interest</i>	
F. Bergeron	CNESST, Joliette, Québec, Canada <i>Category: Regulatory Authority</i>	
F. Boudreau	WorkSafeNB, Dieppe, New Brunswick, Canada <i>Category: Regulatory Authority</i>	
J. Brkljacich	Vale, Copper Cliff, Ontario, Canada	<i>Non-voting</i>
I. Bullock	Alberta Health Services, Lethbridge, Alberta, Canada	<i>Non-voting</i>
J. Burt	REV Engineering Ltd., Calgary, Alberta, Canada	<i>Non-voting</i>
D. G. Campbell	Vale, Thompson, Manitoba, Canada <i>Category: User Labour</i>	
T. Cecchini	Ontario Power Generation, Timmins, Ontario, Canada	<i>Non-voting</i>
K. S. Cheng	Kinectrics Inc., Toronto, Ontario, Canada <i>Category: General Interest</i>	

G. Christensen	PCL Construction, Sherwood Park, Alberta, Canada <i>Category: User Labour</i>	
L. Cicero	Lenco Training & Tech. Services, Burlington, Ontario, Canada <i>Category: General Interest</i>	
M. E. Doherty	Blue Arc Electrical Safety Technologies Inc, Oshawa, Ontario, Canada <i>Category: General Interest</i>	
N. El-Sherif	MNKYBR Technologies Inc, Saskatoon, Saskatchewan, Canada	<i>Non-voting</i>
M. Fitzpatrick	TC Energy, Calgary, Alberta, Canada	<i>Non-voting</i>
P. S. Ghosh	PSAMS Inc, Calgary, Alberta, Canada <i>Category: General Interest</i>	
K. Gray	Hydro-Québec, Montréal, Québec, Canada <i>Category: Regulatory Authority</i>	
R. Hallé	BBA, Mont-Saint-Hilaire, Québec, Canada	<i>Non-voting</i>
J. Hansen	Unifor, Windsor, Ontario, Canada <i>Category: User Labour</i>	
K. Heid	Shermco Industries Canada Inc., Regina, Saskatchewan, Canada <i>Category: General Interest</i>	
J. Hiller	De Beers Group Managed Operations, Calgary, Alberta, Canada	<i>Non-voting</i>
M. B. Hodder	Eaton Industries (Canada) Company, Milton, Ontario, Canada	<i>Non-voting</i>
C. K. Kennedy	BCE, St. John's, Newfoundland and Labrador, Canada	<i>Non-voting</i>

A. Kerr	Burlington Hydro, Burlington, Ontario, Canada <i>Category: User Management</i>	
G. Kooner	Vancouver Airport Authority, Richmond, British Columbia, Canada <i>Category: User Management</i>	
G. Leask	Bruce Power, Tiverton, Ontario, Canada <i>Category: User Management</i>	
S. Leblanc	ArcelorMittal, Port-Cartier, Québec, Canada	<i>Non-voting</i>
J. Milinkovic	Ontario Ministry of Labour, Training and Skills Development, Mississauga, Ontario, Canada	<i>Non-voting</i>
R. Mitchell	Electrical Safety Authority, Mississauga, Ontario, Canada <i>Category: Regulatory Authority</i>	
J. Moody	Westex by Milliken, Spartanburg, South Carolina, USA <i>Category: Producer Interest</i>	
A. Muzyczka	Manitoba Hydro, Gillam, Manitoba, Canada <i>Category: Regulatory Authority</i>	
S. Nair	WorkSafe BC, Richmond, British Columbia, Canada	<i>Non-voting</i>
R. W. Neish	Shell Global Solutions Canada, Calgary, Alberta, Canada	<i>Non-voting</i>
D. Okaekwu	Department of Labour and Advanced Education, Occupational Health & Safety Division, Dartmouth, Nova Scotia, Canada <i>Category: Regulatory Authority</i>	
P. Olders	Toronto, Ontario, Canada <i>Category: User Labour</i>	

J. Pollard	Unlimited PPE Inc., Stoney Creek, Ontario, Canada <i>Category: Producer Interest</i>	
D. T. Roberts	Schneider Electric, Mississauga, Ontario, Canada <i>Category: Producer Interest</i>	
T. Sawatzky	Husky Oil Operations Limited, Calgary, Alberta, Canada <i>Category: User Management</i>	
L. G. Silecky	Mersen Canada Toronto Inc., Mississauga, Ontario, Canada <i>Category: Producer Interest</i>	
P. Urbanek	United Association Local 787, Joint Training and Apprenticeship, Brampton, Ontario, Canada <i>Category: User Labour</i>	
M. E. Valdes	ABB, Chapel Hill, North Carolina, USA <i>Category: Producer Interest</i>	
T. Donovska	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Preface

This is the fifth edition of CSA Z462, *Workplace electrical safety*. It supersedes the previous editions published in 2018, 2015, 2012, and 2008.

This Standard is based on NFPA 70E, *Standard for Electrical Safety for the Workplace*, and has been harmonized with Parts I, II, and III of the *Canadian Electrical Code*; CSA Z460, *Control of hazardous energy — Lockout and other methods*; and CSA M421, *Use of electricity in mines*. This revised edition of CSA Z462 has been developed by CSA Group from the original edition as promulgated by the National Fire Protection Association. In addition to its initial source, it includes significant revisions by CSA Group. This Standard is fully the responsibility of CSA Group. The NFPA, holder of the copyright in this edition, takes no responsibility for any portion thereof.

This Standard specifies requirements for and provides guidance on safety management systems, safe work procedures, and selection of personal protective equipment and other safety devices for persons exposed to hazards associated with energized electrical equipment. In addition, this Standard sets out criteria for the identification and training of qualified electrical workers and for determination of hazardous work to be performed only by those qualified individuals.

By permission of the National Fire Protection Association, many of the clauses, tables, and figures in this Standard have been copied from NFPA 70E. CSA Group wishes to thank the NFPA for its support throughout the development of this Standard.

The following is an overview of the major revisions to the 2021 edition:

- a) definitions for “normal operation”, “policy”, “procedure”, “process”, and “program” have been added (Clause [3](#));
- b) a requirement for employers to create and document an electrical safety policy has been added (Clause [4.1.5](#));
- c) Several organizational changes were made, including
 - i) relocation of content into Clause [4.1](#) to create a more complete listing of the general requirements for electrical-safety related work practices (Clauses [4.1.6](#), [4.1.7.8.4](#), [4.1.11.4](#), and [4.1.12.1](#))
 - ii) relocation of content in Clause [4.3](#) to create a more logical flow;
- d) the term “normal operating condition” and its meaning have been modified. The term now appears as “normal equipment condition” (Clause [4.1.7.8.4](#), and definition of “normal operation” in Clause [3](#));
- e) additional means of training were added to recognize that training may be achieved by any of several methods provided that it achieves specific measurable outcomes (Clause [4.1.8.1.5](#));
- f) the minimum threshold for potentially-hazardous energy was changed from 30 V to 30 V ac or 60 V dc (Clauses [4.1.6.1](#), [4.1.6.2.3](#), [4.1.11.5](#), and [4.3.7.4.8](#));
- g) a new method for selecting arc-flash PPE for ac voltages has been added (Clauses [4.3.5.5](#), [4.3.5.7](#), [4.3.7.3.15.2](#), [4.3.7.3.15.4](#), [B.2](#), [H.1](#), and [H.2](#), Annex [V](#), and Tables [6C](#) and [H.1](#));
- h) added guidance on methods that may be used to reduce likelihood of occurrence of an arcing event or the severity of exposure when incident energy is greater than the arc rating of commercially available arc-rated PPE (Clause [4.3.7.3.1](#));
- i) added Table [4A](#), which provides voltage ratings for various classes of rubber insulating gloves. The previous Table 4 is now Table [4B](#);
- j) Table [6A](#) has been modified with several changes to the equipment categories and a change to the associated arc flash PPE category for 600 V switchgear;

- k) Table 6C has been modified with additions of high-visibility apparel and hand protection methods and a new arc flash PPE category 5 has been added for arc-rated clothing up to 75 cal/cm²;
- l) Clause 5 has been completely rewritten;
- m) Table A.1 has been completely rewritten;
- n) an example of a job safety planning checklist has been added in Annex I (Figure I.2);
- o) Annex O has been largely rewritten to increase clarity, provide more methods to reduce incident energy, and provide further options for safety by design;
- p) Annex P has been added to provide guidance on electrical switching and isolation; and
- q) Annex T has been added to provide guidance on temporary protective grounding.

This Standard was prepared by the Technical Committee on Workplace Electrical Safety, under the jurisdiction of the Strategic Steering Committee on Occupational Health and Safety, and has been formally approved by the Technical Committee.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.
- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

CSA Z462:21

Workplace electrical safety

1 Scope

1.1 General

This Standard specifies requirements for workplace electrical safety necessary for the practical safeguarding of workers during activities such as the installation, removal, inspection, operation, maintenance, and demolition of electric conductors and electric equipment, as well as work in proximity of energized electrical equipment.

1.2 Application

While it can be applied by organizations of any type or size, this Standard does not cover:

- a) installations in ships, watercraft other than floating buildings, railway rolling stock, aircraft, and automotive vehicles other than mobile homes and recreational vehicles;
- b) installations of railways for the generation, transformation, transmission, or distribution of power used exclusively for operation of rolling stock or installations used exclusively for signalling and communications;
- c) installations of communications equipment under the exclusive control of communications utilities located outdoors or in building spaces used exclusively for such installations; and
- d) installations under the exclusive control of an electric utility when such installations
 - i) consist of service drops or service laterals, and associated metering;
 - ii) are located in legally established easements or rights-of-way designated or recognized by public service commissions, utility commissions, or other regulatory agencies having jurisdiction for such installations; or
 - iii) are on property owned or leased by the electric utility for communications or for metering, generation, control, transformation, transmission, or distribution of electric energy.

1.3 Suitability

It is the responsibility of the users of this Standard to judge its suitability for their particular purpose (see Note 2 to the Preface).

1.4 Use with related standards and regulations

This Standard is intended for use with Parts I, II, and III of the *Canadian Electrical Code* and other related Canadian workplace electrical safety standards (e.g., CSA M421 and CSA Z460), and should be used with such standards. In addition, users of this Standard should always refer to provincial, territorial, and federal safety regulations that have jurisdiction over their work facility, contract job site, or profession.

1.5 Organization of this Standard

The requirements of this Standard are organized in three main clauses and one Annex, as shown in Figure 1. Annexes [A](#) to [U](#), [W](#), and [X](#) do not specify requirements and are included for information only.