

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 13: Equipment protection by pressurized room “p”**

**Atmosphères explosives –
Partie 13: Protection du matériel par salle à surpression interne « p »**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour toute ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 13: Equipment protection by pressurized enclosure “p”**

**Atmosphères explosives –
Partie 13: Protection du matériel par salle à surpression interne « p »**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

W

ICS 29.260.20

ISBN 978-2-88912-164-9

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	10
3 Terms and definitions	10
4 Requirements for rooms	13
4.1 General.....	13
4.2 Construction.....	13
4.3 Mechanical strength	14
4.4 Openings, penetrations and seals	14
4.5 Doors	14
4.6 Inlets and outlets.....	14
4.7 Ducts	14
5 Clean air supply	14
5.1 Source of clean air	14
5.2 Environmental and air temperature conditions	15
5.3 Heating, ventilation and air conditioning services	15
5.4 Minimum flow rate	15
6 Purging and cleaning.....	15
6.1 General.....	15
6.2 Gases – Purging.....	15
6.2.1 General	15
6.2.2 Purge volume	15
6.2.3 Purging flow rate	15
6.2.4 Sequence of operations for the purging safety devices for type of protection px.....	16
6.2.5 Enclosures within the room.....	16
6.3 Dusts – Cleaning.....	16
7 Temperature limits.....	16
8 Minimum safety provisions, safety devices and electrical disconnects	16
8.1 Safety devices	16
8.2 Safety device, based upon type of protection.....	17
8.3 Gas detector	18
8.4 Failure of the pressurization system	18
9 Pressurized room in a hazardous area and with no internal source of flammable substance.....	18
9.1 General.....	18
9.2 Protective gas	18
9.2.1 Type of protection px.....	18
9.2.2 Type of protection py	18
9.2.3 Type of protection pz	19
9.3 Pressurization system	19
9.3.1 Room pressure differential.....	19
9.3.2 Power for pressurization system	19
9.4 Preventing the explosive atmosphere from entering an open door	19
9.5 Airlock.....	19
9.6 Outward air velocity through a door	20

9.7	Air consuming device	20
9.8	Action when pressurization system fails	20
9.8.1	Type of protection px	20
9.8.2	Types of protection py and pz	20
9.9	Re-energizing the room	21
10	Pressurized room in a hazardous area and containing an internal source of flammable substance	21
10.1	Evaluation of internal sources of a flammable substance	21
10.1.1	Flammable substance assessment	21
10.1.2	Assessment of release	21
10.1.3	Release – Additional requirements	21
10.1.4	Adequate dilution	21
10.2	Applicability of Clause 9	21
10.3	Containment system	21
10.4	Sample lines	21
10.5	Types of anticipated releases	22
10.5.1	General	22
10.5.2	No release	22
10.5.3	Negligible release	22
10.5.4	Limited release	22
10.5.5	Unlimited release	22
10.6	Safety measures	23
10.7	Minimum flow rate for dilution	23
10.8	Warning to prevent entry into a room	25
10.9	Air distribution	25
10.10	Protective gas	25
10.11	Additional pressurization system requirements when inert gas is used	25
11	Pressurized room in a non-hazardous area with internal source of flammable substance (type of protection pv)	25
11.1	Applicability of Clause 9	26
11.2	Applicability of Clause 10	26
11.3	Loss of flow of the protective gas	26
11.4	Safety devices	26
12	Verification	26
12.1	General	26
12.2	Sequence of tests	26
12.3	Mechanical strength test	26
12.4	Overpressure test	27
12.5	Purging test	27
12.6	Minimum pressure differential test for types of protection px, py and pz	27
12.7	Minimum flow rate test	27
12.8	Overpressure test for containment systems with limited release	27
12.9	Confirmation of the ratings of the safety devices	27
12.10	Verification sequence of operation of the safety devices	27
13	Marking	28
14	Technical documentation	28
	Annex A (normative) Containment system	30
	Annex B (informative) Maintenance	33

Annex C (informative) Guidelines when pressurization not immediately restored 34

Annex D (normative) Classification of the type of release within rooms 35

Bibliography 37

Table 1 – Exclusion of specific clauses of IEC 60079-0 8

Table 2 – Safety devices based on type of protection 17

Table 3 – Safety devices, loss of pressurization or use of inert protective gas 24

Table 4 – Protective gas requirements for a pressurized room with an internal flammable substance 25

Currently in preview, click buy full version

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 13: Equipment protection by pressurized room “p”**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-13 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This first edition of this part of IEC 60079 cancels and replaces the original technical report issued in 1982. It constitutes a technical revision and now has the status of an International Standard.

The significant technical changes with respect to the previous edition are listed below:

- Addition of types of protection px, py, pz and pv based upon whether external area is classified as Zone 1, Zone 2 or non-hazardous and whether internal electrical equipment is ignition capable or not.
- Addition of requirements related to Group III dusts.
- Addition of equipment protection levels (EPL).
- Expansion of requirements for various types of doors to prevent the entrance of a flammable atmosphere.
- Allowance for air intake located in a Zone 2 under specific conditions.

- Addition of negligible release conditions and negligible release containment system, as well as conditions and containment for limited release and unlimited release.

This part of IEC 60079 is to be read in conjunction with IEC 60079-0.

The text of this part of IEC 60079 is based on the following documents:

FDIS	Report on voting
31/878/FDIS	31/891/RVD

Full information on the voting for the approval of this part of IEC 60079 can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all parts of IEC 60079 series, under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://www.store.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 13: Equipment protection by pressurized room “p”

1 Scope

This part of IEC 60079 gives requirements for the design, construction, assessment and testing and marking of rooms protected by pressurization in:

- a room located in an explosive gas atmosphere or explosive dust atmosphere hazardous area that does not include an internal source of a flammable substance;
- a room located in an explosive gas atmosphere or explosive dust atmosphere hazardous area that includes an internal source of a flammable substance;
- a room located in a non-hazardous area that includes an internal source of a flammable substance.

NOTE If ventilation is used and pressurization is not used, then this part of IEC 60079 does not apply. The situation is covered by the requirements of IEC 60079-10-1.

A room may be a single room, multiple rooms, a complete building or a room contained within a building and includes inlet and outlet ducts. This part of IEC 60079 also includes requirements for associated equipment, safety devices and controls necessary to ensure that pressurization is established and maintained.

This part of IEC 60079 covers rooms or buildings that are constructed or assembled on site, which may be either on land or off-shore, designed to facilitate the entry of personnel and primarily intended for installation by an end-user and verification on site. The room may be located in an explosive gas atmosphere or a explosive dust atmosphere requiring equipment protection levels (EPL) Gb, Db, Gc or D.

This part of IEC 60079 does not specify the methods that may be required to ensure adequate air quality for personnel with regard to toxicity and temperature within the room.

NOTE 1 Whilst the scope of this part of IEC 60079 does not address toxicity it is vital that proper consideration is given to this aspect to ensure the safety of personnel. National regulations and requirements should be observed in this regard.

NOTE 2 There is a related standard IEC60079-2 (Equipment protection by pressurized enclosure) covering the different conditions encountered when using the pressurization technique.

NOTE 3 Maintenance needs are contained in Annex B until they are included IEC 60079-17.

NOTE 4 For the purposes of this part of IEC 60079, the terms "lower flammable limit (LFL)" and "lower explosive limit (LEL)" are deemed to be synonymous, and likewise the terms "upper flammable limit (UFL)" and "upper explosive limit (UEL)" are deemed to be synonymous. For ease of reference, the two abbreviations LFL and UFL may be used hereinafter to denote these two sets of terms. It should be recognized that particular authorities having jurisdiction may have overriding requirements that dictate the use of one of these sets of terms and not the other.

This part of IEC 60079 supplements and modifies the general requirements of IEC 60079-0, except as indicated in Table 1. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.