

FINAL VERSION

VERSION FINALE

**Explosive atmospheres –
Part 18: Equipment protection by encapsulation "m"**

**Atmosphères explosives –
Partie 18: Protection du matériel par encapsulage "m"**

CONTENTS

FOREWORD.....	5
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 General	10
4.1 Level of protection (equipment protection level (EPL))	10
4.2 Additional requirements for levels of protection “ma” and “mb”	10
4.3 Additional requirements for level of protection “ma”	10
4.4 Rated voltage and prospective short circuit current	11
5 Requirements for compounds	11
5.1 General.....	11
5.2 Specification	11
5.3 Properties of the compound	11
5.3.1 Water absorption	11
5.3.2 Dielectric strength.....	11
6 Temperatures	12
6.1 General.....	12
6.2 Determination of the limiting temperatures	12
6.2.1 Maximum surface temperature.....	12
6.2.2 Temperature of the compound	12
6.3 Temperature limitation	12
7 Constructional requirements	12
7.1 General.....	12
7.2 Determination of faults	13
7.2.1 Fault examination	13
7.2.2 Components considered as not subject to fail	13
7.2.3 Isolating components.....	14
7.2.4 Infallible separation distances.....	14
7.3 Free space in the encapsulation	15
7.3.1 Group “h” equipment.....	15
7.3.2 Group I and Group II “m” equipment	16
7.4 Thickness of the compound.....	17
7.4.1 “m” equipment	17
7.4.2 Windings for electrical machines.....	19
7.4.3 Rigid, multi-layer printed wiring boards with through connections	19
7.5 Switching contacts	20
7.5.1 General	20
7.5.2 Level of protection “ma”	21
7.5.3 Level of protection “mb”	21
7.5.4 Level of protection “mc”	21
7.6 External connections.....	21
7.6.1 General	21
7.6.2 Additional requirements for “ma” equipment.....	21
7.7 Protection of bare live parts	21
7.8 Cells and batteries	21
7.8.1 General	21

7.8.2	Prevention of gassing	22
7.8.3	Protection against inadmissible temperatures and damage to the cells or batteries	22
7.8.4	Reverse current	22
7.8.5	Current limitation	23
7.8.6	Protection against the polarity inversion and deep discharge of the cells	23
7.8.7	Charging of cells or batteries	23
7.8.8	Requirements for control safety devices for cells or batteries	24
7.9	Protective devices	24
7.9.1	General	24
7.9.2	Electrical protective devices	25
7.9.3	Thermal protective devices	25
7.9.4	Built-in protective devices	26
8	Type tests	26
8.1	Tests on the compound	26
8.1.1	Water absorption test	26
8.1.2	Dielectric strength test	26
8.2	Tests on the apparatus	26
8.2.1	Test sequence	26
8.2.2	Maximum temperature	27
8.2.3	Thermal endurance test	27
8.2.4	Dielectric strength test	28
8.2.5	Cable pull test	28
8.2.6	Pressure test for Group I and Group II electrical equipment	29
8.2.7	Test for resettable thermal protective device	30
8.2.8	Sealing test for built-in protective devices	30
9	Routine verifications and tests	30
9.1	Visual inspections	30
9.2	Dielectric strength test	30
10	Marking	31
Annex A (informative)	Basic requirements for compounds for “m” equipment	32
Annex B (informative)	Allocation of test samples	33
Annex C (normative)	Dielectric strength test between circuits and environment	34
C.1	General	34
C.2	Batch test procedure	34
Bibliography	35
Figure 1	- Dimensional key for thickness through the compound	18
Figure 2	- Minimum distances for multi-layer printed wiring boards	20
Figure 3	- Fitting of blocking diodes	23
Figure A.1	- Basic requirements for compounds for “m” equipment	32
Table 1	- Distances through the compound	15
Table 2	- Minimum thickness of compound adjacent to free space for Group III “m” equipment	16
Table 3	- Minimum thickness of compound adjacent to free space for Group I and Group II “m” equipment	17

Table 4 – Thickness of the compound	19
Table 5 – Minimum distances for multi-layer printed wiring boards	20
Table 6 – Test pressure	29
Table B.1 – Allocation of test samples	33

Currently in preview, click buy full version

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

Part 18: Equipment protection by encapsulation “m”

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 60079-18 bears the edition number 4.1. It consists of the fourth edition (2014-12) [documents 31/1152/FDIS and 31/1168/RVD] and its amendment 1 (2017-08) [documents 31/1323/FDIS and 31/1336/RVD]. The technical content is identical to the base edition and its amendment.

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

Standard IEC 60079-18 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fourth edition constitutes a technical revision.

This International Standard is to be used in conjunction with IEC 60079-0, *Explosive atmospheres – Part 0: Equipment-General requirements*.

This edition includes the following significant technical changes with respect to the previous edition:

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Definitions deleted and moved to IEC 60079-0	3	X		
Heading modified /added to clarify which requirements are additional requirements for “ma” level of protection only	4	X		
Thermal conductivity added	5.2		X	
Note added that it is not a requirement of this standard that conformity to the manufacturer’s specification of the compound needs to be verified	5.3.2			
Clarification added	6.2.2	X		
Clarification added	7.1	X		
For the determination of faults options added and clarification given	7.2		X	
Additional information included in Figure 1	7.4.1	X		
“Varnish and similar coatings are not considered to be solid insulation.” was added in this section and deleted in the definition on 3.8	7.4.2	X		
For rigid, multi-layer printed wiring boards with through connections additional standards added	7.4.3.1		X	
Protection against inadmissible temperatures and damage to the cells	7.8.3			C1
Electrical protective devices clarified and additional possibilities added	7.9.2		X	
Thermal protective devices clarified and additional possibilities added	7.9.3		X	
2/3 voltage limitation device	7.9.3		X	
Determination of the maximum temperature for “Da” fixed	8.2.2			C2
Stabilization of the temperature	8.2.2			C3
Thermal endurance to heat	8.2.3.1		X	
Temperature fixed as reference service temperatures and test given as alternatives	8.2.3.1.1		X	
For the dielectric strength test procedure alternative possibilities added	8.2.4.1		X	
Alternative test methods for the required pressure test for Group I and Group II electrical equipment added	8.2.6		X	
Sealing test for build-in protective devices	8.2.8		X	
For the dielectric strength test procedure alternative possibilities added	9.2		X	
Marking	10	X	X	

Explanation of the Types of Significant Changes:**A) Definitions****1. Minor and editorial changes:**

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2. Extension:

- Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3. Major technical changes:

- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in item B) below.

Note These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major technical changes'

C1 Clause 7.8.3 modified and additional requirements added for cells or batteries.

C2 The flexibility given in IEC 60079-0 is replaced by a min. requirement. For level of protection "ma" equipment, designed for EPL "Da" the maximum surface temperature shall be determined with the equipment mounted in accordance with the manufacturer's instructions, and surrounded on all available surfaces by dust with a layer thickness of at least 200 mm

C3 The increase of the temperature during the test can be a very slow process. The final temperature shall be considered to have been reached when the rate of rise of temperature does not exceed 1 K/24 h

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60079 series, published under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 18: Equipment protection by encapsulation “m”

1 Scope

This part of IEC 60079 gives the specific requirements for the construction, testing and marking of electrical equipment, parts of electrical equipment and Ex components with the type of protection encapsulation “m” intended for use in explosive gas atmospheres or explosive dust atmospheres.

This part applies only for encapsulated electrical equipment, encapsulated parts of electrical equipment and encapsulated Ex components (hereinafter always referred to as “m” equipment) where the rated voltage does not exceed 11 kV.

The application of electrical equipment in atmospheres, which may contain explosive gas as well as combustible dust simultaneously, may require additional protective measures.

This standard does not apply to dusts of explosives, which do not require atmospheric oxygen for combustion, or to pyrophoric substances

This standard does not take account of any risk due to an emission of flammable or toxic gas from the dust.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety “e”*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety “i”*

IEC 60079-15, *Explosive atmospheres – Part 15: Equipment protection by type of protection “n”*

IEC 60079-26, *Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga*

IEC 60079-31, *Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure “t”*

IEC 60127 (all parts), *Miniature fuses*