

FINAL VERSION

VERSION FINALE

**Explosive atmospheres –
Part 6: Equipment protection by liquid immersion "o"**

**Atmosphères explosives –
Partie 6: Protection du matériel par immersion dans le liquide "o"**

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	7
4 Constructional requirements	9
4.1 General.....	9
4.2 Levels of protection and requirements of electrical equipment.....	9
4.2.1 Level of Protection.....	9
4.2.2 Requirements for Level of Protection “ob”	9
4.2.3 Requirements for Level of Protection “oc”	10
4.3 Switching device	10
4.4 Creepage and clearance	10
4.5 Liquid containment enclosures	10
4.5.1 General	10
4.5.2 Sealed enclosures	10
4.5.3 Unsealed enclosures	11
4.5.4 Outlet of breathing device or pressure relief device	11
4.5.5 Enclosures intended to be opened	11
4.5.6 Determination of the maximum/minimum amount of the protective liquid.....	11
4.6 Immersion depth	11
4.7 Protective liquid level indication	12
4.7.1 General	12
4.7.2 Remote-indicating protective liquid level indicator.....	12
4.7.3 Safety devices for Level of Protection “ob”	13
4.8 Temperature limitations	13
4.8.1 General	13
4.8.2 Maximum Surface Temperature	13
4.8.3 Flashpoint of the protective liquid	13
4.9 Field wiring connections to liquid immersion equipment	13
4.10 Constructional elements of enclosures	13
4.10.1 Operating rods, shafts etc.....	13
4.10.2 Device for draining of liquid.....	13
5 Protective Liquid.....	14
5.1 Protective liquid specification.....	14
5.2 Detailed alternative specification.....	14
5.3 Group I equipment	14
5.4 Liquid contamination and gassing that may result from arcing.....	14
5.5 Total volume of the protective liquid.....	14
6 Verifications and tests	15
6.1 Type tests	15
6.1.1 Overpressure test on sealed enclosures	15
6.1.2 Reduced pressure test on sealed enclosures	15
6.1.3 Overpressure test on unsealed enclosures	15
6.1.4 Maximum temperature	15
6.1.5 Switching Tests	15
6.2 Routine tests.....	16

6.2.1	Sealed enclosures	16
6.2.2	Unsealed enclosures	16
7	Marking	16
8	Instructions	17
Annex A (normative)	Selection and erection requirements	18
Annex B (normative)	Maintenance requirements	19
Annex C (normative)	Repair and Overhaul requirements	20
Annex D (normative)	Supplementary requirements for electrical equipment with Level of Protection "oc" for voltages greater than 15 kV and up to and including 245 kV	21
	Bibliography	24
	Table 1 – Working voltage	10
	Table 2 – Depth of immersion	12
	Table B.1 – Inspection requirements	19

Currently in preview, click buy full vers.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 6: Equipment protection by liquid immersion "o"**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This consolidated version of IEC 60079-6 bears the edition number 4.1. It consists of the fourth edition (2015-02) [documents 31/1157/FDIS and 31/1172/RVD] and its amendment 1 (2020-02) [documents 31/1517/FDIS and 31/1526/RVD]. The technical content is identical to the base edition and its amendment.

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60079-6 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fourth edition constitutes a technical revision.

The significant changes with respect to the previous edition are listed below:

- Edition 4 represents a major technical revision of the requirements for oil immersion “o” and should be considered as introducing all new requirements. The normal “Table of Significant Changes” has not been included for this reason. In particular:
 - The requirements for oil immersion “o” have been redefined into liquid immersion , levels of protection “ob” and “oc” as recommended by the responses to 31/715/DC
 - The ability to protect sparking contacts has been added to both “ob” and “oc”
- Additional requirements have been introduced for the protective liquid.

This part of IEC 60079 is to be used in conjunction with IEC 60079-0, *Explosive atmospheres – Part 0: Equipment – General requirements*.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60079 series, under the general title *Explosive atmospheres*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under “<http://webstore.iec.ch>” in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES –

Part 6: Equipment protection by liquid immersion "o"

1 Scope

This part of IEC 60079 specifies the requirements for the design, construction, testing and marking of Ex Equipment and Ex Components with type of protection liquid immersion "o" intended for use in explosive gas atmospheres.

Ex Equipment and Ex Components of type of protection liquid immersion "o" are with:

- Level of Protection "ob" (EPL "Mb" or "Gb")
- Level of Protection "oc" (EPL "Gc")

For Level of Protection "ob", this standard applies where the rated voltage does not exceed 11 kV r.m.s. a.c. or d.c.

For Level of Protection "oc", this standard applies where the rated voltage does not exceed 15 kV r.m.s. a.c. or d.c.

Additionally, for Level of Protection "oc", Annex D applies where the rated voltage exceeds 15 kV AC RMS or DC and up to 245 kV AC RMS or DC.

Annex D applies specifically to liquid immersed transformers and reactors, and other liquid immersed equipment such as swivels for off-shore platforms, power regulators, tap changers and earthing/switching resistors.

This standard supplements and modifies the general requirements of IEC 60079-0. Where a requirement of this standard conflicts with a requirement of IEC 60079-0, the requirement of this standard takes precedence.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60071 (all parts), *Insulation co-ordination*

IEC 60076-3, *Power transformers – Part 3: Insulation levels, dielectric tests and external clearances in air*

IEC 60079-0, *Explosive Atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"*

IEC 60079-2, *Explosive atmospheres – Part 2: Equipment protection by pressurized enclosure "p"*