

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



Low-voltage fuses –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

Fusibles basse tension –

Partie 2: Exigences supplémentaires pour les fusibles destinés à être utilisés par des personnes habilitées (fusibles pour usages essentiellement industriels) – Exemples de systèmes de fusibles normalisés A à K



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



Low-voltage fuses –

Part 2: Supplementary requirements for fuses to be used by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

Fusibles basse tension –

Partie 2: Exigences supplémentaires pour les fusibles destinés à être utilisés par des personnes habilitées (fusibles pour usages essentiellement industriels) – Exemples de systèmes de fusibles normalisés A à K

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50

ISBN 978-2-8322-3536-2

Warning! Make sure that you obtained this publication from an authorized distributor.

Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

Currently in preview, click buy full version

REDLINE VERSION

VERSION REDLINE



Low-voltage fuses –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

Fusibles basse tension –

Partie 2: Exigences supplémentaires pour les fusibles destinés à être utilisés par des personnes habilitées (fusibles pour usages essentiellement industriels) – Exemples de systèmes de fusibles normalisés A à K

CONTENTS

FOREWORD.....	16
INTRODUCTION.....	18
1 General scope.....	19
1.1 Scope.....	19
1.2 Normative references	19
Fuse system A – Fuses with fuse-links with blade contacts (NH fuse system).....	21
1 General.....	21
1.1 Scope.....	21
2 Terms and definitions	21
3 Conditions for operation in service	22
4 Classification.....	22
5 Characteristics of fuses	22
5.2 Rated voltage	22
5.3.1 Rated current of the fuse-link	22
5.3.2 Rated current of the fuse-holder	22
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	22
5.6 Limits of time-current characteristics	22
5.6.1 Time-current characteristics, time-current zones and overload curves	22
5.6.2 Conventional times and currents	22
5.6.3 Gates	23
5.7.2 Rated breaking capacity	23
6 Markings	23
6.1 Markings of fuse-holders.....	23
6.2 Markings of fuse-links	24
7 Standard conditions for construction	24
7.1 Mechanical design	24
7.1.2 Connections, including terminals	24
7.1.3 Fuse contacts	25
7.1.6 Construction of fuse-bases.....	25
7.1.7 Construction of a fuse-link.....	25
7.2 Insulating properties and suitability for insulation.....	26
7.7 I^2t characteristics	26
7.8 Overcurrent discrimination of fuse-links.....	27
7.9 Protection against electric shock.....	27
8 Tests.....	28
8.1.4 Arrangement of the fuse and dimensions	28
8.1.6 Testing of fuse-holders.....	28
8.2.4 Acceptability of test results.....	29
8.2.5 Resistance to tracking.....	29
8.3 Verification of temperature rise and power dissipation	29
8.3.1 Arrangement of the fuse	29
8.3.2 Measurement of the temperature rise	29
8.5.5 Test method.....	30

8.5.8	Acceptability of test results.....	31
8.7.4	Verification of overcurrent discrimination	31
8.9	Verification of resistance to heat	32
8.9.1	Fuse-base	33
8.9.2	Fuse-links with gripping-lugs of moulded material or of metal fixed in moulded material	33
8.10	Verification of non-deterioration of contacts.....	34
8.10.1	Arrangement of the fuse	34
8.10.2	Test method.....	36
8.10.3	Acceptability of test results.....	37
8.11	Mechanical and miscellaneous tests	39
FIGURES	42
Annex AA (informative)	Special test for cable overload protection	62
AA.1	Arrangement of the fuse	62
AA.2	Test method and acceptability of test results	62
Fuse system B – Fuses with striker fuse-links with blade contacts (NH fuse system)	63
1	General.....	63
1.1	Scope.....	63
2	Terms and definitions	63
3	Conditions for operation in service	63
4	Classification.....	63
5	Characteristics of fuses	63
5.2	Rated voltage	63
5.3.1	Rated current of the fuse link	64
5.3.2	Rated current of the fuse-holder	64
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	64
5.6	Limits of time-current characteristics	64
5.7.2	Rated breaking capacity	64
6	Markings	64
7	Standard conditions for construction	64
7.1	Mechanical design.....	64
7.1.1	Connections, including terminals	64
7.1.3	Fuse-contacts	64
7.1.7	Construction of a fuse-link.....	65
7.2	Insulating properties and suitability for insulation.....	65
7.7	I^2t characteristics	65
7.8	Overcurrent discrimination of "gG" fuse-links.....	65
7.9	Protection against electric shock.....	65
8	Tests.....	65
8.1.6	Testing of fuse-holders.....	65
8.3	Verification of temperature rise and power dissipation	65
8.7.4	Verification of overcurrent discrimination	66
8.9	Verification of resistance to heat	66
8.9.1	Fuse-base	66

FIGURES 68

Fuse system C – Fuse-rails (NH fuse system)..... 75

1 General 75
 1.1 Scope..... 75
 2 Terms and definitions 75
 3 Conditions for operation in service 75
 4 Classification..... 75
 5 Characteristics of fuses 75
 5.2 Rated voltage 75
 5.3.2 Rated current..... 75
 5.5.1 Rated acceptable power dissipation..... 75
 6 Markings 76
 7 Standard conditions for construction 76
 7.1 Mechanical design 76
 7.1.2 Connections, including terminals 76
 7.2 Insulating properties 76
 8 Tests..... 76
 8.1.6 Testing of fuse-holders..... 76
 8.3 Verification of temperature rise and power dissipation 77
 8.3.1 Arrangement of the fuse 77
 8.9 Verification of resistance to heat 78
 8.9.1 Fuse-base 78
 8.10 Verification of non-deterioration of contacts..... 78
 8.10.1 Arrangement of the fuse 78

FIGURES 80

Fuse system D – Fuse-bases for busbar mounting (40 mm system) (NH fuse system)..... 85

1 General 85
 1.1 Scope..... 85
 2 Terms and definitions 85
 3 Conditions for operation in service 85
 4 Classification..... 85
 5 Characteristics of fuses 85
 5.2 Rated voltage 85
 5.3.2 Rated current..... 86
 5.5.2 Rated acceptable power dissipation of tandem fuse-bases..... 86
 6 Markings 86
 7 Standard conditions for construction 86
 7.1 Mechanical design 86
 7.1.2 Connections, including terminals 86
 7.1.5 Construction of a fuse-base for busbar mounting 87
 7.2 Insulating properties and suitability for insulation..... 87
 8 Tests..... 87

8.3	Verification of temperature rise and power dissipation	87
8.3.1	Arrangement of the fuse	87
8.9.1	Fuse-base	88
8.10	Verification of non-deterioration of contacts	88
8.10.1	Arrangement of the fuse	88
8.10.2	Test method	89
8.11	Mechanical and miscellaneous tests	89
FIGURES	90

**Fuse system E – Fuses with fuse-links for bolted connections
 (BS bolted fuse system)**

1	General	97
1.1	Scope	97
2	Terms and definitions	97
3	Conditions for operation in service	97
4	Classification	97
5	Characteristics of fuses	97
5.3.1	Rated current of the fuse-link	97
5.3.2	Rated current of the fuse-holder	97
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	98
5.6	Limits of time-current characteristics	98
5.6.1	Time-current characteristics, time-current zones and overload curves	98
5.6.2	Conventional times and currents	98
5.6.3	Gates	98
5.7.2	Rated breaking capacity	98
6	Markings	98
6.1	Markings of fuse-holders	99
6.2	Markings of fuse-links	99
7	Standard conditions for construction	99
7.1	Mechanical design	99
7.1.2	Connections including terminals	99
7.2	Insulating properties and suitability for insulation	99
7.9	Protection against electric shock	99
8	Tests	99
8.3	Verification of temperature rise and power dissipation	99
8.3.1	Arrangement of the fuse	99
8.3.3	Measurement of the power dissipation of the fuse-link	99
8.4	Verification of operation	100
8.4.1	Arrangement of the fuse	100
8.5	Verification of breaking capacity	100
8.5.1	Arrangement of the fuse	100
8.5.8	Acceptability of test results	100
8.9	Verification of resistance to heat	100
8.10	Verification of non-deterioration of contacts	100
8.10.1	Arrangement of the fuse	100
8.10.2	Test method	100

8.10.3 Acceptability of the results	101
8.11 Mechanical and miscellaneous tests	101
FIGURES	102

Fuse system F – Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)..... 111

1 General	111
1.1 Scope.....	111
2 Terms and definitions	111
3 Conditions for operation in service	111
4 Classification.....	111
5 Characteristics of fuses	111
5.2 Rated voltage	111
5.3.1 Rated current of the fuse-link	112
5.3.2 Rated current of the fuse-holder	112
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	112
5.6 Limits of time-current characteristics	113
5.6.1 Time-current characteristics, time-current zones and overload curves	113
5.6.2 Conventional times and currents	113
5.6.3 Gates	114
5.7.2 Rated breaking capacity	114
6 Markings	114
6.1 Markings of fuse-holders.....	114
6.2 Markings of fuse-links	115
7 Standard conditions for construction	115
7.1 Mechanical design.....	115
7.1.2 Connections including terminals	115
7.2 Insulating properties and suitability for insulation.....	115
7.7 I^2t characteristics	116
7.8 Overcurrent discrimination of "gG" fuse-links.....	116
7.9 Protection against electric shock.....	116
8 Tests.....	116
8.1.6 Testing of fuse-holders.....	117
8.3 Arrangement of the fuse	117
8.4 Verification of overcurrent discrimination	119
8.9 Verification of resistance to heat	120
8.10 Verification of non-deterioration of contacts.....	120
8.10.1 Arrangement of the fuse	120
8.10.2 Test method.....	120
8.10.3 Acceptability of test results.....	121
FIGURES	122

Fuse system G – Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)..... 126

1 General	126
1.1 Scope.....	126

2	Terms and definitions	126
3	Conditions for operation in service	126
4	Classification	126
5	Characteristics of fuses	126
5.2	Rated voltage	127
5.3.1	Rated current of the fuse-link	127
5.3.2	Rated current of the fuse-holder	127
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	127
5.6.1	Time-current characteristics, time-current zones	127
5.6.2	Conventional times and currents	127
5.6.3	Gates	127
5.7.2	Rated breaking capacity	128
6	Markings	128
6.1	Markings of fuse-holders	128
6.2	Markings of fuse-links	128
7	Standard conditions for construction	128
7.1	Mechanical design	128
7.1.2	Connections including terminals	128
7.2	Insulating properties and suitability for insulation	129
7.7	I^2t characteristics	129
7.9	Protection against electric shock	129
8	Tests	129
8.3.3	Measurement of the power dissipation of the fuse-link	129
8.4.1	Arrangement of the fuse	130
8.5.1	Arrangement of the fuse	130
8.7.4	Verification of overcurrent discrimination	130
8.9	Verification of resistance to heat	130
8.10	Verification of non-deterioration of contacts	130
8.10.1	Arrangement of the fuse	130
8.10.2	Test method	131
8.10.3	Acceptability of test results	131
8.11	Mechanical and miscellaneous tests	131
FIGURES	132

Fuse system H – Fuses with fuse-links having "gD" and "gN" characteristics (class J, class T, and class L time delay and non time delay fuse types)		
1	General	137
1.1	Scope	137
2	Terms and definitions	137
3	Conditions for operation in service	137
4	Classification	137
5	Characteristics of fuses	137
5.2	Rated voltage	137
5.3.1	Rated current of the fuse-link	138
5.3.2	Rated current of the fuse-holder	138

5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	138
5.6	Limits of the time-current characteristics	138
5.6.1	Time-current characteristics, time-current zones	138
5.6.2	Conventional times and currents	138
5.6.3	Gates	138
5.7.2	Rated breaking capacity	139
6	Markings	139
6.1	Markings of fuse-holders	139
6.2	Markings of fuse-links	139
7	Standard conditions for construction	139
7.1	Mechanical design	139
7.2	Insulating properties and suitability for insulation	139
7.5	Breaking capacity	139
7.6	Cut-off current characteristics	140
7.7	I^2t characteristics	140
7.8	Overcurrent discrimination	141
7.9	Protection against electric shock	141
8	Tests	141
8.3	Verification of temperature rise and power dissipation	141
8.3.1	Arrangement of the fuse	141
8.4	Verification of operation	142
8.4.1	Arrangement of the fuse	142
8.5.4	Recovery voltage	143
8.6	Verification of cut-off current characteristics	143
8.7	Verification of I^2t characteristics and overcurrent discrimination	144
8.9	Verification of resistance to heat	144
8.10	Verification of non-deterioration of contacts	144
8.10.1	Arrangement of the fuse	144
8.10.2	Test method	145
8.10.3	Acceptability of test results	145
8.11	Mechanical and miscellaneous tests	145
8.11.2	Miscellaneous tests	145
FIGURES	146

Fuse system I – gU fuse-links with wedge tightening contacts	159
1	General	159
1.1	Scope	159
2	Terms and definitions	159
3	Conditions for operation in service	160
3.9	Discrimination of fuse-links	160
4	Classification	160
5	Characteristics of fuses	160
5.2	Rated voltage	160
5.3.1	Rated current of the fuse-link	160
5.5	Rated power dissipation of a fuse-link	160
5.6.1	Time-current characteristics, time-current zones	160

5.6.2	Conventional times and currents	161
5.6.3	Gates	161
5.7.2	Rated breaking capacity	161
5.8	Cut-off current and I^2t characteristics	161
6	Markings	161
6.1	Markings of fuse-holders.....	161
6.2	Markings of fuse-links	161
7	Standard conditions for construction	161
7.1	Mechanical design	161
7.2	Insulating properties and suitability for insulation.....	161
7.5	Breaking capacity	161
7.7	I^2t characteristics	162
7.8	Overcurrent discrimination of the fuse-links	162
8	Tests.....	162
8.1.1	Kind of tests.....	162
8.3.1	Arrangement of the fuse	162
8.3.3	Measurement of the power dissipation of the fuse-link	163
8.4.1	Arrangement of the fuse	163
8.5.1	Arrangement of the fuse	163
8.5.2	Characteristics of the test circuit	163
8.5.5	Test method.....	163
8.5.8	Acceptability of test results.....	163
8.7.3	Verification of compliance for fuse-links at 0,01 s.....	164
8.9	Verification of resistance to heat	164
8.11	Mechanical and miscellaneous tests	164
FIGURES	165

Fuse system J – Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)	173
1	General	173
1.1	Scope.....	173
2	Terms and definitions	173
3	Conditions for operation in service	173
4	Classification.....	173
5	Characteristics of fuses	173
5.2	Rated voltage	173
5.3.1	Rated current of the fuse-link	174
5.3.2	Rated current of the fuse-holder	174
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	174
5.6	Limits of the time-current characteristics	174
5.6.1	Time-current characteristics, time-current zones.....	174
5.6.2	Conventional times and currents	174
5.6.3	Gates	174
5.7.2	Rated breaking capacity	174
6	Markings	175
6.1	Markings of fuse-holders.....	175

6.2	Markings of fuse-links	175
7	Standard conditions for construction	175
7.1	Mechanical design	175
7.2	Insulating properties and suitability for insulation	175
7.5	Breaking capacity	175
7.6	Cut-off current characteristics	175
7.7	I^2t characteristics	175
7.8	Overcurrent discrimination	176
7.9	Protection against electric shock	176
8	Tests	176
8.3	Verification of temperature rise and power dissipation	176
8.3.1	Arrangement of the fuse	176
8.4	Verification of operation	177
8.4.1	Arrangement of the fuse	177
8.5.4	Recovery voltage	177
8.6	Verification of cut-off current characteristics	177
8.7	Verification of I^2t characteristics and overcurrent discrimination	178
8.9	Verification of resistance to heat	179
8.10	Verification of non-deterioration of contacts	179
8.10.1	Arrangement of the fuse	179
8.10.2	Test method	179
8.10.3	Acceptability of test results	179
8.11	Mechanical and miscellaneous tests	179
8.11.2	Miscellaneous tests	180
FIGURES	181

Fuse system K – gK fuse-links with blade contacts for bolted connections – High current fuse-link ratings from 1 250 A up to 4 800A (Master fuse-links)		
1	General	191
1.1	Scope	191
2	Terms and definitions	191
3	Conditions for operation in service	191
3.9	Discrimination of fuse-links	191
4	Classification	191
5	Characteristics of fuses	191
5.2	Rated voltage	192
5.3.1	Rated current of the fuse-link	192
5.3.2	Rated current of the fuse-holder	192
5.5	Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	192
5.6	Limits of the time-current characteristics	192
5.6.1	Time-current characteristics, time-current zones	192
5.6.2	Conventional times and currents	193
5.6.3	Gates	193
5.7.2	Rated breaking capacity	193
6	Markings	193
6.2	Markings of fuse-links	194

7	Standard conditions for construction	194
7.1	Mechanical design	194
7.1.3	Fuse-contacts	194
7.6	Cut-off current characteristics	194
7.7	I^2t characteristics	194
7.8	Over-current selectivity of “gK” fuse-links	194
7.9	Protection against electric shock	194
8	Tests	195
8.3	Verification of temperature rise and power dissipation	195
8.3.1	Arrangement of the fuse	195
8.4.1	Arrangement of the fuse	195
8.6	Verification of cut-off current characteristics	195
8.7	Verification of I^2t characteristics and over-current selectivity	196
8.9	Verification of resistance to heat	197
8.10	Verification of non-deterioration of contacts	197
8.10.1	Arrangement of the fuse	197
8.10.2	Test method	197
8.10.3	Acceptability of test results	197
	FIGURES	198
	Bibliography	205
	Figure 101 – Fuse-links with blade contacts (1 of 3)	42
	Figure 102 – Fuse-bases for fuse-links with blade contacts (1 of 3)	45
	Figure 103 – Replacement handle	49
	Figure 104 – Time-current zones for “gG” fuse-links (1 of 5)	50
	Figure 105 – Dummy fuse-link according to 8.3.4.1, 8.9.1 and 8.10	55
	Figure 106 – Measuring points according to 8.3.4 of IEC 60269-1, 8.3.4.1, 8.3.4.2 and 8.10.2 of fuse system A	56
	Figure 107 – Test knife according to 8.5.5.1.2	56
	Figure 108 – Example of a measuring device for determining the withdrawal forces according to 8.9.1 and 8.11.1.2	57
	Figure 109 – Facility for verifying the mechanical strength of gripping-lugs (see 8.11.1.8)	58
	Figure 110 – Measuring points according to 8.10.2	59
	Figure 111 – Reference fuse-base	60
	Figure 112 – Design mark for isolated gripping-lugs	61
	Figure 201 – Fuse-links with blade contacts with striker (1 of 4)	68
	Figure 202 – Fuse-bases for fuse-links with blade contacts with striker (1 of 3)	72
	Figure 301 – Fuse-rails for fuse-links with blade contacts (1 of 3)	80
	Figure 302 – Test arrangement for fuse-rails (1 of 2)	83
	Figure 401 – Busbar mounting bases, 1 pole	90
	Figure 402 – Busbar mounting bases, 3 pole	91
	Figure 403 – Busbar mounting base, size 00, 2 × 3 pole (tandem fuse-base)	92
	Figure 404 – Test arrangement for single-pole and triple-pole fuse-bases for busbar-mounting according to 8.3.1	93

Figure 405 – Test arrangement for two single-pole and six single-pole fuse-bases in tandem arrangement for busbar-mounting according to 8.3.1	94
Figure 406 – Test arrangement for the verification of the peak withstand current.....	95
Figure 407 – Dummy fuse-link.....	96
Figure 501 – Fuse-links for bolted connection – Sizes A, B, C and D (1 of 2).....	102
Figure 502 – Typical fuse-holder (1 of 2)	104
Figure 503 – Time-current zones for "gG" fuse-link	106
Figure 504 – Time-current zones for "gG" fuse-link.....	107
Figure 505 – Power dissipation test rig.....	108
Figure 506 – Breaking capacity test rig for fuse-links for bolted connection (1 of 2)	109
Figure 601 – Fuse-links with cylindrical caps	122
Figure 602 – Fuse-links with cylindrical contact caps with striker – Additional dimensions for sizes 14 × 51 and 22 × 58 only.....	123
Figure 603 – Base for fuse-links with cylindrical caps (1 of 2)	124
Figure 701 – Fuse-links having offset blade contacts, sizes E1, F1, F2 and F3.....	132
Figure 702 – Typical fuse-holder	133
Figure 703 – Time-current zones for "gG" fuse-links	134
Figure 704 – Time-current zones for "gG" fuse-links	135
Figure 705 – Power dissipation test rig.....	136
Figure 801 – Class J fuse-links (1 A to 600 A)	146
Figure 802 – Class L fuse-links (700 A to 6 000 A)	147
Figure 803 – Fuse-base and contacts for class J fuse-links 1 A to 600 A.....	148
Figure 804 – Fuse-base and contacts for class L fuse-links 700 A to 6 000 A.....	149
Figure 805 – Class T fuse-links (1 A to 1 200 A).....	150
Figure 806 – Fuse-base and contacts for class T fuse-links 1 A to 1 200 A.....	151
Figure 807 – Temperature test arrangement.....	152
Figure 808 – Time-current zones for "gN" fuse-links	153
Figure 809 – Time-current zones for "gN" fuse-links	154
Figure 810 – Time-current zones for "gN" fuse-links	155
Figure 811 – Time-current zones for "gD" fuse-links	156
Figure 812 – Time-current zones for "gD" fuse-links	157
Figure 813 – Time-current zones for "gD" fuse-links	158
Figure 901 – Time-current zones for current ratings 100 A, 200 A, 355 A and 630 A.....	165
Figure 902 – Time-current zones for current ratings 160 A and 315 A	166
Figure 903 – Time-current zones for current ratings 250 A and 500 A	167
Figure 904 – Time-current zones for current ratings 200 A and 400 A	168
Figure 905 – Dimensions for fuse-links with L type and U type tags	169
Figure 906 – Power dissipation test rig.....	170
Figure 907 – Breaking capacity test rig (1 of 2).....	171
Figure 1001 – Class CC fuse-links (1 A to 30 A)	181
Figure 1002 – Fuse-base and contacts for class CC fuse-links 1 A to 30 A.....	181
Figure 1003 – Class CC dummy fuse-link dimensions	182
Figure 1004 – Temperature test arrangement.....	183

Figure 1005 – Time-current zones for class CC “gN” fuses	184
Figure 1006 – Time-current zones for class CC “gN” fuses	185
Figure 1007 – Time-current zones for class CC “gN” fuses	187
Figure 1008 – Time-current zones for class CC “gD” fuses	188
Figure 1009 – Time-current zones for class CC “gD” fuses	189
Figure 1010 – Time-current zones for class CC “gD” fuses	190
Figure 1101 – “gK” fuse-links (1 of 2)	198
Figure 1102 – Connecting dimensions for “gK” fuse-links (1 of 3).....	200
Figure 1103 – Dummy fuse-link	202
Figure 1104 – Time-current zones for “gK” fuse system K (1 of 2).....	203
Table 101 – Conventional time and current for "gG" fuse-links with rated current lower than 16 A.....	23
Table 102 – Gates for specified pre-arcing and operating times of "gG" fuse-links.....	23
Table 103 – Minimum rated breaking capacities	23
Table 104 – Marking of fuse-links.....	24
Table 105 – Minimum cross-sectional ranges of unprepared conductors	25
Table 106 – Pre-arcing and operating I^2t values at 0,01 s for "gG" fuse-links.....	26
Table 107 – Maximum operating I^2t values for “aM” fuse-links	27
Table 108 – Pre-arcing I^2t values for discrimination of gG fuse-links	27
Table 109 – Survey of tests on fuse-holders and number of fuse-holders to be tested	28
Table 110 – Rated impulse withstand voltage	28
Table 111 – Torque to be applied to the terminal screws	29
Table 112 – Test currents	30
Table 113 – Test currents and I^2t limits for discrimination test.....	32
Table 114 – Torques to be applied when no values are given by the manufacturer	35
Table 115 – Cross-sectional area of aluminium conductors for tests corresponding to 8.10	35
Table 116 – Test sequence for direct terminal clamps.....	37
Table 117 – Permissible changes of the resistance.....	38
Table 118 – Force to withdraw the fuse-link from the fuse-base contacts	39
Table 201 – Position and force of the striker.....	65
Table 301 – Minimum cross-sectional ranges of unprepared conductors for fuse-rails	76
Table 302 – Survey of complete tests on fuse-rails and number of fuse-rails to be tested	77
Table 401 – Minimum cross-sectional ranges of unprepared conductors for fuse-bases for busbar mounting.....	86
Table 402 – Torques to be applied to contact making screws.....	87
Table 403 – Test currents	88
Table 404 – Force to withdraw the fuse-link from the fuse-base contacts	89
Table 501 – Conventional time and current for "gG" fuse-links	98
Table 502 – Gates for specified pre-arcing times of "gG" fuse-links.....	98
Table 601 – Maximum rated current of fuse-links with cylindrical caps	112
Table 602 – Maximum rated current of fuse-holders.....	112

Table 603 – Maximum values of the rated power dissipation of a fuse-link	113
Table 604 – Rated acceptable power dissipation of a fuse-holder	113
Table 605 – Conventional time and current for “gG” fuse-links with rated current lower than 16 A.....	114
Table 606 – Gates for specified pre-arcing and operating times of “gG” fuse-links with rated current lower than 16 A	114
Table 607 – Minimum rated breaking capacities	114
Table 608 – Marking of fuse-links.....	115
Table 609 – Minimum range of cross-sections for rigid copper conductors.....	115
Table 610 – Pre-arcing and operating I^2t values at 0,01 s for “gG” fuse-links	116
Table 611 – Maximum operating I^2t values for “aM” fuse-links	116
Table 612 – Survey of tests on fuse-holders and number of fuse-holders to be tested	117
Table 613 – Torque to be applied to the terminal screws	117
Table 614 – Test currents	118
Table 615 – Test currents and I^2t limits for discrimination test	120
Table 701 – Conventional time and current for "gG" fuse-links	127
Table 702 – Gates for specified pre-arcing times of "gG" fuse-links.....	128
Table 703 – Sizes of copper conductors	129
Table 704 – Pre-arcing I^2t values at 0,01 s for "gG" fuse-links	129
Table 801 – Conventional time and current for "gD" and "gN" fuse-links.....	138
Table 802 – Gates for specified pre-arcing times of "gD" and "gN" fuse-links	139
Table 803 – Pre-arcing I^2t values at 0,01 s for "gD" and "gN" fuse-links	140
Table 804 – Cross-sectional area of copper conductors for tests corresponding to 8.3 and 8.4.....	141
Table 805 – Class J dummy fuse-link dimensions	142
Table 806 – Class T dummy fuse-link dimensions.....	142
Table 807 – Maximum cut-off current (I_C) for "gD" and "gN" fuse-links at 200 kA prospective current	143
Table 808 – Maximum operating I^2t values for "gD" and "gN" fuse-links at 200 kA prospective current	144
Table 901 – Maximum power dissipation values	160
Table 902 – Pre-arcing I^2t values for gU fuse-links at 0,01 s	162
Table 903 – Cross-sectional area of conductors for power dissipation and temperature-rise tests	163
Table 1001 – Conventional time and current for "gD class CC" and "gN class CC" fuse-links.....	174
Table 1002 – Gates for specified pre-arcing times of "gD class CC" and "gN class CC" fuse-links	174
Table 1003 – Pre-arcing I^2t values at 0,01 s for "gD class CC" and "gN class CC" fuse-links.....	176
Table 1005 – Maximum cut-off current (I_C) for "gD class CC" and "gN class CC" fuse-links at 200 kA prospective current.....	178
Table 1006 – Maximum operating I^2t values for "gD class CC" and "gN class CC" fuse-links at 200 kA prospective current	178
Table 1101 – Maximum power dissipation values for «gK» fuse-links	192
Table 1102 – Conventional time and current for «gK» fuse-links	193

Table 1103 – Gates for specified pre-arcing and operating times of “gK” fuse-links	193
Table 1104 – Minimum rated breaking capacities for “gK” fuse-links.....	193
Table 1105 – Pre-arcing and operating I^2t values at 0,01 s for “gK” fuse-links	194
Table 1106 – Cross-sectional area of copper conductors for tests corresponding to 8.3 and 8.4.....	195
Table 1107 – Maximum cut-off current (I_C) for “gK”fuse-links (1 250 A to 4 800 A) at 100 kA prospective current.....	196
Table 1108 – Test currents and I^2t limits for “gK” fuse-links selectivity test	196

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE FUSES –**Part 2: Supplementary requirements for fuses
for use by authorized persons
(fuses mainly for industrial application) –
Examples of standardized systems of fuses A to K****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 60269-2 bears the edition number 5.1. It consists of the fifth edition (2013-07) [documents 32B/611/FDIS and 32B/615/RVD] and its amendment 1 (2016-08) [documents 32B/641/CDV and 32B/648/RVC]. The technical content is identical to the base edition and its amendment.

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60269-2 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

This edition includes the following significant technical changes with respect to the previous edition:

- a) fuse systems A and B: modified values for the power dissipation of NH aM fuse-links;
- b) fuse systems A and B: introduction of dimension r for NH fuse-links;
- c) addition of new fuse system K: gK fuse-links with contacts for bolted connections.

This part is to be used in conjunction with IEC 60269-1:2006, *Low-voltage fuses – Part 1: General requirements* and its Amendment 1 (2009).

This Part 2 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 2 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 101 in fuse system A, from 201 in fuse system B, etc. Additional annexes are numbered AA, BB, etc.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60269 series, published under the general title *Low-voltage fuses*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

- Part 1: General requirements
- Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K
- Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F
- Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices
- Part 5: Guidance for the application of low-voltage fuses
- Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems

LOW-VOLTAGE FUSES –

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K

1 General scope

1.1 Scope

Fuses for use by authorized persons are generally designed to be used in installations where the fuse-links are accessible to, and may be replaced by, authorized persons only.

Fuses for use by authorized persons according to the following fuse systems also comply with the requirements of the corresponding subclauses of IEC 60269-1, unless otherwise defined in this standard.

This standard is divided into fuse systems, each dealing with a specific example of standardized fuses for use by authorized persons:

- Fuse system A: Fuses with fuse-links with blade contacts (NH fuse system)
- Fuse system B: Fuses with striker fuse-links with blade contacts (NH fuse system)
- Fuse system C: Fuse-rails (NH fuse system)
- Fuse system D: Fuse-bases for busbar mounting (NH fuse system)
- Fuse system E: Fuses with fuse-links for bolted connections (BS bolted fuse system)
- Fuse system F: Fuses with fuse-links having cylindrical contact caps (NF cylindrical fuse system)
- Fuse system G: Fuses with fuse-links with offset blade contacts (BS clip-in fuse system)
- Fuse system H: Fuses with fuse-links having "gD" and "gN" characteristic (class J class L and class T time delay and non time delay fuse types)
- Fuse system I: gU fuse-links with wedge tightening contacts
- Fuse system J: Fuses with fuse-links having "gD class CC" and "gN class CC" characteristics (class CC time delay and non-time delay fuse types)
- Fuse system K: gK fuse-links with blade for bolted connections – High fuse-link ratings from 1 250 A up to 4 800 A (master fuse-links)

NOTE The above-mentioned fuse systems are standardized systems in respect to their safety aspects. The National Committees can select from the examples of standardized fuses one or more systems for their own standards.

1.2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60112, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60269-1, *Low-voltage fuses – Part 1: General requirements*