

FINAL VERSION

VERSION FINALE

**Low-voltage fuses –
Part 6: Supplementary requirements for fuse-links for the protection of solar
photovoltaic energy systems**

**Fusibles basse tension –
Partie 6: Exigences supplémentaires concernant les éléments de remplacement
utilisés pour la protection des systèmes d'énergie solaire photovoltaïque**

CONTENTS

FOREWORD.....	4
1 General.....	6
1.1 Scope and object.....	6
1.2 Normative references.....	6
2 Terms and definitions.....	7
2.2 General terms.....	7
3 Conditions for operation in service.....	9
3.4 Voltage.....	9
3.4.1 Rated voltage.....	9
3.5 Current.....	9
3.5.1 Rated Current.....	9
3.6 Frequency, power factor and time constant.....	9
3.6.1 Frequency.....	9
3.6.2 Power factor.....	9
3.6.3 Time constant.....	10
3.10 Temperature inside an enclosure.....	10
4 Classification.....	10
5 Characteristics of fuses.....	10
5.1 Summary of characteristics.....	10
5.1.2 Fuse-links.....	10
5.2 Rated voltage.....	10
5.5 Rated power dissipation of the fuse-link.....	10
5.6 Limits of time-current characteristics.....	10
5.6.1 Time-current characteristics, time-current zones.....	10
5.6.2 Conventional times and currents.....	11
5.6.3 Gates.....	11
5.7 Breaking range and breaking capacity.....	11
5.7.1 Breaking range and utilization category.....	11
5.7.2 Rated breaking capacity.....	11
6 Markings.....	11
6.2 Markings on fuse-links.....	11
7 Standard conditions for construction.....	12
7.5 Breaking capacity.....	12
8 Tests.....	12
8.1 General.....	12
8.1.4 Arrangement of the fuse and dimensions.....	12
8.1.5 Testing of fuse-links.....	12
8.3 Verification of temperature rise limits and power dissipation.....	13
8.3.1 Arrangement of the fuse-link.....	13
8.3.3 Measurement of power dissipation of the fuse-link.....	13
8.3.5 Acceptability of test results.....	14
8.4 Verification of operation.....	14
8.4.1 Arrangement of fuse-link.....	14
8.4.3 Test method and acceptability of test results.....	14
8.5 Verification of the breaking capacity.....	15

8.5.1	Arrangement of the fuse	15
8.5.5	Test method	15
8.5.8	Acceptability of test results	15
8.11	Mechanical and miscellaneous tests	16
Annex AA (normative)	Examples of standardized fuse-links for the protection of solar photovoltaic energy systems	18
Annex BB (informative)	Guidance for the protection of photovoltaic strings and arrays with fuse-links designed for PV applications	29
Bibliography	30
Figure 101	– Current of test cycling	7
Figure AA.1	– Fuse-links with cylindrical contact caps, type A	19
Figure AA.2	– Fuse-links with cylindrical contact caps type A with striker – Additional dimensions for sizes 14 × 51, 20 × 127 and 22 × 127 only	20
Figure AA.3	– Cylindrical fuse-links with blade contacts – Sizes 61-600 A	21
Figure AA.4	– Fuse-links with blade contacts, type C, C referring IEC 60269-2 “Fuse system A (NH fuse system)”	23
Figure AA.5	– Long fuse-links with blade contacts, type D (specific for PV application)	25
Figure AA.6	– Replacement handle for long fuse-links with blade contacts	26
Figure AA.7	– Fuse-bases for long fuse-links with blade contacts	27
Figure AA.8	– Fuse-links with bolted blade contacts, type L (specific for PV application)	28
Table 101	– Conventional times and currents for “gPV” fuse-links	11
Table 102	– Survey of complete tests on fuse-links and number of fuse-links to be tested	12
Table 103	– Survey of tests on fuse-links of the smallest rated current of a homogeneous series and number of fuse-links to be tested	13
Table 104	– Values for breaking-capacity tests on “gPV” fuse-links	16

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE FUSES –

**Part 6: Supplementary requirements for fuse-links
for the protection of solar photovoltaic energy systems**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60269-6 edition 1.1 contains the first edition (2010-09) [documents 32B/561/FDIS and 32B/569/RVD] and its corrigendum (2010-12), and its amendment 1 (2021-04) [documents 32B/698/FDIS and 32B/699/RVD].

This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60269-6 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

This part is to be used in conjunction with IEC 60269-1:2006, *Low-voltage fuses, Part 1: General requirements*.

This Part 6 supplements or modifies the corresponding clauses or subclauses of Part 1.

Where no change is necessary, this Part 6 indicates that the relevant clause or subclause applies.

Tables and figures which are additional to those in Part 1 are numbered starting from 10.

Additional annexes are lettered AA, BB, etc.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60269 series, under the general title: *Low voltage fuses*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

LOW-VOLTAGE FUSES –

Part 6: Supplementary requirements for fuse-links for the protection of solar photovoltaic energy systems

1 General

IEC 60269-1 applies with the following supplementary requirements.

Fuse-links for the protection of solar photovoltaic (PV) energy systems shall comply with all requirements of IEC 60269-1, if not otherwise indicated hereinafter, and shall also comply with the supplementary requirements laid down below.

NOTE The abbreviation “PV” (photovoltaic) is used in this document.

1.1 Scope and object

These supplementary requirements apply to fuse-links for protecting PV strings and PV arrays in equipment for circuits of nominal voltages up to 1 500 V DC, and also, in so far as they are applicable, for circuits of higher nominal voltages.

NOTE 1 Such fuse-links are commonly referred to as “PV fuse-links”.

NOTE 2 In most cases, a part of the associated equipment serves the purpose of a fuse-base. Owing to the great variety of equipment, no general rules can be given; the suitability of the associated equipment to serve as a fuse-base should be subject to agreement between the manufacturer and the user. However, if separate fuse-bases or fuse-holders are used, they should comply with the appropriate requirements of IEC 60269 series.

NOTE 3 PV fuse-links protect down stream inverter components such as capacitors or the discharge of capacitors back into the arrays or array wiring up to the rated breaking capacity.

The object of these supplementary requirements is to establish the characteristics of PV fuse-links in such a way that they can be replaced by other fuse-links having the same characteristics, provided that their dimensions are identical. For this purpose, this standard refers in particular to

- a) the following characteristics of fuses:
 - 1) their rated value;
 - 2) their utilisation category;
 - 3) their temperature rises in normal service;
 - 4) their power dissipation;
 - 4) their time-current characteristics;
 - 5) their breaking capacity;
 - 7) their dimensions or size (if applicable).
- b) type tests for verification of the characteristics of fuses;
- c) the markings on fuses.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60269-1, *Low-voltage fuses – Part 1: General requirements*