

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Electrical measuring transducers for converting AC and DC electrical quantities to analogue or digital signals

Transducteurs électriques de mesure convertissant les grandeurs électriques alternatives ou continues en signaux analogiques ou numériques



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications preview. With a subscription you will always have access to up-to-date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Electrical measuring transducers for converting AC and DC electrical quantities to analogue or digital signals

Transducteurs électriques de mesure convertissant les grandeurs électriques alternatives ou continues en signaux analogiques ou numériques

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.20

ISBN 978-2-8322-1009-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references.....	13
3 Terms and definitions	13
3.1 General terms	13
3.2 Terms describing transducers according to the measurand	15
3.3 Terms describing transducers according to their output load	17
3.4 Nominal values	17
3.5 Terms describing transducers with provisions to be adjusted by users.....	18
3.6 Influence quantities and reference conditions.....	18
3.7 Errors and variations	19
3.8 Accuracy, accuracy class, class index	19
4 General	19
4.1 Transducer general architecture	19
4.2 Classification of transducers (TRD)	20
5 Requirements for TRD1	20
5.1 Safety requirements: clearances and creepage distances	20
5.2 EMC requirements	20
5.2.1 Immunity.....	20
5.2.2 Emission.....	21
5.3 Class index requirements	21
5.3.1 Class index.....	21
5.3.2 Class index for transducers used with sensors	21
5.3.3 Intrinsic error	21
5.4 Conditions for the determination of intrinsic error	21
5.5 Auxiliary supply.....	23
5.5.1 General	23
5.5.2 DC supply.....	23
5.5.3 AC supply	23
5.6 Input values	24
5.6.1 General	24
5.6.2 Adjustment ranges	24
5.6.3 Preferred nominal values.....	24
5.7 Analogue output signals	24
5.7.1 General	24
5.7.2 Output current.....	24
5.7.3 Compliance voltage.....	24
5.7.4 Maximum output voltage	24
5.7.5 Interference risk of output current.....	24
5.7.6 Output voltage	25
5.8 Output transfer function.....	25
5.9 Digital output signals.....	27
5.10 Ripple (for analogue outputs)	27
5.11 Response time	28
5.12 Variation due to over-range of the measurand.....	28

5.13	Limiting value of the output signal.....	28
5.14	Limiting conditions of operation	28
5.15	Limits of the measuring range.....	28
5.16	Limiting conditions for storage and transport.....	28
5.17	Sealing	29
5.18	Stability	29
6	Tests for TRD1	29
6.1	General.....	29
6.1.1	Determination of variations.....	29
6.1.2	Environmental conditions	29
6.1.3	Computations.....	30
6.2	Variations due to auxiliary supply voltage	30
6.2.1	Application.....	30
6.2.2	Procedure.....	30
6.2.3	Computation	30
6.2.4	Permissible variations	31
6.3	Variations due to auxiliary supply frequency	31
6.3.1	Application.....	31
6.3.2	Procedure.....	31
6.3.3	Computation	31
6.3.4	Permissible variations	31
6.4	Variations due to ambient temperature	32
6.4.1	Application.....	32
6.4.2	Procedure.....	32
6.4.3	Computation	32
6.4.4	Permissible variations	32
6.5	Variations due to the frequency of the input quantity(ies)	32
6.5.1	Application.....	32
6.5.2	Procedure.....	33
6.5.3	Computation	33
6.5.4	Permissible variations	33
6.6	Variations due to the input voltage.....	33
6.6.1	Application.....	33
6.6.2	Procedure.....	33
6.6.3	Computation	33
6.6.4	Permissible variations	34
6.7	Variations due to the input current.....	34
6.7.1	Application.....	34
6.7.2	Procedure.....	34
6.7.3	Computation	34
6.7.4	Permissible variations	34
6.8	Variations due to power factor	35
6.8.1	Application.....	35
6.8.2	Procedure.....	35
6.8.3	Computation	35
6.8.4	Permissible variations	35
6.9	Variation due to output load.....	35
6.9.1	Application.....	35
6.9.2	Procedure.....	35

6.9.3	Computation	36
6.9.4	Permissible variations	36
6.10	Variations due to distortion of the input quantity(ies)	36
6.10.1	Application	36
6.10.2	Procedure	36
6.10.3	Computation	36
6.10.4	Permissible variations	37
6.11	Variation due to magnetic field of external origin	37
6.11.1	Application	37
6.11.2	Procedure	37
6.11.3	Computation	37
6.11.4	Permissible variations	37
6.12	Variation due to unbalanced currents	38
6.12.1	Application	38
6.12.2	Procedure	38
6.12.3	Computation	38
6.12.4	Permissible variations	38
6.13	Variation due to interaction between measuring elements	38
6.13.1	Application	38
6.13.2	Procedure	38
6.13.3	Computation	39
6.13.4	Permissible variations	39
6.14	Variation due to self-heating	39
6.14.1	Application	39
6.14.2	Method	39
6.14.3	Computation	39
6.14.4	Permissible variations	39
6.15	Variation due to continuous operation	39
6.15.1	Application	39
6.15.2	Procedure	40
6.15.3	Computation	40
6.15.4	Permissible variation	40
6.16	Variation due to common mode interference	40
6.16.1	Application	40
6.16.2	Procedure	40
6.16.3	Computation	40
6.16.4	Permissible variations	40
6.17	Variation due to series mode interference	40
6.17.1	Application	40
6.17.2	Procedure	40
6.17.3	Computation	41
6.17.4	Permissible variations	41
6.18	Permissible excessive inputs	41
6.18.1	Continuous excessive inputs	41
6.18.2	Excessive inputs of short duration	41
6.19	Voltage test, insulation tests and other safety requirements	41
6.20	Impulse voltage tests	42
6.21	High frequency disturbance test	42
6.22	Test for temperature rise	42

6.23	Other tests	42
7	Marking and information for TRD1	42
7.1	Marking on the case	42
7.2	Markings relating to the reference conditions and nominal ranges of use for transducers	43
7.3	Identification of connections and terminals	44
7.4	Information to be given in a separate document	44
Annex A	(normative) Requirements for TRD2	46
A.0	General	46
A.1	Scope	46
A.2	Normative references	46
A.3	Terms and definitions	46
A.4	Environmental conditions	46
A.4.1	General	46
A.4.2	Normal environmental conditions	46
A.4.3	Special environmental conditions	46
A.5	Ratings for TRD2	46
A.5.1	General	46
A.5.2	Input ratings	47
A.5.3	Output ratings	48
A.5.4	General ratings	49
A.6	Requirements for design of TRD2	50
A.6.1	General	50
A.6.2	Safety requirements	50
A.6.3	EMC requirements	53
A.6.4	Climatic requirements	55
A.6.5	Mechanical requirements	55
A.6.6	Interface requirements	56
A.6.7	Accuracy requirements	56
A.6.8	Marking requirements	60
A.6.9	Documentation requirements	61
A.7	Tests for TRD2	62
A.7.1	Type tests	62
A.7.2	Routine tests	71
Annex B	(normative) Interface coding	73
B.1	General	73
B.2	Characteristics of interface connection	73
B.3	Coding of rated output values for transducers	73
B.4	Coding of auxiliary power supply for transducers	75
B.5	Coding of transfer function curves for transducers	76
B.6	Interface full coding for output of transducers	76
B.6.1	General	76
B.6.2	Examples of interface codes and most common interface codes	77
Annex C	(Informative) Anti-aliasing requirements	79
Annex D	(informative) Requirements for the measurement of harmonics and low frequencies	81
D.1	General	81
D.2	Measuring accuracy classes with harmonics	81
D.3	Accuracy class extensions of transducers for high bandwidth applications	82

Annex E (normative) Markings terminals of TRD2	83
E.1 Marking of terminals for TRD2 monitoring AC current	83
E.2 Marking of terminals for TRD2 monitoring voltage	83
Annex F (informative) Guidance related to cables, busbars and bare conductors within an installation	85
F.1 Insulation of cables	85
F.2 Temperature of cables and busbars	85
F.2.1 Cables	85
F.2.2 Busbars	85
Annex G (informative) Guidance related to overvoltage categories and measurement categories	86
G.1 Concept of overvoltage category	86
G.2 Approach of IEC 60664-1 for primary circuits of TRD2	86
G.2.1 General	86
G.2.2 Examples with IEC 60664-1:2020, for primary measuring circuit OVC III, PD 2, altitude under 2 000 m, inhomogeneous field	86
G.3 Approach of IEC 61010 for primary circuits of TRD2	87
G.3.1 General	87
G.3.2 Example with IEC 61010-2-030:2017, for primary measuring circuits, OVC III, PD 2, altitude under 2 000 m, inhomogeneous field	87
G.4 Approach for secondary circuits of TRD2	88
Bibliography	89
Figure 1 – Transducer (TRD) architecture	20
Figure 2 – Transfer function curve A	25
Figure 3 – Transfer function curve B	25
Figure 4 – Transfer function curve C	26
Figure 5 – Transfer function curve D	26
Figure 6 – Transfer function curve E	27
Figure A.1 – Relationship between ambient air temperature and relative humidity	50
Figure A.2 – Accuracy limit for a TRD2-IDC	58
Figure A.3 – Measurement of the step response time	66
Figure A.4 – Temperature cycle accuracy test	68
Figure C.1 – Digital data acquisition system example	79
Figure C.2 – Frequency response mask for metering accuracy class 1 ($f_r = 60$ Hz, $f_s = 4 800$ Hz)	80
Table 1 – Functional classification of transducers with minimal required functions	20
Table 2 – Relationship between the limits of intrinsic error, expressed as a percentage of the fiducial value, and the class index	21
Table 3 – Pre-conditioning	22
Table 4 – Reference conditions of the influence quantities and tolerances or testing purposes	22
Table 5 – Reference conditions relative to the measurand	23
Table 6 – Usage groups	30
Table 7 – Permissible variations due to AC auxiliary supply	31
Table 8 – Permissible variations due to DC auxiliary supply	31

Table 9 – Permissible variations due to auxiliary supply frequency.....	32
Table 10 – Permissible variations due to ambient temperature.....	32
Table 11 – Permissible variations due to the frequency of input quantity.....	33
Table 12 – Permissible variations due to the input voltage.....	34
Table 13 – Permissible variations due to the input current.....	34
Table 14 – Permissible variations due to power factor.....	35
Table 15 – Permissible variations due to output load.....	36
Table 16 – Permissible variations due to distortion of input quantities.....	37
Table 17 – Permissible variations due to magnetic field of external origin.....	37
Table 18 – Permissible variations due to unbalance currents.....	38
Table 19 – Permissible variations due to interactions between measuring elements.....	39
Table 20 – Permissible variations due to self-heating.....	39
Table 21 – Permissible variations due to continuous operation.....	40
Table 22 – Permissible variations due to series mode interference.....	41
Table 23 – Examples of marking relating to the reference conditions and normal range of use for temperature.....	43
Table 24 – Symbols for marking transducers.....	45
Table A.1 – Rated burden for TRD2 with an AC or DC voltage output, or a frequency output.....	48
Table A.2 – Rated burden for TRD2 with an AC or DC current output.....	49
Table A.3 – Rated temperatures for TRD2.....	49
Table A.4 – Rated humidity classes.....	50
Table A.5 – Definition of ports.....	54
Table A.6 – Performance criteria for EMC immunity tests.....	55
Table A.7 – RJ45 connector pinout.....	56
Table A.8 – Limits for error and phase error for TRD2-IAC.....	57
Table A.9 – Limits of ratio error for TRD2-IDC.....	58
Table A.10 – Limits of ratio error for TRD2-UAC.....	59
Table A.11 – Limits of ratio error for TRD2-UDC.....	59
Table A.12 – Burden values for basic accuracy tests.....	64
Table B.1 – Coding of interface connection.....	73
Table B.2 – Rated AC RMS voltage output.....	74
Table B.3 – Rated DC voltage output.....	74
Table B.4 – Rated range of DC voltage output.....	74
Table B.5 – Rated AC RMS current output less than 1A.....	74
Table B.6 – Rated range of DC current output.....	75
Table B.7 – Rated frequency output.....	75
Table B.8 – Rated pulse density output.....	75
Table B.9 – Coding of power supply for transducers supplied from measuring instrument via the connector.....	76
Table B.10 – Coding of external power supply for transducers.....	76
Table B.11 – Coding of transfer function curves for transducers.....	76
Table B.12 – Interface full coding for output of transducers.....	77
Table B.13 – Examples of interface codes and most common interface codes.....	77

Table C.1 – Anti-aliasing filter	79
Table D.1 – Limits of error for harmonics – Accuracy classes	81
Table D.2 – Limits of error for harmonics – Accuracy class extensions WB1 and WB2	82
Table E.1 – Marking of terminals for TRD2 monitoring current	83
Table E.2 – Marking of terminals for TRD2 monitoring voltage	84
Table G.1 – Clearances according to IEC 60664-1:2020	86
Table G.2 – Creepage distances according to IEC 60664-1:2020	87
Table G.3 – Clearances according to IEC 61010-2-030:2017	88
Table G.4 – Creepage distances according to IEC 61010-2-030:2017	88

Currently in preview, click buy full version

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICAL MEASURING TRANSDUCERS FOR CONVERTING AC AND DC
ELECTRICAL QUANTITIES TO ANALOGUE OR DIGITAL SIGNALS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60688 has been prepared by IEC technical committee 85: Measuring equipment for electrical and electromagnetic quantities. It is an International Standard.

This fourth edition cancels and replaces the third edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) updating normative references;
- b) additional requirements for specific transducers used for LV monitoring applications;
- c) creation of interface coding to ease selection by the end-user.

The text of this International Standard is based on the following documents:

CDV	Report on voting
85/748/CDV	85/781/RVC

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

In this document, the following print types are used:

- requirements and definitions: in roman type;
- NOTES: in smaller roman type;
- *compliance*: in italic type.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

New transducers can now be equipped with microprocessors that utilise digital data processing, communication methods and auxiliary sensors. This makes them more complex than conventional analogue transducers and gives them considerable added value.

The class index system of classification used in this document is based upon IEC 60051 (all parts). Under this system, the permitted variations of the output signal due to varying influence quantities – ambient temperature, voltage, frequency, etc. – are implicit in the classification.

For those unfamiliar with the class index system, a word of warning is necessary. If, for example, a transducer is classified as class 1, it does not mean that the error under practical conditions of use will be within ± 1 % of the actual value of the output or ± 1 % of the full output value. It means that the error should not exceed ± 1 % of the fiducial value under closely specified conditions. If the influence quantities are varied between the limits specified by the nominal ranges of use, a variation of amount comparable with the value of the class index may be incurred for each influence quantity.

The permissible error of a transducer under working conditions is the sum of the permissible intrinsic error and of the permissible variations due to each of the influence quantities. However, the actual error is likely to be much smaller because not all of the influence quantities are likely to be simultaneously at their most unfavourable values and some of the variations may cancel one another. It is important that these facts be taken into consideration when specifying transducers for a particular purpose.

Furthermore, some of the terms used in this document are different from those used in IEC 60051 (all parts) due to the fundamental differences between indicating instruments and measuring transducers.

All statements of performance are related to the output which is governed by two basic terms:

- "the nominal value", which may have a positive or a negative sign or both;
- "the span", which is the range of values of the output signal from maximum positive to maximum negative, if appropriate.

ELECTRICAL MEASURING TRANSDUCERS FOR CONVERTING AC AND DC ELECTRICAL QUANTITIES TO ANALOGUE OR DIGITAL SIGNALS

1 Scope

This document applies to transducers with electrical inputs and outputs for making measurements of AC or DC electrical quantities. The output signal can be in the form of an analogue direct current, an analog direct voltage or in digital form.

This document applies to measuring transducers used for converting electrical quantities such as

- current,
- voltage,
- active power,
- reactive power,
- power factor,
- phase angle,
- frequency,
- harmonics or total harmonic distortion, and
- apparent power

to an output signal.

This document is not applicable for

- instrument transformers that comply with IEC 61869 (all parts),
- transmitters for use in industrial process application that comply with IEC 60770 (all parts), and
- performance measuring and monitoring devices (PMD) that comply with IEC 61557-12:2018.

Within the measuring range, the output signal is a function of the measurand. An auxiliary supply can be needed.

This document applies

- a) if the nominal frequency of the input(s) lies between 0 Hz and 1 500 Hz,
- b) to the electrical measuring transducer if it is part of a system for the measurement of a non-electrical quantity, and if it otherwise falls within the scope of this document, and
- c) to transducers for use in a variety of applications such as telemetry and process control and in one of a number of defined environments.

This document is intended:

- to specify the terminology and definitions relating to transducers whose main application is in industry,
- to unify the test methods used in evaluating transducer performance, and
- to specify accuracy limits and output values for transducers.