

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Power cables with extruded insulation and their accessories for rated voltages above 30 kV ($U_m = 36$ kV) up to 150 kV ($U_m = 170$ kV) – Test methods and requirements

Câbles d'énergie à isolation extrudée et leurs accessoires pour des tensions assignées supérieures à 30 kV ($U_m = 36$ kV) et jusqu'à 150 kV ($U_m = 170$ kV) – Méthodes et exigences d'essai



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour toute ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Power cables with extruded insulation and their accessories for rated voltages above 30 kV ($U_m = 36$ kV) up to 150 kV ($U_m = 170$ kV) – Test methods and requirements

Câbles d'énergie à isolation extrudée et leurs accessoires pour des tensions assignées supérieures à 30 kV ($U_m = 36$ kV) et jusqu'à 150 kV ($U_m = 170$ kV) – Méthodes et exigences d'essai

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE **XB**
CODE PRIX

ICS 29.060.20

ISBN 978-2-88912-752-8

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions	10
3.1 Definitions of dimensional values (thicknesses, cross-sections, etc.).....	10
3.2 Definitions concerning tests	11
3.3 Other definitions	11
4 Voltage designations and materials	12
4.1 Rated voltages	12
4.2 Cable insulating materials.....	12
4.3 Cable metal screens/sheaths	12
4.4 Cable oversheathing materials.....	12
5 Precautions against water penetration in cables	12
6 Cable characteristics	13
7 Accessory characteristics.....	13
8 Test conditions	14
8.1 Ambient temperature	14
8.2 Frequency and waveform of power frequency test voltages	14
8.3 Waveform of lightning impulse test voltages.....	14
8.4 Relationship of test voltages to rated voltage	14
8.5 Determination of the cable conductor temperature	14
9 Routine tests on cables and on the main insulation of prefabricated accessories	15
9.1 General	15
9.2 Partial discharge test.....	15
9.3 Voltage test	15
9.4 Electrical test on oversheath of the cable	15
10 Sample tests on cables	16
10.1 General	16
10.2 Frequency tests.....	16
10.3 Repetition of tests.....	16
10.4 Conductor examination	16
10.5 Measurement of electrical resistance of conductor and metal screen.....	16
10.6 Measurement of thickness of cable insulation and oversheath.....	17
10.6.1 General	17
10.6.2 Requirements for the insulation.....	17
10.6.3 Requirements for the cable oversheath	17
10.7 Measurement of thickness of metal sheath.....	18
10.7.1 Lead or lead alloy sheath	18
10.7.2 Plain or corrugated aluminium sheath	18
10.8 Measurement of diameters	19
10.9 Hot set test for XLPE, EPR and HEPR insulations	19
10.9.1 Procedure.....	19
10.9.2 Requirements	19
10.10 Measurement of capacitance.....	19

10.11	Measurement of density of HDPE insulation	19
10.11.1	Procedure	19
10.11.2	Requirements	19
10.12	Lightning impulse voltage test	19
10.13	Water penetration test	20
10.14	Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath	20
11	Sample tests on accessories	20
11.1	Tests on components	20
11.2	Tests on complete accessory	20
12	Type tests on cable systems	20
12.1	General	20
12.2	Range of type approval	21
12.3	Summary of type tests	21
12.4	Electrical type tests on complete cable systems	22
12.4.1	Test voltage values	22
12.4.2	Tests and sequence of tests	22
12.4.3	Bending test	23
12.4.4	Partial discharge tests	24
12.4.5	Tan δ measurement	24
12.4.6	Heating cycle voltage test	24
12.4.7	Lightning impulse voltage test followed by a lower frequency voltage test	25
12.4.8	Examination	25
12.4.9	Resistivity of semi-conducting screens	25
12.5	Non-electrical type tests on cable components and on complete cable	26
12.5.1	Check of cable construction	26
12.5.2	Tests for determining the mechanical properties of insulation before and after ageing	26
12.5.3	Tests for determining the mechanical properties of oversheaths before and after ageing	27
12.5.4	Ageing test on pieces of complete cable to check compatibility of materials	27
12.5.5	Loss of mass test on PVC oversheaths of type ST ₂	28
12.5.6	Pressure test at high temperature on oversheaths	28
12.5.7	Test on PVC oversheaths (ST ₁ , ST ₂) at low temperature	28
12.5.8	Heat shock test for PVC oversheaths (ST ₁ and ST ₂)	29
12.5.9	Ozone resistance test for EPR and HEPR insulations	29
12.5.10	Hot set test for EPR, HEPR and XLPE insulations	29
12.5.11	Measurement of density of HDPE insulation	29
12.5.12	Measurement of carbon black content of black PE oversheaths (ST ₃ and ST ₇)	29
12.5.13	Test under fire conditions	29
12.5.14	Water penetration test	30
12.5.15	Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath	30
12.5.16	Shrinkage test for PE, HDPE and XLPE insulations	30
12.5.17	Shrinkage test for PE oversheaths (ST ₃ and ST ₇)	30
12.5.18	Determination of hardness of HEPR insulation	30
12.5.19	Determination of the elastic modulus of HEPR insulation	31

13	Prequalification test of the cable system.....	31
13.1	General and range of prequalification test approval.....	31
13.2	Prequalification test on complete system.....	32
13.2.1	Summary of prequalification tests	32
13.2.2	Test voltage values.....	32
13.2.3	Test arrangement	32
13.2.4	Heating cycle voltage test	33
13.2.5	Lightning impulse voltage test	34
13.2.6	Examination.....	34
13.3	Tests for the extension of the prequalification of a cable system.....	34
13.3.1	Summary of the extension of prequalification test.....	34
13.3.2	Electrical part of the extension of prequalification tests on complete cable system.....	34
14	Type tests on cables.....	36
14.1	General	36
14.2	Range of type approval.....	36
14.3	Summary of type tests	37
14.4	Electrical type tests on completed cables	37
15	Type tests on accessories.....	38
15.1	General	38
15.2	Range of type approval.....	38
15.3	Summary of type tests	38
15.4	Electrical type tests on accessories.....	39
15.4.1	Test voltage values.....	39
15.4.2	Tests and sequence of tests	39
16	Electrical tests after installation.....	40
16.1	General	40
16.2	DC voltage test of the oversheath.....	40
16.3	AC voltage test of the insulation.....	40
	Annex A (informative) Determination of the cable conductor temperature.....	47
	Annex B (normative) Rounding of numbers.....	52
	Annex C (informative) List of type, prequalification and extension of prequalification tests for cable systems, cables and accessories.....	53
	Annex D (normative) Method of measuring resistivity of semi-conducting screens.....	56
	Annex E (normative) Water penetration test	58
	Annex F (normative) Tests on components of cables with a longitudinally applied metal tape or foil, bonded to the oversheath.....	60
	Annex G (normative) Tests of outer protection for joints	63
	Annex H (normative) Determination of hardness of HEPR insulations	65
	Bibliography.....	67
	Figure 1 – Example of the test arrangement for the prequalification test.....	33
	Figure 2 – Example of extension of prequalification test arrangement for the prequalification of a system with another joint, designed for rigid and flexible installation	35
	Figure A.1 – Typical test set-up for the reference loop and the main test loop	48
	Figure A.2 – Example of an arrangement of the temperature sensors on the conductor of the reference loop	49

Figure D.1 – Preparation of samples for measurement of resistivity of conductor and insulation screens	57
Figure E.1 – Schematic diagram of apparatus for water penetration test	59
Figure F.1 – Adhesion of metal foil	60
Figure F.2 – Example of overlapped metal foil	61
Figure F.3 – Peel strength of overlapped metal foil	61
Figure H.1 – Test on surfaces of large radius of curvature	66
Figure H.2 – Test on surfaces of small radius of curvature.....	66
Table 1 – Insulating compounds for cables	40
Table 2 – Oversheathing compounds for cables.....	41
Table 3 – Tan δ requirements for insulating compounds for cables.....	41
Table 4 – Test voltages	41
Table 5 – Non-electrical type tests for insulating and oversheathing compounds for cables	42
Table 6 – Test requirements for mechanical characteristics of insulating compounds for cables (before and after ageing)	43
Table 7 – Test requirements mechanical characteristics of oversheathing compounds for cables (before and after ageing).....	44
Table 8 – Test requirements for particular characteristics of insulating compounds for cables	45
Table 9 – Test requirements for particular characteristics of PVC oversheathing for cables	46
Table C.1 – Type tests on cable systems, on cables and on accessories	54
Table C.2 – Prequalification tests on cable systems with a calculated nominal conductor electric stress above 8,0 kV/mm or a calculated nominal insulation electric stress above 4,0 kV/mm.....	54
Table C.3 – Extension of prequalification tests on cable systems with a calculated nominal conductor electric stress above 8,0 kV/mm or a calculated nominal insulation electric stress above 4,0 kV/mm	55
Table G.1 – Impulse voltage tests	64

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**POWER CABLES WITH EXTRUDED INSULATION AND
THEIR ACCESSORIES FOR RATED VOLTAGES ABOVE 30 kV
($U_m = 36$ kV) UP TO 150 kV ($U_m = 170$ kV) –
TEST METHODS AND REQUIREMENTS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, issue IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60840 has been prepared by IEC technical committee 20: Electric cables.

This fourth edition cancels and replaces the third edition, published in 2004, and constitutes a major technical revision.

The significant technical change with respect to the previous edition is as follows:

- introduction of a prequalification test procedure for cables with high electrical stresses and tested as a cable system including accessories.

NOTE For a more detailed history of events leading up to this fourth edition, see the Introduction.

The text of this standard is based on the following documents:

FDIS	Report on voting
20/1267/FDIS	20/1277A/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The first edition of IEC 60840, published in 1988, dealt only with cables. Accessories were added to the second edition, published in February 1999, which separately covered test methods and test requirements for

- a) cables alone,
- b) cables together with accessories (a cable system).

Some countries then suggested that a better discrimination be made between systems, cables and accessories, particularly for the lower voltages of the scope, e.g. 45 kV. This was taken into account in the third edition and is retained in this revision, which gives the type approval requirements and the range of approvals for

- a) cable systems,
- b) cables alone,
- c) accessories alone.

Manufacturers and users may choose the most appropriate option for type approval.

At its meeting in November 2004, TC 20 decided to prepare a further major revision of IEC 60840 and concluded that this edition should incorporate the recommendations for testing HV and EHV extruded cables that were under preparation by CIGRE study committee B1 WG B1.06. This work was made available as CIGRE technical brochure No. 303, before the meeting of TC 20 in October 2006. The brochure, entitled 'Revision of qualification procedures for extruded (extra) high voltage a.c. underground cables' has therefore been considered by TC 20, and considerable parts implemented in this standard. Cables with high electrical stresses at the conductor screen and/or insulation screen are now required to undergo a prequalification test procedure (simplified compared to that in IEC 62067) as a cable system inclusive of accessories.

Additionally the following other significant changes to this standard have been introduced:

- a) The clause numbering of this standard and IEC 62067 (which has been revised at the same time as this standard) has been coordinated to achieve as much commonality as possible to assist users who use both standards.
- b) In the case of the sample test, the lightning impulse voltage test is no longer followed by a power frequency voltage test.

A list of relevant CIGRE references is given in the bibliography.

**POWER CABLES WITH EXTRUDED INSULATION AND
THEIR ACCESSORIES FOR RATED VOLTAGES ABOVE 30 kV
($U_m = 36$ kV) UP TO 150 kV ($U_m = 170$ kV) –
TEST METHODS AND REQUIREMENTS**

1 Scope

This International Standard specifies test methods and requirements for power cable systems, cables alone and accessories alone, for fixed installations and for rated voltages above 30 kV ($U_m = 36$ kV) up to and including 150 kV ($U_m = 170$ kV).

The requirements apply to single-core cables and to individually screened three-core cables and to their accessories for usual conditions of installation and operation, but not to special cables and their accessories, such as submarine cables, for which modifications to the standard tests may be necessary or special test conditions may need to be devised.

This standard does not cover transition joints between cables with extruded insulation and paper insulated cables.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE The IEC 60811 series is currently undergoing a revision, which will lead to a restructuring of its parts. A description of this, as well as a cross-reference table between the current and planned parts will be given in IEC 60811-100.

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60183, *Guide to the selection of high-voltage cables*

IEC 60228, *Conductors of insulated cables*

IEC 60229:2007, *Electric cables – Tests on extruded oversheaths with a special protective function*

IEC 60230, *Impulse tests on cables and their accessories*

IEC 60287-1-1:2006, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60811-1-1:1993, *Common test methods for insulating and sheathing materials of electric cables – Part 1: Methods for general application – Section 1: Measurement of thickness and overall dimensions – Tests for determining the mechanical properties*
Amendment 1 (2001)