

INTERNATIONAL
STANDARD

IEC
60870-6-503

Second edition
2002-04

Telecontrol equipment and systems –

**Part 6-503:
Telecontrol protocols compatible with
ISO standards and ITU-T recommendations –
TASE.2 Services and protocol**

Matériels et systèmes de téléconduite –

*Partie 6-503:
Protocoles de téléconduite compatibles avec les
normes ISO et les recommandations de l'UIT-T –
Services et protocole TASE.2*

© IEC 2002 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

XF

For price, see current catalogue

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 Control centre.....	8
1.2 Architecture.....	9
1.3 Network Model.....	10
1.4 Relation between TASE.2 and MMS.....	10
2 Normative references.....	11
3 Definitions.....	13
4 Abbreviations.....	15
5 TASE.2 Model.....	15
5.1 Informal TASE.2 Model Description.....	15
5.1.1 Associations.....	17
5.1.2 Bilateral Agreements, Bilateral Tables and Access Control.....	18
5.1.3 Data Value Objects and Services.....	20
5.1.4 Data Set Objects and Services.....	20
5.1.5 Account Objects and Services.....	20
5.1.6 Information Message Object and Services.....	20
5.1.7 Transfer Set Objects and Services.....	21
5.1.8 Common Data Transfer Mechanisms.....	23
5.1.9 Special Transfer Objects and Services.....	24
5.1.10 Device Objects and Services.....	24
5.1.11 Program Objects and Services.....	25
5.1.12 Event Enrollment Objects and Services.....	26
5.1.13 Event Condition Objects and Services.....	26
5.2 Formal TASE.2 Model Description.....	26
5.2.1 General Access Control Requirements.....	29
5.2.2 Association Management.....	29
5.2.3 Bilateral Tables.....	31
5.2.4 List of Access Control Specification.....	32
5.2.5 Data Values.....	33
5.2.6 Data Sets.....	34
5.2.7 Accounts.....	36
5.2.8 Information Messages.....	36
5.2.9 Transfer Sets.....	37
5.2.10 Special Transfer Objects.....	45
5.2.11 Devices.....	46
5.2.12 Programs.....	48
5.2.13 Event Enrollments.....	49
5.2.14 Event Conditions.....	49
6 Mapping of TASE.2 Object Models onto MMS Object Models.....	50
6.1 Object Modelling Notation (Informative).....	50
6.2 The Virtual Control Centre (VCC).....	51
6.2.1 TASE.2 Domain Mapping.....	51
6.2.2 TASE.2 Control Centre Mapping.....	52
6.2.3 OSI Application Processes, Application Entities and Presentation Addresses.....	52

6.3	Association Object Model Mapping	52
6.4	Bilateral Table Object Model Mapping	53
6.5	Data Value Object Model Mapping	55
6.6	Data Set Object Model Mapping	55
6.7	Account Object Model Mapping	56
6.8	Information Message Object Model Mapping	56
6.9	Transfer Set Object Model Mapping	57
6.9.1	Data Set Transfer Set Object Model Mapping	57
6.9.2	Time Series Transfer Set Object Model Mapping	59
6.9.3	Transfer Account Transfer Set Object Model Mapping	60
6.9.4	Information Message Transfer Set Object Model Mapping	61
6.10	Next Transfer Set Object Model Mapping	61
6.11	Transfer Set Name Object Model Mapping	62
6.12	Conditions Object Model Mapping	62
6.13	Event Code Object Model Mapping	62
6.14	Transfer Set Time Stamp Object Model Mapping	62
6.15	Device Object Model Mapping	63
6.16	Program Object Model Mapping	63
6.17	Event Enrollment Object Model Mapping	64
6.18	Event Condition Object Model Mapping	64
7	Mapping of TASE.2 Operations and Actions onto MMS Services	65
7.1	Use of MMS Services	66
7.1.1	Association Management Mapping to MMS	67
7.1.2	Data Value Operations Mapping to MMS	70
7.1.3	Data Set Operations Mapping to MMS	73
7.1.4	Transfer Set Operations and Actions Mapping to MMS	80
7.1.5	Account Operations and Actions Mapping	92
7.1.6	Device Operations and Actions Mapping to MMS	93
7.1.7	Program Operations Mapping to MMS	99
7.1.8	Event Enrollment Operations Mapping to MMS	104
7.1.9	Event Condition Operations Mapping onto MMS	106
7.1.10	Summary of TASE.2 Operations	107
8	Standardized Application-specific Objects	109
8.1	Named Type Objects	109
8.1.1	Visible-String-32 Type	109
8.1.2	MMS ObjectName	109
8.1.3	Time Stamp Types	110
8.1.4	TimeStampExtended Type	110
8.1.5	Time Interval Types	111
8.1.6	TransferSet Types	111
8.1.7	Conditions Types	113
8.1.8	SupportedFeatures Type	114
8.1.9	TASE.2Version Type	114
8.2	Named Variable Objects	115
8.2.1	"Supported_Features"	115
8.2.2	"Bilateral_Table_ID"	115
8.2.3	"TASE.2_Version"	115
8.2.4	Data Value Objects	115
8.2.5	Transfer Set Objects	116

8.2.6 "Next_DSTransfer_Set"..... 116

8.2.7 "Next_TSTransfer_Set"..... 116

8.2.8 "Transfer_Set_Name" 116

8.2.9 "TA_Transfer_Set" 116

8.2.10 "IM_Transfer_Set" 116

8.2.11 "DSConditions_Detected"..... 117

8.2.12 "TSConditions_Detected"..... 117

8.2.13 "TAConditions_Detected" 117

8.2.14 "Event_Code_Detected"..... 117

8.2.15 "Transfer_Set_Time_Stamp" 117

8.2.16 "Transfer_Report_ACK" 117

8.2.17 "Transfer_Report_NACK"..... 118

8.3 Named Variable List Objects..... 118

8.4 Information Message Objects..... 118

8.5 Event Condition Objects 118

9 Conformance..... 119

9.1 Allowable Subsets 119

9.2 PICS 120

9.3 MMS Services Required..... 124

Annex A (normative) TASE.2 Operations and Actions Summary..... 125

Annex B (normative) Quality of Service (QOS), Routing and Priority..... 127

Figure 1 – Protocol relationships 9

Figure 2 – Router-based WAN..... 10

Figure 3 – Mesh network 10

Figure 4 – Informal TASE.2 Model..... 17

Figure 5 – Transfer Reporting Mechanism 22

Figure 6 – Relationship between TASE.2 and Real Control Centres 27

Figure 7 – TASE.2 server components 66

Figure 8 – TASE.2 Server Association Control Components..... 67

Figure 9 – Data Value operations 70

Figure 10 – Sequence of Get Data Value..... 71

Figure 11 – Data Set operations 74

Figure 12 – Sequence of Create Data Set..... 76

Figure 13 – Sequence of Delete Data Set..... 77

Figure 14 – Transfer Set services..... 81

Figure 15 – Sequence of Transfer Set operations and actions..... 90

Figure 16 – Device operations 94

Figure 17 – Sequence of Device Control..... 95

Figure 18 – Server Program Components..... 100

Figure 19 – Sequence of Program Invocation operations 104

Table 1 – Scope of the object models in the VCC 28

Table 2 – Summary of TASE.2 Operations..... 107

INTERNATIONAL ELECTROTECHNICAL COMMISSION

TELECONTROL EQUIPMENT AND SYSTEMS –

**Part 6-503: Telecontrol protocols compatible with
ISO standards and ITU-T recommendations –
TASE.2 Services and protocol**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each national committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60370-6-503 has been prepared by IEC technical committee 57: Power system control and associated communications.

This second edition cancels and replaces the first edition published in 1997 and constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/574/FDIS	57/582/RVD

All information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Annexes A and B form an integral part of this standard.

The committee has decided that the contents of this publication will remain unchanged until 2004. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

Currently in preview, click buy full version

INTRODUCTION

The Telecontrol Application Service Element (TASE.2) protocol (also known as Inter-Control Centre Communications Protocol, ICCP) allows for data exchange over Wide Area Networks (WANs) between a utility control centre and other control centres, other utilities, power pools, regional control centres, and Non-Utility Generators. Data exchange information consists of real-time and historical power system monitoring and control data, including measured values, scheduling data, energy accounting data, and operator messages. This data exchange occurs between one control centre's Supervisory Control And Data Acquisition/Energy Management System/Distribution Management System (SCADA/EMS/DMS) host and another centre's host, often through one or more intervening communications processors.

This part of IEC 60870 defines a mechanism for exchanging time-critical data between control centres. In addition, it provides support for device control, general messaging and control of programs at a remote control centre. It defines a standardized method of using the ISO 1506 Manufacturing Message Specification (MMS) services to implement the exchange of data. The definition of TASE.2 consists of three documents. This part of IEC 60870 defines the TASE.2 application modelling and service definitions. IEC 60870-6-702 defines the application profile for use with TASE.2. IEC 60870-6-802 defines a set of standardized object definitions to be supported.

The TASE.2 describes real control centres with respect to their external visible data and behaviour using an object oriented approach. The objects are abstract in nature and may be used in a wide variety of applications. The use of TASE.2 goes far beyond the application in the control centre to control centre communications. This standard must be understood as a tool box for any application domain with comparable requirements, i.e. the TASE.2 may be applied in areas like substation automation, power plants, factory automation, chemical plants, or others which have comparable requirements. It provides a generic solution for advanced Information and Communication Technology.

The TASE.2 version number for this standard is 2001-08. See 8.2.3 for more details.

TELECONTROL EQUIPMENT AND SYSTEMS –

Part 6-503: Telecontrol protocols compatible with ISO standards and ITU-T recommendations – TASE.2 Services and protocol

1 Scope

This part of IEC 60870 specifies a method of exchanging time-critical control centre data through wide-area and local-area networks using a full ISO compliant protocol stack. It contains provisions for supporting both centralized and distributed architectures. This standard includes the exchange of real-time data indications, control operations, time-series data, scheduling and accounting information, remote program control and event notification.

Though the primary objective of TASE.2 is to provide control centre (telecontrol) data exchange, its use is not restricted to control centre data exchange. It may be applied in any other domain having comparable requirements. Examples of such domains are power plants, factory automation, process control automation, and others.

This standard does not specify individual implementations or products, nor does it constrain the implementation of entities and interfaces within a computer system. This standard specifies the externally visible functionality of implementations together with conformance requirements for such functionalities.