

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Short-circuit currents in three-phase a.c. systems –
Part 0: Calculation of currents**

**Courants de court-circuit dans les réseaux triphasés à courant alternatif –
Partie 0: Calcul des courants**





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Short-circuit currents in three-phase a.c. system, –
Part 0: Calculation of currents**

**Courants de court-circuit dans les réseaux triphasés à courant alternatif –
Partie 0: Calcul des courants**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220.01; 29.240.20

ISBN 978-2-8322-3158-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references.....	8
3 Terms and definitions	8
4 Symbols, subscripts and superscripts.....	13
4.1 General.....	13
4.2 Symbols.....	13
4.3 Subscripts.....	15
4.4 Superscripts.....	16
5 Characteristics of short-circuit currents: calculating method.....	16
5.1 General.....	16
5.2 Calculation assumptions.....	19
5.3 Method of calculation	20
5.3.1 Equivalent voltage source at the short-circuit location	20
5.3.2 Symmetrical components	22
6 Short-circuit impedances of electrical equipment.....	23
6.1 General.....	23
6.2 Network feeders.....	23
6.3 Transformers	25
6.3.1 Two-winding transformers	25
6.3.2 Three-winding transformers.....	25
6.3.3 Impedance correction factors for two- and three-winding network transformers	27
6.4 Overhead lines and cables	28
6.5 Short-circuit current-limiting reactors	29
6.6 Synchronous machines	29
6.6.1 Synchronous generators	29
6.6.2 Synchronous compensators and motors.....	31
6.7 Power station units.....	31
6.7.1 Power station units with on-load tap-changer.....	31
6.7.2 Power station units without on-load tap-changer	32
6.8 Wind power station units	33
6.8.1 General	33
6.8.2 Wind power station units with asynchronous generator	33
6.8.3 Wind power station units with doubly fed asynchronous generator.....	34
6.9 Power station units with full size converter.....	35
6.10 Asynchronous motors.....	35
6.11 Static converter fed drives.....	36
6.12 Capacitors and non-rotating loads	36
7 Calculation of initial short-circuit current.....	36
7.1 General.....	36
7.1.1 Overview	36
7.1.2 Maximum and minimum short-circuit currents	41
7.1.3 Contribution of asynchronous motors to the short-circuit current.....	42
7.2 Three-phase initial short-circuit current.....	43
7.2.1 General	43

7.2.2	Short-circuit currents inside a power station unit with on-load tap-changer	44
7.2.3	Short-circuit currents inside a power station unit without on-load tap-changer	46
7.3	Line-to-line short circuit	47
7.4	Line-to-line short circuit with earth connection	47
7.5	Line-to-earth short circuit	49
8	Calculation of peak short-circuit current	49
8.1	Three-phase short circuit	49
8.1.1	Single-fed and multiple single-fed short circuits	49
8.1.2	Multiple-fed short circuit	51
8.2	Line-to-line short circuit	52
8.3	Line-to-line short circuit with earth connection	52
8.4	Line-to-earth short circuit	52
9	Calculation of symmetrical breaking current	53
9.1	Three-phase short circuit	53
9.1.1	Symmetrical breaking current of synchronous machines	53
9.1.2	Symmetrical breaking current of asynchronous machines	54
9.1.3	Symmetrical breaking current of power station units with doubly fed asynchronous generator	55
9.1.4	Symmetrical breaking current of power station units with full size converter	55
9.1.5	Symmetrical breaking current of network feeder	56
9.1.6	Symmetrical breaking current in case of multiple single-fed short-circuits	56
9.1.7	Symmetrical breaking current in case of multiple-fed short circuits	56
9.2	Unbalanced short-circuits	57
10	DC component of the short-circuit current	57
11	Calculation of steady-state short-circuit current	58
11.1	General	58
11.2	Three-phase short circuit	58
11.2.1	Steady-state short-circuit current of one synchronous generator or one power station unit	58
11.2.2	Steady-state short-circuit current of asynchronous motor or generator	61
11.2.3	Steady-state short-circuit current of wind power station unit with doubly fed asynchronous generator	61
11.2.4	Steady-state short-circuit current of wind power station unit with full size converter	61
11.2.5	Steady-state short-circuit current of network feeder	61
11.2.6	Steady-state short-circuit current in case of multiple single-fed short circuits	61
11.2.7	Steady-state short-circuit current in case of multiple-fed short circuits	62
11.3	Unbalanced short circuits	62
12	Short circuits at the low-voltage side of transformers, if one line conductor is interrupted at the high-voltage side	62
13	Terminal short circuit of asynchronous motors	64
14	Joule integral and thermal equivalent short-circuit current	65
	Annex A (normative) Formulas for the calculation of the factors m and n	68
	Annex B (informative) Nodal admittance and nodal impedance matrices	69
	Bibliography	73

Figure 1 – Short-circuit current of a far-from-generator short circuit with constant AC component (schematic diagram).....	17
Figure 2 – Short-circuit current of a near-to-generator short-circuit with decaying AC component (schematic diagram).....	18
Figure 3 – Characterization of short-circuits and their currents.....	19
Figure 4 – Illustration for calculating the initial symmetrical short-circuit current I_k'' in compliance with the procedure for the equivalent voltage source	21
Figure 5 – System diagram and equivalent circuit diagram for network feeders	24
Figure 6 – Three-winding transformer (example).....	27
Figure 7 – Diagram to determine the short-circuit type (Figure 3) for the highest initial short-circuit current referred to the initial three-phase short-circuit current when the impedance angles of the sequence impedances $Z_{(1)}$, $Z_{(2)}$, $Z_{(0)}$ are identical	38
Figure 8 – Examples of single-fed short-circuits.....	40
Figure 9 – Example of a multiple single-fed short circuit	40
Figure 10 – Example of multiple-fed short circuit	41
Figure 11 – Short-circuit currents and partial short-circuit currents for three-phase short circuits between generator and unit transformer with or without load tap-changer, or at the connection to the auxiliary transformer of a power station unit and at the auxiliary busbar A	45
Figure 12 – Factor κ for series circuit as a function of ratio R/Y or X/R	50
Figure 13 – Factor μ for calculation of short-circuit breaking current I_b	54
Figure 14 – Factor q for the calculation of the symmetrical short-circuit breaking current of asynchronous motors	55
Figure 15 – Factors λ_{\min} and λ_{\max} factors for cylindrical rotor generators.....	60
Figure 16 – Factors λ_{\min} and λ_{\max} for salient pole generators.....	60
Figure 17 – Transformer secondary short-circuits, if one line (fuse) is opened on the high-voltage side of a transformer, Dyn.....	63
Figure 18 – Factor m for the heat effect of the DC component of the short-circuit current (for programming, the formula to calculate m is given in Annex A)	66
Figure 19 – Factor n for the heat effect of the AC component of the short-circuit current (for programming, the formula to calculate n is given in Annex A).....	67
Figure B.1 – Formula for the nodal admittance matrix.....	70
Figure B.2 – Example	71
Table 1 – Voltage factor c	22
Table 2 – Importance of short-circuit currents	37
Table 3 – Factors α and β for the calculation of short-circuit currents with Formula (23), rated transformation ratio $t_r = U_{rTHV}/U_{rTLV}$	64
Table 4 – Calculation of short-circuit currents of asynchronous motors in the case of a short circuit at the terminals	65
Table B.1 – Impedances of electrical equipment referred to the 110 kV side.....	71

INTERNATIONAL ELECTROTECHNICAL COMMISSION

SHORT-CIRCUIT CURRENTS IN THREE-PHASE AC SYSTEMS –**Part 0: Calculation of currents**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60909-0 has been prepared by IEC technical committee 73: Short-circuit currents.

This second edition cancels and replaces the first edition published in 2001. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) contribution of windpower station units to the short-circuit current;
- b) contribution of power station units with full size converters to the short-circuit current;
- c) new document structure.

The text of this standard is based on the following documents:

CDV	Report on voting
73/172/CDV	73/175A/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60909 series, published under the general title *Short-circuit currents in three-phase a.c. systems*, can be found on the IEC website.

This part of IEC 60909 is to be read in conjunction with the following International Standards and Technical Reports:

- IEC TR 60909-1:2002, *Short-circuit currents in three-phase a.c. systems – Part 1: Factors for the calculation of short-circuit currents according to IEC 60909-0*
- IEC TR 60909-2:2008, *Short-circuit currents in three-phase a.c. systems – Part 2: Data of electrical equipment for short-circuit current calculations*
- IEC 60909-3:2009, *Short-circuit currents in three-phase a.c. systems – Part 3: Currents during two separate simultaneous line-to-earth short circuits and partial short-circuit currents flowing through earth*
- IEC TR 60909-4:2000, *Short-circuit currents in three-phase a.c. systems – Part 4: Examples for the calculation of short-circuit currents*

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

SHORT-CIRCUIT CURRENTS IN THREE-PHASE AC SYSTEMS –

Part 0: Calculation of currents

1 Scope

This part of IEC 60909 is applicable to the calculation of short-circuit currents

- in low-voltage three-phase AC systems, and
- in high-voltage three-phase AC systems,

operating at a nominal frequency of 50 Hz or 60 Hz.

Systems at highest voltages of 550 kV and above with long transmission lines need special consideration.

This part of IEC 60909 establishes a general, practicable and concise procedure leading to results which are generally of acceptable accuracy. For this calculation method, an equivalent voltage source at the short-circuit location is introduced. This does not exclude the use of special methods, for example the superposition method, adjusted to particular circumstances, if they give at least the same precision. The superposition method gives the short-circuit current related to the one load flow presupposed. This method, therefore, does not necessarily lead to the maximum short-circuit current.

This part of IEC 60909 deals with the calculation of short-circuit currents in the case of balanced or unbalanced short circuits.

A single line-to-earth fault is beyond the scope of this part of IEC 60909.

For currents during two separate simultaneous single-phase line-to-earth short circuits in an isolated neutral system or a resonance earthed neutral system, see IEC 60909-3.

Short-circuit currents and short-circuit impedances may also be determined by system tests, by measurement on a network analyser, or with a digital computer. In existing low-voltage systems it is possible to determine the short-circuit impedance on the basis of measurements at the location of the prospective short circuit considered.

The calculation of the short-circuit impedance is in general based on the rated data of the electrical equipment and the topological arrangement of the system and has the advantage of being possible both for existing systems and for systems at the planning stage.

In general, two types short-circuit currents, which differ in their magnitude, are considered:

- the maximum short-circuit current which determines the capacity or rating of electrical equipment; and
- the minimum short-circuit current which can be a basis, for example, for the selection of fuses, for the setting of protective devices, and for checking the run-up of motors.

NOTE The current in a three-phase short circuit is assumed to be made simultaneously in all poles. Investigations of non-simultaneous short circuits, which may lead to higher aperiodic components of short-circuit current, are beyond the scope of this part of IEC 60909.

This part of IEC 60909 does not cover short-circuit currents deliberately created under controlled conditions (short-circuit testing stations).