

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Low-voltage switchgear and controlgear –
Part 2: Circuit-breakers**

**Appareillage à basse tension –
Partie 2: Disjoncteurs**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour toute ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Low-voltage switchgear and controlgear –
Part 2: Circuit-breakers**

**Appareillage à basse tension –
Partie 2: Disjoncteurs**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

CT

ICS 29.130.20

ISBN 2-8318-1034-9

CONTENTS

FOREWORD.....	7
1 General	9
1.1 Scope and object.....	9
1.2 Normative references	10
2 Definitions	12
3 Classification	16
4 Characteristics of circuit-breakers.....	16
4.1 Summary of characteristics.....	17
4.2 Type of circuit-breaker.....	17
4.3 Rated and limiting values of the main circuit.....	17
4.4 Selectivity categories	21
4.5 Control circuits	21
4.6 Auxiliary circuits	22
4.7 Releases	22
4.8 Integral fuses (integrally fused circuit-breakers).....	23
5 Product information.....	23
5.1 Nature of the information	23
5.2 Marking	24
5.3 Instructions for installation, operation and maintenance.....	25
6 Normal service, mounting and transport conditions.....	25
7 Constructional and performance requirements	25
7.1 Constructional requirements	25
7.2 Performance requirements.....	27
7.3 Electromagnetic compatibility (EMC).....	33
8 Tests.....	33
8.1 Kind of tests	33
8.2 Compliance with constructional requirements.....	33
8.3 Type tests	33
8.4 Routine tests	64
Annex A (normative) Co-ordination under short-circuit conditions between a circuit-breaker and another short-circuit protective device associated in the same circuit.....	69
Annex B (normative) Circuit-breakers incorporating residual current protection	78
Annex C (normative) Individual pole short-circuit test sequence	110
Annex D (vacant).....	111
Annex E (informative) Items subject to agreement between manufacturer and user.....	112
Annex F (normative) Additional tests for circuit-breakers with electronic over-current protection.....	113
Annex G (normative) Power loss	143
Annex H (normative) Test sequence for circuit-breakers for IT systems	146
Annex J (normative) Electromagnetic compatibility (EMC) – Requirements and test methods for circuit-breakers.....	148
Annex K (informative) Glossary of symbols and graphical representation of characteristics.....	161

Annex L (normative) Circuit-breakers not fulfilling the requirements for overcurrent protection.....	170
Annex M (normative) Modular residual current devices (without integral current breaking device).....	175
Annex N (normative) Electromagnetic compatibility (EMC) – Additional requirements and test methods for devices not covered by Annexes B, F and M	219
Annex O Instantaneous trip circuit-breakers (ICB)	223
 Bibliography.....	 226
 Figure 1 – Test arrangement (connecting cables not shown) for short-circuit tests	 68
Figure A.1 – Over-current co-ordination between a circuit-breaker and a fuse or back-up protection by a fuse: operating characteristics	74
Figure A.2 Figure A.3.....	75
Total discrimination between two circuit-breakers	75
Figure A.4 Figure A.5.....	76
Back-up protection by a circuit-breaker – Operating characteristics.....	76
Figure A.6 – Example of test circuit for conditional short-circuit breaking capacity tests showing cable connections for a 3-pole circuit-breaker (C_1).....	77
Figure B.1 – Test circuit for the verification of the operating characteristic (see B.8.2)	102
Figure B.2 – Test circuit for the verification of the limiting value of the non-operating current under over-current conditions (see B.8.5)	103
Figure B.3 – Test circuit for the verification of the behaviour of CBRs classified under B.3.1.2.2 (see B.8.9)	104
Figure B.4 – Current ring wave 0,5 μ s/100 kHz	105
Figure B.5 – Example of test circuit for the verification of resistance to unwanted tripping	106
Figure B.6 – Surge current wave 8/20 μ s	106
Figure B.7 – Test circuit for the verification of resistance to unwanted tripping in case of flashover without follow-on current (B.8.6.2)	107
Figure B.8 – Test circuit for the verification of the correct operation of CBRs, in the case of residual pulsating direct currents (see B.8.7.2.1, B.8.7.2.2 and B.8.7.2.3)	108
Figure B.9 – Test circuit for the verification of the correct operation of CBRs, in the case of a residual pulsating direct current superimposed by a smooth direct residual current (see B.8.7.2.4)	109
Figure F.1 – Representation of test current produced by back-to-back thyristors in accordance with F.4.1	122
Figure F.2 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.2 – Two phase poles in series.....	123
Figure F.3 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.2 – Three phase poles in series	124
Figure F.4 – Test circuit for immunity and emission tests in accordance with F.4.1.3, F.4.2, F.4.3, F.4.6, F.4.7.1, F.5.4 and F.6.2 – Three-phase connection	125
Figure F.5 – Test current for the verification of the influence of the current dips and interruptions in accordance with F.4.7.1.....	126
Figure F.6 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Two phase poles in series.....	127
Figure F.7 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Three phase poles in series	128

Figure F.8 – Circuit for electrical fast transients/bursts (EFT/B) immunity test in accordance with F.4.4 – Three-phase connection	129
Figure F.9 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Two phase poles in series	130
Figure F.10 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Three phase poles in series	131
Figure F.11 – Test circuit for the verification of the influence of surges in the main circuit (line-to-earth) in accordance with F.4.5 – Three-phase connection.....	132
Figure F.12 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Two phase poles in series	133
Figure F.13 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Three phase poles in series.....	133
Figure F.14 – Test circuit for the verification of the influence of current surges in the main circuit in accordance with F.4.5 – Three-phase connection	134
Figure F.15 – Temperature variation cycles at a specified rate of change in accordance with F.9.1	134
Figure F.16 – General test set up for immunity tests	135
Figure F.17 – Test set up for the verification of immunity to radiated r.f. electromagnetic fields.....	136
Figure F.18 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on power lines	137
Figure F.19 – Test set up for verification of immunity to electrical fast transients/bursts (EFT/B) on signal lines	138
Figure F.20 – General test set-up for the verification of immunity to conducted disturbances induced by r.f. fields (common mode).....	139
Figure F.21 – Arrangement of connections for the verification of immunity to conducted disturbances induced by r.f. fields - Two phase poles in series configuration.....	140
Figure F.22 – Arrangement of connections for the verification of immunity to conducted disturbances induced by r.f. fields - Three phase poles in series configuration	141
Figure F.23 – Arrangement of connections for the verification of immunity to conducted disturbances induced by r.f. fields – Three-phase configuration	142
Figure G.1 – Example of power loss measurement according to G.2.1	145
Figure G.2 – Example of power loss measurement according to G.2.2 and G.2.3	145
Figure J.1 – EUT mounted in a metallic enclosure	155
Figure J.2 – Test set up for the measurement of radiated r.f. emissions.....	156
Figure J.3 – Test set up for the verification of immunity to electrostatic discharges	157
Figure J.4 – Test set up for the verification of immunity to radiated r.f. electromagnetic fields.....	158
Figure J.5 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on power lines	159
Figure J.6 – Test set up for the verification of immunity to electrical fast transients/bursts (EFT/B) on signal lines	160
Figure K.1 – Relationship between symbols and tripping characteristics.....	163
Figure K.2 – Template for characteristics of cut-off current versus prospective current from 1 kA to 200 kA	164
Figure K.3 – Template for characteristics of cut-off current versus prospective current from 0,01 kA to 200 kA.....	165
Figure K.4 – Template for characteristics of let-through energy versus prospective current from 1 kA to 200 kA.....	166

Figure K.5 – Template for characteristics of let-through energy versus prospective current from 0,01 kA to 200 kA.....	167
Figure K.6 – Example of the use of template K.2	168
Figure K.7 – Example of the use of template K.4	169
Figure M.1 – Test circuits for the verification of operation in the case of a steady increase of residual current.....	198
Figure M.2 – Test circuits for the verification of operation in the case of a sudden appearance of residual current (with breaking device)	199
Figure M.3 – Test circuits for the verification of operation in the case of a sudden appearance of residual current (without breaking device).....	200
Figure M.4 – Test circuits for the verification of the limiting value of non-operating current under overcurrent conditions	201
Figure M.5 – Test circuits for the verification of the resistance to unwanted tripping in the case of loading of the network capacitance.....	202
Figure M.6 – Test circuit for the verification of the resistance to unwanted tripping in the case of flashover without follow-on current	203
Figure M.7 – Test circuits for the verification of operation in the case of a continuous rise of a residual pulsating direct current	204
Figure M.8 – Test circuits for the verification of operation in the case of a sudden appearance of residual pulsating direct current (without breaking device)	205
Figure M.9 – Test circuits for the verification of operation in the case of a sudden appearance of residual pulsating direct current (with breaking device)	206
Figure M.10 – Test circuits for the verification of operation in the case of a residual pulsating direct current superimposed by smooth direct current of 6 mA	207
Figure M.11 – Test circuits for the verification of operation in the case of a slowly rising residual smooth direct current.....	208
Figure M.12 – Test circuits for the verification of operation in the case of a sudden appearance of residual smooth direct current (without breaking device).....	209
Figure M.13 – Test circuits for the verification of operation in the case of a sudden appearance of residual smooth direct current (with breaking device).....	210
Figure M.14 – Test circuits for the verification of operation in the case of a slowly rising residual current resulting from a fault in a circuit fed by a three-pulse star or a six-pulse bridge connection.....	211
Figure M.15 – Test circuits for the verification of operation in the case of a slowly rising residual current resulting from a fault in a circuit fed by a two-pulse bridge connection line-to-line.....	212
Figure M.16 – Test circuit for the verification of the behaviour of MRCDs with separate sensing means in the case of a failure of the sensor means connection.....	213
Figure M.17 – Test circuit for the verification of the behaviour of MRCD with separate sensing means under short-circuit conditions	214
Figure M.18 – Test circuit for the verification of the behaviour of MRCD with integral sensing means under short-circuit conditions	215
Figure M.19 – Test circuit for the verification of the behaviour of terminal type MRCD under short-circuit conditions.....	216
Figure M.20 – Verification of immunity to radiated r.f. electromagnetic fields – Test set-up for MRCD with separate sensing means (additional to the test of Annex B)	217
Figure M.21 – Verification of immunity to electrical fast transients/bursts (EFT/B) on the sensing means connection of an MRCD with separate sensing means (additional to the test of Annex B)	218
Figure M.22 – Verification of immunity to conducted disturbances induced by r.f. fields – Test set up for MRCD with separate sensing means (additional to the test of Annex B).....	218

Table 1 – Standard ratios between I_{CS} and I_{CU}	20
Table 2 – Ratio n between short-circuit making capacity and short-circuit breaking capacity and related power factor (for a.c. circuit-breakers).....	20
Table 3 – Minimum values of rated short-time withstand current.....	21
Table 4 – Selectivity categories.....	21
Table 5 – Preferred values of the rated control supply voltage, if different from that of the main circuit.....	22
Table 6 – Characteristics of the opening operation of inverse time-delay over-current opening releases at the reference temperature.....	29
Table 7 – Temperature-rise limits for terminals and accessible parts.....	30
Table 8 – Number of operating cycles.....	32
Table 9 – Overall schema of test sequences ^a	36
Table 9a – Applicability of test sequences according to the relationship between I_{CS} , I_{CU} and I_{CW}	37
Table 9b – Applicability of tests or test sequences to four-pole circuit-breakers in a given frame size and design when tested according to the alternative programme 1 of 8.3.1.4.....	38
Table 9c – Applicability of tests or test sequences to 3-pole circuit-breakers in a given frame size and design when tested according to the alternative programme 2 of 8.3.1.4.....	40
Table 10 – Number of samples for test.....	43
Table 11 – Values of power factors and time constants corresponding to test currents.....	45
Table 12 – Test circuit characteristics for overload performance.....	56
Table B.1 – Operating characteristic for non-time-delay type.....	83
Table B.2 – Operating characteristic for time-delay-type having a limiting non-actuating time of 0,06 s.....	84
Table B.3 – Requirements for CBRs functionally dependent on line voltage.....	88
Table B.4 – Additional test sequence.....	91
Table B.5 – Tripping current range for CBRs in case of an earth fault comprising a d.c. component.....	96
Table F.1 – Test parameters for current dips and interruptions.....	118
Table J.1 – EMC – Immunity tests.....	150
Table J.2 – Reference data for immunity test specifications.....	151
Table J.3 – EMC – Emission tests.....	154
Table J.4 – Reference data for emission test specifications.....	154
Table M.1 – Product information.....	181
Table M.2 – Requirements for MRCDs with voltage source.....	183
Table M.3 – Test sequences.....	185

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 2: Circuit-breakers**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60947-2 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

The main changes introduced in this new edition are an amendment to the verification of dielectric properties, the improvement of EMC clauses in Annexes B, F, J and M, and the addition of a new Annex O regarding instantaneous trip circuit-breakers.

This consolidated version of IEC 60947-2 consists of the fourth edition (2006) [documents 17B/1455/FDIS and 17B/1463/RVD] and its amendment 1 (2009) [documents 17B/1636/FDIS and 17B/1651/RVD].

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience.

It bears the edition number 4.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The IEC 60947 series comprises the following parts under the general title *Low-voltage switchgear and controlgear*:

- Part 1: General rules
- Part 2: Circuit-breakers
- Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units
- Part 4: Contactors and motor-starters
- Part 5: Control circuit devices and switching elements
- Part 6: Multiple function equipment
- Part 7: Ancillary equipment
- Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 2: Circuit-breakers

1 General

The provisions of the general rules dealt with in IEC 60947-1 are applicable to this standard, where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to IEC 60947-1, for example, 1.2.3 of IEC 60947-1, Table 4 of IEC 60947-1, or Annex A of IEC 60947-1.

1.1 Scope and object

This standard applies to circuit-breakers, the main contacts of which are intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.; it also contains additional requirements for integrally fused circuit-breakers.

It applies whatever the rated currents, the method of construction or the proposed applications of the circuit-breakers may be.

The requirements for circuit-breakers which are also intended to provide earth-leakage protection are contained in Annex B.

The additional requirements for circuit-breakers with electronic over-current protection are contained in Annex F.

The additional requirements for circuit-breakers for IT systems are contained in Annex H.

The requirements and test methods for electromagnetic compatibility of circuit-breakers are contained in Annex J.

The requirements for circuit-breakers not fulfilling the requirements for over-current protection are contained in Annex L.

The requirements for modular residual current devices (without integral current breaking device) are contained in Annex M.

The requirements and test methods for electromagnetic compatibility of circuit-breaker auxiliaries are contained in Annex N.

Supplementary requirements for circuit-breakers used as direct-on-line starters are given in IEC 60947-4-1, applicable to low-voltage contactors and starters.

The requirements for circuit-breakers for the protection of wiring installations in buildings and similar applications, and designed for use by uninstructed persons, are contained in IEC 60898.

The requirements for circuit-breakers for equipment (for example electrical appliances) are contained in IEC 60934.