

INTERNATIONAL STANDARD

**Low-voltage switchgear and controlgear –
Part 3: Switches, disconnectors, switch-disconnectors and fuse combination
units**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2025 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.



IEC 60947-3

Edition 4.1 2025-04
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

**Low-voltage switchgear and controlgear –
Part 3: Switches, disconnectors, switch-disconnectors and fuse combination
units**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.120.40, 29.130.20

ISBN 978-2-8327-0405-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
2 Normative references	12
3 Terms, definitions and index of terms	13
3.1 General.....	13
3.2 Alphabetical index of terms	13
3.3 General terms	14
4 Classification.....	17
4.1 According to the utilization category.....	17
4.2 According to the method of operation.....	17
4.2.1 Manually operated equipment.....	17
4.2.2 Remotely operated equipment.....	17
4.3 According to suitability for isolation.....	17
4.4 According to the degree of protection provided.....	17
4.5 Summary of symbols for equipment types.....	17
5 Characteristics	18
5.1 Summary of characteristics.....	18
5.2 Type of equipment	18
5.3 Rated and limiting values for the main circuit.....	18
5.3.1 General	18
5.3.2 Rated voltages	18
5.3.3 Currents	19
5.3.4 Rated frequency	19
5.3.5 Rated duty.....	19
5.3.6 Normal load and overload characteristics	19
5.3.7 Short-circuit characteristics	20
5.4 Utilization category	20
5.5 Control circuits.....	21
5.6 Auxiliary circuits.....	21
5.7 Relays and releases	21
5.8 Co-ordination with short-circuit protective devices (SCPD).....	21
5.9 Remote operation	22
6 Product information	22
6.1 Nature of information	22
6.2 Marking.....	22
6.3 Instructions for installation, operation and maintenance, decommissioning and dismantling.....	24
6.4 Normal service, mounting and transport conditions.....	24
7 Constructional and performance requirements	24
8.1 Constructional requirements	24
8.1.1 General	24
8.1.7 Additional requirements for equipment suitable for isolation.....	25
8.1.9 Additional requirements for equipment provided with a neutral pole.....	25
8.1.10 Additional requirements for remotely operated equipment.....	25
8.2 Performance requirements.....	25

8.2.1	Operating conditions.....	25
8.2.2	Temperature-rise.....	27
8.2.3	Dielectric properties.....	27
8.2.4	Ability to make and break under no-load, normal load and overload conditions.....	27
8.2.5	Ability to make, break or withstand short-circuit currents.....	30
8.2.6	Void.....	30
8.2.7	Additional performance requirements for equipment suitable for isolation.....	30
8.2.8	Critical load current performance: DC equipment.....	30
8.2.9	Overload requirements for equipment incorporating fuses.....	30
8.3	Electromagnetic compatibility (EMC).....	30
8.3.1	General.....	30
8.3.2	Immunity.....	30
8.3.3	Emission.....	31
9	Tests.....	32
9.1	Kinds of test.....	32
9.1.1	General.....	32
9.1.2	Type tests.....	32
9.1.3	Routine tests.....	32
9.1.4	Sampling tests.....	33
9.1.5	Special tests.....	33
9.2	Compliance with constructional requirements.....	33
9.2.1	General.....	33
9.3	Performance.....	34
9.3.1	General.....	34
9.3.2	Test sequences.....	34
9.3.3	General test conditions.....	35
9.3.4	Test sequence I: general performance characteristics.....	38
9.3.5	Test sequence II: operational performance capability.....	42
9.3.6	Test sequence III: short-circuit performance capability.....	45
9.3.7	Test sequence IV: conditional short-circuit current.....	48
9.3.8	Test sequence V: overload performance capability.....	52
9.3.9	Test sequence VI: critical load current performance of equipment with a DC rating.....	53
9.4	Electromagnetic compatibility tests.....	55
9.4.1	General.....	55
9.4.2	Immunity.....	56
9.4.3	Emission.....	56
9.5	Special tests.....	56
9.5.1	Mechanical and electrical durability.....	56
9.5.2	Mechanical durability.....	56
9.5.3	Electrical durability.....	56
9.5.4	Damp heat, salt mist, vibration and shock.....	57
Annex A (normative)	Equipment for direct switching of a single motor.....	58
A.1	General.....	58
A.2	Rated.....	58
A.2.1	Intermittent periodic duty or intermittent duty.....	58
A.2.2	Temporary duty.....	58

A.3	Making and breaking capacities	58
A.4	Utilization category	58
A.5	Operational performance	61
A.6	Mechanical durability	62
A.7	Electrical durability	62
A.8	Verification of making and breaking capacities	62
A.9	Operational performance test	62
A.10	Special tests	62
A.10.1	General	62
A.10.2	Mechanical durability test	63
A.10.3	Electrical durability test	63
A.11	Critical load current performance for DC equipment	64
Annex B (informative)	Items subject to agreement between manufacturer and user	65
Annex C (normative)	Single pole operated three-pole switches	66
C.1	General	66
C.2	Tests	67
C.3	Test set-up and sequence	67
C.3.1	Making and breaking capacities (9.3.4.4) and operational performance (9.3.5.2)	67
C.3.2	Fuse protected short-circuit test (9.3.7.3)	67
C.3.3	Short circuit making test for switches and switch-disconnectors	67
C.4	Condition of equipment after tests	67
C.5	Instructions for use	67
Annex D (normative)	Switches, disconnectors, switch disconnectors and fuse-combination units for use in photovoltaic (PV) DC applications	68
D.1	General	68
D.1.1	Background	68
D.1.2	Object	68
D.2	Normative references	68
D.3	Terms and definitions	68
D.4	Classification	69
D.4.1	According to the utilization category	69
D.5	Characteristics	69
D.6	Product information	70
D.7	Normal service, mounting and transport conditions	70
D.8	Constructional and performance requirements	70
D.9	Tests	74
Annex E (normative)	Additional requirements for LV switchgear intended for connection of aluminium conductors	80
E.1	Object	80
E.2	Normative references	80
E.3	Terms, definitions and index of terms	80
E.4	Classification	81
E.5	Characteristics	81
E.6	Product information	81
E.6.1	Nature of information	81
E.6.2	Marking	81
E.6.3	Instructions for installation, operation and maintenance, decommissioning and dismantling	81

E.7	Normal service, mounting and transport conditions	82
E.8	Constructional and performance requirements	82
E.9	Tests	82
E.9.1	General	82
E.9.2	Current cycling test.....	83
E.9.3	Mechanical properties of terminals	88
E.9.4	Test for insertability of unprepared round aluminium conductors having the maximum cross-section	89
Annex F (informative)	Power loss.....	92
F.1	General.....	92
F.2	Test methods	92
F.2.1	General	92
F.2.2	General case for AC switches and/or disconnectors	92
F.2.3	General case for AC fused combination units and fuse disconnectors	93
F.2.4	Switches and/or disconnectors of rated current not exceeding 400 A.....	93
F.2.5	Fused combination units and fuse disconnectors of rated current not exceeding 400 A.....	93
F.3	Test procedure.....	94
Annex G (normative)	DC disconnectors, switch-disconnectors and fuse combination units for use with battery power supplies (BPS) DC applications	97
G.1	General.....	97
G.2	Vacant	97
G.3	Vacant	97
G.4	Classification	97
G.5	Characteristics.....	98
G.6	Product information.....	98
G.7	Normal service, mounting and transport conditions	98
G.8	Constructional and performance requirements	99
G.9	Tests	103
Bibliography	109
Figure C.1	– Typical arrangements	66
Figure E.1	– General test arrangement	84
Figure E.2	– Mounting of terminals for the current cycling test	84
Figure F.1	– Example of power loss measurement according to F.2.2	95
Figure F.2	– Example of power loss measurement according to F.2.3	95
Figure F.3	– Example of power loss measurement according to F.2.4	96
Figure F.4	– Example of power loss measurement according to F.2.5	96
Table 1	– Summary of equipment definitions.....	17
Table 2	– Utilization categories	21
Table 3	– Product information	22
Table 4	– Verification of rated making and breaking capacities (see 9.3.4.4) – Conditions for making and breaking corresponding to the various utilization categories	28
Table 5	– Verification of operational performance – Number of operating cycles corresponding to the rated operational current.....	29
Table 6	– Test circuit parameters for Table 5	29
Table 7	– Immunity tests ^a	31

Table 8 – Emission limits	31
Table 9 – List of type tests applicable to a given equipment.....	34
Table 10 – Overall scheme of test sequences	35
Table 11 – Test sequence I: general performance characteristics	39
Table 12 – Temperature-rise limits for terminals and accessible parts.....	42
Table 13 – Test sequence II: operational performance capability	43
Table 14 – Test sequence III: short-circuit performance capability	45
Table 15 – Test sequence IV: conditional short-circuit current – circuit-breaker protected	49
Table 16 – Test sequence IV: conditional short-circuit current – fuse protected	51
Table 17 – Test sequence V: overload performance capability	53
Table 18 – Number of operating cycles corresponding to the critical load current.....	55
Table 19 – Test circuit parameters for Table 18	55
Table 20 – Test sequence VI: critical load current performance of equipment with a DC rating	55
Table A.1 – Utilization categories.....	59
Table A.2 – Rated making and breaking capacity conditions corresponding to several utilization categories	60
Table A.3 – Relationship between current broken I_C and off-time for the verification of the rated making and breaking capacities	61
Table A.4 – Operational performance – Conditions for making and breaking corresponding to several utilization categories.....	61
Table A.5 – Verification of the number of on-load operating cycles – Conditions for making and breaking corresponding to several utilization categories.....	64
Table D.1 – Utilization categories	69
Table D.2 – Service arrangements	70
Table D.3 – Environmental condition	70
Table D.4 – Rated impulse withstand levels for PV switches, PV disconnectors, PV switch-disconnectors or PV fuse-combination units.....	71
Table D.5 – Verification of rated making and breaking capacities (see 9.3.4.4) – Conditions for making and breaking corresponding to the DC-PV category	72
Table D.6 – Number of operating cycles	73
Table D.7 – Test circuit parameters for Table D.6	73
Table D.8 – Overall scheme of test sequences	75
Table D.9 – Number of operating cycles corresponding to the critical load current.....	77
Table D.10 – Test circuit parameters for Table D.9	77
Table E.1 – List of tests for terminal connections ^a with aluminium cables	83
Table E.2 – Conductor length for current cycling test as per conductor cross-section.....	85
Table E.3 – Equalizer dimensions.....	85
Table E.4 – Starting test current for the current cycling test.....	87
Table E.5 – Example of stability factor calculation	88
Table E.6 – Test values for flexion and pull-out test for cables.....	89
Table E.7 – Test aluminium cable for test currents up to 800 A ^{a, d}	90
Table E.8 – Test aluminium bars for test currents above 150 A and up to 3 150 A ^{a, f}	91
Table G.1 – Utilization categories	98
Table G.2 – Service arrangements.....	98

Table G.3 – Environmental conditions	99
Table G.4 – Rated impulse withstand levels for BPS disconnectors, BPS switch-disconnectors or BPS fuse-combination units	100
Table G.5 – Verification of rated making and breaking capacities (see 9.3.4.4) – Conditions for making and breaking corresponding to the DC-BPS category	101
Table G.6 – Number of operating cycles	101
Table G.7 – Test parameters for Table G.6	102
Table G.8 – Overall scheme of test sequences	103
Table G.9 – Number of operating cycles corresponding to the critical load current	106
Table G.10 – Test circuit parameters for Table G.9	106

Currently in preview, click buy full version.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 3: Switches, disconnectors, switch-disconnectors and
fuse-combination units**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the most recent edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60947-3 edition 4.1 contains the fourth edition (2020-04) [documents 121A/340/FDIS and 121A/354/RVD], its corrigendum 1 (2021-10) and its amendment 1 (2025-04) [documents 121A/645/FDIS and 121A/675/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60947-3 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low voltage.

This fourth edition cancels and replaces the third edition published in 2008, Amendment 1:2012 and Amendment 2:2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- addition of critical load current tests for DC switches (see 9.3.9);
- addition of requirements for a conditional short-circuit rating for disconnectors, switches, and switch-disconnectors protected by circuit-breakers (see 9.3.7.2);
- addition of new categories for high-efficiency motors switching (see Annex A);
- addition of new Annex E for connection to aluminium conductors;
- addition of new Annex F for power losses measurement.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
121A/340/FDIS	121A/354/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60947 series, published under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This part is to be used in conjunction with the sixth edition of IEC 60947-1:2020. The numbering of the subclauses is sometimes not continuous because it is based on IEC 60947-1:2020.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

The provisions of the general rules dealt with in IEC 60947-1 are applicable to this document, where specifically called for. Clauses and subclauses, tables, figures and annexes of the general rules thus applicable are identified by reference to the sixth edition of IEC 60947-1:2020, for example, 5.3.4.1 of IEC 60947-1:2020, Table 4 of IEC 60947-1:2020, or Annex A of IEC 60947-1:2020.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

1 Scope

This part of IEC 60947 applies to switches, disconnectors, switch-disconnectors and fuse-combination units and their dedicated accessories to be used in distribution circuits and motor circuits of which the rated voltage does not exceed 1 000 V AC or 1 500 V DC.

NOTE 1 Accessories are interconnecting units, extended terminals, internal coils, auxiliary contacts, motor operator, etc. offered as options with the basic unit.

This document does not apply to equipment coming within the scope of IEC 60947-2, IEC 60947-4-1 and IEC 60947-5-1.

Particular requirements for switches, disconnectors, switch-disconnectors and fuse-combination units for use in photovoltaic (PV) DC applications are given in Annex D.

Specific requirements for LV switchgear intended for the connections of aluminium conductors are given in Annex E.

Guidance on measurement of power loss is provided in Annex F.

This document does not include the additional requirements necessary for electrical apparatus for explosive gas atmospheres.

NOTE 2 Depending on its design, a switch (or disconnector) can be referred to as "a rotary switch (disconnector)", "cam-operated switch (disconnector)", "knife-switch (disconnector)", etc.

NOTE 3 In this document, the word "switch" also applies to the apparatus referred to in French as "commutateurs", intended to modify the connections between several circuits and *inter alia* to substitute a part of a circuit for another.

NOTE 4 In general, throughout this document, switches, disconnectors, switch-disconnectors and fuse-combination units will be referred to as "equipment".

The object of this document is to state:

- a) the characteristics of the equipment;
- b) the conditions that apply to the equipment with reference to:
 - 1) operation and behaviour in normal service;
 - 2) operation and behaviour in case of specified abnormal conditions, e.g. short-circuit;
 - 3) dielectric properties;
- c) the tests for confirming that these conditions have been met and the methods that are adopted for these tests;
- d) the information relevant to the marking of the equipment or made available by the manufacturer, e.g. in the catalogue.

Specific items requiring agreement between the user and the manufacturer are identified in Annex B.