

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**Low-voltage switchgear and controlgear –  
Part 6-2: Multiple function equipment – Control and protective switching devices  
(or equipment) (CPS)**

**Appareillage à basse tension –  
Partie 6-2: Matériels à fonctions multiples – Appareils (ou matériel) de connexion  
de commande de protection (ACP)**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

#### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

#### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### IEC Glossary - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

---

### A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

#### Recherche de publications IEC -

[webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

#### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

#### Service Clients - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: [sales@iec.ch](mailto:sales@iec.ch).

#### Electropedia - [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

#### Glossaire IEC - [std.iec.ch/glossary](http://std.iec.ch/glossary)

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

---

**Low-voltage switchgear and controlgear –  
Part 6-2: Multiple function equipment – Control and protective switching devices  
(or equipment) (CPS)**

**Appareillage à basse tension –  
Partie 6-2: Matériels à fonctions multiples – Appareils (ou matériel) de connexion  
de commande de protection (ACP)**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

---

ICS 29.120.40; 29.130.20

ISBN 978-2-8322-9161-0

**Warning! Make sure that you obtained this publication from an authorized distributor.  
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

## CONTENTS

FOREWORD.....	7
1 Scope.....	10
2 Normative references .....	10
3 Terms and definitions .....	11
3.1 General.....	11
3.2 Terms and definitions related to the equipment.....	12
3.3 Terms and definitions concerning characteristic quantities.....	13
3.4 Terms and definitions concerning safety aspects .....	14
4 Classification.....	15
5 Characteristics .....	15
5.1 Summary of characteristics.....	15
5.2 Type of equipment .....	15
5.2.1 Number of poles .....	15
5.2.2 Kind of current (alternating current or direct current).....	15
5.2.3 Method of operation.....	15
5.2.4 Method of control.....	16
5.2.5 Method of resetting after overload .....	16
5.2.6 Method of rearming after short-circuit .....	16
5.3 Rated and limiting values of the main circuit.....	16
5.3.1 Rated voltages .....	16
5.3.2 Currents and powers .....	16
5.3.3 Rated frequency .....	16
5.3.4 Rated duties .....	16
5.3.5 Normal load and overload characteristics – Rated making and breaking capacities .....	17
5.3.6 Short circuit characteristics – Rated service short-circuit breaking capacity ( $I_{CS}$ ).....	17
5.3.7 Pole impedance of a CPS ( $Z$ ).....	17
5.4 Utilization categories.....	17
5.4.1 General .....	17
5.4.2 Assignment of utilization categories based on the results of tests .....	18
5.4.3 Application of utilization categories for motor control duty.....	19
5.5 Control circuits.....	19
5.6 Auxiliary circuits.....	20
5.7 Relays or releases .....	20
5.7.1 Summary of characteristics.....	20
5.7.2 Types of relays or releases.....	20
5.7.3 Characteristic values .....	21
5.7.4 Designation and current setting of overload relays or releases .....	21
5.7.5 Time-current characteristics of over current relays or releases .....	21
5.7.6 Influence of ambient air temperature.....	22
6 Product information .....	22
6.1 Nature of information .....	22
6.1.1 Identification.....	22
6.1.2 Characteristics.....	22
6.2 Marking.....	23
6.3 Instructions for installation, operation and maintenance .....	24

6.4	Environmental information .....	24
7	Normal service, mounting and transport conditions .....	24
8	Constructional and performance requirements .....	25
8.1	Constructional requirements .....	25
8.1.1	General .....	25
8.1.2	Materials .....	25
8.1.3	Current-carrying parts and their connections .....	26
8.1.4	Clearances and creepage distances .....	26
8.1.5	Actuator .....	26
8.1.6	Indication of the contact position .....	27
8.1.7	Additional requirements for equipment suitable for isolation .....	27
8.1.8	Terminals .....	27
8.1.9	Additional requirements for equipment provided with a neutral pole .....	27
8.1.10	Provisions for protective earthing .....	27
8.1.11	Enclosures for equipment .....	27
8.1.12	Degrees of protection of enclosed equipment .....	28
8.1.13	Conduit pull-out, torque and bending with metallic conduit .....	28
8.1.14	Limited energy source .....	28
8.1.15	Stored charge energy circuit .....	30
8.1.16	Fault and abnormal conditions .....	30
8.1.17	Short-circuit and overload protection of poles .....	31
8.2	Performance requirements .....	31
8.2.1	Operating conditions .....	31
8.2.2	Temperature-rise .....	37
8.2.3	Dielectric properties .....	39
8.2.4	Performance under no load, normal load and overload conditions .....	39
8.2.5	Ability to make, carry and break short-circuit currents .....	45
8.2.6	Pole impedance .....	46
8.2.7	Leakage currents of equipment suitable for isolation .....	46
8.2.8	Coil power consumption .....	46
8.2.9	Co-ordination between a CPS and another short-circuit protective device .....	46
8.3	Electromagnetic compatibility (EMC) .....	46
8.3.1	General .....	46
8.3.2	Immunity .....	47
8.3.3	Emission .....	47
9	Tests .....	48
9.1	Kind of tests .....	48
9.1.1	General .....	48
9.1.2	Type test .....	48
9.1.3	Routine tests .....	48
9.1.4	Sampling tests .....	48
9.1.5	Special tests .....	48
9.2	Compliance with constructional requirements .....	49
9.2.1	General .....	49
9.2.2	Electrical performance of screwless-type clamping units .....	49
9.2.3	Ageing test for screwless-type clamping units .....	50
9.2.4	Limited energy source test .....	50
9.2.5	Breakdown of components .....	51

9.3	Compliance with performance requirements .....	51
9.3.1	Test sequences .....	51
9.3.2	General test conditions .....	52
9.3.3	Performance under no load, normal load and overload conditions.....	52
9.3.4	Performance under short-circuit conditions .....	61
9.4	EMC tests .....	63
9.4.1	General .....	63
9.4.2	Immunity.....	64
9.4.3	Emission.....	69
9.5	Test sequences .....	70
9.5.1	General .....	70
9.5.2	Test sequence I: temperature-rise, operating limits, dielectric properties .....	71
9.5.3	Test sequence II: performance under normal load and overload conditions .....	75
9.5.4	Test sequence III: operational performance before and after operating sequences at conventional prospective current $I_{Cr}$ and conventional prospective current "r" test .....	76
9.5.5	Test sequence IV: operational performance before and after operating sequences at $I_{CS}$ .....	77
9.5.6	Test sequence V: additional breaking capacity .....	78
9.5.7	Test sequence VI: additional test sequence for four-pole CPS's.....	78
9.5.8	Test sequence VII: additional test sequence for CPS's intended for use in an individual enclosure .....	79
9.5.9	Test sequence VIII: EMC .....	79
9.6	Routine tests.....	79
9.6.1	General .....	79
9.6.2	Operation and operating limits .....	80
9.6.3	Dielectric tests.....	80
Annex A (normative)	Special tests .....	81
A.1	General.....	81
A.2	Mechanical durability .....	81
A.2.1	General .....	81
A.2.2	Verification of mechanical durability.....	81
A.3	Electrical durability .....	83
Annex B (xxx)	Vacant .....	84
Annex C (normative)	Marking and identification of CPS terminals .....	85
C.1	General.....	85
C.2	Marking and identification of terminals of main circuits.....	85
C.2.1	General .....	85
C.2.2	Marking and identification of terminals of auxiliary circuits .....	85
Annex D (informative)	Items subject to agreement between manufacturer and user .....	86
Annex E (xxx)	Vacant .....	87
Annex F (normative)	Requirements for auxiliary contact linked with power contact (mirror contact).....	88
F.1	Application and object.....	88
F.1.1	Application.....	88
F.1.2	Object.....	88
F.2	Terms and definitions.....	88
F.3	Characteristics.....	88

F.4	Product information.....	88
F.5	Normal service, mounting and transport conditions .....	89
F.6	Constructional and performance requirements .....	89
F.7	Tests .....	89
F.7.1	General .....	89
F.7.2	Tests on products in a new condition .....	89
F.7.3	Test after conventional operational performance (defined under Table 10) ....	90
Annex G (normative)	Test sequence for CPS's for IT systems .....	91
G.1	General.....	91
G.2	Individual pole short circuit .....	91
G.3	Verification of dielectric withstand .....	92
G.4	Verification of overload releases .....	92
G.5	Marking.....	92
Annex H (xxx)	Vacant .....	93
Annex I (informative)	Glossary of symbols and graphical representation of characteristics .....	94
Annex J (xxx)	Vacant .....	95
Annex K (normative)	Procedure to determine data for electromechanical CPS used in functional safety applications .....	96
K.1	General.....	96
K.2	Test requirements .....	96
K.3	Characterization of a failure mode .....	96
K.4	Failure ratios of a CPS.....	96
Annex L (xxx)	Vacant.....	98
Annex M (informative)	Load monitoring indicators.....	99
M.1	General.....	99
M.2	Indicators list .....	99
M.3	Uncertainty .....	101
M.4	Tests .....	102
M.4.1	Routine tests .....	102
M.4.2	Type tests.....	102
Annex N (normative)	Additional requirements and tests for equipment with protective separation.....	104
N.1	General.....	104
N.2	Terms and definitions.....	104
N.3	Requirements .....	104
N.3.1	Test method for implementing protective impedance.....	104
N.3.2	Touch current measurement .....	105
Bibliography	.....	107
Figure 1	Multiple of current setting limits for ambient air temperature time-delay overload relays or releases (see 8.2.1.5.1) .....	34
Figure 2	Thermal memory test .....	36
Figure 3	Voltage drop measurement at contact point of the clamping terminal .....	50
Figure 4	Example of a pole impedance measurement for a three-pole CPS.....	59
Figure 5	Representation of test current produced by back-to-back thyristors.....	67
Figure 6	Test current for the verification of the influence of the current dips and interruptions.....	68

Figure F.1 – Mirror contact.....	89
Figure M.1 – Example of quantification of a process change.....	101
Figure N.1 – Protection by means of protective impedance.....	105
Figure N.2 – Measuring instrument.....	106
Table 1 – Utilization categories.....	18
Table 20 – Limits for limited energy sources without an over-current protective device.....	29
Table 21 – Limits for limited energy sources with an over-current protective device.....	29
Table 22 – Limits for limited energy source with current limiting impedance.....	30
Table 2 – Limits of operation of inverse time-delay overload relays or releases when energized on all poles.....	33
Table 3 – Trip classes of overload relays or releases for utilization categories AC-2, AC-3, AC-3e, AC-4, DC-3, DC-5.....	34
Table 4 – Limits of operation of three-pole inverse time-delay overload relays or releases when energized on two poles only.....	35
Table 5 – Temperature-rise limits of terminals.....	37
Table 6 – Temperature-rise limits for insulated coils in air.....	38
Table 7 – Intermittent duty test cycle data.....	38
Table 8 – Rated making and breaking capacities – Making and breaking conditions corresponding to the utilization categories.....	40
Table 9 – Relationship between current broken $I_C$ and OEF time for the verification of rated making and breaking capacities.....	41
Table 10 – Conventional operational performance after making/breaking capacity tests – Making and breaking conditions according to utilization category.....	43
Table 11 – Operational performance before and after short-circuit tests at $I_{CR}$ and $I_{CS}$ – Making and breaking conditions according to utilization category.....	44
Table 12 – Value of the prospective test current according to the rated operational current.....	45
Table 13 – Value of the prospective test current according to the rated operational current (harmonized table).....	46
Table 14 – Performance criteria when EM disturbances are present.....	47
Table 15 – EMC immunity tests.....	64
Table 16 – Test parameters for harmonics and interruptions.....	68
Table 17 – Terminal disturbance voltage limits for conducted radio-frequency emission (for mains poles).....	69
Table 18 – Radiated emission test limits.....	70
Table 19 – Test sequences.....	70
Table F.1 – Test voltage according to altitude.....	90
Table G.1 – Individual pole.....	91
Table K.1 – Failure mode of CPS.....	96
Table K.2 – Typical failure ratios for CPS.....	97
Table M.1 – AC monitoring indicators list.....	100
Table M.2 – Different possibilities authorized for verification of indicators.....	102
Table M.3 – Reference for verification conditions.....	103
Table M.4 – Harmonic levels.....	103

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 6-2: Multiple function equipment –  
Control and protective switching devices (or equipment) (CPS)**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publications"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60947-6-2 has been prepared by subcommittee 121A: Low-voltage switchgear and controlgear, of IEC technical committee 121: Switchgear and controlgear and their assemblies for low-voltage.

This third edition cancels and replaces the second edition published in 2002 and its Amendment 1:2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- editorial changes according to ISO/IEC directives Part 2,
- alignments with IEC 60947-1:2020:
  - markings ("s", "sol", "r" or "f");
  - constructional requirements including material requirements;
  - requirements for screwless terminals;

- measurement method of the pole impedance;
- EMC requirement and testing;
- procedure to determine data for electromechanical CPS's used in functional safety applications;
- harmonisation with IEC 60947-2:2016:
  - operation tests of under-voltage relays and shunt releases;
  - CPS for IT systems (Annex G);
  - coordination with other short-circuit protective devices;
- alignments with IEC 60947-4-1:2018:
  - test at the rated conditional short-circuit current  $I_q$  of protected switching devices;
  - short-circuit tests harmonisation with North America;
  - reliability data for functional safety applications (new Annex K);
  - safety aspects related to electronic circuits and protective impedance (new Annex N);
  - introduction of provisions covering the impact of higher locked rotor current to achieve high efficiency class;
  - mention of dedicated wiring accessories;
  - definitions and measurement method of the power consumption of the control circuit during holding and pick-up operations;
  - load monitoring indicators (new Annex M).

The text of this International Standard is based on the following documents:

FDIS	Report on voting
121A/384/FDIS	121A/392/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60947 series, under the general title *Low-voltage switchgear and controlgear*, can be found on the IEC website.

This document shall be read in conjunction with IEC 60947-1, *Low voltage switchgear and controlgear – Part 1: General rules*.

The provisions of the general rules are applicable to this part of IEC 60947-6, where specifically called for. General rules clauses and subclauses thus applicable as well as tables, figures and annexes are identified by reference to IEC 60947-1, for example, 1.2.3, Table 4, or Annex A of IEC 60947-1:2020.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 6-2: Multiple function equipment – Control and protective switching devices (or equipment) (CPS)

#### 1 Scope

This document applies to control and protective switching devices (or equipment) (CPS), the main contacts of which are intended to be connected to circuits of rated voltage not exceeding 1 000 V AC or 1 500 V DC.

It covers control and protective switching device (CPS):

- which provides protective and control functions for circuits and motors;
- where its control function is operated exclusively otherwise than by hand;
- which provides continuity of service after over-current conditions; and
- which can have additional functions, such as isolation or communication.

This document does not apply to:

- auxiliary contacts, covered by IEC 60947-5-1;
- CPS used downstream to frequency drive<sup>1</sup>;

NOTE Additional requirements for CPS used downstream to frequency drive are under consideration for the next maintenance cycle.

- the use of the product with additional measure within explosive atmospheres, covered by IEC 60079 (all parts);
- embedded software design rules, covered by IEC TR 63201;
- cyber security aspects, covered by IEC TS 63208.

The object of this document is to state:

- the characteristics of CPS's;
- the conditions with which CPS's are complying with reference to their operation and behaviour, their dielectric properties, the degree of protection provided by their enclosure where applicable, its construction including safety measures against electric shock, fire hazard and mechanical hazard;
- the tests intended to verify that these conditions have been met, and the methods to be adopted for these tests;
- the information to be marked on or given with the CPS's.

#### 2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

---

<sup>1</sup> For this subject, the manufacturer is responsible to take additional safety measures.