

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Rules for steam turbine thermal acceptance tests –
Part 0: Wide range of accuracy for various types and sizes of turbines**

**Règles pour les essais thermiques de réception des turbines à vapeur –
Partie 0: Plage de précision étendue pour différents types et dimensions de
turbines**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Rules for steam turbine thermal acceptance tests –
Part 0: Wide range of accuracy for various types and sizes of turbines**

**Règles pour les essais thermiques de réception des turbines à vapeur –
Partie 0: Plage de précision étendue pour différents types et dimensions de
turbines**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.040

ISBN 978-2-8322-0938-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	11
1.1 General.....	11
1.2 Object.....	11
1.3 Matters to be considered in the contract	12
2 Normative references	12
3 Units, symbols, terms and definitions.....	12
3.1 General.....	12
3.2 Symbols, units	13
3.3 Subscripts, superscripts and definitions	14
3.4 Definition of guarantee values and test results	16
3.4.1 Guidance on guarantee parameters	16
3.4.2 Thermal efficiency	16
3.4.3 Heat rate	18
3.4.4 Thermodynamic efficiency	18
3.4.5 Steam rate.....	19
3.4.6 Main steam flow capacity.....	19
3.4.7 Power output.....	19
3.4.8 Guarantee values for extraction and mixed-pressure turbines.....	20
3.4.9 Thermal Load Capacity (for Nuclear applications).....	20
4 Guiding principles.....	20
4.1 Advance planning for test.....	20
4.2 Preparatory agreements and arrangements for tests	21
4.3 Planning of the test.....	22
4.3.1 Time for acceptance tests	22
4.3.2 Direction of acceptance tests.....	22
4.4 Preparation of the tests	22
4.4.1 Condition of the plant	22
4.4.2 Condition of the steam turbine	23
4.4.3 Condition of the condenser	23
4.4.4 Isolation of the cycle.....	24
4.4.5 Checks for leakage of condenser and feed water heaters	26
4.4.6 Cleanliness of the steam strainers	26
4.4.7 Checking of the test measuring equipment	26
4.5 Comparison measurements.....	26
4.6 Settings for tests.....	27
4.6.1 Load settings.....	27
4.6.2 Special settings	28
4.7 Preliminary tests.....	28
4.8 Acceptance tests	28
4.8.1 Constancy of test conditions	28
4.8.2 Maximum deviation and fluctuation in test conditions.....	28
4.8.3 Duration of test runs and frequency of reading.....	29
4.8.4 Reading of integrating measuring instruments	30
4.8.5 Alternative methods	30
4.8.6 Recording of tests	30

4.8.7	Additional measurement	30
4.8.8	Preliminary calculations	30
4.8.9	Consistency and number of tests	30
4.9	Repetition of acceptance tests	31
5	Measuring techniques and measuring instruments	31
5.1	Overview	31
5.1.1	Instrument accuracy requirements	31
5.1.2	Measuring instruments	31
5.1.3	Measuring uncertainty	31
5.1.4	Calibration of instruments	32
5.1.5	Alternative instrumentation	32
5.2	Measurement of power	36
5.2.1	Determination of mechanical turbine output	36
5.2.2	Measurement of boiler feed pump power	36
5.2.3	Determination of electrical power of a turbine generator	37
5.2.4	Measurement of electrical power	38
5.2.5	Electrical instrument connections	38
5.2.6	Electrical instruments	38
5.2.7	Instrument transformers	39
5.3	Flow measurement	39
5.3.1	Determination of flows to be measured	39
5.3.2	Measurement of primary flow	39
5.3.3	Installation and location of flow measuring devices	42
5.3.4	Calibration of primary flow devices for water flow	43
5.3.5	Inspection of flow measuring devices	44
5.3.6	Differential pressure measurements	45
5.3.7	Water flow fluctuation	45
5.3.8	Secondary flow measurements	45
5.3.9	Occasional secondary flows	48
5.3.10	Density of water and steam	49
5.3.11	Determination of cooling water flow of condenser	49
5.4	Pressure measurement (excluding condensing turbine exhaust pressure)	50
5.4.1	Pressures to be measured	50
5.4.2	Instruments	50
5.4.3	Main pressure measurements	50
5.4.4	Pressure tapping holes and connecting lines	51
5.4.5	Shut-off valves	52
5.4.6	Calibration of pressure measuring devices	52
5.4.7	Atmospheric pressure	52
5.4.8	Correction of readings	52
5.5	Condensing turbine exhaust pressure measurement	53
5.5.1	General	53
5.5.2	Plane of measurement	53
5.5.3	Pressure taps	53
5.5.4	Manifolds	54
5.5.5	Connecting lines	54
5.5.6	Instruments	54
5.5.7	Calibration	54
5.6	Temperature measurement	54

5.6.1	Points of temperature measurement	54
5.6.2	Instruments	55
5.6.3	Main temperature measurements	55
5.6.4	Feed train temperature measurements (including bled steam)	55
5.6.5	Condenser cooling water temperature measurement	56
5.6.6	Thermometer wells	56
5.6.7	Precautions to be observed in the measurement of temperature	57
5.7	Steam quality determination	57
5.7.1	General	57
5.7.2	Tracer technique	57
5.7.3	Condensing method	58
5.7.4	Constant rate injection method	61
5.7.5	Extraction enthalpy determined by constant rate injection method	62
5.7.6	Tracers and their use	64
5.8	Time measurement	65
5.9	Speed measurement	65
6	Evaluation of tests	65
6.1	Preparation of evaluation	65
6.2	Computation of results	66
6.2.1	Calculation of average values of instrument readings	66
6.2.2	Correction and conversion of averaged readings	66
6.2.3	Checking of measured data	66
6.2.4	Thermodynamic properties of steam and water	67
6.2.5	Calculation of test results	68
7	Correction of test results and comparison with guarantee	68
7.1	Guarantee values and guarantee conditions	68
7.2	Correction of initial steam flow capacity	68
7.3	Correction of output	69
7.3.1	Correction of maximum output	69
7.3.2	Correction of Output with specified initial steam flow	69
7.4	Correction of the normal performance	69
7.5	Definition and application of correction values	70
7.6	Correction methods	70
7.6.1	General	70
7.6.2	Correction by heat balance calculation	71
7.6.3	Correction by use of correction curves prepared by the manufacturer	72
7.6.4	Tests to determine correction values	72
7.7	Variables to be considered in the correction of specific turbine cycles	72
7.7.1	Scope of corrections	72
7.7.2	Turbines with regenerative feed-water heating	72
7.7.3	Turbines which have no provision for the addition or extraction of steam after partial expansion	74
7.7.4	Turbines with steam extraction for purposes other than feed-water heating (extraction turbines)	74
7.7.5	Other types of turbine	74
7.8	Guarantee comparison	75
7.8.1	Tolerance and weighting	75
7.8.2	Guarantee comparison with locus curve	75
7.8.3	Guarantee comparison with guarantee point	76

7.8.4	Guarantee comparison for turbines with throttle governing	76
7.8.5	Guarantee comparison for extraction turbines	76
7.9	Deterioration of turbine performance (ageing)	77
7.9.1	Timing to minimise deterioration	77
7.9.2	Correction with comparison tests	77
7.9.3	Correction without comparison tests	77
8	Measuring uncertainty	78
8.1	General	78
8.2	Determination of measuring uncertainty of steam and water properties	79
8.2.1	Pressure	79
8.2.2	Temperature	79
8.2.3	Enthalpy and enthalpy difference	79
8.3	Calculation of measuring uncertainty of output	80
8.3.1	Electrical measurement	80
8.3.2	Mechanical measurement	82
8.3.3	Additional uncertainty allowance because of unsteady load conditions	82
8.4	Determination of measuring uncertainty of mass flow	82
8.4.1	Measuring uncertainty of mass flow measurements	82
8.4.2	Measuring uncertainty of multiple measurements of primary flow	82
8.4.3	Uncertainty allowance for cycle imperfections	83
8.5	Calculation of measuring uncertainty of results	83
8.5.1	General	83
8.5.2	Measuring uncertainty of thermal efficiency	83
8.5.3	Measuring uncertainty of thermodynamic efficiency	84
8.5.4	Uncertainty of corrections	84
8.5.5	Guiding values for the measuring uncertainty of results	85
8.6	Example uncertainty calculation	85
Annex A (normative)	Feedwater heater leakage and condenser leakage tests	87
A.1	Feedwater heater leakage tests	87
A.2	Condenser leakage tests	87
Annex B (normative)	Evaluation of multiple measurements, compatibility	88
Annex C (normative)	Mass flow balances	89
C.1	General	89
C.2	Flows for further evaluations (informative)	90
Annex D (informative)	Short-statistical definition of measuring uncertainty and error propagation in acceptance tests	92
Annex E (informative)	Temperature variation method	96
E.1	Description of the problem	96
E.2	Possibility to determine the leakage flow	96
E.3	Applied example	98
	Bibliography	102
	Figure 1 – Diagrams for interpretation of symbols and subscripts	17
	Figure 2 – Diagram showing location and type of test instrumentation (fossil fuel plant)	33
	Figure 3 – Diagram showing location and type of test instrumentation (nuclear plant)	34
	Figure 4 – USM with flow conditioner or flow straightener	41
	Figure 5 – Throttle steam quality calculations for boiling water reactor	60

Figure 6 – Throttle steam quality calculations for pressurized water reactor	61
Figure 7 – Typical installation of injection and sampling points	63
Figure 8 – Oxygen content of sample stream	64
Figure 9 – Guarantee comparison on locus curve	76
Figure 10 – Correction factor for steam table tolerance	80
Figure C.1 – Diagram of cycle for plant with steam turbine with single reheating and five stages of regenerative feedwater heating extraction	90
Figure E.1 – IP turbine bowl expansion line depending on different labyrinth flow rates	97
Figure E.2 – Schematic diagram of a combined HP/IP1/IP2 turbine	98
Figure E.3 – Result of temperature variation tests. IP2 turbine bowl efficiency as a function of the labyrinth flow rate (sealing 2) for varying live and reheat temperatures	101
Table 1 – Maximum deviations and fluctuations in operating conditions	29
Table 2 – Acceptable instrumentation and uncertainties for acceptance tests	35
Table 3 – Apportionment of unaccounted leakages	67
Table 4 – Average deterioration by ageing	77
Table 5 – Deterioration of thermal efficiency and power output	77
Table 6 – Guiding values for the uncertainty of test results	85
Table 7 – Example uncertainty calculation for reheat cycle with uncalibrated primary flows measurements	86
Table E.1 – Measured thermodynamic parameters and calculated IP2 turbine bowl isentropic efficiencies	100

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RULES FOR STEAM TURBINE THERMAL ACCEPTANCE TESTS –**Part 0: Wide range of accuracy for various types and sizes of turbines**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60953-0 has been prepared by subcommittee WG 11/MT 14: Thermal Acceptance Test, of IEC technical committee 11: Steam Turbines. It is an International Standard.

This first edition cancels and replaces IEC 60953-2, published in 1990. This edition constitutes a technical revision. This edition includes the following significant technical changes with respect to the previous edition:

- a) IEC 60953-2:1990 has been used as the basis to develop IEC 60953-0;
- b) Outdated measuring techniques have been updated and the corresponding reduction of the expected test result measuring uncertainty indicated;
- c) Guarantee of power output at specified steam flow has been included;
- d) A proposal for assignment of unaccounted for leakages has been included;
- e) Correction methods and guarantee comparisons are updated;
- f) Various appendices deleted:
 - Appendix B (flow nozzle)
 - Appendix E (generalized correction curves)
 - Appendix G (power measurement uncertainty)

g) Annex added:

- Annex E (Temperature variation method) taken over from IEC 60953-3:2002, Annex L

The text of this International Standard is based on the following documents:

Draft	Report on voting
5/248/FDIS	5/250/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

A list of all parts in the IEC 60953 series, published under the general title *Rules for sea turbine thermal acceptance tests*, can be found on the IEC website.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2 and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be


- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The continuing development of measuring techniques, the increasing capacity of steam turbines and increasing variety of steam turbine configurations has necessitated a revision of IEC 60953:1990.

Since all the needs of the power industry could not be satisfied by one single performance test standard covering the requirements for all of the steam turbine configurations and accuracy, the revision to this standard is based upon one reference standard and various supplementary parts as indicated below:



1) Basic philosophy and figures on uncertainty

IEC 60953-0 provides for acceptance tests of steam turbines of various types and capacities with corresponding measuring uncertainty, it is based upon the Method B of IEC 60953-2:1990. Additional and alternative guidance will be given for specific steam turbine applications in the supplementary standards where it is required.

Instrumentation and measuring procedures are chosen accordingly from a scope specified in the standard series which is centred mainly on standardized instrumentation and procedures, but may extend up to high accuracy provisions requiring calibration of flow measuring devices. The resulting measuring uncertainty of the test result is then determined by calculating methods presented in the standard series and normally, if not stated otherwise in the contract, taken into account in the comparison between test result and guarantee value. The total cost of an acceptance test can therefore be maintained in relationship with the economic value of the guarantee values to be ascertained.

When good-standardized instrumentation and procedures are applied in a test, the measuring uncertainty given in Table 6 can be achieved. The parties to the test should reach agreement on the measuring uncertainty desired for the acceptance tests.

2) Guiding principles

The requirements concerning the preparation and conditions of the test and especially such conditions of the test as duration, deviations and constancy of test conditions are defined.

The test should be conducted preferably within eight weeks after first synchronisation. It is the intent during this period to minimize performance deterioration and risk of damage to the turbine.

Enthalpy drop tests should be made during this period to monitor HP and IP turbine section performance. However, these tests do not provide LP section performance and for this reason it is imperative to conduct the acceptance tests as soon as practicable.

Adjustment of the heat rate and power output test results for the effects of aging preferably by use of start-up enthalpy drop efficiency tests or by application of a standard allowance according to 7.9 is to be applied unless otherwise agreed in the contract.

3) Instruments and methods of measurement

a) Measurement instruments (for electrical power, pressure, temperature)

The measuring instruments used should be individually calibrated shortly before the test.

b) Flow measurement devices

For the measurement of main flows, uncalibrated or calibrated standardized flow measuring devices may be used.

Typically uncalibrated standardized flow measuring devices are used, however calibration is recommended where a reduction of overall measuring uncertainty is desirable. Double or multiple measurement of primary flow is recommended for the reduction of measuring uncertainty and a method for checking the compatibility is described.

4) Evaluation of tests

The preparatory work for the evaluation and calculation of the test results is covered.

Detailed methods for calculation of measuring uncertainty values of measured variables and tests results are given.

5) Correction of test results and comparison with guarantees

The correction of test results to guarantee conditions is covered. The measuring uncertainty of the result is taken into account in the guarantee comparison.

6) Proposals for application

Since the acceptance test method to be applied has to be considered in the details of the plant design, it should be stated as early as possible, preferably in the turbine contract, which method will be used.

This standard series can be applied to steam turbines of any type and any power. The desired measuring uncertainty should be decided upon sufficiently early, so that the necessary provisions can be included in the plant.

If the guarantee includes the complete power plant or large parts thereof, the relevant parts of this standard series can be applied for an acceptance test in accordance with the definition of the guarantee value.

RULES FOR STEAM TURBINE THERMAL ACCEPTANCE TESTS –

Part 0: Wide range of accuracy for various types and sizes of turbines

1 Scope

1.1 General

The rules given in this document are applicable to thermal acceptance tests covering a wide range of accuracy on steam turbines of every type, rating and application. Only the relevant portion of these rules will apply to any individual case.

The rules provide for the testing of turbines, whether operating with either superheated or saturated steam. They include measurements and procedures required to determine specific enthalpy within the moisture region and describe precautions necessary to permit testing while respecting radiological safety rules in nuclear plants.

Uniform rules for the preparation, carrying out, evaluation, comparison with guarantee and calculation of measuring uncertainty of acceptance tests are defined in this standard. Details of the conditions under which the acceptance test can take place are included.

Should any complex or special case arise which is not covered by these rules, appropriate agreement is to be reached by manufacturer and purchaser before the contract is signed.

1.2 Object

The purpose of the thermal acceptance tests of steam turbines and turbine cycles described in this document is to verify guarantees given by the manufacturer of the equipment concerning:

Efficiency guarantees

- a) Thermal efficiency;
- b) Heat rate;
- c) Thermodynamic efficiency;
- d) Steam rate;
- e) Power output.

Capacity guarantees

- a) Main steam flow capacity;
- b) Maximum power output at specified steam conditions according to IEC 60045-1 (other than steam flow);
- c) Nuclear: thermal load capacity of the steam turbine under defined conditions.

The guarantees with their provisions are formulated completely and without contradictions (see 3.4). The acceptance tests may also include such measurements as are necessary for corrections according to the conditions of the guarantee and checking of the results.