

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Rules for steam turbine thermal acceptance tests –
Part 3: Thermal performance verification tests on retrofitted steam turbines**

**Règles pour les essais thermiques de réception des turbines à vapeur –
Partie 3: Essais de vérification des performances thermiques des turbines à
vapeur rénovées**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Rules for steam turbine thermal acceptance tests –
Part 3: Thermal performance verification tests on refitted steam turbines**

**Règles pour les essais thermiques de réception des turbines à vapeur –
Partie 3: Essais de vérification des performances thermiques des turbines à
vapeur renouvelées**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.040

ISBN 978-2-8322-3974-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

| | |
|-----------------------------------------------------------------------------|----|
| FOREWORD..... | 8 |
| INTRODUCTION..... | 10 |
| 1 Scope..... | 13 |
| 1.1 General..... | 13 |
| 1.2 Object..... | 13 |
| 1.3 Matters to be considered in the contract | 13 |
| 2 Normative references | 13 |
| 3 Units, symbols, terms and definitions..... | 14 |
| 3.1 General..... | 14 |
| 3.2 Symbols, units | 14 |
| 3.3 Subscripts, superscripts and definitions | 14 |
| 3.4 Guarantee parameters | 16 |
| 3.4.1 Guidance on guarantee parameters | 16 |
| 3.4.2 Thermal efficiency | 16 |
| 3.4.3 Heat rate | 16 |
| 3.4.4 Thermodynamic efficiency | 16 |
| 3.4.5 Steam rate..... | 16 |
| 3.4.6 Main steam flow capacity..... | 16 |
| 3.4.7 Power output..... | 16 |
| 3.4.8 Guarantee values for extraction and mixed-pressure turbines..... | 16 |
| 3.4.9 Thermal Load Capacity (for Nuclear applications)..... | 16 |
| 3.5 Additional guarantee parameters | 16 |
| 3.5.1 General | 16 |
| 3.5.2 Cylinder isentropic efficiency – expansion in superheated region..... | 16 |
| 3.5.3 Cylinder isentropic efficiency – expansion involving wet region..... | 17 |
| 3.5.4 Pressure loss..... | 19 |
| 3.5.5 Flow-passing capacity (FPC) | 19 |
| 4 Guiding principles..... | 19 |
| 4.1 Advance planning for test..... | 19 |
| 4.2 Preparatory agreements and arrangements for tests | 20 |
| 4.3 Planning of the test..... | 20 |
| 4.3.1 Time for verification tests..... | 20 |
| 4.3.2 Direction of acceptance tests..... | 21 |
| 4.4 Preparation of the tests..... | 21 |
| 4.4.1 Condition of the plant..... | 21 |
| 4.4.2 Condition of the steam turbine | 22 |
| 4.4.3 Condition of the condenser | 22 |
| 4.4.4 Isolation of the cycle..... | 22 |
| 4.4.5 Checks for leakage of condenser and feed water heaters | 22 |
| 4.4.6 Cleanliness of the steam strainers | 22 |
| 4.4.7 Checking of the test measuring equipment | 22 |
| 4.5 Comparison measurements..... | 22 |
| 4.6 Settings for test | 23 |
| 4.6.1 Load settings..... | 23 |
| 4.6.2 Special settings | 23 |
| 4.7 Preliminary tests | 23 |
| 4.8 Acceptance tests | 23 |

| | | |
|--------|----------------------------------------------------------------------------|----|
| 4.8.1 | Constancy of test conditions | 23 |
| 4.8.2 | Maximum deviation and fluctuation in test conditions | 23 |
| 4.8.3 | Duration of test runs and frequency of reading | 23 |
| 4.8.4 | Reading of integrating measuring instruments | 23 |
| 4.8.5 | Alternative methods | 23 |
| 4.8.6 | Recording of tests | 23 |
| 4.8.7 | Additional measurement | 23 |
| 4.8.8 | Preliminary calculations | 23 |
| 4.8.9 | Consistency and number of tests | 24 |
| 4.9 | Repetition of acceptance tests | 24 |
| 4.10 | Guidance on retrofit guarantees | 24 |
| 4.10.1 | General | 24 |
| 4.10.2 | Absolute guarantees | 25 |
| 4.10.3 | Relative guarantees | 26 |
| 5 | Measuring techniques and measuring instruments | 27 |
| 5.1 | Overview | 27 |
| 5.1.1 | Instrument accuracy requirements | 27 |
| 5.1.2 | Measuring instruments | 27 |
| 5.1.3 | Measuring uncertainty | 27 |
| 5.1.4 | Calibration of instruments | 27 |
| 5.1.5 | Alternative instrumentation | 27 |
| 5.1.6 | Consistency of pre- and post-retrofit test | 27 |
| 5.2 | Measurement of power | 27 |
| 5.2.1 | Determination of mechanical turbine output | 27 |
| 5.2.2 | Measurement of boiler feed pump power | 27 |
| 5.2.3 | Determination of electrical power of a turbine generator | 28 |
| 5.2.4 | Measurement of electrical power | 28 |
| 5.2.5 | Electrical instrument connections | 28 |
| 5.2.6 | Electrical instruments | 28 |
| 5.2.7 | Instrument transformers | 28 |
| 5.2.8 | Determination of electrical power of pre- and post-retrofit tests | 28 |
| 5.3 | Flow measurement | 28 |
| 5.3.1 | Determination of flows to be measured | 28 |
| 5.3.2 | Measurement of primary flow | 29 |
| 5.3.3 | Installation and location of flow measuring devices | 29 |
| 5.3.4 | Calibration of primary flow devices for water flow | 29 |
| 5.3.5 | Inspection of flow measuring devices | 29 |
| 5.3.6 | Differential pressure measurements | 30 |
| 5.3.7 | Water flow fluctuation | 30 |
| 5.3.8 | Secondary flow measurements | 30 |
| 5.3.9 | Occasional secondary flows | 31 |
| 5.3.10 | Density of water and steam | 31 |
| 5.3.11 | Determination of cooling water flow of condenser | 31 |
| 5.4 | Pressure measurement (excluding condensing turbine exhaust pressure) | 31 |
| 5.4.1 | Pressures to be measured | 31 |
| 5.4.2 | Instruments | 31 |
| 5.4.3 | Main pressure measurements | 31 |
| 5.4.4 | Pressure tapping holes and connecting lines | 31 |
| 5.4.5 | Shut-off valves | 32 |

| | | |
|-------|-----------------------------------------------------------------------|----|
| 5.4.6 | Calibration of pressure measuring devices..... | 32 |
| 5.4.7 | Atmospheric pressure..... | 32 |
| 5.4.8 | Correction of readings..... | 32 |
| 5.5 | Condensing turbine exhaust pressure measurement..... | 32 |
| 5.5.1 | General..... | 32 |
| 5.5.2 | Plane of measurement..... | 32 |
| 5.5.3 | Pressure taps..... | 32 |
| 5.5.4 | Manifolds..... | 32 |
| 5.5.5 | Connecting lines..... | 32 |
| 5.5.6 | Instruments..... | 32 |
| 5.5.7 | Calibration..... | 32 |
| 5.6 | Temperature measurement..... | 33 |
| 5.6.1 | Points of temperature measurement..... | 33 |
| 5.6.2 | Instruments..... | 33 |
| 5.6.3 | Main temperature measurements..... | 33 |
| 5.6.4 | Feed train temperature measurements (including bled steam)..... | 33 |
| 5.6.5 | Condenser cooling water temperature measurement..... | 33 |
| 5.6.6 | Thermometer wells..... | 33 |
| 5.6.7 | Precautions to be observed in the measurement of temperature..... | 33 |
| 5.7 | Steam quality determination..... | 33 |
| 5.7.1 | General..... | 33 |
| 5.7.2 | Tracer technique..... | 33 |
| 5.7.3 | Condensing method..... | 33 |
| 5.7.4 | Constant rate injection method..... | 33 |
| 5.7.5 | Extraction enthalpy determined by constant rate injection method..... | 33 |
| 5.7.6 | Tracers and their use..... | 34 |
| 5.7.7 | Use of tracer techniques in retrofit applications..... | 34 |
| 5.8 | Time measurement..... | 34 |
| 5.9 | Speed measurement..... | 34 |
| 6 | Evaluation of tests..... | 34 |
| 6.1 | Preparation of evaluation..... | 34 |
| 6.2 | Computation of results..... | 35 |
| 6.2.1 | Calculation of average values of instrument readings..... | 35 |
| 6.2.2 | Correction and conversion of averaged readings..... | 35 |
| 6.2.3 | Checking of measured data..... | 35 |
| 6.2.4 | Thermodynamic properties of steam and water..... | 36 |
| 6.2.5 | Calculation of test results..... | 36 |
| 7 | Corrections of test results and comparison with guarantee..... | 39 |
| 7.1 | Guarantee values and guarantee conditions..... | 39 |
| 7.1.1 | Guarantee values and guarantee conditions specific to retrofits..... | 39 |
| 7.2 | Correction of initial steam flow capacity..... | 40 |
| 7.3 | Correction of output..... | 40 |
| 7.3.1 | Correction of maximum output..... | 40 |
| 7.3.2 | Correction of Output with specified initial steam flow..... | 40 |
| 7.4 | Correction of the thermal performance..... | 40 |
| 7.5 | Definition and application of correction values..... | 40 |
| 7.6 | Correction methods..... | 40 |
| 7.6.1 | General..... | 40 |
| 7.6.2 | Correction by heat balance calculation..... | 40 |

| | | |
|---------------------|-----------------------------------------------------------------------------------------------------------|----|
| 7.6.3 | Correction by use of correction curves prepared by the manufacturer | 41 |
| 7.6.4 | Tests to determine correction values | 41 |
| 7.7 | Variables to be considered in the correction of specific turbine cycles..... | 41 |
| 7.7.1 | Scope of corrections | 41 |
| 7.7.2 | Turbines with regenerative feed-water heating..... | 41 |
| 7.7.3 | Turbines which have no provision for the addition or extraction of steam after partial expansion | 41 |
| 7.7.4 | Turbines with steam extraction for purposes other than feed-water heating (extraction turbines) | 41 |
| 7.7.5 | Other types of turbine | 41 |
| 7.8 | Guarantee comparison | 41 |
| 7.8.1 | Tolerance and weighting..... | 41 |
| 7.8.2 | Guarantee comparison with locus curve..... | 41 |
| 7.8.3 | Guarantee comparison with guarantee point..... | 41 |
| 7.8.4 | Guarantee comparison for turbines with throttle governing..... | 41 |
| 7.8.5 | Guarantee comparison for extraction turbines..... | 41 |
| 7.8.6 | Additional consideration for retrofit guarantee comparison..... | 42 |
| 7.9 | Deterioration of turbine performance (ageing)..... | 42 |
| 7.9.1 | Timing to minimise deterioration | 42 |
| 7.9.2 | Correction with comparison tests | 42 |
| 7.9.3 | Correction without comparison tests | 42 |
| 7.9.4 | Deterioration of performance of retrofitted components..... | 42 |
| 8 | Measuring uncertainty | 43 |
| 8.1 | General..... | 43 |
| 8.2 | Determination of measuring uncertainty of steam and water properties | 43 |
| 8.2.1 | Pressure..... | 43 |
| 8.2.2 | Temperature..... | 43 |
| 8.2.3 | Enthalpy and enthalpy difference | 43 |
| 8.3 | Calculation of measuring uncertainty of output..... | 43 |
| 8.3.1 | Electrical measurement | 43 |
| 8.3.2 | Mechanical measurement..... | 43 |
| 8.3.3 | Additional uncertainty allowance because of unsteady load conditions | 43 |
| 8.4 | Determination of measuring uncertainty of mass flow | 44 |
| 8.4.1 | Measuring uncertainty of mass flow measurements | 44 |
| 8.4.2 | Measuring uncertainty of multiple measurements of primary flow..... | 44 |
| 8.4.3 | Uncertainty allowance for cycle imperfections..... | 44 |
| 8.5 | Calculation of measuring uncertainty of results | 44 |
| 8.5.1 | General | 44 |
| 8.5.2 | Measuring uncertainty of thermal efficiency | 44 |
| 8.5.3 | Measuring uncertainty of thermodynamic efficiency | 44 |
| 8.5.4 | Uncertainty of corrections..... | 44 |
| 8.5.5 | Guiding values for the measuring uncertainty of results | 44 |
| 8.6 | Example uncertainty calculation..... | 44 |
| Annex A (normative) | Feedwater heater leakage and condenser leakage tests | 45 |
| A.1 | Feedwater heater leakage tests | 45 |
| A.2 | Condenser leakage tests | 45 |
| Annex B (normative) | Evaluation of multiple measurements, compatibility..... | 46 |
| Annex C (normative) | Mass flow balances..... | 47 |
| C.1 | General..... | 47 |

| | | |
|-----------------------|-----------------------------------------------------------------------------------------------------|----|
| C.2 | Flows for further evaluations (informative) | 47 |
| Annex D (informative) | Short-statistical definition of measuring uncertainty and error propagation in acceptance test | 48 |
| Annex E (informative) | Temperature variation method | 49 |
| E.1 | Description of the problem | 49 |
| E.2 | Possibility to determine the leakage flow | 49 |
| E.3 | Applied example | 49 |
| Annex F (normative) | Measuring uncertainty of results – retrofit application | 50 |
| Annex G (informative) | Retrofit improvement calculation – numerical examples (fossil and nuclear) | 53 |
| G.1 | General | 53 |
| G.2 | Example of retrofitting a fossil-fired reheat turbine | 53 |
| G.2.1 | General | 53 |
| G.2.2 | HP cylinder retrofitting | 57 |
| G.2.3 | LP cylinder retrofitting with relative guarantee on heat rate (treated separately from the HP case) | 58 |
| G.2.4 | Effect of retrofit on associated plant performance | 59 |
| G.3 | Example of retrofitting a nuclear turbine | 65 |
| G.3.1 | General | 65 |
| G.3.2 | Retrofit scenario and testing procedure | 66 |
| G.3.3 | Correction curves | 66 |
| G.3.4 | Application of correction curves | 67 |
| G.3.5 | Comparison of the measured values to the guarantees | 69 |
| Annex H (informative) | Uncertainty calculation – numerical examples (fossil and nuclear) | 78 |
| H.1 | General | 78 |
| H.2 | Fossil case study | 78 |
| H.2.1 | General | 78 |
| H.2.2 | Evaluation | 79 |
| H.3 | Nuclear case study | 90 |
| H.3.1 | General | 90 |
| H.3.2 | Evaluation | 90 |
| Figure 1 | – Isentropic efficiency of the HP cylinder | 17 |
| Figure 2 | – LP turbine expansion line | 18 |
| Figure G.1 | – HP cylinder expansion | 54 |
| Figure G.2 | – LP cylinder expansion | 55 |
| Figure G.3 | – Original heat balance diagram (or base line) | 60 |
| Figure G.4 | – Correction curves | 61 |
| Figure G.5 | – Pre-retrofit test | 62 |
| Figure G.6 | – Pre-retrofit test: HP cylinder replaced | 63 |
| Figure G.7 | – Pre-retrofit test: LP cylinder replaced | 64 |
| Figure G.8 | – Leaving loss curve | 65 |
| Figure G.9 | – Correction curve of heat rate due to live steam pressure | 70 |
| Figure G.10 | – Correction curve of heat rate due to thermal power | 71 |
| Figure G.11 | – Correction curve of heat rate due to exhaust pressure | 71 |
| Figure G.12 | – Correction curve of heat rate due to quality of live steam | 72 |

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------|----|
| Figure G.13 – Correction curve of heat rate for Δp of the moisture separator/reheaters | 72 |
| Figure G.14 – Correction curve of heat rate due to temperature of the reheat steam..... | 73 |
| Figure G.15 – Correction curve of heat rate due to quality of steam after the moisture separator | 73 |
| Figure G.16 – Curve of live steam pressure before the valves of the turbine as a function of thermal power..... | 74 |
| Figure G.17 – Baseline heat balance | 75 |
| Figure G.18 – Guarantee heat balance | 76 |
| Figure G.19 – Post-retrofit test re-calculated heat balance..... | 77 |
| Figure H.1 – Instrumentation for a fossil plant..... | 81 |
| Figure H.2 – Instrumentation for a nuclear plant | 92 |
| | |
| Table 1 – Maximum deviations and fluctuations in operating conditions from specified and relative data..... | 21 |
| Table 2 – Guarantee alternatives | 25 |
| Table 3 – Apportionment of unaccounted leakages | 36 |
| Table 4 – Typical effects of cylinder efficiency on heat rate..... | 43 |
| Table G.1 – Main parameters of the heat balances (Figure G.17 to Figure G.19)..... | 68 |
| Table G.2 – Comparison between guaranteed and post-test re-calculated heat balance | 68 |
| Table G.3 – Measured and corresponding calculated values from the post-test..... | 69 |
| Table G.4 – Corrections due to differences between measured and calculated values (from post re-calculated heat balance, Figure G.19)..... | 69 |
| Table G.5 – Summary of corrections | 70 |
| Table H.1 – Assumed total measured variable uncertainty for pressure, temperature and generator output..... | 78 |
| Table H.2 – Uncertainty percentage of calculated results at different flow measurement uncertainty levels for a fossil plant..... | 80 |
| Table H.3 – Uncertainty percentage of calculated results at different correlation levels for a fossil plant..... | 80 |
| Table H.4 – Heat Rate uncertainty of a fossil plant..... | 82 |
| Table H.5 – HP isentropic efficiency uncertainty of a fossil plant..... | 84 |
| Table H.6 – IP isentropic efficiency uncertainty of a fossil plant | 86 |
| Table H.7 – LP isentropic efficiency uncertainty of a fossil plant | 88 |
| Table H.8 – Uncertainty percentage of calculated results at different flow measurement uncertainty levels for a nuclear plant..... | 91 |
| Table H.9 – Uncertainty percentage of calculated results at different correlation levels for a nuclear plant..... | 91 |
| Table H.10 – Heat Rate uncertainty of a nuclear plant | 93 |
| Table H.11 – HP isentropic efficiency uncertainty of a nuclear plant | 95 |
| Table H.12 – LP isentropic efficiency uncertainty of a nuclear plant..... | 97 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RULES FOR STEAM TURBINE THERMAL ACCEPTANCE TESTS –**Part 3: Thermal performance verification tests
of retrofitted steam turbines**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. For this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publications"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60953-3 has been prepared by subcommittee WG11/MT14: Thermal Acceptance Test, of IEC technical committee 5: Steam turbines. It is an International Standard.

This second edition cancels and replaces the first edition published in 2001. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) The Reference Standard has changed from IEC 60953-2 to IEC 60953-0 and therefore all changes made in IEC 60953-0 are relevant to this revised Supplementary Standard;
- b) Further detailed guidance is given for guarantee types in Clause 4.10;
- c) Annex H – Measuring uncertainty of results has been revised to more closely align with the ISO/IEC Guide 98: Uncertainty of measurement;
- d) Annex K – Tracer technique has been deleted;
- e) Annex L – Temperature variation method has been moved to IEC 60953-0.

The text of this International Standard is based on the following documents:

| Draft | Report on voting |
|------------|------------------|
| 5/249/FDIS | 5/252/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This part of IEC 60953 is to be read in conjunction with IEC 60953-0, and the words 'verification test' are to be read in place of 'acceptance test'. IEC 60953-0 is taken as a Reference Standard.

A list of all parts in the IEC 60953 series, published under the general title *Rules for steam turbine thermal acceptance tests*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

Retrofitting steam turbines in an existing power plant frequently involves an improvement of performance. IEC 60953-0, which defines the rules for steam turbine thermal acceptance tests in power plants, does not cater for all the requirements specific to retrofit projects. It has, therefore, been deemed necessary to draw up a Supplementary Standard (this document) for guidance on the thermal acceptance tests of retrofitted steam turbines.

However, a large number of the provisions and recommendations of IEC 60953-0 are still applicable to retrofits and, therefore, in order to avoid a repetitive and bulky document, only the retrofit-specific addenda will be found in this document.

Although this document is intended to apply to the retrofit of large condensing steam turbines, it can nevertheless be used for other types and sizes of turbines to define the basis of a specific procedure to be agreed upon by the parties involved.

The rules given in this document cover all hardware change in the steam turbine equipment. Changes to other hardware components (e.g. boiler, feedwater heaters, etc.) are not covered by this document, although these changes may affect the thermodynamic cycle.

The purpose of this document is to cover the retrofit of steam turbine components which influence the efficiency of the power plant and are subject to a performance guarantee. Many different situations are likely to be encountered: for example, the replacement of steam valves, the replacement of part of the turbine blading, of a rotor, of a complete module, etc. The guarantee values will depend on the retrofit considered and are subject to agreement between the parties involved in the contract. This document helps the parties determine the most appropriate parameters that characterise the retrofit and that could be used as guaranteed values.

A major difficulty in retrofit projects is the choice of parameters to be guaranteed. Although the original manufacturer will generally favour a relative improvement guarantee, another vendor who does not necessarily know all the details of the equipment installed may prefer to have an absolute guarantee value for the retrofitted equipment. This document gives guidance on the parameters to be guaranteed. Once the guaranteed values are established, they may need to be re-evaluated after a pre-retrofit performance test. This document provides such rules required for the verification of the guaranteed values.

The many variations of possible retrofits make it difficult to cover all cases comprehensively but a few detailed examples illustrating the application of this document are presented in the annexes.

The structure and clause numbering of this document follow that of IEC 60953-0. Subclauses found in this document supersede the whole of the equivalent subclause in IEC 60953-0. Subclause numbering has been extended whenever new items have been included.

The main differences between this document and IEC 60953-0 are listed below.

Clause 1: Scope

Specifically, this document requires the definitions of new options regarding guarantees. It is possible to guarantee parameters typical of the retrofitted equipment (turbine cylinder efficiency, pressure drop in valve chest, etc.). IEC 60953-0 defines absolute guarantees that are not suitable for specifying improvements between initial and retrofitted equipment, and therefore, relative guarantee values are introduced in this document.

This document reviews the contractual provisions, which can vary from one case to another, on account of the wide range of feasible retrofits. These will be subject to an agreement between the parties involved at the time the guarantees are defined i.e. during the formulation of the contract prior to the performance of the verification tests.

Clause 3: Units, symbols, terms and definitions

This document includes new concepts and terms associated with the retrofit situation

Clause 4: Guidance on guarantees

This document includes the definition of guarantees which can be offered, either additionally or in lieu of those of IEC 60953-0. A guide matrix has been included to allow the parties involved to choose the parameters to be guaranteed, as appropriate to the project.

The guarantees provided by the manufacturer can be

a) Guarantees of absolute values

- Turbine thermal efficiency or heat rate;
- turbine thermodynamic efficiency or steam rate or power output at specified steam flow conditions;
- main steam flow-passing capacity and/or maximum power output;
- internal efficiency of turbine sections.

b) Guarantees of relative values

- Improvement of turbine thermal efficiency or heat rate;
- improvement of thermodynamic efficiency or steam rate or power output at specified steam flow;
- improvement of main steam flow-passing capacity and/or maximum power output;
- improvement of internal efficiency of turbine sections.

Clause 4: Guiding principles

The majority of the guiding principles contained in IEC 60953-0 are also applicable to the retrofit situation. Amendments or addenda to this clause mainly cover the precautions to be taken when tests are to be run before and after the retrofit, and address the reference to be taken when a guarantee on improvement in performance is offered.

Special attention is directed to the problems of isolation of the cycle, and allowable deviations of measured quantities which can greatly affect the interpretation of results.

Clause 5: Measuring techniques and measuring instruments

In the case of retrofit projects, rigid rules cannot be formulated for measuring techniques and instruments. The instruments are to be chosen to suit the requirements of the installation and the guarantee value to be verified. Guidance is given in Annex H on the sensitivity of the parameters guaranteed to the accuracy of the individual measurements, so that the most appropriate choice of instrumentation can be made.

Since flow is among the most important measurements, this document gives guidance on the necessity to fit additional flow-measuring devices. Methods which allow simultaneous measurement and comparison of primary flows are recommended in this document. The use of flow measurement methods using tracers can be an alternative if the method has shown to be reliable and has been agreed by the parties to the test.

Clause 6: Evaluation of tests

This document gives details of the evaluation of additional guarantees applicable to retrofit projects. Specific rules are also given for unaccounted leakages in retrofit applications.

Clause 7: Correction of test results and comparison with guarantee

The methods of correction defined in IEC 60953-0 are also applicable to this document but are supplemented by specific rules which apply to the new types of guarantee. For delayed testing, guidance is given on ageing considerations.

This clause also covers the validation of the performance values which are used as a reference for determining improvement guarantee values: an amendment to the guarantee value is acceptable when the pre-retrofit tests have revealed that the actual condition of the turbine undergoing retrofit is different from the specified condition.

The retrofit of the steam turbine, or any part of it, may have consequences on the balance of the plant (feedheaters, condenser, boiler). If the retrofit affects conditions beyond the interface, then the manufacturer may be required to indicate the consequences of the modification on adjacent equipment items.

Clause 8: Measuring uncertainty

This clause of IEC 60953-0 is supplemented by provisions for special cases encountered in retrofit projects in Annex G and Annex H. The examples can be used as reference basis.

Annexes:

Annexes A to E of IEC 60953-0:2022 apply.

In this document, three new annexes (Annex F to Annex H) are added.

Annex F deals with uncertainties for retrofit applications and completes the information given in Annex D of IEC 60953-0:2022.

Annex G and Annex H give examples of performance and uncertainty calculations for several retrofit applications, within fossil-fuel and nuclear power plants.

Matters to be considered in the contract:

Some matters in these rules have to be considered at an early stage. Deviations are to be identified and agreement reached between the parties before signing the contract. Such matters are dealt with in the following subclauses:

| Clause (subclause) | Paragraph | Remark |
|--------------------|----------------|--------------------------------------------------------|
| Introduction | 6 | Specific procedure and guarantee value |
| 1.2 | 2 | Guarantee definition |
| 4.10 | All paragraphs | |
| 4.1 | 1 and 4 | |
| 4.3.1 | 3 | |
| 7.1.1 | Last paragraph | |
| 7.3 | – | Guarantee comparison |
| 7.9.4 | – | Deterioration of performance of retrofitted components |

RULES FOR STEAM TURBINE THERMAL ACCEPTANCE TESTS –

Part 3: Thermal performance verification tests of retrofitted steam turbines

1 Scope

1.1 General

This part of IEC 60953 establishes a Supplementary Standard for thermal verification tests of retrofitted steam turbines.

The rules given in this document follow the guidance given in IEC 60953-0, but contain amendments and supplements regarding guarantees and verification of the guarantees by thermal acceptance tests on retrofitted steam turbines.

General principles for the preparation, performance, evaluation, comparison with guaranteed values and the determination of the measurement uncertainties of verification tests are given in this document.

This document is applicable only when the retrofit involves some hardware change in the steam turbine equipment. Conversely, any modification on the cycle or any retrofit of other equipment of the power plant (e.g. boiler, feedwater heaters, etc.) is not covered by this document.

1.2 Object

The purpose of this document is to establish appropriate guaranteed parameters, to verify these guarantees and to determine measurement uncertainty.

The guarantees with their provisions should be formulated completely and without contradiction (see 3.4 of IEC 60953-0:2022 and 3.5 of this document). The verification tests may also include such measurements as are necessary for corrections according to the conditions of the guarantee and checking of the results.

1.3 Matters to be considered in the contract

Subclause 1.3 of IEC 60953-0:2022 applies.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60953-0:2022, *Rules for steam turbine thermal acceptance tests – Part 0: Wide range of accuracy for various types and sizes of turbines.*