

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear power plants – Control rooms – Supplementary control room for reactor shutdown without access to the main control room

Centrales nucléaires de puissance – Salles de commande – Salle de commande supplémentaire pour l'arrêt des réacteurs sans accès à la salle de commande principale



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear power plants – Control rooms – Supplementary control room for reactor shutdown without access to the main control room

Centrales nucléaires de puissance – Salles de commande – Salle de commande supplémentaire pour l'arrêt des réacteurs sans accès à la salle de commande principale

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.120.20

ISBN 978-2-8322-3203-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions	8
4 Abbreviations	9
5 Design principles	9
5.1 General.....	9
5.2 Main objectives	10
5.3 Safety principles	11
5.3.1 Design basis and design extension conditions	11
5.3.2 Functionality and qualification	12
5.3.3 Accessibility and operator transfer time	12
5.3.4 Control transfer, control prioritisation and security	12
5.3.5 Operational considerations	13
5.4 Human factors engineering principles	14
6 Design process.....	14
7 Functional design	15
7.1 General.....	15
7.2 Human factors.....	15
7.3 Location and access route.....	15
7.4 SCR environment.....	16
7.5 Space and configuration.....	16
7.6 Information and control equipment.....	17
7.7 Communication systems.....	17
7.8 Other equipment	18
7.9 Testing and inspection	18
8 System verification and validation	18
Annex A (informative) Assessment of safe transfer time window	20
Bibliography	21

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**NUCLEAR POWER PLANTS – CONTROL ROOMS –
SUPPLEMENTARY CONTROL ROOM FOR REACTOR SHUTDOWN
WITHOUT ACCESS TO THE MAIN CONTROL ROOM**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60965 has been prepared by subcommittee 45A: Instrumentation, control and electrical systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

This third edition cancels and replaces the second edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) requirements associated with regular testing of the supplementary control room (SCR);
- b) requirements to assess the time available during which the reactor will be safe but unattended, in order to move from the main control room (MCR) to the SCR and for the SCR to become operational;
- c) reference to SSR-2/1 which includes the following new requirements:

- 1) the SCR should be functionally (as well as physically and electrically) separate from the MCR,
 - 2) consideration shall be given to the provision of shielding against radioactivity on the access paths to the SCR;
- d) reference to DS431, the revision of NS-G-1.3, including the following new requirements:
- 1) to implement at least two diverse methods for communication with a set of predefined locations,
 - 2) to implement features to support monitoring of trends in key plant parameters;
- e) requirements for the role, functional capability and robustness of the SCR in design extension conditions;

The text of this standard is based on the following documents:

FDIS	Report on voting
45A/1060/FDIS	45A/1078/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under <http://webstore.iec.ch> in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

a) Technical background, main issues and organization of the standard

IEC 60965:1989 was developed to provide requirements relevant to the design of NPP supplementary control points for reactor shutdown without access to the main control room. The first edition of IEC 60965 has been used extensively within the nuclear industry. It was however recognized in 2007 that technical developments especially those which were based on software technology should be incorporated. It was also recognized that the relationships with the standard for the main control room (i.e. IEC 60964) and the derivative standards to that standard (i.e. IEC 61227, IEC 61771, IEC 61772, IEC 61839, and IEC 62241) should be clarified and conditioned. In 2009 the second edition of IEC 60965 was published.

In June 2013, during the Moscow meeting, WG A8 experts recommended a limited revision be launched to take into account the lessons learned from TEPCO Fukushima Daiichi accident and some comments formulated during the circulation of the FLIS of the published second edition. In the course of development of this revision, the title of the standard was amended to refer to Supplementary Control 'Room' for consistency with IAEA SSR-2/1.

This IEC standard specifically focuses on the functional design process of the supplementary control room of an NPP. It is intended that the standard be used by NPP designers, design authorities, vendors, utilities, and by licensors.

b) Situation of the current standard in the structure of the IEC SC 45A standard series

IEC 60965 is the third level IEC SC 45A document tackling the issue of the design of a supplementary control room.

IEC 60965 is to be read in association with IEC 60964 for the design of the main control room (including the derivative standards mentioned above) which is the appropriate IEC SC 45A document providing guidance on operator controls, verification and validation of design, application of visual display units, functional analysis and assignment, and alarm functions and presentation.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this Standard

The purpose of this standard is to provide functional design requirements to be used in the design of the supplementary control room of a nuclear power plant to meet safety requirements.

This standard is intended for application to a supplementary control room whose conceptual design is initiated after the publication of this standard. The recommendations of the standard may be used for refits, upgrades and modifications.

Aspects for which special recommendations have been provided in this Standard, in accordance with IAEA safety standards, are:

- definition of the MCR and plant design bases for which the supplementary control room are to be used;
- access by station staff to the supplementary control room in such emergencies;
- assurance for the station staff that the environment in the supplementary control room is safe when it is to be used;
- provision of information in the supplementary control room on the state of the reactor critical functions;
- transfer of control and indication functions from the main control room to the supplementary control room in emergencies;
- independence and separation of the cabling used by the supplementary control room from that used by the main control room;
- assurance that a safe state has been reached using the supplementary control room;

- communication facilities between the supplementary control room and to the station management.

To ensure that the Standard will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level document of the IEC SC 45A standard series is IEC 61513. It provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 61513 structures the IEC SC 45A standard series.

IEC 61513 refers directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation of systems, defence against common cause failure, software aspects of computer-based systems, hardware aspects of computer-based systems, and control room design. The standards referenced directly at this second level should be considered together with IEC 61513 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 are standards related to specific equipment, technical methods, or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45A standard series corresponds to the Technical Reports which are not normative.

IEC 61513 has adopted a presentation format similar to the basic safety publication IEC 61508 with an overall safety life-cycle framework and a system life-cycle framework. Regarding nuclear safety, it provides the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector, regarding nuclear safety. In this framework IEC 60880 and IEC 62138 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 refers to ISO as well as to IAEA GS-R-3, IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

The IEC SC 45A standards series consistently implements and details the principles and basic safety aspects provided in the IAEA code on the safety of NPPs and in the IAEA safety series, in particular the Requirements SSR-2/1, establishing safety requirements related to the design of Nuclear Power Plants, and the Safety Guide NS-G-1.3 dealing with instrumentation and control systems important to safety in Nuclear Power Plants. The terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

NOTE It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards) international or national standards would be applied, that are based on the requirements of a standard such as IEC 61508.

NUCLEAR POWER PLANTS – CONTROL ROOMS – SUPPLEMENTARY CONTROL ROOM FOR REACTOR SHUTDOWN WITHOUT ACCESS TO THE MAIN CONTROL ROOM

1 Scope

This International Standard establishes requirements for the Supplementary Control Room provided to enable the operating staff of nuclear power plants to shut down the reactor, where previously operating, and maintain the plant in a safe shut-down state in the event that control of the safety functions can no longer be exercised from the Main Control Room, due to unavailability of the Main Control Room or its facilities. The design has to ensure that the Supplementary Control Room is protected against the hazards, including any localised extreme hazards, leading to the unavailability of the Main Control Room.

The standard also establishes requirements for the selection of functions, the design and organisation of the human-machine interface, and the procedures which shall be used systematically to verify and validate the functional design of the supplementary control room.

It is assumed that supplementary control room provided for shutdown operations from outside the main control room would be unattended during normal plant conditions other than for periodic testing. The requirements reflect the application of human engineering principles as they apply to the human-machine interface during such periodic testing and during abnormal plant conditions.

This standard does not cover special emergency response facilities (e.g. a technical support centre) or facilities provided for radioactive waste handling. Detailed equipment design is also outside the scope of the standard.

This standard follows the principles of IAEA Specific Safety Requirements SSR-2/1 and IAEA Safety Guide NS-G-1.3.

The purpose of this standard is to provide functional design requirements to be used in the design of the supplementary control room of a nuclear power plant to meet safety requirements.

This standard is intended for application to a supplementary control room whose conceptual design is initiated after the publication of this standard. If it is desired to apply it to existing plants or designs, special care must be taken to ensure a consistent design basis. This relates, for example, to factors such as the consistency between the supplementary control room and the main control room, the ergonomic approach, the automation level and the information technology, and the extent of modifications to be implemented in I&C systems.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60709, *Nuclear power plants – Instrumentation and control systems important to safety – Separation*

IEC 60964:2009, *Nuclear power plants – Control rooms – Design*