

**INTERNATIONAL  
STANDARD**

**IEC  
61131-2**

Third edition  
2007-07

---

---

**Programmable controllers –**

**Part 2:  
Equipment requirements and tests**



Reference number  
IEC 61131-2:2007(E)



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00

**INTERNATIONAL  
STANDARD**

**IEC  
61131-2**

Third edition  
2007-07

---

---

**Programmable controllers –**

**Part 2:  
Equipment requirements and tests**



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE **XF**

*For price, see current catalogue*

## CONTENTS

FOREWORD.....	10
INTRODUCTION.....	12
1 General.....	13
1.1 Scope and object.....	13
1.2 Compliance with this standard.....	14
1.3 Normative references.....	14
2 Type tests.....	17
2.1 Equipment to be tested (equipment under test/EUT).....	17
2.2 Special features for immunity and EMC tests.....	18
2.3 Withstand test conditions.....	19
2.4 Verification procedure.....	19
2.5 Requirements for test programmes and proper functioning verification procedures (PFVPs) to be provided by the manufacturer.....	19
2.6 General conditions for tests.....	20
3 Terms and definitions.....	20
4 Normal service conditions and requirements.....	28
4.1 Climatic conditions and requirements.....	28
4.1.1 Operating ambient air temperature.....	28
4.1.2 Relative humidity.....	28
4.1.3 Altitude.....	28
4.1.4 Pollution degree.....	29
4.2 Mechanical service conditions and requirements.....	29
4.2.1 Vibrations.....	29
4.2.2 Shock.....	29
4.2.3 Free falls (portable and hand-held equipment).....	30
4.3 Transport and storage conditions and requirements.....	30
4.3.1 Temperature.....	30
4.3.2 Relative humidity.....	30
4.3.3 Altitude.....	30
4.3.4 Free falls (PLC units in manufacturer's original packaging).....	31
4.3.5 Other conditions.....	31
4.4 Electrical service conditions and requirements.....	31
4.4.1 AC and d.c. equipment power supply.....	31
4.4.2 Overvoltage category, control of transient overvoltages.....	31
4.4.3 Non-periodic overvoltages.....	31
4.5 Special conditions and requirements.....	31
5 Functional requirements.....	31
5.1 Functional power supply and memory back-up requirements.....	33
5.1.1 AC and d.c. power supply.....	33
5.1.2 Memory back-up.....	34
5.2 Digital I/Os.....	34
5.2.1 Digital inputs (current sinking).....	35
5.2.2 Digital outputs for alternating currents (current sourcing).....	37
5.2.3 Digital outputs for direct current (current sourcing).....	40

5.3	Analogue I/Os .....	41
5.3.1	Analogue inputs.....	41
5.3.2	Analogue outputs.....	41
5.4	Communication interface requirements.....	42
5.5	Main processing unit(s) and memory(ies) of the PLC-system requirements .....	42
5.6	Remote input/output stations (RIOSs) requirements .....	42
5.7	Peripherals (PADTs, TEs, HMIs) requirements .....	42
5.8	PLC-system self-tests and diagnostics requirements .....	43
5.9	Functional earthing.....	43
5.10	Mounting requirements .....	43
5.11	General marking requirements .....	44
5.11.1	Functional identifications .....	44
5.11.2	Module location and module identifications.....	44
5.11.3	Functional earth terminals markings .....	44
5.12	Requirements for normal service and functional type tests and verifications.....	44
5.13	Requirements for information on normal service and function.....	44
6	Normal service and functional type tests and verifications .....	44
6.1	Climatic tests .....	44
6.2	Dry-heat and cold withstand tests.....	45
6.2.1	Variation of temperature .....	46
6.2.2	Cyclic damp heat withstand test .....	47
6.3	Mechanical tests .....	48
6.3.1	Vibration (type test associated with normal service conditions).....	48
6.3.2	Shock (type test associated with normal service conditions).....	48
6.3.3	Free fall (type test associated with normal service conditions).....	49
6.3.4	Free fall (type test associated with transport and storage conditions) .....	49
6.3.5	Plugging/unplugging of removable units.....	49
6.4	Verification of special functional requirements for power ports and memory back-up – Special immunity tests for power ports .....	49
6.4.1	Verification of functional equipment power input port (a.c. or d.c.).....	50
6.4.2	External energy supply variation tests (immunity tests).....	51
6.4.3	Improper equipment power supply connection tests.....	54
6.4.4	Verification of memory back-up requirements .....	55
6.5	Verification of input/output requirements .....	55
6.5.1	General .....	55
6.5.2	Verification of digital inputs.....	56
6.5.3	Verification of digital outputs .....	56
6.5.4	Verification of analogue I/Os.....	57
6.6	Verification of communication interface requirements .....	58
6.7	Verification of MPU requirements .....	58
6.8	Verification of remote I/O stations .....	59
6.8.1	Response time test.....	59
6.8.2	Loss of communication test .....	59
6.8.3	Verification of other requirements .....	59
6.9	Verification of peripheral (PADTs, TEs, HMIs) requirements.....	59
6.10	Verification of PLC-system self-tests and diagnostics .....	59
6.11	Verification of markings and manufacturer's documentation.....	59
7	General information to be provided by the manufacturer.....	60
7.1	Information on type and content of documentation.....	60

7.1.1	Information on catalogues and datasheets	60
7.1.2	Information on user's manuals	60
7.1.3	Information on technical documentation	60
7.2	Information on compliance with this standard	60
7.3	Information on reliability	61
7.4	Information on other conditions	61
7.5	Information on shipping and storage	61
7.6	Information on a.c. and d.c. power supply	61
7.7	Information on digital inputs (current sinking)	61
7.8	Information on digital outputs for alternating currents (current sourcing)	62
7.9	Information on digital outputs for direct current (current sourcing)	63
7.10	Information on analogue inputs	63
7.10.1	Information on analogue input static characteristics	63
7.10.2	Information on analogue input dynamic characteristics	63
7.10.3	Information on analogue input general characteristics	64
7.10.4	Information on analogue input miscellaneous characteristics	64
7.11	Information on analogue outputs	64
7.11.1	Information on analogue output static characteristics	64
7.11.2	Information on analogue output dynamic characteristics	64
7.11.3	Information on analogue output general characteristics	65
7.11.4	Information on analogue output miscellaneous characteristics	65
7.12	Information on communication interfaces	65
7.13	Information on main processing unit(s) and memory(ies) of the PLC-system	65
7.14	Information on remote input/output stations (RIOs)	66
7.15	Information on peripherals (PADTs, TEs, PMIs)	67
7.16	Information on self-tests and diagnostics	67
8	Electromagnetic compatibility (EMC) requirements	67
8.1	General	67
8.2	Emission requirements	68
8.2.1	General requirements for emission	68
8.2.2	Emission limits in the low-frequency range	68
8.2.3	Emission limits in the high-frequency range	68
8.3	EMC immunity requirements	68
8.3.1	General	69
8.3.2	Performance criteria	70
8.3.3	Immunity levels	71
8.3.4	Voltage dips and interruptions power ports	73
8.4	Requirements for EMC tests and verifications	74
8.5	Requirements for information on EMC	74
9	Electromagnetic compatibility (EMC) type tests and verifications	74
9.1	Electromagnetic compatibility-related tests	74
9.2	Test environment	75
9.3	Measurement of radiated interference	75
9.4	Measurement of conducted interference	75
9.5	Electrostatic discharge	76
9.6	Radiofrequency electromagnetic field – Amplitude modulated	76
9.7	Power-frequency magnetic fields	77
9.8	Fast transient bursts	77
9.9	High-energy surges	78

9.10	Conducted radiofrequency interference .....	78
9.11	Damped oscillatory wave (for zone C only) .....	79
9.12	Voltage dips and interruptions .....	79
10	Electromagnetic compatibility (EMC) information to be provided by the manufacturer .....	80
11	Safety requirements .....	80
11.1	Equipment types and protection .....	80
11.1.1	Open PLC-system equipment .....	80
11.1.2	Enclosed PLC-system equipment .....	80
11.2	Protection against electrical shock .....	82
11.2.1	Permissible limits for accessible parts .....	82
11.2.2	Dielectric strength .....	83
11.2.3	Ports requiring protection .....	83
11.2.4	Protection in normal condition .....	84
11.2.5	Protection in single-fault condition .....	85
11.2.6	Secondary circuits which do not pose a risk of electrical shock .....	86
11.3	Protection against the spread of fire .....	87
11.3.1	Limited power circuits .....	87
11.4	Clearance and creepage distances requirements .....	88
11.4.1	Clearances relating to overvoltage category II .....	89
11.4.2	Clearances for micro-environment where voltages are known and controlled .....	90
11.4.3	Creepage distances for basic and supplementary insulation .....	91
11.4.4	Creepage distances for double/reinforced insulation .....	94
11.4.5	Creepage for field-wiring terminals .....	94
11.5	Flame-retardant requirements for non-metallic materials .....	94
11.5.1	Non-metallic enclosure material .....	94
11.5.2	Non-metallic material supporting live parts .....	94
11.5.3	Non-metallic parts .....	95
11.5.4	Decorative and labelling materials .....	95
11.5.5	Internal wiring or interconnection cables .....	95
11.6	Temperature limits .....	95
11.7	Enclosures .....	95
11.7.1	Open equipment .....	96
11.7.2	Enclosed equipment .....	96
11.8	Operator-accessible hazardous live field-wiring terminal constructional requirements .....	96
11.9	Provisions for protective earthing .....	96
11.9.1	Protective earthing requirements for enclosed equipment .....	97
11.9.2	Protective earthing requirements for open equipment .....	97
11.10	Wiring .....	98
11.10.1	Internal wiring .....	98
11.10.2	Interconnection wiring .....	98
11.10.3	Equipment power input cord .....	98
11.11	Switching devices .....	99
11.12	Components related to safety requirements .....	99
11.13	Battery requirements .....	99
11.14	Maximum voltage and minimum voltage .....	99
11.15	Markings and identification .....	99
11.15.1	External wiring terminals identification .....	100

11.15.2	Live parts .....	100
11.15.3	Protective earth terminals markings.....	100
11.15.4	Enclosed Class II equipment .....	100
11.15.5	Equipment supplied by SELV/PELV.....	101
11.15.6	Rating information .....	101
11.16	Requirements for safety type tests and verifications .....	101
11.17	Requirements for safety routine tests and verifications .....	101
11.17.1	Requirement for dielectric strength verification .....	101
11.17.2	Requirement for protective earthing verification.....	101
11.18	Requirements for information on safety.....	101
12	Safety type tests and verifications .....	102
12.1	Safety-related mechanical tests and verifications .....	102
12.1.1	Impact withstand test.....	102
12.1.2	Operator accessibility tests.....	103
12.1.3	General examination of openings.....	103
12.1.4	Wire flexing test.....	104
12.1.5	Temperature test .....	104
12.1.6	Protective coating test .....	104
12.1.7	Rigidity test .....	104
12.1.8	Clearance and creepage verification.....	105
12.1.9	Field-wiring terminals constructional verification.....	105
12.2	Safety-related electrical tests .....	105
12.2.1	Dielectric withstand verification test.....	105
12.2.2	Protective earthing continuity test .....	107
12.2.3	Stored energy injury risk test .....	108
12.2.4	Overload test.....	108
12.2.5	Endurance test .....	108
12.3	Single-fault condition tests .....	109
12.3.1	Single-fault condition – General.....	109
12.3.2	Single-fault condition – Breakdown of components test .....	109
12.3.3	Single-fault condition – Protective impedance test.....	110
12.3.4	Single-fault condition – isolation transformers test.....	110
12.4	Limited power circuits test.....	110
13	Safety routine tests .....	110
13.1	Dielectric withstand test .....	110
13.2	Dielectric withstand verification test.....	111
13.3	Protective earthing test .....	111
14	Safety information to be provided by the manufacturer .....	111
14.1	Information on evaluation of enclosures for open equipment (power dissipation).....	112
14.2	Information on mechanical terminal connection .....	112
Annex A (informative)	Illustration of PLC-system hardware definitions .....	113
Annex B (informative)	Digital input standard operating range equations.....	114
Annex C (normative)	Test tools.....	115
Annex D (informative)	Zone C – EMC immunity levels .....	118
Annex E (informative)	Overvoltage example.....	120
Bibliography	.....	122

Figure 1 – EUT configurations .....	18
Figure 2 – Typical interface/port diagram of a PLC-system .....	32
Figure 3 – I/O Parameters.....	35
Figure 4 – U-I operation regions of current-sinking inputs .....	36
Figure 5 – Temporary overload waveform for digital a.c. outputs.....	38
Figure 6 – Temporary overload waveform for digital d.c. outputs.....	40
Figure 7 – Third harmonic immunity test .....	51
Figure 8 – Gradual shut-down/start-up test .....	52
Figure 9 – Fast supply voltage variation test .....	53
Figure 10 – Slow supply voltage variation test .....	54
Figure 11 – EMC immunity zones.....	69
Figure 12 – Impact withstand test procedure.....	102
Figure 13 – Dielectric withstand test procedures .....	107
Figure A.1 – Programmable controller system (PLC-system).....	113
Figure C.1 – Jointed test finger.....	115
Figure C.2 – 15 mm × 3 mm test pin .....	116
Figure C.3 – 100 mm × 4 mm test pin .....	116
Figure C.4 – 100 mm × 3 mm test pin .....	117
Figure E.1 – Creepage distances of circuits where returning peak voltages are generated .....	120
Table 1 – General conditions for tests.....	20
Table 2 – Operating ambient air temperature of PLC-systems.....	28
Table 3 – Sinusoidal vibrations service conditions for PLC-systems.....	29
Table 4 – Free fall on concrete floor for portable and hand-held equipment .....	30
Table 5 – Free fall on concrete floor in manufacturer's original packaging .....	31
Table 6 – Rated values and operating ranges of incoming power supply.....	33
Table 7– Voltage interruptions (functional requirements).....	34
Table 8 – Standard operating ranges for digital inputs (current sinking) .....	37
Table 9 – Rated values and operating ranges for current sourcing digital a.c. outputs .....	38
Table 10 – Rated values and operating ranges (d.c.) for current-sourcing digital d.c. outputs .....	40
Table 11 – Rated values and impedance limits for analogue inputs.....	41
Table 12 – Rated values and impedance limits for analogue outputs.....	41
Table 13 – Dry-heat and cold withstand tests.....	45
Table 14 – Change of temperature, withstand and immunity tests .....	46
Table 15 – Cyclic (12 + 12) damp-heat test.....	47
Table 16 – Immunity vibration test .....	48
Table 17 – Immunity shock test.....	48
Table 18 – Free-fall immunity/withstand tests (portable and hand-held equipment) .....	49
Table 19 – Free-fall withstand test (units within manufacturer's original packaging) .....	49
Table 20 – Insertion/withdrawal of removable units .....	49
Table 21 – Voltage ripple and frequency range immunity test.....	50

Table 22 – Third harmonic immunity test.....	50
Table 23 – Gradual shut-down/start-up test .....	52
Table 24 – Supply voltage variation tests.....	53
Table 25 – Voltage interruptions immunity test (Functional tests).....	54
Table 26 – Back-up duration withstand test.....	55
Table 27 – Change of energy source test.....	55
Table 28 – Overload and short-circuit tests for digital outputs .....	57
Table 29 – Emission limits .....	68
Table 30 – EMC immunity zones, example regarding surge .....	70
Table 31 – Criteria to prove the performance of a PLC-system against EMC disturbances .....	70
Table 32 – Enclosure port tests, Zones A and B.....	71
Table 33 – Conducted immunity tests, Zone B .....	72
Table 34 – Conducted immunity tests, zone A.....	73
Table 35 – Voltage dips and interruptions (EMC requirements).....	74
Table 36 – Radiated emission measurement.....	75
Table 37 – Conducted emission measurement.....	75
Table 38 – Electrostatic discharge immunity test.....	76
Table 39 – Radiated electromagnetic field immunity test.....	76
Table 40 – Power-frequency magnetic field immunity test.....	77
Table 41 – Fast transient burst immunity test.....	77
Table 42 – High-energy surge immunity test .....	78
Table 43 – Conducted r.f. immunity test.....	78
Table 44 – Damped oscillatory wave immunity test.....	79
Table 45 – Voltage dips and interruptions immunity test (EMC tests).....	79
Table 46 – Shock protection requirements for open and enclosed equipment.....	84
Table 47 – Limits of output current and output power for inherently limited power sources.....	88
Table 48 – Limits of output current, output power and ratings for over-current protective devices for non-inherently limited power sources.....	88
Table 49 – Minimum clearances in air corresponding to overvoltage category II conditions (except for field wiring terminals) for basic/supplementary insulation.....	89
Table 50 – Minimum clearances in air corresponding to overvoltage category II conditions (except for field wiring terminals) for double /reinforced insulation .....	90
Table 51 – Minimum clearances in air at field-wiring terminals .....	90
Table 52 – Minimum clearances in air for micro-environment where the voltages are known and controlled.....	91
Table 53 – Classification of material group according to comparative tracking index (CTI).....	91
Table 54 – Minimum creepage distances for other than printed circuit boards (1).....	92
Table 55 – Minimum creepage distances for printed circuit boards (1), (6), (9) (basic and supplementary insulation) .....	93
Table 56 – Minimum creepage distances related to recurring peak voltages on printed wiring boards without protective coating (1) (pollution degrees 1 and 2).....	94
Table 57 – Temperature limits .....	95
Table 58 – Impact withstand test (1) .....	102

Table 59 – Operator accessibility tests (1) .....	103
Table 60 – Dielectric withstand voltages for impulse a.c. power-frequency and d.c. tests for basic/supplementary insulation (5) .....	106
Table 61 – Dielectric withstand voltages for impulse a.c. power frequency and d.c. tests for double/reinforced insulation (5) .....	107
Table 62 – Overload test circuit values .....	108
Table 63 – Endurance test circuit values.....	109
Table 64 – Routine dielectric withstand test (5).....	111
Table D.1 – Enclosure port tests, Zone C.....	118
Table D.2 – Conducted immunity tests, Zone C.....	119

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**PROGRAMMABLE CONTROLLERS –****Part 2: Equipment requirements and tests**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61131-2 has been prepared by subcommittee 65B: Devices, of IEC technical committee 65: Industrial-process measurement and control.

This third edition of IEC 61131-2 cancels and replaces the second edition published in 2003 and constitutes a technical revision.

This third edition includes the following significant technical changes with respect to the previous edition.

- a) DC power port requirements have been moved from Clause 8 to Clause 5.
- b) Correction of the following tests of Clause 6:
  - voltage range test;
  - fast supply voltage variation test;
  - slow supply voltage variation test;
  - gradual shut-down/start-up test.
- c) Change of EMC requirements in Clause 8:

- requirements for radiofrequency interference in Table 33 changed from 3 V to 10 V for Zone B equipment;
  - reference to EMC basic standards with the last version;
  - reference to generic standards 61000-6-x;
  - cable length aligned to generic standards.
- d) Correction of the following tests in Clause 9:
- voltage dips and interruptions – power port type tests and verifications.
- e) New organization of Clause 11:
- equipment types and protection;
  - open PLC-system equipment;
  - enclosed PLC-system equipment:
    - Class I equipment;
    - Class II equipment;
    - Class III equipment;
  - protection against electric shock;
  - definition of secondary circuits which do not pose a risk of electric shock:
    - Class 2 circuit;
    - limited voltage/current circuit;
    - limited voltage circuit;
    - limited energy circuit  $\leq 30$  V a.c. or 42,2 V peak;
    - limited impedance circuit;
  - protection against the spread of fire within limited power circuits;
  - protective earthing requirements for enclosed equipment;
  - minor improvements in different subclauses;
  - impulse test only for verification of clearances.

The text of this standard is based on the following documents:

FDIS	Report on voting
65B/623/FDIS	65B/636/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all parts of the IEC 61131 series, under the general title *Programmable controllers*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

## INTRODUCTION

IEC 61131-2 is part of a series of standards on programmable controllers and the associated peripherals and should be read in conjunction with the other parts of the series.

Where a conflict exists between this and other IEC standards (except basic safety standards), the provisions of this standard should be considered to govern in the area of programmable controllers and their associated peripherals.

Compliance with IEC 61131-2 cannot be claimed unless the requirements of 7.2 are met.

Service and physical environment requirements are specified in Clause 4. Functional requirements are specified in Clause 5. Electromagnetic compatibility requirements are specified in Clause 8. Safety requirements are specified in Clause 11.

Terms of general use are defined in IEC 61131-1. More specific terms are defined in each part.

## PROGRAMMABLE CONTROLLERS –

### Part 2: Equipment requirements and tests

#### 1 General

##### 1.1 Scope and object

This part of IEC 61131 specifies requirements and related tests for programmable controllers (PLCs) and their associated peripherals (for example, programming and debugging tools (PADTs), human-machine interfaces (HMIs), etc.) which have as their intended use the control and command of machines and industrial processes.

PLCs and their associated peripherals are intended to be used in an industrial environment and may be provided as open or enclosed equipment. If a PLC or its associated peripherals are intended for use in other environments (light industrial, commercial, residential), then the specific requirements, standards and installation practices for those other environments should be additionally applied to the PLC and its associated peripherals.

This standard also applies to any products performing the function of PLCs and/or their associated peripherals.

Equipment covered in this standard is intended for use in overvoltage category II (IEC 60664-1) in low-voltage installations, where the rated equipment supply voltage does not exceed a.c. 1 000 V r.m.s. (50/60 Hz), or d.c. 1 500 V. (If PLCs or their associated peripherals are applied in overvoltage category III installations, then additional analysis will be required to determine the suitability of the equipment for those applications.)

This standard does not deal with the functional safety or other aspects of the overall automated system. PLCs, their application programme and their associated peripherals are considered as components of a control system.

Since PLCs are component devices, safety considerations for the overall automated system including installation and application are beyond the scope of this standard. Refer to IEC 60364-1 or applicable national/local regulations for electrical installation and guidelines.

However, PLC safety as related to electric shock and fire hazards, electrical interference immunity and error detecting of the PLC-system operation (such as the use of parity checking, self-testing diagnostics, etc.), are addressed.

The object of this standard is

- to establish the definitions and identify the principal characteristics relevant to the selection and application of PLCs and their associated peripherals;
- to specify the minimum requirements for functional, electrical, mechanical, environmental and construction characteristics, service conditions, safety, EMC, user programming and tests applicable to PLCs and the associated peripherals.

This standard also specifies

- a) service, storage and transportation requirements for PLCs and their associated peripherals (Clause 4);
- b) functional requirements for PLCs and their associated peripherals (Clause 5);
- c) EMC requirements for PLCs and their associated peripherals (Clause 8);