

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 3-21: Data-link layer service definition – Type 2 elements**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - webstore.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 3-21: Data-link layer service definition – Type 21 elements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.040.40; 35.100.20; 35.110

ISBN 978-2-8322-6790-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 Overview.....	8
1.2 Specifications	8
1.3 Conformance	8
2 Normative references	9
3 Terms, definitions, symbols, abbreviations, and conventions	9
3.1 Reference model terms and definitions	9
3.2 Service convention terms and definitions	11
3.3 Common data-link service terms and definitions	12
3.4 Additional Type 21 data-link specific definitions	15
3.5 Common symbols and abbreviations	15
3.6 Additional Type 21 symbols and abbreviations	16
3.7 Common conventions.....	16
3.8 Additional Type 21 conventions.....	17
4 Data-link layer services and concepts.....	17
4.1 General.....	17
4.1.1 Overview	17
4.1.2 Overview of full duplex flow control.....	17
4.1.3 Types and classes of DL-layer service.....	18
4.2 Detailed description of the data service.....	21
4.2.1 General	21
4.2.2 Sequence of primitives	21
4.2.3 Transmit/receive data	22
4.3 Detailed description of the sporadic data service	23
4.3.1 General	23
4.3.2 Sequence of Primitive.....	24
4.3.3 Transmit/receive sporadic data	24
4.4 Detailed description of network control message service.....	25
4.4.1 General	25
4.4.2 Sequence of Primitives	25
4.4.3 Transmit/receive network control message	25
5 Data-link management services	28
5.1 General.....	28
5.2 Data link management service (DLMS) facilities.....	28
5.3 Data link management service (DLMS)	28
5.3.1 Overview	28
5.3.2 Reset.....	29
5.3.3 Set-value	29
5.3.4 Get-value.....	29
5.3.5 SAP-allocation.....	29
5.3.6 SAP-deallocation	29
5.3.7 Get-SAP information.....	29
5.3.8 Get-diagnostic-information.....	29
5.3.9 Event.....	29

5.3.10	Get-path	29
5.4	Overview of interactions	29
5.5	Detailed specification of service and interactions	31
5.5.1	Reset	31
5.5.2	Set-value	31
5.5.3	Get-value	32
5.5.4	SAP-allocation	33
5.5.5	SAP-deallocation	34
5.5.6	Get-SAP-information	35
5.5.7	Get-diagnostic-information	36
5.5.8	Event	37
5.5.9	Get-path	38
6	MAC control service	39
6.1	General	39
6.2	MAC control service	39
6.2.1	Overview	39
6.2.2	MAC-reset	39
6.2.3	MAC-forward-control	39
6.3	Overview of interactions	39
6.4	Detailed specification of service and interactions	40
6.4.1	MAC-reset	40
6.4.2	MAC-forward-control	41
7	Ph-control service	42
7.1	General	42
7.2	Ph-control service	42
7.2.1	Overview	42
7.2.2	Ph-reset	42
7.2.3	Ph-get-link-status	42
7.2.4	Ph-link-status-change	42
7.3	Overview of interaction	42
7.4	Detailed specification of service and interactions	43
7.4.1	Ph-reset	43
7.4.2	Ph-get-link-status	44
7.4.3	Ph-link-status-change	45
	Bibliography	46
	Figure 1 – Full-duplex flow control	18
	Figure 2 – Sequence diagram of DL-DATA service	18
	Figure 3 – Sequence diagram of DL-SPDATA service	19
	Figure 4 – Sequence diagram of NCM service primitive	19
	Figure 5 – Relationships of DLSAPs, DLSAP-addresses, and group DL-addresses	20
	Figure 6 – DL-DATA service	21
	Figure 7 – Sequence diagram of Reset, Set-value, Get-value, SAP-allocation, SAP-deallocation, Get-SAP information and Get-diagnostic information service primitives	30
	Figure 8 – Sequence diagram of Event service primitive	31
	Figure 9 – Sequence diagram of MAC-reset and MAC-forward-control service primitive	40
	Figure 10 – Sequence diagram of Ph-reset and Ph-get-link-status service primitive	43

Figure 11 – Sequence diagram of Ph-link-status-change service primitive	43
Table 1 – Destination DL-address	20
Table 2 – Primitives and parameters used in DL-DATA service	22
Table 3 – DL-DATA Primitives and Parameters	22
Table 4 – Primitives and parameters used in DL-SPDATA service	24
Table 5 – DL-SPDATA Primitives and Parameters	24
Table 6 – Primitives and parameters used on DL-NCM_SND service	25
Table 7 – DL-NCM_SND Primitives and Parameters	26
Table 8 – Summary of Network Control Message Type	27
Table 9 – Summary of DL-management primitives and parameters	30
Table 10 – DLM-RESET primitives and parameters	31
Table 11 – DLM-SET_VALUE primitives and parameters	32
Table 12 – DLM-GET_VALUE primitives and parameters	33
Table 13 – DLM-SAP_ALLOC primitives and parameters	34
Table 14 – DLM-SAP_DEALLOC primitives and parameters	35
Table 15 – DLM-GET_SAP_INFO primitives and parameters	35
Table 16 – DLM-GET_DIAG primitives and parameters	36
Table 17 – DLM-EVENT primitives and parameters	37
Table 18 – DLM event identifier	38
Table 19 – DLM-GET_PATH primitives and parameters	38
Table 20 – Summary of MAC control primitives and parameters	40
Table 21 – MAC-RESET primitives and parameters	40
Table 22 – MAC-FW_CTRL primitives and parameters	41
Table 23 – Summary of Ph-control primitives and parameters	42
Table 24 – Ph-RESET primitives and parameters	43
Table 25 – Ph-GET_LINK_STATUS primitives and parameters	44
Table 26 – Ph-LINK_STATUS_CHANGE primitives and parameters	45

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 3-21: Data-link layer service definition –
Type 21 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization, comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-3-21 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2010. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- added Network Control Message Type;
- miscellaneous editorial corrections.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/945/FDIS	65C/954/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://www.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

Currently in preview, click buy full version

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-21: Data-link layer service definition – Type 21 elements

1 Scope

1.1 Overview

This part of IEC 61158 provides the common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” in this context means the prioritized full-duplex collision-free time-deterministic communication, of which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the required time risks the failure of the applications requesting the actions, with attendant risk to equipment, plant, and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the Type 21 data-link layer in terms of:

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form that they take; and
- c) the interrelationships between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to:

- The Type 21 application layer at the boundary between the application and DLLs of the fieldbus reference model;
- Systems management at the boundary between the DLL and the systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this document is to specify the characteristics of conceptual DLL services suitable for time-critical communications, and to supplement the OSI Basic Reference Model in guiding the development of data link protocols for time-critical communications. A secondary objective is to provide migration paths from previously existing industrial communications protocols.

This document may be used as the basis for formal data link programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this document, including:

- a) The sizes and octet ordering of various multi-octet service parameters;
- b) The correlation of paired primitives for request and confirm, or indication and response.

1.3 Conformance

This document does not specify individual implementations or products, nor do they constrain the implementations of data-link entities within industrial automation systems.