



IEC 61158-4-13

Edition 1.0 2007-12

INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –
Part 4-13: Data-link layer protocol specification – Type 13 elements**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XC**

ICS 35.100.20; 25.040.40

ISBN 2-8318-9437-9

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 General.....	8
1.2 Specifications.....	8
1.3 Procedures.....	8
1.4 Applicability.....	9
1.5 Conformance.....	9
2 Normative references.....	9
3 Terms, definitions, symbols and abbreviations.....	9
3.1 Reference model terms and definitions.....	9
3.2 Service convention terms and definitions.....	11
3.3 Data-link service terms and definitions.....	12
3.4 Symbols and abbreviations.....	17
3.5 Common conventions.....	18
3.6 Additional conventions.....	19
4 Overview of the DL-protocol.....	19
4.1 Overview.....	19
4.2 General description.....	19
4.3 Service assumed from the PhL.....	22
4.4 DLL architecture.....	23
4.5 Local parameters and variables.....	24
5 General structure and encoding of PhIDUs and DLPDU and related elements of procedure.....	26
5.1 Overview.....	26
5.2 MA_PDU structure and encoding.....	26
5.3 Common MAC frame structure, encoding and elements of procedure.....	27
5.4 Invalid DLPDU.....	29
6 DLPDU-specific structure encoding and elements of procedure.....	29
6.1 General.....	29
6.2 Overview.....	30
6.3 Start of synchronization (SoC).....	30
6.4 Poll request (PReq).....	32
6.5 Poll response (PRes).....	34
6.6 Start of asynchronous (SoA).....	38
6.7 Asynchronous send (ASnd).....	41
7 DLE elements of procedure.....	45
7.1 Overall structure.....	45
7.2 Cycle state machine (CSM).....	45
7.3 Isochronous transmission TX/RX control (ITC).....	65
7.4 Asynchronous transmission TX/RX control (ATC).....	69
7.5 Asynchronous slot scheduler (ASS).....	73
7.6 Exception signaling (ES).....	75
7.7 NMT signaling (NS).....	77
7.8 DLL management protocol.....	78
Bibliography.....	83

Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses	14
Figure 2 – Slot communication network management.....	20
Figure 3 – Overall flow of data frames during one cycle	20
Figure 4 – Interaction of PhS primitives to DLE	22
Figure 5 – Data-link layer internal architecture	24
Figure 6 – Type 13 fieldbus DLPDU	27
Figure 7 – State transition diagram of the MNs CSM.....	51
Figure 8 – State transition diagram of MNs CSM at CSM_MS_NON_CYCLIC	53
Figure 9 – State transition diagram of MNs CSM at CSM_MS_CYCLIC.....	55
Figure 10 – State transition diagram of the CNs CSM	59
Figure 11 – State transition diagram of CNs CSM at CSM_CS_NON_CYCLIC	60
Figure 12 – State transition diagram of CNs CSM at CSM_CS_CYCLIC.....	61
Figure 13 – Multiple slot assignment.....	66
Figure 14 – State transition diagram of ITC.....	68
Figure 15 – State transition diagram of ATC	71
Figure 16 – State transition diagram of ASS	74
Figure 17 – State transition diagram of ES.....	76
Figure 18 – State transition diagram of NS.....	78
Figure 19 – State transition diagram of DLM	81
Table 1 – Data-link layer components	23
Table 2 – MAC multicast addresses	28
Table 3 – Message types	28
Table 4 – Node ID assignment.....	29
Table 5 – Structure of SoC DLPDU	30
Table 6 – Structure of SoC-Flag	31
Table 7 – Structure of PRes-DLPDU	33
Table 8 – Structure of FReq-Flag.....	33
Table 9 – Structure of FRes DLPDU	35
Table 10 – Structure of PRes-Flag	36
Table 11 – Structure of SoA DLPDU	38
Table 12 – Structure of SoA-Flag.....	39
Table 13 – Definition of the RequestedServiceID in the SoA DLPDU.....	40
Table 14 – Structure of ASnd DLPDU	42
Table 15 – Definition of the ServiceID in the ASnd DLPDU	43
Table 16 – Structure of NMTRrequest user data.....	44
Table 17 – Primitives exchanged between CSM and ITC	46
Table 18 – Parameters used with primitives exchanged between CSM and ITC	46
Table 19 – Primitives exchanged between CSM and ATC	47
Table 20 – Parameters used with primitives exchanged between CSM and ATC.....	47
Table 21 – Primitives exchanged between CSM and ASS	48
Table 22 – Parameters used with primitives exchanged between CSM and ASS.....	48

Table 23 – Primitives exchanged between CSM and ES	49
Table 24 – Parameters used with primitives exchanged between CSM and ES	49
Table 25 – Primitives exchanged between CSM and NS	49
Table 26 – Parameters used with primitives exchanged between CSM and NS	50
Table 27 – Primitives exchanged between CSM and DLM.....	50
Table 28 – Parameters used with primitives exchanged between CSM and DLM.....	50
Table 29 – Transitions of the MNs CSM.....	52
Table 30 – Transitions of MNs CSM at CSM_MS_NON_CYCLIC	53
Table 31 – Transitions of MNs CSM at CSM_MS_CYCLIC.....	56
Table 32 – Transitions of the CNs CSM	59
Table 33 – Transitions of CNs CSM at CSM_CS_NON_CYCLIC	60
Table 34 – Transitions of CNs CSM at CSM_CS_CYCLIC.....	62
Table 35 – CSM function table	63
Table 36 – Example of isochronous slot assignment.....	67
Table 37 – Primitives exchanged between ITC and DLS-user	67
Table 38 – Parameters used with primitives exchanged between ITC and DLS-user	67
Table 39 – Transitions of ITC.....	68
Table 40 – ITC function table	68
Table 41 – Primitives exchanged between ATC and DLS-user	69
Table 42 – Parameters used with primitives exchanged between ATC and DLS-user.....	70
Table 43 – Primitives exchanged between ATC and ES.....	70
Table 44 – Parameters used with primitives exchanged between ATC and ES.....	70
Table 45 – Transitions of ATC	71
Table 46 – ATC function table.....	73
Table 47 – Transitions of ASS	74
Table 48 – ASS function table.....	75
Table 49 – Primitives exchanged between ES and DLS-user	75
Table 50 – Parameters used with primitives exchanged between ES and DLS-user	75
Table 51 – Transitions of ES.....	76
Table 52 – Primitives exchanged between NS and DLS-user	77
Table 53 – Parameters used with primitives exchanged between NS and DLS-user.....	78
Table 54 – Transitions of NS.....	78
Table 55 – Primitives exchanged between DLM and DLS-user.....	79
Table 56 – Parameters used with primitives exchanged between DLM and DLS-user.....	80
Table 57 – Transitions of DLM	81
Table 58 – DLM function table	82

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
 FIELDBUS SPECIFICATIONS –**
Part 4-13: Data-link layer protocol specification – Type 13 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in the IEC 61784 series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

International Standard IEC 61158-4-13 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This first edition and its companion parts of the IEC 61158-4 subseries cancel and replace IEC 61158-4:2003. This edition of this part constitutes a technical addition, which also replaces IEC/PAS 62408, published in 2005.

This edition of IEC 61158-4 includes the following significant changes from the previous edition:

- a) deletion of the former Type 6 fieldbus, and the placeholder for a Type 5 fieldbus data link layer, for lack of market relevance;

- b) addition of new types of fieldbuses;
- c) division of this part into multiple parts numbered -4-1, -4-2, ..., -4-19.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/474/FDIS	65C/485/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This edition of IEC 61158-4 includes the following significant changes from the prior edition:

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under <http://webstore.iec.ch> in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

NOTE The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

The list of all the parts of the IEC 61158 series, under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-13: Data-link layer protocol specification – Type 13 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities

- a) in a synchronously-starting cyclic manner, according to a pre-established schedule, and
- b) in a cyclic or acyclic asynchronous manner, as requested each cycle by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This standard specifies

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed data-link service provider;
- b) procedures for giving communications opportunities to all participating DL-entities, sequentially and in a cyclic manner for deterministic and synchronized transfer at cyclic intervals up to one millisecond;
- c) procedures for giving communication opportunities available for time-critical data transmission together with non-time-critical data transmission without prejudice to the time-critical data transmission;
- d) procedures for giving cyclic and acyclic communication opportunities for time-critical data transmission with prioritized access;
- e) procedures for giving communication opportunities based on standard ISO/ IEC 8802-3 medium access control, with provisions for nodes to be added or removed during normal operation;
- f) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI or fieldbus reference models, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

1.5 Conformance

This standard also specifies conformance requirements for systems implementing these procedures. This standard does not contain tests to demonstrate compliance with such requirements.

2 Normative references

The following referenced documents are indispensable for the application of this standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61158-3-13, *Industrial communication networks – Fieldbus specifications – Part 3-13: Data-link layer service definition – Type 13 elements*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems - Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and Physical Layer specifications*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*