

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 4-24: Data-link layer protocol specification – Type 24 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 4-24: Spécification du protocole de la couche liaison de données –
Éléments de type 24**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – Fieldbus specifications –
Part 4-24: Data-link layer protocol specification – Type 24 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 4-24: Spécification du protocole de la couche liaison de données –
Éléments de type 24**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.20; 35.110

ISBN 978-2-8322-9159-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	10
1.1 General.....	10
1.2 Specifications	10
1.3 Procedures	10
1.4 Applicability	11
1.5 Conformance	11
2 Normative references	1
3 Terms, definitions, symbols, abbreviations and conventions	12
3.1 Reference model terms and definitions	12
3.2 Service convention terms and definitions	13
3.3 Common terms and definitions.....	13
3.4 Symbols and abbreviations	16
3.5 Additional Type 24 symbols and abbreviations.....	17
3.6 Common Conventions.....	17
3.7 Additional Type 24 conventions	18
3.7.1 Primitive conventions.....	18
3.7.2 State machine conventions.....	18
4 Overview of DL-protocol	19
4.1 Characteristic feature of the DL-protocol	19
4.2 DL layer component.....	20
4.2.1 Cyclic transmission control (CTC).....	21
4.2.2 Send Receive Control (SRC).....	21
4.2.3 DL-management.....	21
4.3 Timing sequence.....	21
4.3.1 Overview	21
4.3.2 Cyclic transmission mode	21
4.3.3 Acyclic transmission mode.....	29
4.4 Service assumed on the PhL	30
4.4.1 General requirement.....	30
4.4.2 DL_Symbols	30
4.4.3 Assumed primitives of the PhS	30
4.5 Local parameters, variables, counters, timers	30
4.5.1 Overview	30
4.5.2 Variables, parameters, counters and timers to support DLE function	31
5 DL PDU structure	35
5.1 Overview	35
5.1.1 Transfer syntax for bit sequences	35
5.1.2 Data type encodings	36
5.1.3 Frame format.....	36
5.2 Basic format DLPDU structure	36
5.2.1 General	36
5.2.2 Synchronous frame.....	40
5.2.3 Output data or Input data frame	40
5.2.4 Delay measurement start frame	41

5.2.5	Delay measurement frame	41
5.2.6	Message token frame	42
5.2.7	Status frame	42
5.2.8	Cycle Information frame	43
5.2.9	Message frame	44
5.3	Short format DLPDU structure	45
5.3.1	General	45
5.3.2	Synchronous frame	47
5.3.3	Output data or Input data frame	48
5.3.4	Message frame	49
6	DLE element procedure	49
6.1	Overview	49
6.2	Cyclic transmission control sublayer	49
6.2.1	General	49
6.2.2	DLS-user interface	49
6.2.3	Protocol machines in CTC	50
6.2.4	CTC-DLM interface	101
6.3	Send Receive Control	102
6.3.1	General	102
6.3.2	SRC-CTC interface	103
6.3.3	Detailed specification of SRC	104
6.3.4	SRC-DLM interface	108
7	DL-management layer (DLM)	109
7.1	Overview	109
7.2	Primitive definitions	109
7.2.1	Primitives exchanged between DLMs-user and DLM	109
7.2.2	Parameters used with DLM primitives	110
7.3	DLM protocol machine	110
7.3.1	C1 master	110
7.3.2	Slave and C2 master	115
7.4	Functions	119
	Bibliography	122
	Figure 1 – Data-link layer component	21
	Figure 2 – Timing chart of fixed-width time slot type cyclic communication	22
	Figure 3 – Timing chart of configurable time slot type cyclic communication	24
	Figure 4 – Schematic diagram of cyclic event occurrence	26
	Figure 5 – Timing relationship between cyclic transmission and data processing	29
	Figure 6 – Timing chart example of acyclic communication	29
	Figure 7 – Basic format DLPDU structure	37
	Figure 8 – Short format DLPDU structure	45
	Figure 9 – The state diagram of the C1 master for fixed-width time slot	51
	Figure 10 – The state diagram of the C2 master for fixed-width time slot	58
	Figure 11 – The state diagram of the slave for fixed-width time slot	62
	Figure 12 – The state diagram of the C1 master for configurable time slot	65
	Figure 13 – The state diagram of the C2 master for configurable time slot	74
	Figure 14 – The state diagram of slave for configurable time slot	77

Figure 15 – The state diagram of message initiator for basic format.....	82
Figure 16 – The state diagram of message responder for basic format	86
Figure 17 – The state diagram of message initiator for short format.....	90
Figure 18 – The state diagram of message responder for short format.....	94
Figure 19 – The state diagram of the acyclic transmission protocol machine.....	100
Figure 20 – Internal architecture of one-port SRC	104
Figure 21 – Internal architecture of multi-port SRC	104
Figure 22 – Internal architecture of serializer	105
Figure 23 – Internal architecture of deserializer	106
Figure 24 – State diagram of the C1 master DLM.....	111
Figure 25 – State diagram of the Slave and the C2 master DLM	116
Table 1 – State transition descriptions	18
Table 2 – Description of state machine elements	19
Table 3 – Conventions used in state machines	19
Table 4 – Characteristic features of the fieldbus data-link protocol.....	20
Table 5 – List of the values of the variable Cyc_sel	31
Table 6 – List of the values of the variable Tunit	32
Table 7 – List of the values of the variable PDUType	33
Table 8 – List of the values of the variable SlotType	34
Table 9 – Transfer syntax for bit sequences.....	36
Table 10 – Bit order	36
Table 11 – Destination and Source address format.....	37
Table 12 – Station address	37
Table 13 – Extended address	38
Table 14 – Message control field format (Information transfer format).....	38
Table 15 – Message control field format (Supervisory format).....	38
Table 16 – The list of Supervisory function bits.....	39
Table 17 – Frame type and data length format.....	39
Table 18 – The list of Frame type.....	39
Table 19 – Data format of the Synchronous frame	40
Table 20 – The field list of the Synchronous frame.....	40
Table 21 – Data format of the Output data or the Input data frame.....	40
Table 22 – The field list of the Output data or the Input data frame	41
Table 23 – Data format of Delay measurement start frame.....	41
Table 24 – The field list of Delay measurement start frame.....	41
Table 25 – Data format of Delay measurement frame.....	42
Table 26 – The field list of Delay measurement frame.....	42
Table 27 – Data format of Status frame.....	42
Table 28 – The field list of Status frame.....	43
Table 29 – The list of the DLE status	43
Table 30 – The list of Repeater status	43
Table 31 – Data format of Delay measurement frame.....	44

Table 32 – The field list of Cycle Information frame.....	44
Table 33 – Data format of Message frame	44
Table 34 – The field list of Message frame.....	45
Table 35 – Range of Station address field.....	46
Table 36 – Control field format (I/O data exchange format).....	46
Table 37 – Control field format (Message format)	46
Table 38 – The field list of Message format.....	47
Table 39 – Data format of the Synchronous frame	47
Table 40 – The field list of the Synchronous frame.....	48
Table 41 – Data format of the Output data frame	48
Table 42 – The field list of the Output data frame.....	48
Table 43 – Data format of the Input data frame	48
Table 44 – The field list of the Input data frame	48
Table 45 – Primitives and parameters for the DLS-user interface issued by the DLS-user.....	49
Table 46 – Primitives and parameters for the DLS-user interface issued by the CTC	50
Table 47 – The state table of the C1 master for fixed-width time slot	52
Table 48 – The state table of the C2 master for fixed-width time slot	59
Table 49 – The state table of the slave for fixed-width time slot	63
Table 50 – The state table of the C1 master for configurable time slot	66
Table 51 – The state table of the C2 master for configurable time slot	75
Table 52 – The state table of slave for configurable time slot.....	78
Table 53 – The list of functions used by cyclic transmission machine.....	79
Table 54 – The state table of message initiator for basic format.....	82
Table 55 – The state table of message responder for basic format.....	86
Table 56 – The state table of message initiator for short format	90
Table 57 – The state table of message responder for short format.....	95
Table 58 – List of functions used by the message segmentation machine	99
Table 59 – The state table of the acyclic transmission protocol machine.....	101
Table 60 – The list of functions used acyclic transmission protocol machine	101
Table 61 – Primitives and parameters exchanged between CTC and DLM	102
Table 62 – Error event primitive and parameters.....	102
Table 63 – Primitives and parameters for SRC-CTC interface	103
Table 64 – Send frame primitive and parameters	103
Table 65 – Receive frame primitives and parameters	104
Table 66 – Primitives and parameters exchanged between SRC and DLM.....	108
Table 67 – Get value primitive and parameters	109
Table 68 – Error event primitive and parameters.....	109
Table 69 – The list of primitives and parameters (DLMS-user source).....	110
Table 70 – The list of primitives and parameters (DLM source).....	110
Table 71 – State table of the C1 Master DLM.....	112
Table 72 – State table of the Slave and the C2 master DLM	117
Table 73 – The list of the functions used by DLM protocol machine	120

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 4-24: Data-link layer protocol specification –
Type 24 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization, comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-4-24 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- patent declaration in the Introduction;
- corrections on transmission sequence of fixed-width time slot type in 4.3.2;
- technical extension for band sharing between I/O data exchange and message communication; and
- spelling and grammar.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/946/FDIS	65C/955/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under <http://webstore.iec.ch> in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementers and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in the profile series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents as follows, where the [xx] notation indicates the holder of the patent right:

US 8223804	[YE]	COMMUNICATION DEVICE, SYNCHRONIZED
JP 4760978		SYSTEM AND SYNCHRONIZED COMMUNICATION METHOD
CN 200880002225.3		
DE 602008046644.2		

US 7769935	[YE]	MASTER SLAVE COMMUNICATION SYSTEM AND MASTER
JP 4683346		SLAVE COMMUNICATION METHOD
US 8046512		
DE 602007041530		

JP 4356698	[YE]	COMMUNICATION DEVICE, SYNCHRONIZED COMMUNICATION
		SYSTEM, AND SYNCHRONIZED COMMUNICATION METHOD

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holders of these patent rights have assured IEC that they are willing to negotiate licenses either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holders of these patent rights is registered with IEC. Information may be obtained from

[YE]	YASKAWA ELECTRIC CORPORATION
	2-1 Kurosakishiroishi, Yahatanishi-ku, Kitakyushu 806-0004, Japan
	Attention; Intellectual Property Rights Section.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch>) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-24: Data-link layer protocol specification – Type 24 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities:

- a) in a synchronously-starting cyclic manner, according to a pre-established schedule, or
- b) in an acyclic manner, as requested by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This document specifies

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed datalink service provider;
- b) procedures for giving communications opportunities to all participating DL-entities (DLEs), sequentially and in a cyclic manner for deterministic and synchronized transfer at cyclic intervals up to 64 ms;
- c) procedures for giving communication opportunities available for time-critical data transmission together with non-time-critical data transmission without prejudice to the time-critical data transmission;
- d) procedures for giving cyclic and acyclic communication opportunities for time-critical data transmission with prioritized access;
- e) procedures for giving communication opportunities based on ISO/IEC/IEEE 8802-3 medium access control, with provisions for nodes to be added or removed during normal operation;
- f) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this document, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.