

# INTERNATIONAL STANDARD

---

**Industrial communication networks – Fieldbus specifications –  
Part 5-26: Application layer service definition – 1 to 26 elements**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

### IEC publications search - [webstore.iec.ch/advsearchform](http://webstore.iec.ch/advsearchform)

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

### IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

### IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [sales@iec.ch](mailto:sales@iec.ch).

### Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

### IEC Glossary - [webstore.iec.ch/glossary](http://webstore.iec.ch/glossary)

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

# INTERNATIONAL STANDARD

---

**Industrial communication networks – Fieldbus specifications –  
Part 5-26: Application layer service definition – Type 26 elements**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-6768-4

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 Overview.....	8
1.2 Specifications.....	9
1.3 Conformance.....	9
2 Normative references.....	9
3 Terms, definitions, symbols, abbreviations and conventions.....	10
3.1 Terms and definitions from other ISO/IEC standards.....	11
3.1.1 Terms and definitions from ISO/IEC 7498-1.....	11
3.1.2 Terms and definitions from ISO/IEC 8822.....	11
3.1.3 Terms and definitions from ISO/IEC 9545.....	11
3.1.4 Terms and definitions from ISO/IEC 8824-1.....	11
3.2 Fieldbus application layer Type 26-specific definitions.....	12
3.3 Abbreviations and symbols.....	18
3.4 Conventions.....	20
3.4.1 Overview.....	20
3.4.2 General conventions.....	20
3.4.3 Conventions for class definitions.....	20
3.4.4 Conventions for service definitions.....	21
4 Concepts.....	22
5 Data type ASE.....	23
5.1 Overview.....	23
5.2 Formal definition of data type objects.....	23
5.2.1 Data type class definitions.....	23
5.2.2 Attributes.....	24
5.3 FAL defined data types.....	25
5.3.1 Fixed length types.....	25
5.3.2 String types.....	29
5.4 Data type ASE service specification.....	30
6 Communication mode specification.....	30
6.1 General.....	30
6.2 Protocol stack for Type 26 fieldbus.....	30
6.3 Overview of Type 26 communication model.....	31
6.4 Cyclic data communication service with Common-memory.....	32
6.4.1 Overview.....	32
6.4.2 Common-memory: allocation to each node.....	32
6.4.3 Data sharing among nodes with the CM.....	33
6.4.4 CM data type.....	35
6.5 ASEs.....	35
6.5.1 Overview of Type 26 ASEs.....	35
6.5.2 Type 26 specific conventions for FAL service common parameters.....	36
6.5.3 Cyclic-data ASE.....	37
6.5.4 Message data ASE.....	42
6.5.5 Communication load measurement ASE.....	69
6.5.6 Network management ASE.....	74

6.5.7	General purpose command server ASE .....	87
6.5.8	AR ASE .....	90
6.5.9	FAL ASE summary .....	101
Bibliography.....		104
Figure 1	– Protocol stack for Type 26 fieldbus .....	31
Figure 2	– Unconfirmed Push-Publisher/Subscriber type interaction .....	32
Figure 3	– Unconfirmed/Confirmed Client/Server type interaction .....	32
Figure 4	– Common memory allocation .....	33
Figure 5	– Data sharing with the CM .....	34
Figure 6	– Node #01 for reception only .....	34
Figure 7	– Node #01 without the CM .....	35
Figure 8	– The structure of ASEs for Type 26 FAL .....	36
Figure 9	– Virtual-address-space for Byte block .....	45
Figure 10	– Virtual-address-space for Word block .....	48
Figure 11	– AR ASE internal architecture .....	91
Figure 12	– Structure of IP address .....	99
Table 1	– Write service parameters.....	39
Table 2	– Send-CM service parameters .....	40
Table 3	– Read service parameters.....	40
Table 4	– Update memory service parameters .....	41
Table 5	– Get- buffer service parameters .....	42
Table 6	– Byte block read service parameters .....	46
Table 7	– Byte block write service parameters .....	47
Table 8	– Word block read service parameters .....	48
Table 9	– Word block write service parameters .....	49
Table 10	– Network parameter read service parameters .....	50
Table 11	– Network parameter write service parameters .....	51
Table 12	– Stop command service parameters.....	52
Table 13	– Operation command service parameters.....	53
Table 14	– prompt read service parameters .....	53
Table 15	– transparent message service parameters .....	56
Table 16	– Log data read service parameters .....	57
Table 17	– Log data items.....	57
Table 18	– Log data clear service parameters.....	61
Table 19	– Message return service parameters.....	62
Table 20	– Vendor specific message service parameters .....	63
Table 21	– Set remote node configuration parameter service parameters .....	64
Table 22	– Data elements and Node configuration parameters.....	64
Table 23	– Service parameters of Read remote participating node management information parameter service.....	65
Table 24	– Participating node management information parameters.....	66
Table 25	– Read remote node management information parameter service parameters .....	67

Table 26 – Node management information parameters .....	67
Table 27 – Read remote node setting information parameter service parameters.....	68
Table 28 –Node setting information parameters .....	69
Table 29 – Start TK-holding-time measurement service parameters.....	71
Table 30 – Terminate TK-holding-time measurement service parameters.....	71
Table 31 – Token-holding-time measurement result .....	72
Table 32 – Start GP_Comm sender log service parameters .....	73
Table 33 – Terminate GP_Comm sender log service parameters .....	73
Table 34 – GP_Comm sender log measurement result.....	74
Table 35 – Service parameters for Set configuration parameter .....	77
Table 36 – Configuration parameters .....	78
Table 37 – Read node management information parameter service parameters.....	78
Table 38 – Node management information parameters .....	79
Table 39 – Service parameters for Read participating node mgt. information parameter .....	80
Table 40 – Participating node management information parameters.....	80
Table 41 – Service parameters for Read network management information parameter.....	81
Table 42 – Network management information parameters.....	81
Table 43 – Service parameters for Read message sequence number management information.....	82
Table 44 – Read message sequence number management information parameters .....	82
Table 45 –Read node status service parameters.....	83
Table 46 – Read node status parameters.....	83
Table 47 – Upper layer operating condition matrix .....	84
Table 48 –Reset node service parameters .....	84
Table 49 – Set network address service parameters .....	85
Table 50 – Register service parameters .....	85
Table 51 – Event service parameters .....	86
Table 52 – Activate/Deactivate measurement service parameters .....	86
Table 53 – Get log data service parameters.....	87
Table 54 – Send command service parameters.....	90
Table 55 – CT send service parameters.....	93
Table 56 – MT send service parameters .....	95
Table 57 – CS send service parameters.....	96
Table 58 – Notify state change service parameters .....	97
Table 59 – Control measurement service parameters.....	97
Table 60 – DLSAP assignments.....	99
Table 61 – DLS Primitives and parameters .....	100
Table 62 – Lower layer T-profile and the required standards.....	101
Table 63 – Summary of FAL ASEs .....	101

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**INDUSTRIAL COMMUNICATION NETWORKS –  
 FIELDBUS SPECIFICATIONS –**
**Part 5-26: Application layer service definition –  
 Type 26 elements**
**FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization, comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61158-5-26 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement and control.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
65C/947/FDIS	65C/950/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

Currently in preview, click buy full version

## INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This document defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this document is a conceptual architectural service, independent of administrative and implementation divisions.

## INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

### Part 5-26: Application layer service definition – Type 26 elements

#### 1 Scope

##### 1.1 Overview

The Fieldbus Application Layer (FAL) provides user programs with a means to access the Fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 26 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This International Standard defines in an abstract way the externally visible service provided by the different Types of fieldbus Application Layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service;
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this document is to define the services provided to

- a) the FAL user at the boundary between the user and the Application Layer of the Fieldbus Reference Model; and
- b) Systems Management at the boundary between the Application Layer and Systems Management of the Fieldbus Reference Model.

This document specifies the structure and services of the IEC Fieldbus Application Layer, in conformance with the OSI Basic Reference Model (see ISO/IEC 7498-1) and the OSI Application Layer Structure (see ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can