

# EXTENDED VERSION



This Extended version of IEC 61204-7:2016 includes the provisions of the general rules of IEC 62477-1:2012

## Low-voltage switch mode power supplies – Part 7: Safety requirements



**THIS PUBLICATION IS COPYRIGHT PROTECTED**  
**Copyright © 2016 IEC, Geneva, Switzerland**

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

#### **About the IEC**

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

#### **About IEC publications**

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### **IEC Catalogue - [webstore.iec.ch/catalogue](http://webstore.iec.ch/catalogue)**

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

#### **IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)**

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

#### **IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)**

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

#### **Electropedia - [www.electropedia.org](http://www.electropedia.org)**

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

#### **IEC Glossary - [www.iec.ch/glossary](http://www.iec.ch/glossary)**

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

#### **IEC Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)**

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).

# EXTENDED VERSION



This Extended version of IEC 61204-7:2016 includes the provisions of the general rules of IEC 62477-1:2012

---

## Low-voltage switch mode power supplies – Part 7: Safety requirements

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 29.200

ISBN 978-2-8322-3751-9

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	9
INTRODUCTION.....	12
0 Principles of safety.....	13
0.1 General.....	13
0.2 Hazards.....	14
0.2.1 General.....	14
0.2.2 Electric shock.....	14
0.2.3 Energy related hazards.....	15
0.2.4 Fire.....	15
0.2.5 Heat related hazards.....	16
0.2.6 Mechanical hazards.....	16
0.2.7 Chemical hazards.....	16
0.3 Materials and components.....	16
1 Scope.....	17
1.1 Equipment covered by this document.....	17
1.2 Exclusions.....	17
1.3 Additional requirements.....	18
2 Normative references.....	18
3 Terms and definitions.....	19
4 Protection against hazards.....	29
4.1 General.....	29
4.1.100 Constructions not specifically covered.....	30
4.1.101 Orientation during transport and use.....	30
4.2 Fault and abnormal conditions.....	30
4.2.100 Application of faults and abnormal conditions.....	31
4.3 Short circuit and overload protection.....	32
4.3.1 General.....	32
4.3.2 Specification of input short-circuit withstand strength and output short circuit current capability.....	33
4.3.3 Short-circuit coordination (backup protection).....	34
4.3.4 Protection by several devices.....	34
4.4 Protection against electric shock.....	34
4.4.1 General.....	34
4.4.2 Nominal voltage class.....	34
4.4.3 Provision for basic protection.....	37
4.4.4 Provision for fault protection.....	38
4.5 Enhanced protection.....	44
4.4.6 Protective measures.....	47
4.4.7 Insulation.....	49
4.4.8 Compatibility with residual current-operated protective devices (RCD).....	67
4.4.9 Capacitor discharge.....	67
4.5 Protection against electrical energy hazards.....	68
4.5.1 Operator access areas.....	68
4.5.2 Service access areas.....	69
4.6 Protection against fire and thermal hazards.....	69
4.6.1 Circuits representing a fire hazard.....	69

4.6.2	Components representing a fire hazard .....	69
4.6.3	Fire enclosures .....	70
4.6.4	Temperature limits .....	74
4.6.5	Limited power sources .....	78
4.7	Protection against mechanical hazards .....	79
4.7.1	General .....	79
4.7.2	Specific requirements for liquid cooled SMPS .....	79
4.8	Equipment with multiple sources of supply .....	81
4.9	Protection against environmental stresses .....	81
4.10	Protection against sonic pressure hazards .....	82
4.10.1	General .....	82
4.10.2	Sonic pressure and sound level .....	82
4.11	Wiring and connections .....	83
4.11.1	General .....	83
4.11.2	Routing .....	83
4.11.3	Colour coding .....	83
4.11.4	Splices and connections .....	83
4.11.5	Accessible connections .....	84
4.11.6	Interconnections between parts of the SMPS .....	84
4.11.7	Supply connections .....	84
4.11.8	Terminals .....	84
4.12	Enclosures .....	86
4.12.1	General .....	86
4.12.2	Handles and manual controls .....	86
4.12.3	Cast metal .....	87
4.12.4	Sheet metal .....	87
4.12.5	Stability test for enclosure .....	90
5	Test requirements .....	91
5.1	General .....	91
5.1.1	Test objectives and classification .....	91
5.1.2	Selection of test samples .....	91
5.1.3	Sequence of tests .....	91
5.1.4	Earthing conditions .....	91
5.1.5	General conditions for tests .....	91
5.1.6	Compliance .....	93
5.1.7	Test overview .....	93
5.2	Test specifications .....	95
5.2.1	Visual inspections (type test, sample test and routine test) .....	95
5.2.2	Mechanical tests .....	96
5.2.3	Electrical tests .....	100
5.2.4	Abnormal operation and simulated faults tests .....	119
5.2.5	Material tests .....	127
5.2.6	Environmental tests (type tests) .....	130
5.2.7	Hydrostatic pressure test (type test and routine test) .....	135
6	Information and marking requirements .....	135
6.1	General .....	135
6.2	Information for selection .....	137
6.2.100	Additional marking requirements for SMPS .....	138
6.2.101	Additional information for component SMPS .....	139

6.3	Information for installation and commissioning .....	139
6.3.1	General .....	139
6.3.2	Mechanical considerations.....	139
6.3.3	Environment .....	140
6.3.4	Handling and mounting .....	140
6.3.5	Enclosure temperature.....	140
6.3.6	Connections .....	140
6.3.7	Protection requirements.....	142
6.3.8	Commissioning .....	144
6.4	Information for use.....	144
6.4.1	General .....	144
6.4.2	Adjustment .....	144
6.4.3	Labels, signs and signals.....	144
6.5	Information for maintenance.....	146
6.5.1	General .....	146
6.5.2	Capacitor discharge.....	147
6.5.3	Auto restart/bypass connection.....	147
6.5.4	Other hazards.....	147
6.5.5	Equipment with multiple sources of supply.....	147
6.5.100	Disconnect device external to permanently connected equipment.....	147
6.5.101	Power cord acting as disconnecting device .....	148
7	Components .....	148
7.1	General.....	148
7.2	Switches .....	149
7.2.1	General .....	149
7.2.2	Requirements for switches acting as disconnecting device .....	149
7.2.3	Requirements for switches.....	150
7.2.4	Test method and compliance criteria .....	151
7.3	Overtemperature protection devices (thermal cut-offs or thermal links) .....	151
7.4	PTC thermistors.....	151
7.5	Overcurrent protective devices.....	152
7.6	Protective devices not mentioned in 7.2 to 7.5 .....	152
7.6.1	Other protective devices requirements.....	152
7.6.2	Compliance and test method.....	152
7.7	Transformers .....	152
7.7.1	General .....	152
7.7.2	Insulation.....	152
7.8	Motors .....	153
7.9	Mains supply cords .....	154
7.9.1	General .....	154
7.9.2	Fitting of non-detachable mains supply cords .....	155
7.10	Surge protective devices (SPDs).....	157
7.10.1	Use of an SPD connected to reliable earthing .....	157
7.10.2	Use of an SPD between mains and protective earth.....	157
7.10.3	Bridging of supplementary, double or reinforced insulation by a SPD.....	157
7.10.4	Circuits or components used as transient voltage limiting devices .....	157
7.11	Wound components .....	158
7.12	IC current limiters .....	158
7.12.1	General .....	158

7.12.2	Test program 1 .....	159
7.12.3	Test program 2 .....	159
7.12.4	Test program 3 .....	159
7.13	Capacitors and RC units bridging insulation .....	160
7.14	Optocouplers bridging insulation .....	162
7.15	Relays .....	162
7.16	Electrolytic capacitors .....	163
Annex A (normative)	Additional information for protection against electric shock .....	164
Annex B (informative)	Considerations for the reduction of the pollution degree .....	170
Annex C (informative)	Symbols referred to in IEC 62477-1 .....	171
Annex D (normative)	Evaluation of clearance and creepage distances .....	172
Annex E (informative)	Altitude correction for clearances .....	180
Annex F (normative)	Clearance and creepage distance determination for frequencies greater than 30 kHz .....	181
Annex G (informative)	Cross-sections of round conductors .....	187
Annex H (informative)	Guidelines for RCD compatibility .....	188
Annex I (informative)	Examples of overvoltage category reduction .....	192
Annex J (informative)	Burn thresholds for touchable surfaces .....	199
Annex K (informative)	Table of electrochemical potentials .....	202
Annex L (informative)	Measuring instrument for touch current measurements .....	203
Annex M (informative)	Test probes for determining access .....	204
Annex AA (normative)	<i>Addition</i> Insulated winding wires for use without interleaved insulation .....	207
Annex AB (informative)	Minimum and maximum cross-section of copper conductors suitable for connection to terminals for external conductors .....	210
Annex AC (normative)	DC power and distribution equipment .....	211
Annex AD (informative)	Examples of protective measures according to 4.4.1 to 4.4.5 for protection against electrical shock .....	226
Bibliography	.....	228
Figure 4	– Example of a <i>SMPS</i> assembly and its associated <i>protective equipotential bonding</i> .....	40
Figure 5	– Example of a <i>SMPS</i> assembly and its associated <i>protective equipotential bonding</i> .....	41
Figure 6	– <i>Fire enclosure</i> bottom openings below an unenclosed or partially enclosed fire-hazardous component .....	72
Figure 7	– <i>Fire enclosure</i> baffle construction .....	73
Figure 8	– Supported and unsupported <i>enclosure</i> parts .....	88
Figure 9	– Impact test using a steel ball .....	98
Figure 11	– Protective equipotential bonding impedance test for separate unit with power fed from the <i>SMPS</i> with protection for the power cable .....	112
Figure 12	– Protective equipotential bonding impedance test for sub-assembly with accessible parts and with power fed from the <i>SMPS</i> .....	113
Figure 13	– Circuit for high-current arcing test .....	127
Figure 14	– Test fixture for hot-wire ignition test .....	128
Figure 100	– Electric strength test instrument .....	117
Figure 101	– Mandrel .....	118

Figure 102 – Initial position of mandrel .....	118
Figure 103 – Final position of mandrel .....	118
Figure 104 – Position of metal foil on insulating material.....	119
Figure 105 – Determination of arithmetic average temperature .....	126
Figure 106 – Detachable mains supply cords and connections.....	155
Figure A.1 – Protection by <i>DVC As</i> with <i>protective separation</i> .....	164
Figure A.2 – Protection by means of <i>protective impedance</i> .....	165
Figure A.3 – Protection by using limited voltages .....	166
Figure A.20 – Typical waveform for a.c. <i>working voltage</i> .....	166
Figure A.21 – Typical waveform for d.c. <i>working voltage</i> .....	167
Figure A.22 – Typical waveform for pulsating <i>working voltage</i> .....	167
Figure F.1 – Diagram for dimensioning of clearances.....	182
Figure F.2 – Diagram for dimensioning of creepage distances .....	184
Figure F.3 – Permissible field strength for dimensioning of solid <i>insulation</i> according to Equation (1).....	186
Figure H.1 – Flow chart leading to selection of the RCD type upstream of a <i>SMPS</i> .....	188
Figure H.2 – Fault current waveforms in connections with power electronic converter devices .....	190
Figure I.1 – <i>Basic insulation</i> evaluation for circuits connected to the origin of the <i>installation mains supply</i> .....	192
Figure I.2 – <i>Basic insulation</i> evaluation for circuits connected to the <i>mains supply</i> .....	193
Figure I.3 – <i>Basic insulation</i> evaluation for single and three phase equipment not permanently connected to the <i>mains supply</i> .....	193
Figure I.4 – <i>Basic insulation</i> evaluation for circuits connected to the origin of the <i>installation mains supply</i> where internal <i>SPDs</i> are used.....	193
Figure I.5 – <i>Basic insulation</i> evaluation for circuits connected to the <i>mains supply</i> where internal <i>SPDs</i> are used.....	194
Figure I.6 – Example of <i>protective separation</i> evaluation for circuits connected to the <i>mains supply</i> where internal <i>SPDs</i> are used .....	194
Figure I.7 – Example of <i>protective separation</i> evaluation for circuits connected to the <i>mains supply</i> where internal <i>SPDs</i> are used .....	194
Figure I.8 –Example of <i>protective separation</i> evaluation for circuits connected to the <i>mains supply</i> where internal <i>SPDs</i> are used .....	195
Figure I.9 – <i>Basic insulation</i> evaluation for circuits not connected directly to the <i>mains supply</i> .....	195
Figure I.10 – <i>Basic insulation</i> evaluation for circuits not connected directly to the supply <i>mains</i> .....	195
Figure I.11 – Functional <i>insulation</i> evaluation within circuits affected by external transients.....	196
Figure I.12 – <i>Basic insulation</i> evaluation for circuits both connected and not connected directly to the <i>mains supply</i> .....	196
Figure I.13 – <i>Insulation</i> evaluation for accessible circuit of <i>DVC A</i> .....	197
Figure I.14 – <i>PEC</i> with <i>mains</i> and non- <i>mains supply</i> without galvanic separation.....	197
Figure I.15 – Transformer (basic) isolated <i>PEC</i> inverter with <i>SPD</i> and transformer to reduce impulse voltage for functional and <i>basic insulation</i> .....	198
Figure J.1 – Burn threshold spread when the skin is in contact with a hot smooth surface made of bare (uncoated) metal.....	199

Figure J.2 – Rise in the burn threshold spread from Figure J.1 for metals which are coated by shellac varnish of a thickness of 50 µm, 100 µm and 150 µm.....	200
Figure J.3 – Rise in the burn threshold spread from Figure J.1 for metals coated with the specific materials .....	200
Figure J.4 – Burn threshold spread when the skin is in contact with a hot smooth surface made of ceramics, glass and stone materials .....	201
Figure J.5 – Burn threshold spread when the skin is in contact with a hot smooth surface made of plastics .....	201
Figure K.1 – Electrochemical potentials (V).....	202
Figure M.1 – Sphere 50 mm probe (IPXXA) .....	204
Figure M.2 – Jointed test finger (IPXXB) .....	205
Figure M.3 – Test rod 2,5 mm (IP3X) .....	206
Figure AC.100 – Resistance and short circuit calculations .....	214
Table 1 – Environmental tests.....	131
Table 5 – Voltage limits .....	36
Table 6 – Separation requirements for circuit under consideration .....	37
Table 7 – PE conductor cross-section .....	42
Table 8 – Definitions of pollution degrees .....	49
Table 9 – Impulse withstand voltage and <i>temporary overvoltage</i> versus system voltage .....	51
Table 10 – Clearance distances for <i>functional, basic or supplementary insulation</i> .....	58
Table 11 – Creepage distances (in millimetres).....	60
Table 12 – Generic materials for the direct support of <i>uninsulated live parts</i> .....	62
Table 13 – Permitted openings in <i>fire enclosure</i> bottoms .....	73
Table 14 – Maximum measured total temperatures for internal materials and components .....	75
Table 15 – Maximum measured temperatures for accessible parts of the <i>SMPS</i> .....	77
Table 16 – Limits for sources without an overcurrent protective device .....	78
Table 17 – Limits for power sources with an overcurrent protective device.....	79
Table 18 – Environmental service conditions .....	82
Table 19 – Wire bending space from terminals to <i>enclosure</i> .....	86
Table 20 – Thickness of sheet metal for <i>enclosures</i> : carbon steel or stainless steel.....	89
Table 21 – Thickness of sheet metal for <i>enclosures</i> : aluminium, copper or brass .....	90
Table 22 – Test overview .....	94
Table 23 – Pull values for handles and manual control securement.....	99
Table 24 – Impulse voltage test .....	101
Table 25 – Impulse test voltage .....	102
Table 26 – AC or d.c. test voltage for circuits connected directly to <i>mains supply</i> .....	103
Table 27 – A.c. or d.c. test voltage for circuits connected to <i>non-mains supply</i> without <i>temporary overvoltages</i> .....	104
Table 28 – Partial discharge test.....	107
Table 29 – Test duration for <i>protective equipotential bonding</i> test.....	114
Table 31 – Dry heat test (steady state) .....	132
Table 32 – Damp heat test (steady state).....	133
Table 33 – Vibration test.....	134

Table 34 – Salt mist test .....	134
Table 35 – Dust and sand test .....	135
Table 36 – Information requirements .....	136
Table 100 – Limits for access of current .....	47
Table 101 – Tests for insulation in non-separable layers .....	64
Table 102 – Temperature limits for transformer windings .....	125
Table 103 – Component requirements .....	148
Table 104 – Peak surge current .....	151
Table 105 – Strain relief test force .....	156
Table 106 – Capacitor ratings according to IEC 60384-14 .....	161
Table A.4 – Examples for protection against electrical shock .....	169
Table C.1 – Symbols used .....	171
Table C.100 – Symbols .....	172
Table D.1 – Width of grooves by pollution degree .....	173
Table E.1 – Correction factor for clearances at altitudes between 2 000 m and 20 000 m .....	180
Table E.2 – Test voltages for verifying clearances at different altitudes .....	180
Table F.1 – Minimum values of clearances in air at atmospheric pressure for inhomogeneous field conditions (Table 1 of IEC 60664-4:2005) .....	183
Table F.2 – Multiplication factors for clearances in air at atmospheric pressure for approximately homogeneous field conditions .....	183
Table F.3 – Minimum values of creepage distance for different frequency ranges (Table 2 of IEC 60664-4:2005) .....	185
Table G.1 – Standard cross-sections of round conductors .....	187
Table AA.1 – Mandrel diameter .....	208
Table AA.2 – Oven temperature .....	208
Table AB.1 – Cross-section of copper conductors suitable for connection to terminals for external conductors (extract from IEC 61439-1:2011) .....	210
Table AC.101 – AC and DC field wiring spacings .....	218
Table AC.102 – Minimum acceptable spacings for uninsulated bus bars .....	219
Table AC.103 – Temperature limits .....	220
Table AC.104 – Switch test sequences .....	222

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## LOW-VOLTAGE SWITCH MODE POWER SUPPLIES –

## Part 7: Safety requirements

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

**DISCLAIMER**

**This Extended version is intended only to provide the user with a comprehensive content consisting of a product standard and its reference document. An Extended version is not an official IEC Standard. Only the current versions of the related standards are to be considered the official documents.**

**This Extended version of IEC 61204-7:2016 includes the provisions of the general rules dealt with in IEC 62477-1:2012. Clauses and subclauses of IEC 62477-1:2012 that are applicable in IEC 61204-7:2016 have been introduced in the content in red text.**

International Standard IEC 61204-7 has been prepared by subcommittee 22E: Stabilized power supplies, of IEC technical committee 22: Power electronic systems and equipment.

This second edition cancels and replaces the first edition published in 2006. This edition constitutes a complete technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) use of IEC 62477-1 as reference document, instead of IEC 60950-1;
- b) modification of the title by deleting the wording “DC output-“ and adding “switch mode”.

IEC 61204-7 has the status of a product standard.

The text of this document is based on the following documents:

FDIS	Report on voting
22E/175/FDIS	22E/177/RVD

Full information on the voting for the approval of this document can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61204 series, published under the general title *Low-voltage power supplies, d.c. output*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

This International Standard is to be read in conjunction with IEC 62477-1:2012.

NOTE A consolidated version is under consideration.

Subclauses that are numbered starting from 100 are additional to those in IEC 62477-1:2012.

Additional tables and figures in this document are numbered starting from 100.

New annexes in this document are lettered AA, AB, AC, etc.

The wordings **SMPS** and "power supply" are considered to be identical throughout this document.

References of the reference document to clauses or tables, which have been modified in this document, shall be read as reference to the relevant clauses or tables of this document.

Refer to 3.100 for further information on how to read this document.

In this document, the following print types are used:

- Requirements proper and normative annexes: in roman type.
- Notes and other informative matter: in smaller roman type.
- Normative conditions within tables: in smaller roman type.
- Terms that are defined in clause 3 or IEC 62477-1:2012: ***Bold Italic***.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

IEC 62477-1:2012, used by this document as a reference, relates to products that include power electronic converters, with a rated system voltage not exceeding 1 000 V AC or 1 500 V DC. It specifies requirements to reduce risks of fire, electric shock, thermal, energy and mechanical hazards, except functional safety as defined in IEC 61508 (all parts). The objectives of this standard are to establish a common terminology and basis for the safety requirements of products that contain power electronic converters across several IEC technical committees.

IEC 62477-1:2012 was developed with the intention

- to be used as a reference document for product committees inside IEC technical committee 22: Power electronic systems and equipment in the development of product standards for power electronic converter systems and equipment,
- to replace IEC 62103 as a product family standard providing minimum requirements for safety aspects of power electronic converter systems and equipment in apparatus for which no product standard exists, and

NOTE The scope of IEC 62103 contains reliability aspects, which are not covered by this document.

- to be used as a reference document for product committees outside TC 22 in the development of product standards of power electronic converter systems and equipment intended for renewable energy sources. TC 82, TC 88, TC 105 and TC 114, in particular, have been identified as relevant technical committees at the time of publication.

As such, IEC technical sub-committee 22E: Stabilized switched-mode power supplies carefully considered the relevance of each paragraph of IEC 62477-1:2012 for the SMPS and referenced, added, replaced or modified requirements as relevant. This is because product-specific topics not covered by the reference document are the responsibility of the technical committee using the reference document.

The reference document, being a group safety standard, will not take precedence over this product-specific standard according to IEC Guide 104. IEC Guide 104 provides information about the responsibility of product committees to use group safety standards for the development of their own product standards.

## LOW-VOLTAGE SWITCH MODE POWER SUPPLIES –

### Part 7: Safety requirements

#### 0 Principles of safety

Safety principles of this document follow the concepts of IEC Guide 116 and Annex D of CENELEC Guide 32:2014.

NOTE The principles of safety are mainly adopted from IEC 60950-1:2005/AMD1:2009/AMD2:2013.

##### 0.1 General

The following principles have been adopted by IEC technical committee 22E in the development of this document. These principles do not cover performance or functional characteristics of equipment.

It is essential that designers understand the underlying principles of safety requirements in order that they can engineer safe equipment.

These principles are not an alternative to the detailed requirements of this document, but are intended to provide designers with an appreciation of the basis of these requirements. Where the equipment involves technologies, components and materials or methods of construction not specifically covered, the design of the equipment should provide a level of safety not less than that described in these principles of safety.

NOTE The need for additional detailed requirements to cope with a new situation is brought promptly to the attention of the appropriate committee.

Designers will take into account not only normal operating conditions of the equipment but also likely fault conditions, consequential faults, foreseeable misuse and external influences such as temperature, altitude, pollution, moisture, overvoltages on the **mains supply** and **non-mains supply**.

Dimensioning of insulation spacings should take account of possible reductions by manufacturing tolerances, or where deformation could occur due to handling, shock and vibration likely to be encountered during manufacture, transport and normal operation.

The following priorities should be observed in determining what design measures to adopt:

- where possible, specify design criteria that will eliminate, reduce or guard against hazards;
- where the above is not practicable because the functioning of the equipment would be impaired, specify the use of protective means independent of the equipment, such as personal protective equipment (which is not specified in this document);
- where neither of the above measures is practicable, or in addition to those measures, specify the provision of markings and instructions regarding the residual risks.

There are two types of persons whose safety needs to be considered, **operators** (or **users**) and **service persons**.

**Operator** is the term applied to all persons other than **service persons**. Requirements for protection should assume that **operators** are not trained to identify hazards, but will not intentionally create a hazardous situation. Consequently, the requirements will provide protection for cleaners and casual visitors as well as the assigned **operators**. In general,