

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Composite hollow insulators – Pressurized and non-pressurized insulators for use in electrical equipment with AC rated voltage greater than 1 000 V AC and D.C. voltage greater than 1500V – Definitions, test methods, acceptance criteria and design recommendations

Isolateurs composites creux – Isolateurs avec ou sans pression interne pour utilisation dans des appareillages électriques de tensions alternatives assignées supérieures à 1 000 V et de tensions continues supérieures à 1 500 V – Définitions, méthodes d'essai, critères d'acceptation et recommandations de conception



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications preview. With a subscription you will always have access to up-to-date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with AC rated voltage greater than 1 000 V AC and D.C. voltage greater than 1500V – Definitions, test methods, acceptance criteria and design recommendations

Isolateurs composites creux – Isolateurs avec ou sans pression interne pour utilisation dans des appareillages électriques de tensions alternatives assignées supérieures à 1 000 V et de tensions continues supérieures à 1 500 V – Définitions, méthodes d'essai, critères d'acceptation et recommandations de conception

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.080.10

ISBN 978-2-8322-7403-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	9
3 Terms and definitions	9
4 Relationships of mechanical loads.....	13
4.1 Loads from outside the insulator	13
4.2 Pressures	13
5 Marking	11
6 Classification of tests.....	14
6.1 General.....	14
6.2 Design tests.....	14
6.3 Type tests.....	16
6.4 Sample tests.....	16
6.5 Routine tests.....	16
7 Design tests	17
7.1 General.....	17
7.2 Tests on interfaces and connections of end fittings.....	17
7.2.1 General	17
7.2.2 Test specimen	17
7.2.3 Reference disruptive – discharge dry power frequency test	17
7.2.4 Thermal-mechanical pre-stressing test.....	17
7.2.5 Water immersion pre-stressing test.....	18
7.2.6 Verification tests.....	18
7.3 Tests on shed and housing material.....	19
7.3.1 Hardness test.....	19
7.3.2 Accelerated weathering test.....	19
7.3.3 Tracking and erosion test – 1000 h salt fog AC voltage test.....	19
7.3.4 Flammability test.....	19
7.3.5 Hydrophobicity transfer test.....	19
7.4 Tests on fibre tube material	19
7.4.1 General	19
7.4.2 Porosity test (Dye penetration test).....	20
7.4.3 Water diffusion test.....	20
7.5 Water diffusion test on core with housing.....	20
8 Final tests (only mechanical tests).....	20
8.1 General.....	20
8.2 Test specimens.....	20
8.3 Preparation of the test specimen.....	21
8.4 Internal pressure test.....	22
8.4.1 General	22
8.4.2 Test procedure	22
8.4.3 Acceptance criteria	23
8.5 Bending test.....	23
8.5.1 General	23
8.5.2 Test procedure	23

8.5.3	Acceptance criteria	24
9	Sample tests	24
9.1	Selection and number of insulators	24
9.2	Testing	25
9.3	Verification of dimensions	25
9.3.1	Test procedure	25
9.3.2	Acceptance criteria	25
9.4	Mechanical tests	25
9.4.1	General	25
9.4.2	Test procedure	25
9.4.3	Acceptance criteria	26
9.5	Galvanizing test	26
9.6	Re-test procedure	26
10	Routine tests	27
10.1	General.....	27
10.2	Visual examination.....	27
10.3	Routine mechanical test.....	27
10.4	Routine pressure test.....	27
10.5	Routine tightness test	28
11	Documentation	28
Annex A (normative) Tolerances of form and position		33
Annex B (informative) General recommendations for design and construction.....		36
B.1	Guidance for design.....	36
B.2	Guidance for the maximum service pressure	36
B.3	Guidance on sample testing of tube material.....	36
B.4	Guidance for the temperature required by the equipment manufacturer.....	37
B.5	Guidance for the mechanical loads required by the equipment manufacturer	37
B.6	Summary of the tests	37
Annex C (informative) Principles of damage limit and use of reversible and irreversible strain caused by internal pressure and/or bending loads on composite hollow insulator tubes		41
C.1	Overview.....	41
C.2	Definition	41
C.3	Example of determining the strain tolerance.....	41
Annex D (informative) Principle sketch of hollow insulators design assembly		44
Annex E (informative) Type tests on tapered (conical) insulators		46
E.1	General.....	46
E.2	Minimum length on the most stressed cylindrical parts on shortened test specimens	46
E.3	Internal pressure test.....	47
E.4	Bending test.....	47
E.5	References	49
Bibliography.....		50
Figure 1 – Thermal-mechanical pre-stressing test – Typical cycles		29
Figure 2 – Thermal-mechanical pre-stressing test – Typical test arrangement.....		30
Figure 3 – Test arrangement for the leakage rate test.....		31
Figure 4 – Examples of sealing systems for composite hollow insulators		32

Figure A.1 – Parallelism, coaxiality and concentricity	33
Figure A.2 – Angular deviation of fixing holes: Example 1	34
Figure A.3 – Angular deviation of fixing holes: Example 2	34
Figure A.4 – Tolerances according to standard drawing practice.....	35
Figure B.1 – Relationship of bending loads	40
Figure B.2 – Relationship of pressures	40
Figure C.1 – Position of strain gauges for pressure load and bending load	42
Figure C.2 – Strain/time curve, reversible elastic phase.....	42
Figure C.3 – Strain/time curve, irreversible plastic phase, damage limit.....	43
Figure D.1 – Interface description for insulator with housing made by modular assembly	44
Figure D.2 – Interface description for insulator with housing made by injection molding and overmolded end fitting.....	45
Figure E.1 – Illustration of tapered insulators in bending.....	47
Figure E.2 – Illustration of axial membrane stress along the insulator when the length of the cylindrical parts is changed	48
Table 1 – Mechanical loads applied to the insulator	13
Table 2 – Pressures applied to the insulator	13
Table 3 – Tests to be carried out after design changes.....	15
Table 4 – Sample sizes.....	24
Table 5 – Choice of re-test procedure	26
Table B.1 – Loads/stress and classification of tests	38
Table B.2 – Example of pressure/bending values – Practical relationship of the values.....	39

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMPOSITE HOLLOW INSULATORS –
PRESSURIZED AND UNPRESSURIZED INSULATORS FOR USE
IN ELECTRICAL EQUIPMENT WITH AC RATED VOLTAGE GREATER
THAN 1 000 V AND DC VOLTAGE GREATER THAN 1 500 V –
DEFINITIONS, TEST METHODS, ACCEPTANCE CRITERIA
AND DESIGN RECOMMENDATIONS**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, issue IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61462 has been prepared by IEC technical committee 36: Insulators. It is an International Standard.

This new edition cancels and replaces the previous edition published in 2007. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) modifications of terms and definitions;
- b) modifications of tests procedures included in IEC TR 62039 and IEC 62217 (Hydrophobicity transfer test; Water diffusion test on the core with housing);
- c) modification of Clause 8 (type tests) to reflect common practice and to also consider tapered (conical) insulators;

- d) modification of order of the stages of mechanical sample test (9.4) by setting the tightness test as last stage;
- e) harmonization of Table 3 (Tests to be carried out after design changes) with other product standards;
- f) addition of a new informative Annex D: Principle sketch of hollow insulators design assembly;
- g) addition of a new informative Annex E: Type tests on tapered (conical) insulators.

The text of this International Standard is based on the following documents:

Draft	Report on voting
36/567/FDIS	36/586/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directive, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under wwwstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

Composite hollow insulators consist of an insulating tube bearing the mechanical load protected by an elastomeric housing, the loads being transmitted to the tube by metal fittings. Despite these common features, the materials used and the construction details employed by different manufacturers may vary.

Some tests have been grouped together as "Design tests" to be performed only once for insulators of the same design and material. The design tests are performed in order to eliminate designs and materials not suitable for high-voltage applications.

The relevant design tests defined in IEC 62217 are applied for composite hollow insulators; additional specific mechanical tests are given in this document. The influence of time on the electrical and mechanical properties of the complete composite hollow insulator and its components (tube material, housing material, interfaces, etc.) has been considered in specifying the design tests in order to ensure a satisfactory lifetime under normal service conditions. These conditions may also depend on the equipment inside or outside the composite hollow insulators; however, this matter has not been covered in this document. It is possible for test methods not specified in this document to be considered for specific combinations of materials and specific applications, and are a matter of agreement between manufacturers and users. In this document, the term "user" in general means the equipment manufacturer using composite hollow insulators.

Composite hollow insulators are used in both AC and DC applications. Before the appropriate standard for DC applications will be issued, the majority of tests listed in this document can also be applied to DC insulators. In spite of this, a specific tracking and erosion test procedure for DC applications as a design test is still being considered to be developed. Some information about the difference of AC and DC material erosion tests can be found in the CIGRE Technical Brochure 611. For the time being, the 1 000 h AC tracking and erosion test of IEC 62217 is used to establish a minimum requirement for the tracking and erosion resistance, for both AC and DC.

This document distinguishes between design tests and type tests because several general characteristics of a specific design and specific combinations of materials do not vary for different insulator types. In these cases, results from design tests can be adopted for different insulator types.

Pollution tests according to IEC 60507 or IEC 61245 are not included in this document since they are designed for non-polymeric items. Specific pollution tests for polymeric insulators are still under consideration.

The mechanical characteristics of composite hollow insulators are quite different compared to those of hollow insulators made of ceramics. In order to determine the onset of mechanical deterioration of composite hollow insulators under the influence of mechanical stress, strain gauge measurements are used.

This document refers to different characteristic pressures which are used for design and testing of composite hollow insulators. The term "maximum service pressure" (MSP) is equivalent to the term "design pressure" which is used in other standards for ceramic hollow insulators; however, this latter term is not used in this standard in order to avoid confusion with "design" as used in "design tests".

General recommendations for the design and construction of composite hollow insulators are presented in Annex B.

**COMPOSITE HOLLOW INSULATORS –
PRESSURIZED AND UNPRESSURIZED INSULATORS FOR USE
IN ELECTRICAL EQUIPMENT WITH AC RATED VOLTAGE GREATER
THAN 1 000 V AND DC VOLTAGE GREATER THAN 1 500 V –
DEFINITIONS, TEST METHODS, ACCEPTANCE CRITERIA
AND DESIGN RECOMMENDATIONS**

1 Scope

This document, which is an International Standard, applies to composite hollow insulators consisting of a load-bearing insulating tube made of resin impregnated fibre, a housing (outside the insulating tube) made of elastomeric material (for example silicone or ethylene-propylene) and metal fixing devices at the ends of the insulating tube (see Figure D.1 and Figure D.2 for examples). Composite hollow insulators as defined in this document are intended for general use (unpressurized) or for use with a permanent gas pressure (pressurized). They are intended for use in both outdoor and indoor electrical equipment operating on alternating current with a rated voltage greater than 1 000 V AC and a frequency not greater than 100 Hz or for use in direct current equipment with a rated voltage greater than 1 500 V DC.

The object of this document is:

- to define the terms used;
- to specify test methods;
- to specify acceptance criteria.

Hollow insulators are integrated into electrical equipment which is electrically type tested as required by the applicable equipment standard. So, it is not the object of this document to specify dielectric type tests because the withstand voltages and flashover behaviour are not characteristics of the hollow insulator itself but of the apparatus of which it ultimately forms a part.

All the tests in this document, apart from the thermal-mechanical test, are performed at normal ambient temperature. This document does not specify tests that might be characteristic of the equipment of which the hollow insulator ultimately forms a part.

Composite hollow insulators are intended for use in electrical equipment, such as, but not limited to:

- HV circuit-breakers,
- switch disconnectors,
- disconnectors,
- station posts,
- disconnecting circuit breakers,
- earthing switches,
- instrument- and power transformers,
- bushings,
- housing for surge arresters,
- cable terminations.

Additional testing defined by the relevant IEC equipment standard may be required.