



IEC 61784-5-3

Edition 1.0 2007-12

INTERNATIONAL STANDARD

**Industrial communication networks – Profiles –
Part 5-3: Installation of fieldbuses – Installation profiles for CPF 3**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XE**

ICS 35.100.05 25.040.40

ISBN 2-8318-9403-4

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references.....	10
3 Terms, definitions and abbreviated terms.....	10
4 CPF 3: Overview of installation profiles.....	10
5 Installation profile conventions.....	10
6 Conformance to installation profiles.....	11
Annex A (normative) CP 3/1 specific installation profile.....	11
A.1 Installation profile scope.....	12
A.2 Normative references.....	12
A.3 Installation profile terms, definitions, and abbreviated terms.....	12
A.3.1 Terms and definitions.....	12
A.3.2 Abbreviated terms.....	12
A.3.3 Conventions for installation profiles.....	13
A.4 Installation planning.....	13
A.4.1 Introduction.....	13
A.4.2 Planning requirements.....	13
A.4.3 Network capabilities.....	15
A.4.4 Selection and use of cabling components.....	18
A.4.5 Cabling planning documentation.....	28
A.4.6 Verification of cabling planning specification.....	28
A.5 Installation implementation.....	28
A.5.1 General requirements.....	28
A.5.2 Cable installation.....	28
A.5.3 Connector installation.....	31
A.5.4 Terminator installation.....	35
A.5.5 Device installation.....	35
A.5.6 Coding and labeling.....	35
A.5.7 Earthing and bonding of equipment and device and shielded cabling.....	35
A.5.8 As-implemented cabling documentation.....	36
A.6 Installation verification and installation acceptance test.....	36
A.6.1 Introduction.....	36
A.6.2 Installation verification.....	37
A.6.3 Installation acceptance test.....	38
A.7 Installation administration.....	44
A.8 Installation maintenance and installation troubleshooting.....	44
A.8.1 General.....	44
A.8.2 Maintenance.....	44
A.8.3 Troubleshooting.....	44
A.8.4 Specific requirements for maintenance and troubleshooting.....	44
Annex B (normative) CP 3/2 (PROFIBUS) specific installation profile.....	46
B.1 Installation profile scope.....	46
B.2 Normative references.....	46
B.3 Installation profile terms, definitions, and abbreviated terms.....	46
B.3.1 Terms and definitions.....	46
B.3.2 Abbreviated terms.....	47

B.3.3	Conventions for installation profiles	47
B.4	Installation planning	48
B.4.1	Introduction	48
B.4.2	Planning requirements	49
B.4.3	Network capabilities	57
B.4.4	Selection and use of cabling components	62
B.4.5	Cabling planning documentation	77
B.4.6	Verification of cabling planning specification	77
B.5	Installation implementation	77
B.5.1	General requirements	78
B.5.2	Cable installation	78
B.5.3	Connector installation	79
B.5.4	Terminator installation	80
B.5.5	Device installation	80
B.5.6	Coding and labelling	80
B.5.7	Earthing and bonding of equipment and device and shielded cabling	80
B.5.8	As-implemented cabling documentation	80
B.6	Installation verification and installation acceptance test	80
B.6.1	Introduction	80
B.6.2	Installation verification	80
B.6.3	Installation acceptance test	81
B.7	Installation administration	82
B.8	Installation maintenance and installation troubleshooting	82
Annex C (normative)	CP 3/3, CP 3/4, CP 3/5, CP 3/6 (PROFINET) specific installation profile	83
C.1	Installation profile scope	83
C.2	Normative references	83
C.3	Installation profile terms, definitions, and abbreviated terms	83
C.3.1	Terms and definitions	83
C.3.2	Abbreviated terms	83
C.3.3	Conventions for installation profiles	83
C.4	Installation planning	83
C.4.1	Introduction	83
C.4.2	Planning requirements	84
C.4.3	Network capabilities	84
C.4.4	Selection and use of cabling components	88
C.4.5	Cabling planning documentation	101
C.4.6	Verification of cabling planning specification	101
C.5	Installation implementation	101
C.5.1	General requirements	101
C.5.2	Cable installation	101
C.5.3	Connector Installation	104
C.5.4	Terminator installation	105
C.5.5	Device installation	105
C.5.6	Coding and labeling	105
C.5.7	Earthing and bonding of equipment and device and shielded cabling	105
C.5.8	As-implemented cabling documentation	106
C.6	Installation verification and installation acceptance test	106
C.6.1	Introduction	106
C.6.2	Installation verification	106

C.6.3	Installation acceptance test	108
C.7	Installation administration.....	109
C.8	Installation maintenance and installation troubleshooting	109
	Bibliography.....	110
Table A.1	– Excerpt of MICE definition.....	15
Table A.2	– Basic network characteristics for balanced cabling not based on Ethernet (ISO/IEC 8802-3).....	16
Table A.3	– Network characteristics for optical fibre cabling.....	17
Table A.4	– Information relevant to copper cable: fixed cables.....	19
Table A.5	– Information relevant to optical fibre cables.....	20
Table A.6	– Connectors for copper cabling CPs not based on Ethernet.....	21
Table A.7	– Optical fibre connecting hardware.....	21
Table A.8	– Parameters for balanced cables.....	29
Table A.9	– Parameters for silica optical fibre cables.....	29
Table A.10	– Parameters for POF optical fibre cables.....	29
Table A.11	– Parameters for hard cladded silica optical fibre cables.....	30
Table A.12	– Use of 9 pin Sub-D connector pins (RS 485).....	32
Table A.13	– Use of 9 pin Sub-D connector pins (RS 485-IS).....	33
Table A.14	– Use of M12 connector pins (RS 485).....	34
Table A.15	– Use of M12 connector pins (RS 485-IS).....	35
Table A.16	– Maximum fibre channel attenuation for CP 3/1 (PROFIBUS).....	44
Table B.1	– Valid parameter range of the FISCO model for use as EEx ib IIC / IIB.....	54
Table B.2	– Valid parameter range of the FISCO model for use as EEx ia IIC.....	54
Table B.3	– Power supply (operational values).....	60
Table B.4	– Minimum line lengths which can be achieved.....	60
Table B.5	– Limit values for distortion, reflection and signal delay.....	61
Table B.6	– Recommended maximum cable lengths including spurs.....	61
Table B.7	– Recommended length of the spurs.....	62
Table B.8	– Maximum length of the splices.....	62
Table B.9	– Information relevant to copper cable: fixed cables.....	63
Table B.10	– Safety limit values for the fieldbus cable.....	64
Table B.11	– Connectors for copper cabling CPs not based on Ethernet.....	65
Table B.12	– Mating devices from different categories.....	67
Table B.13	– Electrical characteristics of fieldbus interfaces.....	68
Table B.14	– Recommended data sheet specifications for CP 3/2 devices.....	69
Table B.15	– Parameters for balanced cables.....	78
Table B.16	– Contact assignments for the external connector for harsh industrial environments.....	79
Table C.1	– General transmission media selection information.....	85
Table C.2	– Network characteristics for balanced cabling based on Ethernet (ISO/IEC 8802-3).....	86
Table C.3	– Network characteristics for optical fibre cabling.....	87
Table C.4	– Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type A fixed cables.....	88

Table C.5 – Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type B fixed cables	89
Table C.6 – Information relevant to copper cable: CP 3/3, CP 3/4, CP 3/5 and CP 3/6 type C fixed cables	89
Table C.7 – Information relevant to optical fibre cables	90
Table C.8 – Requirements for plastic and polymer cladde optical fibre cables	91
Table C.9 – Requirements for glass multimode optical fibre cables	92
Table C.10 – Requirements for glass singlemode optical fibre cables	93
Table C.11 – Information relevant to hybrid cables	94
Table C.12 – Connectors for balanced cabling CPs based on Ethernet	95
Table C.13 – Optical fibre connecting hardware	95
Table C.14 – typical fibre channels common for industrial applications	98
Table C.15 – Parameters for balanced cables	102
Table C.16 – Parameters for silica optical fibre cables	102
Table C.17 – Parameters for POF optical fibre cables	102
Table C.18 – Parameters for hard cladde silica optical fibre cables	103
Table C.19 – colour coding for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 connectors	104
Table C.20 – Maximum fibre channel attenuation for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 (PROFINET)	108
Figure 1 – Standards relationships	9
Figure A.1 – Recommended combination of shielding and earthing for CP 3/1 networks with RS 485-IS	26
Figure A.2 – Sub-D connector pin numberings	32
Figure A.3 – 5-pin M-12 female socket	33
Figure A.4 – 5 pins M-12 male plug for CP 3/1	34
Figure A.5 – Test circuit A - resistance measurement of data line B and shield	39
Figure A.6 – Test circuit B - resistance measurement of data line A and shield	39
Figure A.7 – Test circuit C - resistance measurement of data line A, data line B, and shield	40
Figure A.8 – Test circuit D - resistance measurement between data line A and B	40
Figure A.9 – Resistance measurement without 9-pin Sub-D plug	40
Figure A.10 – Loop cable resistance (cable type A)	41
Figure A.11 – Action and resolution tree for measurement 1 (RS 485 and RS 485-IS)	42
Figure A.12 – Action and resolution tree for measurement 2 (RS 485 and RS 485-IS)	43
Figure A.13 – Action and resolution tree for measurement 3 (RS 485 and RS 485-IS)	43
Figure B.1 – Connection of CP 3/1 networks	49
Figure B.2 – Typical fieldbus architecture	52
Figure B.3 – Fieldbus with stations supplied by auxiliary power sources	52
Figure B.4 – Fieldbus model	56
Figure B.5 – Current modulation (Manchester II code)	56
Figure B.6 – CP 3/2 topology	57
Figure B.7 – Bus topology	58
Figure B.8 – Combination of the tree topology and the bus topology	58
Figure B.9 – Fieldbus extension	59
Figure B.10 – Recommended combination of shielding and earthing	72

Figure B.11 – Ideal combination of shielding and earthing	73
Figure B.12 – Capacitive grounding	74
Figure B.13 – Galvanic isolated field device.....	76
Figure B.14 – Pin assignment of the male and female connectors IEC 60947-5-2 (A-coding)	80
Figure C.1 – End-to-end link without interconnections.....	96
Figure C.2 – Assembled end-to-end link	96
Figure C.3 – Connectionless optical fibre link	97
Figure C.4 – Assembled optical fibre link	97
Figure C.5 – Shielded connectors for CP 3/3, CP 3/4, CP 3/5 and CP 3/6 fieldbus networks	100
Figure C.6 – Pin-assignment for a straight cable.....	104

Currently in preview, click buy full version

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – PROFILES

Part 5-3: Installation of fieldbuses – Installation profiles for CPF 3

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61784-5-3 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automatic.

This standard is to be used in conjunction with IEC 61918:2007.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/471/FDIS	65C/482/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61784-5 series, under the general title *Industrial communication networks – Profiles – Installation of fieldbuses*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of February 2009 have been included in this copy

Currently in preview, click buy full version

INTRODUCTION

This International Standard is one of a series produced to facilitate the use of communication networks in industrial control systems.

IEC 61918:2007 (Ed. 1.0) provides the common requirements for the installation of communication networks in industrial control systems. This installation profile standard provides the installation profiles of the communication profiles (CP) of a specific communication profile family (CPF) by stating which requirements of IEC 61918 fully apply and, where necessary, by supplementing, modifying, or replacing the other requirements (see Figure 1).

For general background on fieldbuses, their profiles, and relationship between the installation profiles specified in this standard, see IEC/TR 61158-1.

Each CP installation profile is specified in a separate annex of this standard. Each annex is structured exactly as the reference standard IEC 61918 for the benefit of the persons representing the roles in the fieldbus installation process as defined in IEC 61918 (planner, installer, verification personnel, validation personnel, maintenance personnel, administration personnel). By reading the installation profile in conjunction with IEC 61918, these persons immediately know which requirements are common for the installation of all CPs and which are modified or replaced. The conventions used to draft this standard are defined in Clause 5.

The provision of the installation profiles in one standard for each CPF (for example IEC 61784-5-3 for CPF 3), allows readers to work with standards of a convenient size.




Figure 1 – Standards relationships

INDUSTRIAL COMMUNICATION NETWORKS – PROFILES

Part 5-3: Installation of fieldbuses – Installation profiles for CPF 3

1 Scope

This part of IEC 61784 specifies the installation profiles for CPF 3 (PROFIBUS/PROFINET)¹.

The installation profiles are specified in the annexes. These annexes are read in conjunction with IEC 61918:2007.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61918:2007, *Industrial communication networks – Installation of communication networks in industrial premises*

The normative references of IEC 61918:2007, Clause 2, apply. For profile specific normative references, see A.2, B.2, and C.2.

¹ PROFIBUS and PROFINET are trade names of the non-profit organization PROFIBUS Nutzerorganisation e.V. (PNO). This information is given for the convenience of users of this International Standard and does not constitute an endorsement by IEC of the trade names holder or any of its products. Compliance to this profile does not require use of the trade names. Use of the trade names PROFIBUS and PROFINET requires permission of the trade name holder.