

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Adjustable speed electrical power drive systems
Part 5-1: Safety requirements – Electrical, thermal and energy**

**Entraînements électriques de puissance à vitesse variable –
Partie 5-1: Exigences de sécurité – Électrique, thermique et énergétique**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2022 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Adjustable speed electrical power drive systems –
Part 5-1: Safety requirements – Electrical, thermal and energy**

**Entraînements électriques de puissance à vitesse variable –
Partie 5-1: Exigences de sécurité – Électrique, thermique et énergétique**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 13.110; 29.130.99; 29.200

ISBN 978-2-8322-4155-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

| | |
|--|-----|
| FOREWORD..... | 15 |
| INTRODUCTION..... | 17 |
| 0.1 General..... | 17 |
| 0.2 Feedback from industry and national committees..... | 19 |
| 0.3 Requirement covered by other relevant parts of the IEC 61800 series | 19 |
| 1 Scope..... | 20 |
| 2 Normative references | 20 |
| 3 Terms and definitions | 24 |
| 4 Protection against hazards | 27 |
| 4.1 General..... | 40 |
| 4.2 <i>Single-fault conditions</i> and <i>abnormal operating conditions</i> | 41 |
| 4.3 Short-circuit and overload protection..... | 42 |
| 4.3.1 General | 42 |
| 4.3.2 Input short-circuit rating and available <i>output short-circuit current</i> | 43 |
| 4.3.3 Short-circuit coordination (upstream protection)..... | 44 |
| 4.3.4 Protection by several devices | 44 |
| 4.3.5 Motor overload and overtemperature protection | 45 |
| 4.3.6 <i>BDM/CDM</i> providing current limiting control..... | 46 |
| 4.4 Protection against electric shock..... | 46 |
| 4.4.1 General | 46 |
| 4.4.2 <i>Decisive voltage class (DVC)</i> | 46 |
| 4.4.3 Provision for <i>basic protection</i> | 53 |
| 4.4.4 Provision for <i>fault protection</i> | 56 |
| 4.4.5 Provisions for <i>enhanced protection</i> | 64 |
| 4.4.6 Protective measures | 65 |
| 4.4.7 <i>Insulation</i> | 67 |
| 4.4.8 Compatibility with residual current-operated protective devices (RCD)..... | 88 |
| 4.4.9 Capacitor discharge | 89 |
| 4.4.10 Access conditions for high-voltage sections of <i>BDM/CDM/PDS</i> (<i>interlock</i>)..... | 89 |
| 4.5 Protection against electrical energy hazards | 91 |
| 4.5.1 General | 91 |
| 4.5.2 Determination of hazardous electrical energy level | 92 |
| 4.5.3 Limited power sources | 92 |
| 4.6 Protection against fire and thermal hazards | 94 |
| 4.6.1 General | 94 |
| 4.6.2 Circuits and <i>components</i> representing a fire hazard | 94 |
| 4.6.3 Selection of <i>components</i> to mitigate the risk of a fire hazard | 94 |
| 4.6.4 Fire protection provided by <i>enclosures</i> | 95 |
| 4.6.5 Temperature limits..... | 96 |
| 4.7 Protection against mechanical hazards | 98 |
| 4.7.1 General | 98 |
| 4.7.2 Critical torsional speed | 99 |
| 4.7.3 Transient torque analysis..... | 99 |
| 4.7.4 Specific requirements for liquid cooled <i>BDM/CDM/PDS</i> | 99 |
| 4.7.5 Mechanical hazards from rotating parts | 101 |
| 4.7.6 Sharp edges | 102 |

| | | |
|---------|---|-----|
| 4.8 | <i>BDM/CDM/PDS</i> with multiple sources of supply | 102 |
| 4.8.1 | General | 102 |
| 4.8.2 | <i>Low-voltage</i> DC link sharing | 103 |
| 4.9 | Protection against environmental stresses | 103 |
| 4.9.1 | General | 103 |
| 4.9.2 | Protection against corrosion | 105 |
| 4.10 | Protection against excessive acoustic noise hazards | 105 |
| 4.10.1 | General | 105 |
| 4.10.2 | Acoustic noise level | 105 |
| 4.11 | Wiring and connections | 106 |
| 4.11.1 | General | 106 |
| 4.11.2 | <i>Insulation</i> of conductors | 107 |
| 4.11.3 | Stranded wire | 109 |
| 4.11.4 | Routing and clamping | 109 |
| 4.11.5 | Identification of conductors and terminals of <i>mains supply</i> and <i>non-mains supply</i> | 109 |
| 4.11.6 | Splices and connections | 110 |
| 4.11.7 | Accessible connections | 110 |
| 4.11.8 | Interconnections between parts of the <i>PDS</i> | 111 |
| 4.11.9 | Supply connections for <i>permanently connected BDM/CDM/PDS</i> | 111 |
| 4.11.10 | Supply connections for pluggable <i>BDM/CDM/PDS</i> | 111 |
| 4.11.11 | Terminals | 113 |
| 4.11.12 | Provisions for connecting the shield of shielded wire or cable | 116 |
| 4.12 | Mechanical requirements for <i>enclosures</i> | 117 |
| 4.12.1 | General | 117 |
| 4.12.2 | Handles and manual controls | 117 |
| 4.12.3 | Cast metal <i>enclosure</i> | 118 |
| 4.12.4 | Sheet metal <i>enclosure</i> | 118 |
| 4.12.5 | Stability for floor-standing <i>BDM/CDM/PDS</i> | 121 |
| 4.12.6 | Wiring strain relief | 121 |
| 4.12.7 | Polymeric <i>enclosure</i> stress relief | 122 |
| 4.12.8 | Internal condensation or accumulation of water | 122 |
| 4.12.9 | Polymer <i>enclosure</i> ultra-violet (UV) resistance | 122 |
| 4.13 | <i>Components</i> | 123 |
| 4.13.1 | <i>Components</i> general | 123 |
| 4.13.2 | <i>Components</i> representing a fire hazard | 123 |
| 4.13.3 | <i>Components</i> being part of an <i>enclosure</i> | 123 |
| 4.13.4 | <i>Components</i> representing a mechanical hazard | 124 |
| 4.13.5 | Wound <i>components</i> | 124 |
| 4.13.6 | Protective devices | 124 |
| 4.14 | Protection against electromagnetic fields | 124 |
| 5 | Test requirements | 124 |
| 5.1 | General | 124 |
| 5.1.1 | Test objectives and classification | 124 |
| 5.1.2 | Selection of test samples | 125 |
| 5.1.3 | Sequence of tests | 125 |
| 5.1.4 | Earthing conditions | 125 |
| 5.1.5 | General conditions for tests | 125 |
| 5.1.6 | Compliance | 126 |

| | | |
|---------------------|--|-----|
| 5.1.7 | Test overview | 126 |
| 5.2 | Test specifications | 129 |
| 5.2.1 | <i>Visual inspections (type test, routine test and sample test)</i> | 129 |
| 5.2.2 | Mechanical tests | 129 |
| 5.2.3 | Electrical tests | 138 |
| 5.2.4 | <i>Abnormal operation and simulated faults tests</i> | 157 |
| 5.2.5 | Material tests | 170 |
| 5.2.6 | Environmental tests (<i>type tests</i>) | 174 |
| 5.2.7 | Hydrostatic pressure test (<i>type test, routine test</i>) | 180 |
| 5.2.8 | Electromagnetic fields (EMF) test (<i>type test</i>) | 181 |
| 6 | Information and marking requirements | 181 |
| 6.1 | General | 181 |
| 6.1.1 | Overview | 181 |
| 6.1.2 | Documentation in electronic form | 184 |
| 6.1.3 | Installation Instructions | 185 |
| 6.2 | Information for selection | 185 |
| 6.2.1 | General | 185 |
| 6.2.2 | Instructions and markings pertaining to <i>accessories</i> | 187 |
| 6.3 | Information for installation and commissioning | 187 |
| 6.3.1 | General | 187 |
| 6.3.2 | Mechanical considerations | 187 |
| 6.3.3 | Environment | 187 |
| 6.3.4 | Handling and mounting | 188 |
| 6.3.5 | <i>Enclosure</i> temperature | 188 |
| 6.3.6 | Open type <i>BDM/CDM</i> | 188 |
| 6.3.7 | Connections | 189 |
| 6.3.8 | Commissioning | 191 |
| 6.3.9 | Protection requirements | 191 |
| 6.3.10 | Motor and driven equipment | 195 |
| 6.3.11 | Field installed <i>components</i> | 196 |
| 6.4 | Information for intended use | 196 |
| 6.4.1 | General | 196 |
| 6.4.2 | Adjustment | 196 |
| 6.4.3 | Labels, signs, symbols and signals | 196 |
| 6.4.4 | Hot surface | 198 |
| 6.4.5 | Control and device marking | 198 |
| 6.4.6 | Stability for floor-standing <i>BDM/CDM/PDS</i> | 199 |
| 6.5 | Supplementary information | 199 |
| 6.5.1 | General | 199 |
| 6.5.2 | Capacitor discharge | 199 |
| 6.5.3 | Special operation mode – Auto restart/bypass connection | 200 |
| 6.5.4 | Other hazards | 200 |
| 6.5.5 | <i>BDM/CDM/PDS</i> with multiple sources of supply | 200 |
| 6.5.6 | PT/CT connection | 200 |
| 6.5.7 | Access conditions for <i>high-voltage BDM/CDM/PDS</i> during maintenance | 200 |
| Annex A (normative) | Additional information for protection against electric shock | 202 |
| A.1 | General | 202 |
| A.2 | Protection by means of <i>DVC As</i> | 202 |
| A.3 | Protection by means of <i>protective impedance</i> | 203 |

| | | |
|---------|---|-----|
| A.4 | Protection by using limited voltages | 204 |
| A.5 | Evaluation of the <i>working voltage</i> of circuits..... | 204 |
| A.5.1 | General | 204 |
| A.5.2 | Classification of the <i>working voltage</i> | 205 |
| A.5.3 | AC <i>working voltage</i> | 205 |
| A.5.4 | DC <i>working voltage</i> | 206 |
| A.5.5 | Pulsating <i>working voltage</i> | 207 |
| A.6 | The concept of protective measures according to 4.4..... | 208 |
| A.6.1 | General | 208 |
| A.6.2 | General concept of protection against electric shock | 209 |
| A.6.3 | Examples of the use of elements of protective measures | 210 |
| Annex B | (informative) Considerations for the reduction of the pollution degree | 215 |
| B.1 | General..... | 215 |
| B.2 | Factors influencing the pollution degree | 215 |
| B.3 | Reduction of influencing factors | 215 |
| Annex C | (informative) Symbols referred..... | 216 |
| C.1 | Symbols used | 216 |
| C.2 | Determination of contrast..... | 218 |
| Annex D | (normative) Evaluation of <i>clearance</i> and <i>creepage distances</i> | 219 |
| D.1 | Measurement..... | 219 |
| D.2 | Relationship of measurement to pollution degree | 219 |
| D.3 | Examples..... | 219 |
| Annex E | (normative) Altitude correction for <i>clearances</i> | 226 |
| E.1 | Correction factor for <i>clearances</i> at altitudes above 2 000 m | 226 |
| E.2 | Test voltages for verifying <i>clearances</i> at different altitudes | 226 |
| Annex F | (normative) <i>Clearance</i> and <i>creepage distance</i> determination for frequencies greater than 30 kHz | 228 |
| F.1 | General influence of the frequency on the withstand characteristics..... | 228 |
| F.2 | <i>Clearance</i> | 228 |
| F.2.1 | General | 228 |
| F.2.2 | <i>Clearance</i> for homogenous fields | 229 |
| F.2.3 | <i>Clearance</i> for approximately homogenous fields | 230 |
| F.3 | <i>Creepage distance</i> | 231 |
| F.4 | <i>Solid insulation</i> | 232 |
| F.4.1 | General | 232 |
| F.4.2 | Approximately uniform field distribution without air gaps or voids..... | 232 |
| F.4.3 | Other cases | 233 |
| Annex G | (informative) Cross-sections of round conductors | 234 |
| Annex H | (informative) Guidelines for RCD compatibility | 235 |
| H.1 | Selection of RCD type..... | 235 |
| H.2 | Fault current waveforms..... | 236 |
| Annex I | (informative) Examples of overvoltage category reduction | 240 |
| I.1 | General..... | 240 |
| I.2 | Protection to the surroundings (see 4.4.7.2)..... | 240 |
| I.2.1 | Circuits connected directly to <i>mains supply</i> (see 4.4.7.2.3)..... | 240 |
| I.2.2 | Circuits connected to the <i>non-mains supply</i> (see 4.4.7.2.4) | 243 |
| I.2.3 | <i>Insulation</i> between circuits (see 4.4.7.2.5)..... | 243 |
| I.3 | <i>Functional insulation</i> (see 4.4.7.3) | 244 |

| | | |
|-----------------------|---|-----|
| I.4 | Further examples | 244 |
| Annex J (informative) | Burn thresholds for touchable surfaces | 246 |
| J.1 | General..... | 246 |
| J.2 | Burn thresholds | 246 |
| Annex K (informative) | Table of electrochemical potentials | 249 |
| Annex L (informative) | Measuring instrument for touch current measurements | 250 |
| L.1 | Measuring test circuit..... | 250 |
| L.2 | Requirements for measuring instruments | 250 |
| Annex M (normative) | Test probes for determining access | 251 |
| Annex N (informative) | Guidance regarding short-circuit current | 254 |
| Annex O (informative) | Guidance for determination of <i>clearance</i> and <i>creepage distance</i> | 255 |
| O.1 | Guideline for determination of <i>clearance</i> | 255 |
| O.2 | Guideline for determination of <i>creepage distance</i> | 256 |
| O.3 | Minimum <i>clearance</i> and <i>creepage distances</i> for material | 257 |
| Annex P (normative) | Protection of persons against electromagnetic fields for frequencies from 0 Hz up to 300 GHz | 258 |
| P.1 | General influence of electromagnetic fields to persons..... | 258 |
| P.1.1 | General | 258 |
| P.1.2 | Low-frequency electric field effects (1 Hz to 100 kHz)..... | 258 |
| P.1.3 | Low-frequency magnetic field effects (1 Hz to 100 kHz)..... | 258 |
| P.1.4 | Low-frequency electric and magnetic field effects | 258 |
| P.1.5 | High-frequency electromagnetic field effects (100 kHz to 300 GHz)..... | 258 |
| P.1.6 | Current knowledge on low-level effects..... | 259 |
| P.1.7 | Biological effects versus adverse health effects..... | 259 |
| P.1.8 | Influence of EMF on passive and active medical implants..... | 259 |
| P.2 | Recommendations from ICNIRP Guidelines against exposure to EMF..... | 259 |
| P.2.1 | Adoption of exposure limits from ICNIRP | 259 |
| P.2.2 | Limits of EMF exposure for transportation and storage | 261 |
| P.3 | Protection of persons against exposure of EMF | 261 |
| P.3.1 | General | 261 |
| P.3.2 | EMF requirements for general public access areas | 262 |
| P.3.3 | EMF requirements for <i>general-access areas</i> , <i>service-access areas</i> and <i>restricted-access areas</i> | 262 |
| P.3.4 | EMF requirements for transportation and storage | 262 |
| P.4 | Electromagnetic fields (EMF) test (<i>type test</i>)..... | 263 |
| P.4.1 | General test set up for EMF | 263 |
| P.4.2 | EMF test..... | 263 |
| P.5 | Electromagnetic fields (EMF) marking | 263 |
| Annex Q (informative) | Automatic disconnection of supply | 264 |
| Q.1 | Maximum disconnection times | 264 |
| Q.2 | Supplementary <i>protective equipotential bonding</i> | 265 |
| Annex R (informative) | Risk assessment according to IEC Guide 116 | 266 |
| R.1 | General..... | 266 |
| R.2 | Risk assessment..... | 266 |
| Annex S (informative) | In-some-country requirements – United States of America voltages less than 1,5 kV AC or DC | 268 |
| S.0 | General..... | 268 |
| S.1 | Scope | 268 |

| | | |
|-----------------------|---|-----|
| S.2 | Normative references..... | 268 |
| S.3 | Terms and definitions..... | 268 |
| S.4 | Protection against hazards..... | 269 |
| S.4.1 | General | 269 |
| S.4.2 | <i>Single-fault conditions and abnormal operating condition</i> | 269 |
| S.4.3 | Short-circuit and overload protection | 269 |
| S.4.4 | Protection against electric shock | 271 |
| S.4.5 | Protection against electrical energy hazards..... | 281 |
| S.4.6 | Protection against fire and thermal hazards..... | 281 |
| S.4.7 | Protection against mechanical hazards..... | 282 |
| S.4.8 | <i>BDM/CDM/PDS with multiple sources of supply</i> | 284 |
| S.4.9 | Protection against environmental stresses..... | 284 |
| S.4.10 | Protection against excessive acoustic noise hazards..... | 284 |
| S.4.11 | Wiring and connections | 284 |
| S.4.12 | Mechanical requirements for <i>enclosures</i> | 294 |
| S.4.200 | Auxiliary device | 306 |
| S.4.201 | <i>Accessories</i> | 306 |
| S.4.202 | Provisions for mounting | 306 |
| S.4.203 | Capacitors | 306 |
| S.5 | Test requirements..... | 307 |
| S.5.1 | General | 307 |
| S.5.2 | Test specifications..... | 308 |
| S.6 | Information and marking requirements | 328 |
| S.6.1 | General | 328 |
| S.6.2 | Information for selection | 328 |
| S.6.3 | Information for installation and commissioning..... | 329 |
| S.6.4 | Information for intended use..... | 333 |
| S.6.5 | Supplementary information..... | 333 |
| S.200 | Evaluation of clearance and <i>creepage distances</i> | 334 |
| S.200.1 | <i>Clearance and creepage distances</i> | 335 |
| S.201 | Normative references and component standards..... | 337 |
| S.202 | IEC to USA standard references | 340 |
| S.203 | Isolated secondary circuits and circuits supplied by battery | 343 |
| S.203.1 | Isolated secondary circuits | 343 |
| S.203.2 | Secondary circuits test | 349 |
| S.203.3 | Circuits supplied by a battery..... | 351 |
| S.204 | Full-load motor-running currents | 351 |
| Annex T (informative) | In-some-country requirements – Canada voltages up to 34,5 kV..... | 354 |
| T.0 | General..... | 354 |
| T.1 | Scope | 354 |
| T.2 | Normative references..... | 354 |
| T.3 | Terms and definitions..... | 356 |
| T.4 | Protection against hazards..... | 357 |
| T.4.1 | General | 357 |
| T.4.2 | <i>Single-fault conditions and abnormal operating condition</i> | 357 |
| T.4.3 | Short-circuit and overload protection | 357 |
| T.4.4 | Protection against electric shock | 358 |
| T.4.5 | Protection against electrical energy hazards..... | 367 |
| T.4.6 | Protection against fire and thermal hazards..... | 368 |

| | | |
|--------|--|-----|
| T.4.7 | Protection against mechanical hazards | 369 |
| T.4.8 | <i>BDM/CDM/PDS</i> with multiple sources of supply | 369 |
| T.4.9 | Protection against environmental stresses | 369 |
| T.4.10 | Protection against excessive acoustic noise hazards | 369 |
| T.4.11 | Wiring and connections | 369 |
| T.4.12 | Mechanical requirements for <i>enclosures</i> | 382 |
| T.4.13 | <i>Components</i> | 386 |
| T.4.14 | Protection against electromagnetic fields | 391 |
| T.5 | Test requirements | 391 |
| T.5.1 | General | 391 |
| T.5.2 | Test specifications | 391 |
| T.6 | Information and marking requirements | 416 |
| T.6.1 | General | 416 |
| T.6.2 | Information for selection | 418 |
| T.6.3 | Information for installation and commissioning | 419 |
| T.6.4 | Information for intended use | 421 |
| T.6.5 | Supplementary information | 423 |
| T.200 | IEC normative references replaced by CSA standards | 423 |
| | Bibliography | 426 |
| | Figure 1 – <i>PDS</i> hardware configuration within an <i>installation</i> | 35 |
| | Figure 2 – Time-voltage zones for <i>DVC A</i> s and <i>DVC B</i> circuits – DC | 50 |
| | Figure 3 – Time-voltage zones for <i>DVC A</i> s and <i>DVC B</i> circuits – AC peak | 51 |
| | Figure 4 – Time-voltage zones for conductive accessible parts | 52 |
| | Figure 5 – Example of a <i>protective class I BDM/CDM</i> arrangement and its associated <i>protective equipotential bonding</i> | 58 |
| | Figure 6 – Example of a <i>protective class I BDM/CDM</i> arrangement and its associated <i>protective equipotential bonding</i> through direct metallic contact | 59 |
| | Figure 7 – Example for interconnections within <i>BDM/CDM</i> and between parts of the <i>PDS</i> | 106 |
| | Figure 8 – Example for interconnections between parts of the <i>PDS</i> (<i>BDM/CDM</i> parts separated by field wiring) | 107 |
| | Figure 9 – Example arrangement of insulated conductors in a cable | 108 |
| | Figure 10 – Detachable <i>mains supply</i> cords and connections | 112 |
| | Figure 11 – Wire bending space | 116 |
| | Figure 12 – Supported and unsupported <i>enclosure</i> parts | 119 |
| | Figure 13 – Impact test using a steel ball | 135 |
| | Figure 14 – Voltage test procedures | 146 |
| | Figure 15 – Partial discharge test procedure | 148 |
| | Figure 16 – Electric strength test instrument | 154 |
| | Figure 17 – Mandrel | 155 |
| | Figure 18 – Initial position of mandrel | 155 |
| | Figure 19 – Final position of mandrel | 155 |
| | Figure 20 – Position of metal foil on insulating material | 156 |
| | Figure 21 – <i>Protective equipotential bonding</i> test set up | 160 |
| | Figure 22 – Example of short-circuit test between <i>BDM/CDM</i> motor power port and <i>protective earth</i> (motor separately earthed) | 162 |

| | |
|---|-----|
| Figure 23 – Example of short-circuit test between <i>BDM/CDM</i> motor power <i>port</i> and <i>protective earth</i> (motor earthed through <i>BDM/CDM</i>)..... | 162 |
| Figure 24 – Example of short-circuit test between <i>BDM/CDM</i> DC link power <i>port</i> and <i>protective earth</i> | 163 |
| Figure 25 – Interpolated values for Table 37 | 165 |
| Figure 26 – Circuit for high-current arcing test | 171 |
| Figure 27 – Test fixture for hot-wire ignition test | 172 |
| Figure A.1 – Protection by <i>DVC As</i> with <i>enhanced protection</i> | 202 |
| Figure A.2 – Protection by means of <i>protective impedance</i> | 203 |
| Figure A.3 – Protection by using limited voltages | 204 |
| Figure A.4 – Typical waveform for AC <i>working voltage</i> | 205 |
| Figure A.5 – Typical waveform for DC <i>working voltage</i> | 206 |
| Figure A.6 – Typical waveform for pulsating <i>working voltage</i> | 207 |
| Figure A.7 – Protective measures according to 4.4.1 to 4.4.5 for protection against electric shock considering <i>protective class I</i> and <i>protective class II BDM/CDM/PDS</i> | 209 |
| Figure A.8 – Protective measures according to 4.4.1 to 4.4.5 for protection against electric shock considering <i>protective class III BDM/CDM/PDS</i> and <i>DVC As</i> circuits | 210 |
| Figure D.1 – Example of measurements including a groove | 220 |
| Figure D.2 – Example of measurements including a groove | 220 |
| Figure D.3 – Example of measurements including a groove | 220 |
| Figure D.4 – Example of measurements including a rib..... | 220 |
| Figure D.5 – Example of measurements providing protection of type 2..... | 221 |
| Figure D.6 – Example of measurements providing protection of type 1..... | 221 |
| Figure D.7 – Example of measurements providing protection of type 1..... | 221 |
| Figure D.8 – Example of measurements providing protection of type 1..... | 222 |
| Figure D.9 – Example of measurements including a barrier (cemented joint)..... | 222 |
| Figure D.10 – Example of measurements including a barrier..... | 222 |
| Figure D.11 – Example of measurements including a gap | 223 |
| Figure D.12 – Example of measurements including a gap | 223 |
| Figure D.13 – Example of measurements including an floating conductive part..... | 224 |
| Figure D.14 – Example of measurements in inner layer of PWB..... | 224 |
| Figure D.15 – Example of measurements in an <i>enclosure</i> of insulating material..... | 225 |
| Figure F.1 – Diagram for dimensioning of <i>clearances</i> above 30 kHz | 229 |
| Figure F.2 – Diagram for dimensioning of <i>creepage distances</i> above 30 kHz | 231 |
| Figure F.3 – Permissible field strength for dimensioning of <i>solid insulation</i> according to Formula (F.1)..... | 233 |
| Figure H.1 – Flow chart leading to selection of the RCD type upstream of a <i>PDS</i> | 235 |
| Figure H.2 – Symbols for marking depending on the type of RCD | 236 |
| Figure H.3 – Fault current waveforms in connections with <i>BDM/CDM/PDS</i> | 239 |
| Figure I.1 – <i>Basic protection</i> evaluation for circuits connected to the origin of the <i>installation mains supply</i> | 240 |
| Figure I.2 – <i>Basic protection</i> evaluation for circuits connected to the <i>mains supply</i> | 241 |
| Figure I.3 – <i>Basic protection</i> evaluation for single and three phase <i>BDM/CDM/PDS</i> not <i>permanently connected</i> to the <i>mains supply</i> | 241 |
| Figure I.4 – <i>Basic protection</i> evaluation for circuits connected to the origin of the <i>installation mains supply</i> where internal SPDs are used..... | 241 |

| | |
|---|-----|
| Figure I.5 – <i>Basic protection</i> evaluation for circuits connected to the <i>mains supply</i> where internal SPDs are used..... | 242 |
| Figure I.6 – Example of <i>enhanced protection</i> evaluation for circuits connected to the <i>mains supply</i> where internal SPDs are used | 242 |
| Figure I.7 – Example of <i>enhanced protection</i> evaluation for circuits connected to the <i>mains supply</i> where internal SPDs are used | 242 |
| Figure I.8 – Example of <i>enhanced protection</i> evaluation for circuits connected to the <i>mains supply</i> where internal SPDs are used | 243 |
| Figure I.9 – <i>Basic protection</i> evaluation for circuits connected to the <i>non-mains supply</i> | 243 |
| Figure I.10 – <i>Basic protection</i> evaluation for circuits connected to the origin of the <i>installation non-mains supply</i> | 243 |
| Figure I.11 – <i>Functional insulation</i> evaluation within circuits affected by external transients..... | 244 |
| Figure I.12 – <i>Basic protection</i> evaluation for circuits connected to the <i>mains supply</i> and a non-mains circuit | 244 |
| Figure I.13 – <i>Insulation</i> evaluation for <i>accessible circuit</i> of <i>DVC As</i> | 245 |
| Figure J.1 – Burn threshold spread when the skin is in contact with a hot smooth surface made of bare (uncoated) metal..... | 246 |
| Figure J.2 – Rise in the burn threshold spread from Figure J.1 for metals which are coated by shellac varnish of a thickness of 50 µm, 100 µm and 150 µm..... | 247 |
| Figure J.3 – Rise in the burn threshold spread from Figure J.1 for metals coated with the specific materials | 247 |
| Figure J.4 – Burn threshold spread when the skin is in contact with a hot smooth surface made of ceramics, glass and stone materials | 248 |
| Figure J.5 – Burn threshold spread when the skin is in contact with a hot smooth surface made of plastics | 248 |
| Figure L.1 – Measuring test circuit | 250 |
| Figure M.1 – Sphere 50 mm probe according to IEC 61032:1997, test probe A..... | 251 |
| Figure M.2 – Jointed test finger according to IEC 61032:1997, test probe B..... | 252 |
| Figure M.3 – Test rod 2,5 mm according to IEC 61032:1997, test probe C | 253 |
| Figure M.4 – Sphere 12,5 mm test probe according to IEC 61032:1997, test probe 2..... | 253 |
| Figure O.1 – Flowchart <i>clearance</i> | 255 |
| Figure O.2 – Flowchart <i>creepage distance</i> | 256 |
| Figure S.1 – Articulate probe with web stop | 298 |
| Figure S.2 – Determination of current for circuits of 10 000 A and less | 318 |
| Figure S.3 – Peak let-through current | 322 |
| Figure S.4 – Application of Simpson's rule to fuse current oscillogram to obtain let-through I^2t | 323 |
| Figure S.5 – Clamped joint..... | 334 |
| Figure T.1 – Routing conductors through a metal barrier..... | 376 |
| Figure T.2 – Wire bending space | 381 |
| Figure T.3 – Test circuit using Formula T.1 | 400 |
| Figure T.4 – Test circuit using Formula T.2 | 401 |
| Figure T.5 – Test circuit using Formula T.3..... | 401 |
| Figure T.6 – Test circuit using Formula T.4 | 402 |
| Figure T.7 – Typical test set sensitivity | 403 |
| Figure T.8 – Determination of current and power factor for circuits of 10 000 A and less..... | 412 |

| | |
|--|-----|
| Table 1 – Alphabetical list of terms | 25 |
| Table 2 – Voltage limits for the <i>decisive voltage classes</i> | 49 |
| Table 3 – Protection requirements for circuits under consideration | 53 |
| Table 4 – <i>PE conductor</i> cross-section | 60 |
| Table 5 – Definitions of pollution degrees | 68 |
| Table 6 – <i>Impulse withstand voltage</i> and <i>temporary overvoltage</i> versus <i>system voltage</i> for <i>low-voltage</i> circuits | 71 |
| Table 7 – <i>Impulse withstand voltage</i> and <i>temporary overvoltage</i> versus <i>system voltage</i> for high-voltage circuits | 71 |
| Table 8 – <i>Clearance</i> for <i>functional insulation</i> , <i>basic insulation</i> or <i>supplementary insulation</i> | 76 |
| Table 9 – Insulating materials classification | 79 |
| Table 10 – <i>Creepage distances</i> | 80 |
| Table 11 – <i>Insulation</i> material requirements | 83 |
| Table 12 – Distance to uninsulated <i>live parts</i> for consideration of HWI, HAI and CTI | 83 |
| Table 13 – Generic materials for <i>insulation</i> material | 84 |
| Table 14 – Requirements based on thin sheet material thickness | 85 |
| Table 15 – Limits for power sources without an <i>overcurrent</i> protective device | 93 |
| Table 16 – Limits for power sources with an <i>overcurrent</i> protective device | 93 |
| Table 17 – Maximum measured temperatures for internal materials and <i>components</i> | 96 |
| Table 18 – Maximum measured temperatures for <i>accessible parts</i> of <i>BDM/CDM/PDS</i> | 98 |
| Table 19 – Minimum tubing wall thickness | 100 |
| Table 20 – Environmental service conditions | 104 |
| Table 21 – Wire bending space from terminals to <i>enclosure</i> | 115 |
| Table 22 – Thickness of sheet metal for <i>enclosures</i> : carbon steel or stainless steel | 120 |
| Table 23 – Thickness of sheet metal for <i>enclosures</i> : aluminium, copper or brass | 121 |
| Table 24 – Environmental conditions for tests | 126 |
| Table 25 – Test overview | 127 |
| Table 26 – Pull values for handles and manual control securement | 136 |
| Table 27 – Values for physical tests on strain relief of <i>enclosure</i> | 137 |
| Table 28 – <i>Impulse withstand voltage</i> test | 139 |
| Table 29 – <i>Impulse withstand voltage</i> test voltage for <i>low-voltage BDM/CDM/PDS</i> | 140 |
| Table 30 – <i>Impulse withstand voltage</i> test voltage for <i>high-voltage BDM/CDM/PDS</i> | 141 |
| Table 31 – AC or DC test voltage for circuits connected directly to <i>low-voltage mains supply</i> | 142 |
| Table 32 – AC or DC test voltage for circuits connected directly to <i>high-voltage mains supply</i> | 143 |
| Table 33 – AC or DC test voltage for circuits connected to <i>non-mains supply</i> without <i>temporary overvoltages</i> | 144 |
| Table 34 – Parameter for <i>BDM/CDM/PDS</i> AC or DC voltage test | 147 |
| Table 35 – Partial discharge test | 148 |
| Table 36 – <i>Prospective short-circuit current</i> for test vs <i>BDM/CDM</i> rated input current | 158 |
| Table 37 – Maximum tripping time for <i>electronic motor overload protection</i> test | 164 |
| Table 38 – Environmental tests | 175 |

| | |
|---|-----|
| Table 39 – Preconditioning or recovery procedure for climatic tests (<i>type test</i>) | 176 |
| Table 40 – Dry heat test (steady state) (<i>type test</i>)..... | 176 |
| Table 41 – Cold test (<i>type test</i>)..... | 177 |
| Table 42 – Damp heat test (steady state) (<i>type test</i>)..... | 177 |
| Table 43 – Damp heat test (cyclic) (<i>type test</i>)..... | 178 |
| Table 44 – Vibration test..... | 179 |
| Table 45 – Salt mist test..... | 179 |
| Table 46 – Dust test..... | 180 |
| Table 47 – Sand test..... | 180 |
| Table 48 – Marking location..... | 182 |
| Table A.1 – Configurations for protection against electric shock..... | 212 |
| Table C.1 – Symbols used..... | 216 |
| Table D.1 – Width of grooves by pollution degree..... | 219 |
| Table E.1 – Correction factor for <i>clearances</i> at altitudes between 2 000 m and 20 000 m..... | 226 |
| Table E.2 – Test voltages for verifying <i>clearances</i> at different altitudes..... | 227 |
| Table F.1 – Minimum values of <i>clearances</i> in air at atmospheric pressure for inhomogeneous field conditions..... | 230 |
| Table F.2 – Multiplication factors for <i>clearances</i> in air at atmospheric pressure for approximately homogeneous field conditions..... | 230 |
| Table F.3 – Minimum values of <i>creepage distances</i> for different frequency ranges..... | 232 |
| Table G.1 – Standard cross-sections of round conductors..... | 234 |
| Table K.1 – Table of electrochemical potentials..... | 249 |
| Table O.1 – Minimum <i>clearance</i> and <i>creepage distances</i> for material..... | 257 |
| Table P.1 – Limits of EMF for general public exposure..... | 260 |
| Table P.2 – Limits of EMF for occupational exposure..... | 261 |
| Table P.3 – Limits for magnetic flux density of static magnetic fields..... | 261 |
| Table P.4 – EMF test overview..... | 263 |
| Table 41.1 – Maximum disconnection times..... | 264 |
| Table R.1 – Risk assessment..... | 266 |
| Table S.1 – Size of bonding conductor..... | 273 |
| Table S.2 – Duration of current flow for bonding-conductor test..... | 273 |
| Table S.3 – Bonding conductor short-circuit test capacity..... | 273 |
| Table S.4 – Maximum rating of <i>overcurrent</i> device..... | 275 |
| Table S.5 – Dimensions of bushings..... | 277 |
| Table S.6 – <i>BDM/CDM/PDS</i> intended for installation in a feeder circuit..... | 277 |
| Table S.7 – <i>Generic materials for barriers</i> | 279 |
| Table S.8 – Tubing wall thickness..... | 283 |
| Table S.9 – Ampacity of flexible cord..... | 286 |
| Table S.10 – Ampacities of insulated conductors..... | 289 |
| Table S.11 – Wire bending space at the terminals of enclosed power conversion equipment..... | 291 |
| Table S.12 – <i>Overcurrent</i> protective device..... | 292 |
| Table S.13 – Branch-circuit <i>short-circuit protective device</i> | 293 |

| | |
|---|-----|
| Table S.14 – Openings in <i>enclosures</i> | 299 |
| Table S.15 – Addition to Table 3 of UL 50:2015: Thickness of sheet metal for <i>enclosures</i> – Carbon steel or stainless steel | 301 |
| Table S.16 – Addition to Table 4 of UL 50:2015: Thickness of sheet metal for <i>enclosures</i> – Aluminum, copper or brass..... | 301 |
| Table S.17 – Dimensions of knockout | 304 |
| Table S.18 – Values of voltage for tests..... | 307 |
| Table S.19 – AC or DC voltage test voltages | 310 |
| Table S.20 – Width of copper bus bars | 311 |
| Table S.21 – Production-line test conditions | 312 |
| Table S.22 – Power factor of test circuits for devices rated 600 V or less..... | 326 |
| Table S.23 – Minimum <i>clearances</i> and <i>creepage distances</i> at <i>field wiring terminals</i> up to 600 V..... | 335 |
| Table S.24 – Minimum <i>clearances</i> and <i>creepage distances</i> for <i>field wiring terminals</i> over 600 V..... | 336 |
| Table S.25 – <i>Clearances</i> and <i>creepage distances</i> at <i>field wiring terminals</i> for pollution degree 2 environments | 337 |
| Table S.26 – IEC normative reference standards that do not apply | 341 |
| Table S.27 – IEC normative references replaced by USA standards | 342 |
| Table S.28 – Secondary circuits, differences in evaluation..... | 344 |
| Table S.29 – Full-load motor-running currents in amperes corresponding to various AC horsepower ratings | 352 |
| Table S.30 – Full-load motor-running currents in amperes corresponding to various DC horsepower ratings | 353 |
| Table T.1 – Size and number of bonding conductors per termination | 359 |
| Table T.2 – Size of bonding conductor | 359 |
| Table T.3 – Minimum <i>clearance</i> and <i>creepage distances</i> on <i>field wiring terminals</i> | 361 |
| Table T.4 – Dimensions of bushings | 362 |
| Table T.5 – Test voltages for verifying <i>clearances</i> | 365 |
| Table T.6 – Test voltages for verifying <i>clearances</i> using AC RMS..... | 365 |
| Table T.7 – Generic material acceptable as a barrier | 366 |
| Table T.8 – Allowable ampacities of insulated copper conductors inside industrial control equipment <i>enclosures</i> (based on a <i>ambient temperature</i> of 40 °C)..... | 370 |
| Table T.9 – Ampacity correction factors for multiple conductor groupings | 370 |
| Table T.10 – Wiring space | 371 |
| Table T.11 – Wire-bending space | 372 |
| Table T.12 – Full-load motor-running currents in amperes corresponding to AC horsepower ratings | 373 |
| Table T.13 – Full-load motor-running currents in amperes corresponding to DC horsepower ratings | 374 |
| Table T.14 – Wire-bending space | 376 |
| Table T.15 – Test values for <i>BDM/CDM/PDS</i> wiring terminals..... | 378 |
| Table T.16 – Ampacity of conductors based on resistor duty cycle ratings | 379 |
| Table T.17 – Thickness of sheet metal for <i>enclosures</i> – Carbon steel or stainless steel..... | 383 |
| Table T.18 – Thickness of sheet metal for <i>enclosures</i> – Aluminum, copper, or brass | 384 |
| Table T.19 – Maximum acceptable rating of primary <i>overcurrent</i> device..... | 388 |

| | |
|--|-----|
| Table T.20 – Minimum acceptable rating of secondary <i>overcurrent</i> device | 388 |
| Table T.21 – <i>Overcurrent</i> protective device – Copper conductors | 389 |
| Table T.22 – <i>High-Voltage BDM/CDM/PDS</i> dielectric strength test values, kV..... | 391 |
| Table T.23 – Tightening torque for testing conduit hubs of polymeric <i>enclosures</i> | 394 |
| Table T.24 – Bending moment | 394 |
| Table T.25 – Test circuit sensitivity formulas..... | 400 |
| Table T.26 – Ampacities of insulated conductors | 405 |
| Table T.27 – Size of copper busbar connections for temperature test | 406 |
| Table T.28 – Short-circuit test values..... | 407 |
| Table T.29 – Short-circuit power factor | 411 |
| Table T.30 – Translation of markings | 416 |
| Table T.31 – IEC normative references replaced by CSA standards..... | 423 |

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ADJUSTABLE SPEED ELECTRICAL POWER DRIVE SYSTEMS –**Part 5-1: Safety requirements – Electrical, thermal and energy**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 61800-5-1 has been prepared by subcommittee 22G: Adjustable speed electric power drive systems (PDS), of IEC technical committee 22: Power electronic systems and equipment. It is an International Standard.

This third edition cancels and replaces the second edition published in 2007 and Amendment 1:2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) harmonization with IEC 62477-1:2022;
- b) harmonization with UL 61800-5-1 and CSA C22.2 No. 274, including an annex with a list of national deviation which was considered not possible to harmonize within a reasonable timeframe;
- c) more detailed information about the evaluation of components according to this document and relevant safety component standards;
- d) updated requirement for mechanical hazards including multiple IP ratings.

The text of this International Standard is based on the following documents:

| Draft | Report on voting |
|--------------|------------------|
| 22G/455/FDIS | 22G/457/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

In this document, terms in *italic* are defined in Clause 3.

The reader's attention is drawn to the fact that

- Annex S and Annex T list all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.
- Due to the rules of ISO/IEC Directives, Part 2, the term "must" instead of the term "shall" is used in Annex S and Annex T.

A list of all parts of the IEC 61800 series, published under the general title *Adjustable speed electrical power drive systems*, is available on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

0.1 General

This document contains the revision of IEC 61800-5-1:2007 and IEC 61800-5-1:2007/AMD1:2016.

Several important issues have influenced the scope and the chosen approach of the maintenance of IEC 61800-5-1:2007 in the development of this document.

The most significant changes compared to IEC 61800-5-1:2007 are the following.

a) Structure and content is based on IEC 62477-1 considering modifications and new topics such as the following

- Clause 1: Scope updated to include radio emitting/transmitting *BDM/CDM/PDS*.
- 4.1, 5.1, 6.1: "Intended use" included.
- 4.2: Single fault/abnormal operation analysis (significantly reworked).
- 4.3: Short-circuit and overload protection included as new subclause.
- 4.4 and Annex A: Protection against electric shock updated according to IEC 61140:2016 and IEC 60364-4-41, including insulation coordination according to IEC 60664 (all parts) considering the following:
 - 4.4.2 – Decisive voltage classification (especially DVC As for dry, wet and salt-water wet); Table 2 and Table 3 reworked;
 - 4.4.3 – Basic protection (reworked);
 - 4.4.4 – Fault protection (reworked);
 - 4.4.5 – Enhanced protection (reworked);
 - 4.4.7 – Insulation (reworked):
 - 4.4.7.1.2 – Working voltage (new);
 - 4.4.7.1.8 – Components bridging insulation (new);
 - 4.4.7.7 – *clearance* and *creepage distances* for functional insulation on PWB and component assemblies (reworked);
 - 4.4.7.8 – Solid insulation (new/reworked);
 - 4.4.7.9 – Connection of parts of solid insulation (cemented joints) (new);
 - 4.4.8/Annex H – Compatibility with RCD (reworked);
 - 4.4.10 – Access conditions for *high-voltage PDS* (new).
- 4.5: Protection against energy hazards (new).
- 4.6: Protection against fire and thermal hazards (new).
- 4.7: Protection against mechanical hazards (new).
- 4.8: *BDM/CDM/PDS* with multiple sources of supply (new).
- 4.9: Protection against environmental stresses (new) (in alignment with IEC 61800-2).
- 4.11: Wiring and connections updated (significantly reworked).
- 4.12: Enclosure updated (significantly reworked).
- 4.13 Bibliography: Evaluation of components (new).
- 4.14 Annex P: Protection against electromagnetic fields (new).
- Clause 5: Updated with some additional/modified test requirement:
 - 5.2.2.2 – Non-accessibility test (significantly reworked);
 - 5.2.2.3 – Ingress protection test (IP rating) (significantly reworked);

- 5.2.2.4 – Enclosure integrity tests (new);
- 5.2.2.5 – Wall or ceiling mounted *BDM/CDM/PDS* test (new);
- 5.2.2.6 – Handles and manual control securement test (new);
- 5.2.2.7 – Strain relief test (new);
- 5.2.3.7 – Touch current measurement test (reworked);
- 5.2.3.9 – Limited power source (new);
- 5.2.3.11 – Protective equipotential bonding test (new);
- 5.2.3.12 – Input test (new);
- 5.2.3.13 – Thin sheet material test (new);
- 5.2.3.14 – Test procedure for determination of working voltage (new);
- 5.2.3.16 – Preconditioning of material (reworked);
- 5.2.4.4 – Protective equipotential bonding short-circuit test (new);
- 5.2.4.9 – Output overload test (new);
- 5.2.4.13.5 – Covering of openings for cooling air test (type test) (new);
- 5.2.5.6 – Cemented joints test (new);
- 5.2.7 – Hydrostatic pressure test (new);
- 5.2.8 – Electromagnetic fields (EMF) test (new).
- Clause 6: – Update with more specific marking.
 - Structure aligned with IEC 62477-1 as close as possible;
 - Table 48 simplified.
- Annex A – Additional information for protection against electric shock (reworked).
- Annex C – Symbols referred (reworked).
- Annex E – Altitude correction for *clearances* (reworked).
- Annex F – *Clearance* and *creepage distance* determination for frequencies greater than 30 kHz (reworked).
- Annex H – Guidelines for RCD compatibility (reworked).
- Annex M – Test probes for determining access (new).
- Annex O – Guidance for determination of *clearance* and *creepage distance* (new).
- Annex P – Protection of persons against electromagnetic fields for frequencies from 0 Hz up to 300 GHz (new).
- Annex Q – Automatic disconnection of supply (new).
- Annex R – Guide 116 risk evaluation included (new).
- Bibliography – Relevant component safety standards (new).

b) Harmonization with UL 61800-5-1

Complete document is modified taken into consideration UL 61800-5-1 US National deviations. US National deviations from UL 61800-5-1 not possible to harmonize have been placed in Annex S.

c) Harmonization with CSA C22.2 No. 274

- Due to a short time frame, only some few topics have been harmonized.
- Canadian National deviations from CSA C22.2 No. 274 not possible to harmonize have been placed in Annex T.

d) Harmonization with UL 347A

- Some few relevant topics have been harmonized considering safety aspects related to *high-voltage BDM/CDM/PDS*.

Further harmonization is expected to be adopted in IEC 61800-5-1 considering the content of UL 61800-5-1, CSA C22.2 No 274 and UL 347A in future editions of IEC 61800-5-1.

0.2 Feedback from industry and national committees

The use of IEC 61800-5-1:2007 by manufacturers and test institutes since its release has identified several topics which are considered useful to implement, or topics which need further information for a better understanding of the intent of the specific requirement. These topics are also implemented in this document.

0.3 Requirement covered by other relevant parts of the IEC 61800 series

- general requirements for DC *power drive systems* are covered in IEC 61800-1;
- general requirements for AC *power drive systems* are covered in IEC 61800-2;
- EMC aspects are covered in IEC 61800-3;
- functional safety aspects are covered in IEC 61800-5-2;
- functional safety aspects for encoders are covered in IEC 61800-5-3;
- type of load duty aspects are covered in IEC TR 61800-6;
- communication profiles aspects are covered in IEC 61800-7 (all parts);
- *power interface* voltage aspects are covered in IEC TS 61800-8;
- ecodesign aspects are covered in IEC 61800-9 (all parts);

The following document is not part of the IEC 61800 series, but is used often as part of the BDM:

- active infeed converters in IEC TS 62578.

ADJUSTABLE SPEED ELECTRICAL POWER DRIVE SYSTEMS –

Part 5-1: Safety requirements – Electrical, thermal and energy

1 Scope

This part of IEC 61800 specifies requirements for adjustable speed electrical *power drive systems (PDS)* or their elements, with respect to electrical, thermal, fire, mechanical, energy and other relevant hazards. It does not cover the driven equipment except for interface requirements. It applies to adjustable speed electrical *PDS* which include the power conversion, *basic drive module (BDM)/complete drive module (CDM)* control, and a motor or motors.

Excluded are traction and electric vehicle *BDM/CDM*.

It applies to low-voltage adjustable speed electrical *PDS* intended to feed a motor or motors from a *BDM/CDM* connected to phase-to-phase voltages of up to and including 1,0 kV AC (50 Hz or 60 Hz) and up to and including 1,5 kV DC.

It also applies to high-voltage adjustable speed electrical *PDS* intended to feed a motor or motors from a *BDM/CDM* connected to phase-to-phase voltages of up to and including 35 kV AC (50 Hz or 60 Hz) and up to and including 52 kV DC.

NOTE 1 At the time of publication of this document, the technical upper voltage limit for DC motors is 2,25 kV DC.

NOTE 2 Above voltage and frequency limits reflect the scope of IEC 61800-1 and IEC 61800-2.

NOTE 3 For adjustable speed electrical *PDS* not covered by the scope of this document, applicable requirements of other standards, for example IEC 62477-1 and IEC 62477-2, can be used.

This document also applies to *PDS* which intentionally emit or receive radio waves for the purpose of radio communication.

Motors for driven equipment (see Figure 1) are covered by IEC 60034 (all parts).

NOTE 4 In some cases, safety requirements of the *PDS* (for example, protection against access to hazardous parts) can necessitate the use of special components and/or additional measures.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034 (all parts), *Rotating electrical machines*

IEC 60034-1:2022, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-5:2020, *Rotating electrical machines – Part 5: Degrees of protection provided by the integral design of rotating electrical machines (IP code) – Classification*

IEC 60050-112, *International Electrotechnical Vocabulary (IEV) – Part 112: Quantities and units* (available at www.electropedia.org)