

INTERNATIONAL STANDARD

IEC 61850-7-3

First edition
2003-05

Communication networks and systems in substations –

Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes

© IEC 2003 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE

XB

For price, see current catalogue

CONTENTS

FOREWORD	6
INTRODUCTION	8
1 Scope	9
2 Normative references.....	9
3 Terms and definitions	10
4 Abbreviated terms.....	10
5 Conditions for attribute inclusion.....	10
6 Common data attribute types	11
6.1 General	11
6.2 Quality.....	11
6.2.1 Overview.....	11
6.2.2 Validity.....	12
6.2.3 Detail quality.....	12
6.2.4 Source.....	13
6.2.5 Test	14
6.2.6 Blocked by operator.....	14
6.2.7 Quality in the client server context.....	14
6.2.8 Relation between quality identifiers.....	15
6.3 Analogue value.....	17
6.4 Configuration of analogue value	17
6.5 Range configuration.....	18
6.6 Step position with transient indication.....	18
6.7 Pulse configuration	19
6.8 Originator	19
6.9 Unit definition	20
6.10 Vector definition.....	20
6.11 Point definition.....	21
6.12 CtlModels definition.....	21
6.13 SboClasses definition.....	21
7 Common data class specifications	21
7.1 General	21
7.2 Name space	21
7.3 Common data class specifications for status information	22
7.3.1 Basic status information template	22
7.3.2 Single point status (SPS).....	22
7.3.3 Double point status (DPS).....	23
7.3.4 Integer status (INS).....	24
7.3.5 Protection activation information (ACT).....	24
7.3.6 Directional protection activation information (ACD)	25
7.3.7 Security violation counting (SEC).....	25
7.3.8 Binary counter reading (BCR)	26
7.4 Common data class specifications for measurand information	27
7.4.1 Basic measurand information template.....	27
7.4.2 Measured value (MV).....	28
7.4.3 Complex measured value (CMV).....	29
7.4.4 Sampled value (SAV).....	30

7.4.5	Phase to ground related measured values of a three phase system (WYE)	31
7.4.6	Phase to phase related measured values of a three phase system (DEL)	32
7.4.7	Sequence (SEQ)	33
7.4.8	Harmonic Value (HMV)	34
7.4.9	Harmonic value for WYE (HWYE)	35
7.4.10	Harmonic value for DEL (HDEL)	36
7.5	Common data class specifications for controllable status information	37
7.5.1	Application of services	37
7.5.2	Controllable single point (SPC)	38
7.5.3	Controllable double point (DPC)	39
7.5.4	Controllable integer status (INC)	40
7.5.5	Binary controlled step position information (BSC)	41
7.5.6	Integer controlled step position information (ISC)	42
7.6	Common data class specifications for controllable analogue information	43
7.6.1	Application of services	43
7.6.2	Controllable analogue set point information (APC)	44
7.7	Common data class specifications for status settings	45
7.7.1	Application of services	45
7.7.2	Single point setting (SPG)	45
7.7.3	Integer status setting (ING)	46
7.8	Common data class specifications for analogue settings	47
7.8.1	Application of services	47
7.8.2	Analogue setting (ASG)	47
7.8.3	Setting curve (CURVE)	48
7.9	Common data class specifications for description information	49
7.9.1	Basic description information template	49
7.9.2	Device name plate (DPL)	49
7.9.3	Logical node name plate (LPL)	50
7.9.4	Curve shape description (CSD)	50
8	Data attribute semantic	51
Annex A (normative) Value range for units and multiplier		60
Annex B (informative) Functional constraints		63
Figure 1 – Quality identifiers in a single client – server relationship		14
Figure 2 – Quality identifiers in a multiple client – server relationship		15
Figure 3 – Interaction of substitution and validity		16
Figure 4 – Configuration of command output pulse		19
Table 1 – Quality		11
Table 2 – Analogue value		17
Table 3 – Configuration of analogue value		17
Table 4 – Range configuration		18
Table 5 – Step position with transient indication		18
Table 6 – Pulse configuration		19
Table 7 – Originator		19
Table 8 – Values for orCat		20

Table 9 – Unit	20
Table 10 – Vector	20
Table 11 – Point	21
Table 12 – Name space attributes	22
Table 13 – Basic status information template	22
Table 14 – Single point status common data class definition	23
Table 15 – Double point status common data class specification	23
Table 16 – Integer status common data class specification	24
Table 17 – Protection activation information common data class specification	24
Table 18 – Directional protection activation information common data class specification	25
Table 19 – Security violation counting common data class specification	25
Table 20 – Binary counter reading common data class specification	26
Table 21 – Basic measurand information template	27
Table 22 – Measured value	28
Table 23 – Complex measured value	29
Table 24 – Sampled value	30
Table 25 – WYE	31
Table 26 – Delta	32
Table 27 – Sequence	33
Table 28 – Harmonic value	34
Table 29 – Harmonic values for WYE	35
Table 30 – Harmonic values for delta	36
Table 31 – Basic controllable status information template	37
Table 32 – Controllable single point	38
Table 33 – Controllable double point	39
Table 34 – Controllable integer status	40
Table 35 – Binary controlled step position information	41
Table 36 – Integer controlled step position information	42
Table 37 – Basic controllable analogue information template	43
Table 38 – Controllable analogue set point information	44
Table 39 – Basic status setting template	45
Table 40 – Single point setting	45
Table 41 – Integer status setting	46
Table 42 – Basic analogue setting template	47
Table 43 – Analogue setting	47
Table 44 – Setting curve	48
Table 45 – Basic description information template	49
Table 46 – Device name plate common data class specification	49
Table 47 – Logical node name plate common data class specification	50
Table 48 – Curve shape description common data class specification	50
Table 49 – Semantics of data attributes	51

Table A.1 – SI units: base units.....	60
Table A.2 – SI units: derived units.....	60
Table A.3 – SI units: extended units.....	61
Table A.4 – SI units: industry specific units.....	61
Table A.5 – Multiplier	62
Table B.1 – Functional constraints	63

Currently in preview, click buy full vers.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –

**Part 7-3: Basic communication structure for substation
and feeder equipment – Common data classes**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organisation for standardisation comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardisation in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organisations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organisation for Standardisation (ISO) in accordance with conditions determined by agreement between the two organisations.
- 2) The formal decisions or agreements of the IEC on technical matters expressed as early as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-3 has been prepared by IEC technical committee 57: Power system control and associated communications.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/618/FDIS	57/635/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 61850 consists of the following parts, under the general title *Communication networks and systems in substations*.

- Part 1: Introduction and overview
- Part 2: Glossary ¹
- Part 3: General requirements
- Part 4: System and project management
- Part 5: Communication requirements for functions and device models ²
- Part 6: Configuration description language for communication in electrical substations related to IEDs ¹
- Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models
- Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)
- Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes
- Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes
- Part 8-1: Specific communication service mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3
- Part 9-1: Specific communication service mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link
- Part 9-2: Specific communication service mapping (SCSM) – Sampled values over ISO/IEC 8802-3 ¹
- Part 10: Conformance testing ¹

The content of this part of IEC 61850 is based on existing or emerging standards and applications. In particular the definitions are based upon:

- the specific data types defined in IEC 60870-5-101 and IEC 60870-5-103;
- the common class definitions from the *Utility Communication Architecture 2.0: Generic Object Models for Substation & Feeder Equipment (GOMSFE) (IEEE TR 1550)*.

The committee has decided that the contents of this publication will remain unchanged until 2005. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

¹ Under consideration.

² To be published.

INTRODUCTION

This document is part of a set of specifications, which details layered substation communication architecture. This architecture has been chosen to provide abstract definitions of classes and services such that the specifications are independent of specific protocol stacks and objects. The mapping of these abstract classes and services to communication stacks is outside the scope of IEC 61850-7-x and may be found in IEC 61850-8-x (station bus) and IEC 61850-9-x (process bus).

IEC 61850-7-1 gives an overview of this communication architecture. This part of IEC 61850 defines common attribute types and common data classes related to substation applications. These common data classes are used in IEC 61850-7-4. To define compatible data classes, the attributes of the instances of data shall be accessed using services defined in IEC 61850-7-2.

This part is used to specify the **abstract common data class** definitions. These abstract definitions shall be mapped into concrete object definitions that are to be used for a particular protocol (for example MMS, ISO 9506).

COMMUNICATION NETWORKS AND SYSTEMS IN SUBSTATIONS –

Part 7-3: Basic communication structure for substation and feeder equipment – Common data classes

1 Scope

This part of IEC 61850 specifies common attribute types and common data classes related to substation applications. In particular it specifies:

- common data classes for **status information**,
- common data classes for **measured information**,
- common data classes for **controllable status information**,
- common data classes for **controllable analogue set point information**,
- common data classes for **status settings**,
- common data classes for **analogue settings** and
- **attribute types** used in these common data classes.

This international standard is applicable to the description of device models and functions of substations and feeder equipment.

This international standard may also be applied, for example, to describe device models and functions for:

- substation to substation information exchange,
- substation to control centre information exchange,
- power plant to control centre information exchange,
- information exchange for distributed generation, or
- information exchange for metering.

2 Normative references

The following reference documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*³

IEC 61850-7-1, *Communication networks and systems in substations – Part 7-1: Basic communication structure for substation and feeder equipment – Principles and models*

IEC 61850-7-2, *Communication networks and systems in substations – Part 7-2: Basic communication structure for substation and feeder equipment – Abstract communication service interface (ACSI)*

IEC 61850-7-4, *Communication networks and systems in substations – Part 7-4: Basic communication structure for substation and feeder equipment – Compatible logical node classes and data classes*

ISO 1000, *SI units and recommendations for the use of their multiples and of certain other units*

³ Under consideration.