

# INTERNATIONAL STANDARD

---

**Mobile and fixed offshore units – Electrical installations –  
Part 2: System design**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2012 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland

Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00  
[info@iec.ch](mailto:info@iec.ch)  
[www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

#### Useful links:

IEC publications search - [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - [webstore.iec.ch/justpublished](http://webstore.iec.ch/justpublished)

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - [webstore.iec.ch/csc](http://webstore.iec.ch/csc)

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: [csc@iec.ch](mailto:csc@iec.ch).



IEC 61892-2

Edition 2.0 2012-03

# INTERNATIONAL STANDARD

Mobile and fixed offshore units – Electrical installations –  
Part 2: System design

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE **XC**

ICS 47.020.60

ISBN 978-2-88912-993-5

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
2 Normative references .....	10
3 Terms and definitions .....	11
4 Sources of electrical power .....	15
4.1 General .....	16
4.2 Main source of electrical power .....	17
4.3 Emergency source of electrical power .....	18
4.4 Starting arrangements for emergency generators .....	21
4.5 Additional requirements for periodically unattended machinery spaces .....	22
4.6 General requirements for renewable sources of electrical power .....	22
4.6.1 Photovoltaic system.....	22
4.6.2 Eolic system .....	23
5 System earthing .....	23
5.1 General .....	23
5.2 General requirements.....	23
5.3 Neutral earthing methods .....	24
5.4 Neutral earthing for systems up to and including 1 000 V a.c.....	24
5.5 Neutral earthing for systems above 1 000 V .....	25
5.6 Generators operated in parallel with source transformers .....	25
5.7 Earthing resistors, connection to hull/structure .....	25
6 Distribution systems .....	27
6.1 DC distribution systems.....	27
6.1.1 Types of distribution systems .....	27
6.1.2 TN d.c. systems.....	28
6.1.3 IT d.c. systems .....	31
6.1.4 DC voltage .....	31
6.2 AC distribution systems.....	32
6.2.1 Primary a.c. distribution systems .....	32
6.2.2 Secondary a.c. distribution systems.....	32
6.2.3 TN a.c. systems.....	32
6.2.4 IT a.c. systems .....	34
6.2.5 AC voltages and frequencies .....	34
6.2.6 Control voltage .....	36
7 Distribution system requirements.....	37
7.1 Earthed distribution systems .....	37
7.2 Methods of distribution .....	37
7.3 Balance of loads.....	37
7.3.1 Balance of load on three-wire d.c. systems.....	37
7.3.2 Balance of loads in three- or four-wire a.c. systems.....	37
7.4 Final circuits.....	37
7.4.1 General .....	37
7.4.2 Final circuits for lighting.....	37
7.4.3 Final circuit for lighting in accommodation spaces .....	38

7.4.4	Final circuits in offices and workshops.....	38
7.4.5	Final circuits for heating .....	38
7.5	Control circuits .....	38
7.5.1	Supply systems and nominal voltages .....	38
7.5.2	Circuit design .....	38
7.5.3	Motor control .....	38
7.5.4	Protection.....	38
7.5.5	Arrangement of circuits.....	39
7.6	Socket-outlets .....	39
7.7	Shore connections for mobile units.....	39
7.8	Motor circuits .....	39
7.8.1	Starting of motors .....	39
7.8.2	Means of disconnection .....	40
7.8.3	Starters remote from motors .....	40
7.8.4	Master-starter system.....	40
8	Diversity (demand) factors.....	40
8.1	Final circuits.....	40
8.2	Circuits other than final circuits .....	40
8.3	Application of diversity (demand) factors .....	40
8.4	Motive power circuits – General .....	40
9	System study and calculations.....	41
9.1	General .....	41
9.2	Electrical load study .....	42
9.3	Load flow calculations .....	42
9.4	Short-circuit calculations .....	43
9.5	Protection and discrimination studies.....	44
9.6	Power system dynamic calculations .....	45
9.7	Calculation of harmonic currents and voltages.....	47
10	Protection.....	47
10.1	General .....	47
10.2	Characteristic and choice of protective devices with reference to short-circuit rating.....	48
10.2.1	General .....	48
10.2.2	Protective devices .....	48
10.2.3	Backup protection.....	48
10.2.4	Rated short-circuit breaking capacity.....	49
10.2.5	Rated short-circuit making capacity .....	49
10.2.6	Co-ordinated choice of protective devices with regard to discrimination requirements .....	49
10.3	Choice of protective devices with reference to overload .....	49
10.3.1	Mechanical switching devices .....	49
10.3.2	Fuses for overload protection .....	49
10.4	Choice of protective devices with regard to their application .....	50
10.4.1	General .....	50
10.4.2	Generator protection .....	50
10.4.3	Protection of essential services .....	51
10.4.4	Protection of transformers .....	51
10.4.5	Circuit protection .....	51
10.4.6	Motor protection .....	51

10.4.7	Protection of lighting circuits .....	52
10.4.8	Protection of power from external sources.....	52
10.4.9	Secondary cells and battery protection.....	52
10.4.10	Protection of meters, pilot lamps and control circuits .....	52
10.4.11	Protection of static or solid state devices.....	52
10.4.12	Protection for heat tracing systems .....	53
10.5	Undervoltage protection .....	53
10.5.1	Generators .....	53
10.5.2	AC and DC motors.....	53
10.6	Overtoltage protection .....	53
10.6.1	General .....	53
10.6.2	AC machines .....	53
10.6.3	DC networks.....	54
11	Lighting .....	54
11.1	General .....	54
11.2	General lighting system .....	54
11.3	Emergency lighting system .....	55
11.4	Escape lighting system.....	56
11.5	Lighting circuits in machinery spaces, accommodation spaces, open deck spaces, etc.....	57
11.6	Navigation and obstruction signals and lights .....	58
11.7	Luminaires .....	58
11.7.1	Discharge lamp luminaires of voltage above 250 V .....	58
11.7.2	Searchlights .....	58
12	Control and instrumentation.....	58
12.1	Safeguarding .....	58
12.2	Supply arrangement .....	58
12.3	Dependability.....	58
12.4	Safety .....	59
12.5	Segregation .....	59
12.6	Performance.....	59
12.7	Integration .....	59
12.8	Development activities.....	59
12.9	Electromagnetic compatibility .....	59
12.10	Design .....	59
12.10.1	Environmental and supply conditions .....	59
12.10.2	Circuit design .....	60
12.10.3	Monitoring equipment .....	60
12.10.4	Time delays .....	60
12.10.5	Closed circuits .....	60
12.10.6	Earth faults .....	60
12.11	Installation and ergonomics .....	60
12.11.1	General .....	60
12.11.2	Remote controls .....	60
12.12	Specific installations .....	61
12.12.1	Safety critical systems .....	61
12.12.2	Fire and gas protection control installations and other control systems .....	62
12.13	Automatic control installations for electrical power supply.....	63

12.13.1	General .....	63
12.13.2	Automatic starting .....	63
12.13.3	Automatic disconnection .....	64
12.13.4	Automatic starting installations for electrical motor-driven auxiliaries .....	64
12.13.5	Manual control .....	65
12.14	Machinery control installations .....	65
12.14.1	General .....	65
12.14.2	General requirement .....	65
12.15	Public address and general alarm systems .....	65
12.15.1	Audibility .....	65
12.15.2	Operation .....	65
12.15.3	Emergency broadcast .....	65
12.15.4	Minimum sound level .....	65
12.15.5	Fault tolerance .....	65
12.15.6	Redundancy .....	66
12.15.7	Segregation .....	66
12.15.8	Power supplies .....	66
12.15.9	Cabling .....	66
12.16	Computer-based systems .....	66
12.16.1	General .....	66
12.16.2	System integration .....	66
12.16.3	Power supply .....	66
12.16.4	Data communication links .....	67
12.16.5	Alarm, control and safety functions .....	67
12.17	Software .....	68
12.17.1	General .....	68
12.17.2	Configuration .....	68
12.17.3	Documentation .....	69
12.18	Tests .....	70
12.18.1	General .....	70
12.18.2	Hardware .....	70
12.18.3	Software .....	71
12.18.4	System testing .....	71
12.19	Documentation .....	71
12.19.1	Apparatus description .....	71
12.19.2	Circuit diagrams .....	71
13	Degrees of protection by enclosures .....	72
Annex A (informative)	Variable a.c. speed drives .....	76
Bibliography	.....	77
Figure 1	– Continuity of supply/continuity of service .....	16
Figure 2	– TN-S d.c. system .....	28
Figure 3	– TN-C d.c. system .....	29
Figure 4	– TN-C-S d.c. system .....	30
Figure 5	– IT d.c. system .....	31
Figure 6	– TN-S a.c. system .....	33
Figure 7	– TN-C-S a.c. system .....	33

Figure 8 – TN-C a.c. system ..... 34

Figure 9 – IT a.c. system ..... 34

Figure A.1 – Typical a.c. drilling system ..... 76

  

Table 1 – Recommended maximum earth fault currents ..... 25

Table 2 – Summary of principal features of the neutral earthing methods ..... 26

Table 3 – Voltages for d.c. systems ..... 32

Table 4 – AC systems having a nominal voltage between 100 V and 1 000 V inclusive  
and related equipment ..... 35

Table 5 – AC three-phase systems having a nominal voltage above 1 kV and not  
exceeding 35 kV and related equipment <sup>a</sup> ..... 36

Table 6 – General lighting illumination levels ..... 55

Table 7 – Recommended measuring points for measuring illumination in an area ..... 55

Table 8 – Escape lighting illumination levels ..... 56

Table 9 – Minimum requirements for the degree of protection for mobile and fixed  
offshore units (Degree of protection as defined in IEC 61892-1) ..... 73

Currently in preview, click buy full version

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –  
ELECTRICAL INSTALLATIONS –****Part 2: System design**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the manner in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, accept IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-2 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

This second edition cancels and replaces the first edition published in 2005. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- the d.c. voltage given in clause 1 has been updated to 1 500 V, to ensure consistency through all parts of the IEC 61892 series;
- Clause 4 has been rewritten, such that all requirements to emergency power are now given in 4.3;
- the tables for nominal a.c. voltages have been updated in accordance with the last revision of IEC 60038;

- the requirement to cross sectional area for earthing conductors has been made dependent on the system earthing arrangement;
- requirement for emergency stop for motor-driven fuel-oil transfer and fuel-oil pressure pumps has been added.

The text of this standard is based on the following documents:

FDIS	Report on voting
18/1240/FDIS	18/1255/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 61892 series, under the general title *Mobile and fixed offshore units – Electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

## INTRODUCTION

IEC 61892 forms a series of International Standards intended to enable safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilisation of electrical energy for all purposes in offshore units, which are being used for the purpose of exploration or exploitation of petroleum resources.

This part of IEC 61892 also incorporates and co-ordinates, as far as possible, existing rules and forms a code of interpretation, where applicable, of the requirements of the International Maritime Organisation (IMO), a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organisations.

This standard is based on equipment and practices, which are in current use, but it is not intended in any way to impede the development of new or improved techniques.

The ultimate aim has been to produce a set of International standards exclusively for the offshore petroleum industry.

# MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

## Part 2: System design

### 1 Scope

This part of IEC 61892 contains provisions for system design of electrical installations in mobile and fixed units used in the offshore petroleum industry for drilling, production, processing and for storage purposes, including pipeline, pumping or 'pigging' stations, compressor stations and exposed location single buoy moorings.

It applies to all installations, whether permanent, temporary, transportable or hand-held, to a.c. installations up to and including 35 000 V and d.c. installations up to and including 1 500 V. (a.c. and d.c. voltages are nominal values). This standard does not apply either to fixed equipment used for medical purposes or to the electrical installations of tankers.

### 2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2009, *IEC standard voltages*

IEC 60092-101:1994, *Electrical installations in ships – Part 101: Definitions and general requirements*

IEC 60092-504:2001, *Electrical installations in ships – Part 504: Special features – Control and instrumentation*

IEC 60447, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

IEC 60533, *Electrical and electronic installations in ships – Electromagnetic compatibility*

IEC 60909-0, *Short-circuit currents in three-phase a.c. systems – Part 0: Calculation of currents*

IEC 60909-1, *Short-circuit currents in three-phase a.c. systems – Part 1: Factors for the calculation of short-circuit currents according to IEC 60909-0*

IEC 60947-2:2006, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 61363-1, *Electrical installations of ships and mobile and fixed offshore units – Part 1: Procedures for calculating short-circuit currents in three-phase a.c.*

IEC 61511 (all parts), *Functional safety – Safety instrumented systems for the process industry sector*