



IEC 61892-7

Edition 2.0 2007-11

INTERNATIONAL STANDARD

**Mobile and fixed offshore units – Electrical installations –
Part 7: Hazardous areas**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XA**

ICS 47.020.60

ISBN 2-8318-9393-3

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references.....	9
3 Terms and definitions.....	10
4 Area classification.....	15
4.1 General.....	15
4.2 Safety principles.....	15
4.3 Sources of release.....	16
4.4 Type of zone.....	17
4.5 Relative density of the gas or vapour when it is released.....	17
4.6 Mobile drilling units.....	17
4.6.1 Zone 0.....	18
4.6.2 Zone 1.....	18
4.6.3 Zone 2.....	18
4.6.4 Well test facilities.....	18
4.7 Fixed production units.....	18
4.7.1 Zone 0.....	19
4.7.2 Zone 1.....	19
4.7.3 Zone 2.....	19
4.7.4 Drilling facilities.....	19
4.8 Mobile production units.....	19
4.9 Provisions regarding mobile and fixed offshore units.....	20
4.10 Openings, access and ventilation conditions affecting the extent of hazardous areas.....	20
4.10.1 General.....	20
4.10.2 Enclosed space with direct access to any zone 1 location.....	20
4.10.3 Enclosed space with direct access to any zone 2 location.....	20
4.10.4 An enclosed space with direct access to any zone 1 location.....	20
4.10.5 Notices.....	21
5 Electrical systems.....	21
5.1 Sources of electrical power.....	21
5.2 Distribution systems.....	21
5.2.1 General.....	21
5.2.2 Earth fault detection.....	21
5.3 Electrical protection.....	21
5.4 Emergency conditions due to drilling operations – Mobile drilling units.....	22
5.5 Emergency switch-off – Ignition source control – Fixed production units.....	22
5.6 Protection from dangerous sparking.....	23
5.6.1 Dangers from live parts.....	23
5.6.2 Dangers from exposed and extraneous conductive parts.....	23
5.6.3 Potential equalization.....	24
5.6.4 Static electricity.....	24
5.6.5 Lightning protection.....	24
5.6.6 Cathodically protected metallic parts.....	25

5.6.7	Electromagnetic radiation	25
5.7	Danger from rotating parts	25
6	Electrical equipment	25
6.1	General	25
6.2	Selection of electrical apparatus	25
6.2.1	Selection with respect to area classification	25
6.2.2	Selection with respect to ignition temperature of the gas or vapour	25
6.2.3	Selection according to apparatus grouping	26
6.2.4	External influences	26
6.2.5	Ambient temperature	27
6.3	Electrical apparatus in hazardous areas	27
6.3.1	Equipment for zone 0	27
6.3.2	Equipment for zone 1	27
6.3.3	Equipment for zone 2	27
6.3.4	Apparatus with multiple types of protection	28
6.4	Selection of apparatus not available in accordance with IEC standards	28
6.5	Portable apparatus	28
7	Installation	29
7.1	General	29
7.2	Selection of apparatus	29
7.3	Wiring system – General	29
7.4	Connections	30
7.5	Unused openings	30
7.6	Circuits traversing a hazardous area	30
7.7	Unused cores	30
7.8	Cable surface temperature	30
7.9	Jointing	30
7.10	Cable wiring systems	31
7.11	Conduit systems	31
7.12	Mixed systems	32
7.13	Apparatus in hazardous areas	33
7.14	Wiring system in zone 0	33
7.15	Intrinsically safe electrical installations	34
7.16	Simple apparatus	35
7.17	Verification of intrinsically safe circuits	36
7.18	Additional requirements for type of protection “d” – Flameproof enclosures	36
7.18.1	General	36
7.18.2	Solid obstacles	36
7.18.3	Protection of flameproof joints	36
7.18.4	Cable entry system	37
7.19	Additional requirements for type of protection “e” – Increased safety	39
7.19.1	Cable entry for Ex e equipment	39
7.19.2	Cage induction motors – Overload protection	39
7.19.3	Motors – Varying frequency and voltage	40
7.20	Additional requirements for type of pressurization “p” – Pressurized apparatus	40
7.20.1	General	40
7.20.2	Ducting	41

7.20.3	Action to be taken on failure of pressurization – Apparatus without an internal source of release	41
7.20.4	Purging.....	42
7.21	Resistance-heating devices.....	43
8	Ventilation	43
8.1	General.....	43
8.2	Ventilation of spaces containing electrical apparatus.....	44
8.3	Ventilation and operation of rooms or buildings protected by pressurization	44
8.4	Values of overpressure and of protective gas flow	45
8.5	Failure of the pressurization	45
8.6	Ventilation of battery compartments	46
8.6.1	Stationary batteries – Vented and valve regulated types.....	46
8.6.2	Hermetically sealed lead-acid batteries	48
8.6.3	Fans and ducts.....	49
8.7	Ventilation of other hazardous spaces	49
9	Inspection and maintenance	49
9.1	General.....	49
9.2	Inspection	49
9.3	Isolation of apparatus.....	50
9.4	Precautions concerning the use of ignition sources	50
9.5	Maintenance.....	50
9.6	Qualifications of personnel	50
10	Documentation	50
10.1	Area classification	50
10.2	Drawings, data sheets and tables.....	51
10.3	Ventilation	51
10.4	Apparatus.....	51
10.4.1	Apparatus for use in zone 0 or zone 1	51
10.4.2	Apparatus for use in zone 2.....	51
10.5	Installation – General.....	52
10.5.1	Installation of rooms or buildings protected by pressurization	52
10.5.2	Installation of electrical apparatus and electrical systems with the type of protection "i"	52
10.6	Maintenance.....	52
10.7	Administration of the documentation.....	52
	Annex A (informative) Examples of sources of release – Process plant.....	53
	Bibliography.....	59
	Figure 1 – Examples of mixed wiring systems	33
	Figure 2 – Selection chart for cable entry devices into flameproof enclosures for cables complying with item b) of 7.18.4.3.....	38
	Figure C.1 – Preferred symbols for hazardous area zones	58
	Table 1 – Relationship between the temperature classes, surface temperatures and ignition temperatures	26

Table 2 – Minimum distance of obstacles from the flameproof flange joints related to the gas/vapour subgroup of the hazardous area	36
Table 3 – Use of spark and particle barrier	41
Table 4 – Action to be taken when the pressurization with protective gas fails for electrical apparatus without an internal source of release	42
Table 5 – Summary of protective measures to be taken in the event of failure of pressurization	46
Table 6 – Values for current I when charging with constant current / constant voltage chargers	48
Table C.1 – Hazardous area classification data sheet – Part I: Flammable material list and characteristics – Sheet: 1/1	56
Table C.2 – Hazardous area classification data sheet – Part II: List of sources of release – Sheet: 1/1	57

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MOBILE AND FIXED OFFSHORE UNITS –
ELECTRICAL INSTALLATIONS –****Part 7: Hazardous areas**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61892-7 has been prepared by IEC technical committee 18: Electrical installations of ships and of mobile and fixed offshore units.

This second edition cancels and replaces the first edition published in 1997. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the clauses regarding area classification have been updated based on changes in IEC 60079-10;
- b) the clauses regarding emergency shut down have been updated, based on current industry practice;
- c) the clauses regarding installation have been updated based on changes in IEC 60079-14;
- d) a new clause regarding ventilation of battery compartment for valve regulated batteries has been added.

The text of this standard is based on the following documents:

FDIS	Report on voting
18/1066/FDIS	18/1072/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61892 series, under the general title *Mobile and fixed offshore units – Electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

IEC 61892 forms a series of International Standards intended to ensure safety in the design, selection, installation, maintenance and use of electrical equipment for the generation, storage, distribution and utilization of electrical energy for all purposes in offshore units which are used for the exploration or production of petroleum resources.

This part of IEC 61892 also incorporates and co-ordinates, as far as possible, existing rules and forms a code of interpretation, where applicable, of the requirements laid down by the International Maritime Organization, and constitutes a guide for future regulations which may be prepared and a statement of practice for offshore unit owners, constructors and appropriate organizations.

This standard is based on equipment and practices which are in current use, but it is not intended in any way to impede development of new or improved techniques.

The ultimate aim has been to produce a set of International Standards exclusively for the offshore petroleum industry.

MOBILE AND FIXED OFFSHORE UNITS – ELECTRICAL INSTALLATIONS –

Part 7: Hazardous areas

1 Scope

This part of IEC 61892 contains provisions for hazardous areas classification and choice of electrical installation in hazardous areas in mobile and fixed offshore units, including pipelines, pumping or 'pigging' stations, compressor stations and exposed location single buoy moorings, used in the offshore petroleum industry for drilling, processing and for storage purposes.

It applies to all installations, whether permanent, temporary, transportable or hand-held, to a.c. installations up to and including 35 000 V and d.c. installations up to and including 750 V.(a.c. and d.c. voltages are nominal values).

This standard does not apply to electrical installations in rooms used for medical purposes, or in tankers.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60079-0:2007, *Explosive atmospheres – Part 0: Equipment – General requirements*

IEC 60079-1:2007, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosure "d"*

IEC 60079-2:2007, *Explosive atmospheres – Part 2: Equipment protection by pressurized enclosure "p"*

IEC 60079-5:2007, *Explosive atmospheres – Part 5: Equipment protection by powder filling "q"*

IEC 60079-6:2007, *Explosive atmospheres – Part 6: Equipment protection by oil immersion "o"*

IEC 60079-7:2006, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-10, *Electrical apparatus for explosive gas atmospheres – Part 10: Classification of hazardous areas*

IEC 60079-11:2006, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"*

IEC 60079-14:2002, *Electrical apparatus for explosive gas atmospheres – Part 14: Electrical installations in hazardous areas (other than mines)*

IEC 60079-15:2005, *Electrical apparatus for explosive gas atmospheres – Part 15: Construction, test and marking of type of protection “n” electrical apparatus*

IEC 60079-18:2004, *Electrical apparatus for explosive gas atmospheres – Part 18: Construction, test and marking of type of protection encapsulation “m” electrical apparatus*

IEC 60079-20, *Electrical apparatus for explosive gas atmospheres – Part 20: Data for flammable gases and vapours, relating to the use of electrical apparatus*

IEC 60079-26:2006, *Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga*

IEC 61892-1, *Mobile and fixed offshore units – Electrical installations – Part 1: General requirements and conditions*

IEC 61892-2, *Mobile and fixed offshore units – Electrical installations – Part 2: System design*

IEC 61892-3, *Mobile and fixed offshore units – Electrical installations – Part 3: Equipment*

IEC 61892-4, *Mobile and fixed offshore units – Electrical installations – Part 4: Cables*

IEC 61892-5, *Mobile and fixed offshore units – Electrical installations – Part 5: Mobile units*

IEC 61892-6, *Mobile and fixed offshore units – Electrical installations – Part 6: Installation*

IMO MODU code: *Code for the construction and equipment of mobile offshore drilling units*