

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electricity metering data exchange – The DLMS/COSEM suite –
Part 6-2: COSEM interface classes**

**Échange des données de comptage de l'électricité – La suite DLMS/COSEM –
Partie 6-2: Classes d'interfaces COSEM**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2017 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electricity metering data exchange – The DLMS/COSEM suite –
Part 6-2: COSEM interface classes**

**Échange des données de comptage de l'électricité – La suite DLMS/COSEM –
Partie 6-2: Classes d'interfaces COSEM**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 17.220; 35.110; 91.140.50

ISBN 978-2-8322-4771-6

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	10
INTRODUCTION.....	12
1 Scope.....	14
2 Normative references	14
3 Terms, definitions and abbreviated terms	17
3.1 Terms and definitions related to the Image transfer process (see 5.3.6).....	17
3.2 Terms and definitions related to the S-FSK PLC setup classes (see 5.9)	18
3.3 Terms and definitions related to the PRIME NB OFDM PLC setup ICs (see 5.11).....	19
3.4 Terms and definitions related to ZigBee® (see 5.13).....	21
3.5 Terms and definitions related to Payment metering interface classes (see 5.5).....	22
3.6 Terms and definitions related to the Arbitrator IC (see 5.4.12)	27
3.7 Abbreviated terms.....	27
4 Basic principles	31
4.1 General.....	31
4.2 Referencing methods	32
4.3 Reserved base_names for special COSEM objects	33
4.4 Class description notation.....	33
4.5 Common data types	35
4.6 Data formats	37
4.6.1 Date and time formats	37
4.6.2 Floating point number formats	39
4.7 The COSEM server model	41
4.8 The COSEM logical device	42
4.8.1 General	42
4.8.2 COSEM logical device name (LDN)	42
4.8.3 The “association view” of the logical device	42
4.8.4 Mandatory contents of a COSEM logical device.....	43
4.8.5 Management of logical device.....	43
4.9 Information security	43
5 The COSEM interface classes	44
5.1 Overview	44
5.2 Interface classes for parameters and measurement data	48
5.2.1 Data (class_id = 1, version = 0)	48
5.2.2 Register (class_id = 3, version = 0)	49
5.2.3 Extended register (class_id = 4, version = 0)	53
5.2.4 Demand register (class_id = 5, version = 0).....	54
5.2.5 Register activation (class_id = 6, version = 0).....	57
5.2.6 Profile generic (class_id = 7, version = 1)	59
5.2.7 Utility tables (class_id = 26, version = 0)	64
5.2.8 Register table (class_id = 61, version = 0).....	65
5.2.9 Status mapping (class_id = 63, version = 0)	67
5.2.10 Compact data	69
5.3 Interface classes for access control and management	77
5.3.1 Overview	77
5.3.2 Client user identification	78

5.3.3	Association SN (class_id = 12, version = 4)	78
5.3.4	Association LN (class_id = 15, version = 3)	83
5.3.5	SAP assignment (class_id = 17, version = 0)	90
5.3.6	Image transfer	90
5.3.7	Security setup (class_id = 64, version = 1)	98
5.3.8	Push interface classes and objects	105
5.3.9	COSEM data protection	111
5.3.10	Function control (class_id: 122, version: 0)	129
5.3.11	Array manager (class_id = 123, version = 0)	131
5.4	Interface classes for time- and event bound control	138
5.4.1	Clock (class_id = 8, version = 0)	138
5.4.2	Script table (class_id = 9, version = 0)	140
5.4.3	Schedule (class_id = 10, version = 0)	142
5.4.4	Special days table (class_id = 11, version = 0)	145
5.4.5	Activity calendar (class_id = 20, version = 0)	146
5.4.6	Register monitor (class_id = 21, version = 0)	149
5.4.7	Single action schedule (class_id = 22, version = 0)	150
5.4.8	Disconnect control (class_id = 70, version = 0)	151
5.4.9	Limiter (class_id = 71, version = 0)	154
5.4.10	Parameter monitor (class_id = 65, version = 0)	157
5.4.11	Sensor manager interface class	158
5.4.12	Arbitrator	162
5.4.13	Modelling examples: tariffication and billing	166
5.5	Payment metering related interface classes	168
5.5.1	Overview of the COSEM accounting model	168
5.5.2	Account (class_id = 111, version = 0)	170
5.5.3	Credit interface class	180
5.5.4	Charge (class_id = 112, version = 0)	190
5.5.5	Token gateway (class_id = 115, version = 0)	196
5.6	Interface classes for setting up data exchange via local ports and modems	199
5.6.1	IEC local port setup (class_id = 19, version = 1)	199
5.6.2	IEC HDLC setup (class_id = 23, version = 1)	200
5.6.3	IEC twisted pair (1) setup (class_id = 24, version = 1)	202
5.6.4	Modem configuration (class_id = 27, version = 1)	204
5.6.5	Auto answer (class_id = 28, version = 2)	206
5.6.6	Auto connect (class_id = 29, version = 2)	209
5.6.7	PRS modem setup (class_id = 45, version = 0)	211
5.6.8	GSM diagnostic (class_id: 47, version: 1)	212
5.6.9	LTE monitoring (class_id: 151, version: 0)	214
5.7	Interface classes for setting up data exchange via M-Bus	215
5.7.1	Overview	215
5.7.2	M-Bus slave port setup (class_id = 25, version = 0)	216
5.7.3	M-Bus client (class_id = 72, version = 1)	216
5.7.4	Wireless Mode Q channel (class_id = 73, version = 1)	221
5.7.5	M-Bus master port setup (class_id = 74, version = 0)	222
5.7.6	DLMS/COSEM server M-Bus port setup (class_id = 76, version = 0)	222
5.7.7	M-Bus diagnostic (class_id = 77, version = 0)	225
5.8	Interface classes for setting up data exchange over the Internet	227
5.8.1	TCP-UDP setup (class_id = 41, version = 0)	227

5.8.2	IPv4 setup (class_id = 42, version = 0)	228
5.8.3	IPv6 setup (class_id = 48, version = 0)	231
5.8.4	MAC address setup (class_id = 43, version = 0)	234
5.8.5	PPP setup (class_id = 44, version = 0)	235
5.8.6	SMTP setup (class_id = 46, version = 0).....	239
5.8.7	NTP setup (class_id = 100, version = 0)	240
5.9	Interface classes for setting up data exchange using S-FSK PLC	242
5.9.1	General	242
5.9.2	Overview	242
5.9.3	S-FSK Phy&MAC set-up (class_id = 50, version = 1)	244
5.9.4	S-FSK Active initiator (class_id = 51, version = 0)	249
5.9.5	S-FSK MAC synchronization timeouts (class_id = 52, version = 0).....	251
5.9.6	S-FSK MAC counters (class_id = 53, version = 0).....	253
5.9.7	IEC 61334-4-32 LLC setup (class_id = 55, version = 1)	256
5.9.8	S-FSK Reporting system list (class_id = 56, version = 0).....	257
5.10	Interface classes for setting up the LLC layer for ISO/IEC 8802-2	258
5.10.1	General	258
5.10.2	ISO/IEC 8802-2 LLC Type 1 setup (class_id = 57, version = 0).....	258
5.10.3	ISO/IEC 8802-2 LLC Type 2 setup (class_id = 58, version = 0).....	259
5.10.4	ISO/IEC 8802-2 LLC Type 3 setup (class_id = 59, version = 0).....	260
5.11	Interface classes for setting up and managing DLMS/COSEM narrowband OFDM PLC profile for PRIME networks	262
5.11.1	Overview	262
5.11.2	Mapping of PRIME NB OFDM PLC PIB attributes to COSEM IC attributes	263
5.11.3	61334-4-32 LLC SCS setup (class_id = 80, version = 0).....	265
5.11.4	PRIME NB OFDM PLC Physical layer parameters	266
5.11.5	PRIME NB OFDM PLC Physical layer counters (class_id = 81, version = 0)	266
5.11.6	PRIME NB OFDM PLC MAC setup (class_id = 82, version = 0)	267
5.11.7	NB OFDM PLC MAC functional parameters (class_id = 83 version = 0)	268
5.11.8	PRIME NB OFDM PLC MAC counters (class_id = 84, version = 0)	270
5.11.9	PRIME NB OFDM PLC MAC network administration data (class_id = 85, version = 0)	271
5.11.10	PRIME NB OFDM PLC MAC address setup (class_id = 86, version = 0)	274
5.11.11	PRIME NB OFDM PLC Application identification (class_id = 86, version = 0)	274
5.12	Interface classes for setting up and managing the DLMS/COSEM narrowband OFDM PLC profile for G3-PLC networks	275
5.12.1	Overview	275
5.12.2	Mapping of G3-PLC PIB attributes to COSEM IC attributes	275
5.12.3	G3-PLC MAC layer counters (class_id = 90, version = 1).....	277
5.12.4	G3-PLC MAC setup (class_id = 91, version = 1)	278
5.12.5	G3-PLC 6LoWPAN adaptation layer setup (class_id = 92, version = 1).....	283
5.13	Interface classes for setting up and managing DLMS/COSEM HS-PLC ISO/IEC 12139-1 neighbourhood networks.....	290
5.13.1	Overview	290
5.13.2	HS-PLC ISO/IEC 12139-1 MAC setup (class_id = 140, version = 0).....	290
5.13.3	HS-PLC ISO/IEC 12139-1 CPAS setup (class_id = 141, version = 0)	291
5.13.4	HS-PLC ISO/IEC 12139-1 IP SSAS setup (class_id = 142, version = 0).....	292

5.13.5	HS-PLC ISO/IEC 12139-1 HDLC SSAS setup (class_id = 143, version = 0)	293
5.14	ZigBee® setup classes	293
5.14.1	Overview	293
5.14.2	ZigBee® SAS startup (class_id = 101, version = 0).....	295
5.14.3	ZigBee® SAS join (class_id = 102, version = 0).....	297
5.14.4	ZigBee® SAS APS fragmentation (class_id = 103, version = 0)	298
5.14.5	ZigBee® network control (class_id = 104, version = 0).....	298
5.14.6	ZigBee® tunnel setup (class_id = 105, version = 0)	305
5.15	Maintenance of the interface classes	307
5.15.1	New versions of interface classes.....	307
5.15.2	New interface classes.....	307
5.15.3	Removal of interface classes	307
6	Relation to OBIS.....	307
6.1	General.....	307
6.2	Abstract COSEM objects.....	308
6.2.1	Use of value group C	308
6.2.2	Data of historical billing periods	309
6.2.3	Billing period values / reset counter entries	310
6.2.4	Other abstract general purpose OBIS codes	310
6.2.5	Clock objects (class_id = 8).....	311
6.2.6	Modem configuration and related objects	311
6.2.7	Script table objects (class_id = 9)	311
6.2.8	Special days table objects (class_id = 11)	313
6.2.9	Schedule objects (class_id = 10)	313
6.2.10	Activity calendar objects (class_id = 20)	314
6.2.11	Register activation objects (class_id = 6).....	314
6.2.12	Single action schedule objects (class_id = 22).....	314
6.2.13	Register monitor objects (class_id = 21)	315
6.2.14	Parameter monitor objects (class_id = 65).....	315
6.2.15	Limiter objects (class_id = 71)	315
6.2.16	Array management objects (class_id = 123).....	315
6.2.17	Payment metering related objects.....	315
6.2.18	IEC M-cap port setup objects (class_id = 19)	316
6.2.19	Standard readout profile objects (class_id = 7)	316
6.2.20	IEC HDLC setup objects (class_id = 23)	317
6.2.21	IEC twisted pair (1) setup objects (class_id = 24)	317
6.2.22	Objects related to data exchange over M-Bus.....	318
6.2.23	Objects to set up data exchange over the Internet	319
6.2.24	Objects for setting up data exchange using S-FSK PLC.....	320
6.2.25	Objects for setting up the ISO/IEC 8802-2 LLC layer	321
6.2.26	Objects for data exchange using narrowband OFDM PLC for PRIME networks.....	321
6.2.27	Objects for data exchange using narrow-band OFDM PLC for G3-PLC networks.....	322
6.2.28	ZigBee® setup objects.....	322
6.2.29	Objects for data exchange using HS-PLC ISO/IEC 12139-1 ISO/IEC 12139-1 networks	323
6.2.30	Association objects (class_id = 12, 15)	323
6.2.31	SAP assignment object (class_id = 17).....	323

6.2.32	COSEM logical device name object	324
6.2.33	Information security related objects	324
6.2.34	Image transfer objects (class_id = 18)	325
6.2.35	Function control objects (class_id = 122)	325
6.2.36	Utility table objects (class_id = 26)	325
6.2.37	Compact data objects (class_id = 62)	326
6.2.38	Device ID objects	326
6.2.39	Metering point ID objects	327
6.2.40	Parameter changes and calibration objects	327
6.2.41	I/O control signal objects	327
6.2.42	Disconnect control objects (class_id = 70)	327
6.2.43	Arbitrator objects (class_id = 68)	328
6.2.44	Status of internal control signals objects	328
6.2.45	Internal operating status objects	328
6.2.46	Battery entries objects	329
6.2.47	Power failure monitoring objects	329
6.2.48	Operating time objects	330
6.2.49	Environment related parameters objects	330
6.2.50	Status register objects	330
6.2.51	Event code objects	330
6.2.52	Communication port log parameter objects	331
6.2.53	Consumer message objects	331
6.2.54	Currently active tariff objects	331
6.2.55	Event counter objects	331
6.2.56	Profile entry digital signature objects	332
6.2.57	Meter tamper event related objects	332
6.2.58	Error register objects	332
6.2.59	Alarm register, Alarm filter and Alarm descriptor objects	333
6.2.60	General list objects	334
6.2.61	Event log objects	334
6.2.62	Inactive objects	334
6.3	Electricity related COSEM objects	335
6.3.1	Value group D definitions	335
6.3.2	Electricity ID numbers	335
6.3.3	Billing period values / reset counter entries	335
6.3.4	Other electricity related general purpose objects	336
6.3.5	Measurement algorithm	337
6.3.6	Metering point ID (electricity related)	339
6.3.7	Electricity related status objects	339
6.3.8	List objects – Electricity (class_id = 7)	339
6.3.9	Threshold values	340
6.3.10	Register monitor objects (class_id = 21)	341
6.4	Coding of OBIS identifications	341
7	Previous versions of interface classes	342
7.1	General	342
7.2	Profile generic (class_id = 7, version = 0)	342
7.3	Association SN (class_id = 12, version = 0)	345
7.4	Association SN (class_id = 12, version = 1)	348
7.5	Association SN (class_id = 12, version = 2)	350

7.6	Association SN (Class_id = 12, version =3).....	353
7.7	Association LN (class_id = 15, version = 0).....	358
7.8	Association LN (class_id = 15, version = 1).....	362
7.9	Association LN (class_id = 15, version = 2).....	368
7.10	Security setup (class_id = 64, version = 0).....	374
7.11	IEC local port setup (class_id = 19, version = 0)	376
7.12	IEC HDLC setup, (class_id = 23, version = 0)	377
7.13	IEC twisted pair (1) setup (class_id = 24, version = 0)	378
7.14	PSTN modem configuration (class_id = 27, version = 0)	379
7.15	Auto answer (class_id = 28, version = 0).....	381
7.16	PSTN auto dial (class_id = 29, version = 0)	383
7.17	Auto connect (class_id = 29, version = 1).....	384
7.18	GSM diagnostic (class_id = 47, version = 0)	385
7.19	S-FSK Phy&MAC setup (class_id = 50, version = 0)	387
7.20	S-FSK IEC 61334-4-32 LLC setup (class_id = 55, version = 0)	391
7.21	Compact data (class_id = 62, version = 0)	392
7.22	M-Bus client (class_id = 72, version = 0).....	395
7.23	G3 NB OFDM PLC MAC layer counters (class_id = 90, version = 0)	400
7.24	G3 NB OFDM PLC MAC setup (class_id = 91, version = 0).....	401
7.25	G3 NB OFDM PLC 6LoWPAN adaptation layer setup (class_id = 92, version = 0).....	405
Annex A (informative) Additional information on Auto answer and Auto connect ICs		411
Annex B (informative) Additional information to M-Bus client (class_id = 72, version 1)		413
Annex C (informative) Additional information on IPv6 setup class (class_id = 48, version = 0)		415
C.1	General.....	415
C.2	IPv6 addressing.....	415
C.3	IPv6 header format	416
C.4	IPv6 header extensions	417
C.4.1	Overview	417
C.4.2	Hop-by-Hop options	418
C.4.3	Destination options	418
C.4.4	Routing options	418
C.4.5	Fragment options.....	419
C.4.6	Security options.....	419
Annex D (informative) Overview of the narrow-band OFDM PLC technology for PRIME networks.....		420
Annex E (informative) Overview of the narrow-band OFDM PLC technology for G3-PLC networks		421
Annex F (informative) Significant technical changes with respect to IEC 62056-6-2, Edition 2.0:2016.....		422
Bibliography.....		423
Index		425
Figure 1 – The meaning of the definitions concerning the Image		18
Figure 2 – An interface class and its instances		32
Figure 3 – The COSEM server model.....		41
Figure 4 – Combined metering device		42

Figure 5 – Overview of the interface classes – Part 1.....	44
Figure 6 – Overview of the interface classes – Part 2.....	45
Figure 7 – The time attributes when measuring sliding demand	54
Figure 8 – The attributes in the case of block demand	54
Figure 9 – The attributes in the case of sliding demand (number of periods = 3)	55
Figure 10 – Image transfer process flow chart.....	96
Figure 11 – COSEM model of push operation	105
Figure 12 – Push windows and delays	107
Figure 13 – COSEM model of data protection	113
Figure 14 – Example: Read <i>protection_buffer</i> attribute.....	115
Figure 15 – Example of managing an array	132
Figure 16 – The generalized time concept.....	138
Figure 17 – State diagram of the Disconnect control IC.....	152
Figure 18 – Definition of upper and lower thresholds.....	161
Figure 19 – COSEM tariffication model (example).....	167
Figure 20 – COSEM billing model (example).....	167
Figure 21 – Outline Account model	169
Figure 22 – Diagram of attribute relationships.....	170
Figure 23 – Credit States when priority >0	181
Figure 24 – Operation of <i>current_credit_status</i> flags.....	183
Figure 25 – Interaction of <i>current_credit_amount</i> and <i>available_credit</i> with Token “Credit” and Emergency “Credit”	189
Figure 26 – Object model of DLMS/COSEM servers	242
Figure 27 – Object model of DLMS/COSEM servers	263
Figure 28 – Example of a ZigBee® network	294
Figure 29 – Data of historical billing periods – example with module 12, VZ = 5.....	309
Figure A.1 – Network connectivity example for a GSM/GPRS network	411
Figure B.1 – Encryption key status diagram	413
Figure C.1 – IPv6 address formats.....	415
Figure C.2 – IPv6 header format.....	416
Figure C.3 – Traffic class parameter format	417
Table 1 – Reserved base_names for SN referencing.....	33
Table 2 – Common data types	36
Table 3 – List of interface classes by class_id	46
Table 4 – Enumerated values for physical units	50
Table 5 – Examples for <i>scaler_unit</i>	53
Table 6 – Daily billing data.....	73
Table 7 – Attributes of the “Compact data” object	74
Table 8 – A-XDR encoding of the data (SEQUENCE OF Get-Data-Result).....	74
Table 9 – Diagnostic and Alarm data	75
Table 10 – Attributes of the “Compact data” object	75
Table 11 – Encoding the data read from the buffer attribute of a “Profile generic” object.....	75

Table 12 – Logbook data	76
Table 13 – Attributes of the “Compact data” object	76
Table 14 – Attributes of the “Compact data” object	77
Table 15 – A-XDR encoding of the data read from the <i>buffer</i> attribute.....	77
Table 16 – Encoding of selective access parameters with <i>data_index</i>	111
Table 17 – Key information required to establish data protection keys	124
Table 18 – Protection parameters of <i>protection_parameters_get</i> attribute	125
Table 19 – Protection parameters of <i>protection_parameters_set</i> attribute	126
Table 20 – Protection parameters of <i>get_protected_attributes</i> method	127
Table 21 – Protection parameters of <i>set_protected_attributes</i> method	128
Table 22 – Protection parameters of <i>invoke_protected_method</i> method.....	129
Table 23 – Schedule	142
Table 24 – Special days table	142
Table 25 – Disconnect control IC – states and state transitions.....	153
Table 26 – Explicit presentation of threshold value arrays.....	162
Table 27 – Explicit presentation of <i>action_sets</i>	162
Table 28 – Credit states.....	180
Table 29 – Credit state transitions	181
Table 30 – ADS address elements	204
Table 31 – Fatal error register	204
Table 32 – Mapping IEC 61334-4-512:2001 MIB variables to COSEM IC attributes / methods.....	243
Table 33 – MAC addresses in the S-FSK profile.....	249
Table 34 – Mapping of PRIME NB OFDM PLC PIB attributes to COSEM IC attributes.....	264
Table 35 – Mapping of G3-PLC IB attributes to COSEM IC attributes.....	276
Table 36 – Use of ZigBee® setup COSEM interface classes	295
Table 37 – Use of value group C for abstract objects in the COSEM context.....	308
Table 38 – Representation of various values by appropriate ICs	335
Table 39 – Measuring algorithms – enumerated values.....	338
Table 40 – Threshold objects, electricity	340
Table 41 – Register monitor objects, electricity.....	341
Table B.1 – Encryption key is preset in the slave and cannot be changed	414
Table B.2 – Encryption key is preset in the slave and new key is set after installation.....	414
Table B.3 – Encryption key is not preset in the slave, but can be set, case a)	414
Table B.4 – Encryption key is not preset in the slave, but can be set, case b)	414
Table C.1 – IPv6 header vs. IPv6 IC	417
Table C.2 – Optional IPv6 header extensions vs. IPv6 IC.....	418

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRICITY METERING DATA EXCHANGE – THE DLMS/COSEM SUITE –

Part 6-2: COSEM interface classes

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this International Standard may involve the use of a maintenance service concerning the stack of protocols on which the present standard IEC 62056-6-2 is based.

The IEC takes no position concerning the evidence, validity and scope of this maintenance service.

The provider of the maintenance service has assured the IEC that he is willing to provide services under reasonable and non-discriminatory terms and conditions for applicants throughout the world. In this respect, the statement of the provider of the maintenance service is registered with the IEC. Information may be obtained from:

DLMS¹ User Association
Zug/Switzerland
www.dlms.com

¹ Device Language Message Specification.

International Standard IEC 62056-6-2 has been prepared by IEC technical committee 13: Electrical energy measurement and control.

This third edition cancels and replaces the second edition of IEC 62056-6-2 published in 2016. It constitutes a technical revision.

The significant technical changes with respect to the previous edition are listed in Annex F (Informative).

The text of this standard is based on the following documents:

FDIS	Report on voting
13/1746/FDIS	13/1750/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 62056 series, published under the general title *Electricity metering data exchange – The DLMS/COSEM suite*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This third edition of IEC 62056-6-2 has been prepared by IEC TC13 WG14 with a significant contribution of the DLMS User Association, its D-type liaison partner.

This edition is in line with the DLMS UA Blue Book Edition 12.2. The main new features are the “Array manager” IC, version 1 of the “Compact data” IC, version 1 of the “GSM diagnostic” IC, the “LTE monitoring” IC, the “NTP setup” IC, the HS-PLC setup ICs and the related new OBIS codes.

Object modelling and data identification

Driven by the business needs of the energy market participants – generally in a liberalized, competitive environment – and by the desire to manage natural resources efficiently and to involve the consumers, the utility meter became part of an integrated metering, control and billing system. The meter is not any more a simple data recording device but it relies critically on communication capabilities. Ease of system integration, interoperability and data security are important requirements.

COSEM, the *Companion Specification for Energy Metering*, addresses these challenges by looking at the utility meter as part of a complex measurement and control system. The meter has to be able to convey measurement results from the metering points to the business processes which use them. It also has to be able to provide information to the consumer and manage consumption and eventually local generation.

COSEM achieves this by using *object modelling* techniques to model all functions of the meter, without making any assumptions about which functions need to be supported, how those functions are implemented and how the data are transported. The formal specification of COSEM interface classes forms a major part of COSEM.

To process and manage the information it is necessary to uniquely identify all data items in a manufacturer-independent way. The definition of OBIS, the *Object Identification System* is another essential part of COSEM. It is based on DIN 43863-3:1997, *Electricity meters – Part 3: Tariff metering device as additional equipment for electricity meters – EDIS – Energy Data Identification System*. The set of OBIS codes has been considerably extended over the years to meet new needs.

COSEM models the utility meter as a *server* application – see 4.7 – used by *client* applications that retrieve data from, provide control information to, and instigate known actions within the meter via controlled access to the COSEM objects. The *clients* act as agents for third parties, i.e. the business processes of energy market participants.

The standardized COSEM interface classes form an extensible library. Manufacturers use elements of this library to design their products that meet a wide variety of requirements.

The server offers means to retrieve the functions supported, i.e. the COSEM objects instantiated. The objects can be organized to *logical devices and application associations* and to provide specific access rights to various clients.

The concept of the standardized interface class library provides different users and manufacturers with a maximum of diversity while ensuring interoperability.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning the Image transfer procedure.

The IEC takes no position concerning the evidence, validity and scope of this patent right.

The holder of this patent right has assured the IEC that he/she is willing to negotiate licenses either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with the IEC. Information may be obtained from Itron, Inc., Liberty Lake, Washington, USA.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. The IEC shall not be held responsible for identifying any or all such patent rights.

IEC (<http://patents.iec.ch>) maintains on-line databases of patents relevant to its standards. Users are encouraged to consult the databases for the most up to date information concerning patents.

Acknowledgement

The actual document has been established by the WG Maintenance of the DLMS UA.

Subclauses 5.3.7 and 5.3.9 are based on parts of NIST documents. Reprinted courtesy of the National Institute of Standards and Technology, Technology Administration, U.S. Department of Commerce. Not copyrightable in the United States.

ELECTRICITY METERING DATA EXCHANGE – THE DLMS/COSEM SUITE –

Part 6-2: COSEM interface classes

1 Scope

This part of IEC 62056 specifies a model of a meter as it is seen through its communication interface(s). Generic building blocks are defined using object-oriented methods, in the form of interface classes to model meters from simple up to very complex functionality.

Annexes A to F (informative) provide additional information related to some interface classes.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61334-4-32:1996, *Distribution automation using distribution line carrier systems – Part 4: Data communication protocols – Section 32: Data link layer – Logical link control (LLC)*

IEC 61334-4-41:1996, *Distribution automation using distribution line carrier systems – Part 4: Data communication protocols – Section 41: Application protocols – Distribution line message specification*

IEC 61334-4-511:2000, *Distribution automation using distribution line carrier systems – Part 4-511: Data communication protocols – Systems management – CIASE protocol*

IEC 61334-4-512:2001, *Distribution automation using distribution line carrier systems – Part 4-512: Data communication protocols – System management using profile 61334-5-1 – Management Information Base (MIB)*

IEC 61334-5-1:2001, *Distribution automation using distribution line carrier systems – Part 5-1: Lower layer profiles – The spread frequency shift keying (S-FSK) profile*

IEC TR 62055-21:2005, *Electricity metering – Payment systems – Part 21: Framework for standardization*

IEC 62056-21:2002, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 21: Direct local data exchange*

IEC 62056-31:1999, *Electricity metering – Data exchange for meter reading, tariff and load control – Part 31: Using local area networks on twisted pair with carrier signalling*

NOTE This Edition is referenced in the interface class “IEC twisted pair (1) setup” (class_id: 24, version: 0).

IEC 62056-3-1:2013, *Electricity metering data exchange – The DLMS/COSEM suite – Part 3-1: Use of local area networks on twisted pair with carrier signalling*

NOTE This Edition is referenced in the interface class “IEC twisted pair (1) setup” (class_id: 24, version: 1).