

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – High availability automation networks –
Part 2: Media Redundancy Protocol (MRP)**

**Réseaux de communication industriels – Réseaux de haute disponibilité pour
l'automatisation –
Partie 2: Protocole de redondance de support (MRP)**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC online collection - oc.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Industrial communication networks – High availability automation networks –
Part 2: Media Redundancy Protocol (MRP)**

**Réseaux de communication industriels – Réseaux de haute disponibilité pour
l'automatisation –
Partie 2: Protocole de redondance du support (MRP)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40; 35.100.05

ISBN 978-2-8322-1057-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
1.1 General.....	10
1.2 Code component distribution.....	10
2 Normative references	11
3 Terms, definitions, abbreviated terms and conventions	11
3.1 Terms and definitions.....	11
3.2 Abbreviated terms.....	11
3.3 Conventions.....	12
4 MRP Overview.....	12
5 MRP Media redundancy behavior	16
5.1 General.....	16
5.2 Ring ports	16
5.3 Media Redundancy Manager (MRM)	17
5.4 Media Redundancy Client (MRC)	19
5.5 Redundancy domain	19
5.6 Media Link Check	19
5.7 Application of the Continuity Check protocol.....	20
5.7.1 General	20
5.7.2 Continuity Check Message Interval	20
5.7.3 Maintenance Domain Level.....	20
5.7.4 Maintenance Association ID (MAID).....	20
5.7.5 Maintenance Association End Point ID (MEPID)	21
5.7.6 Sender ID TLV.....	21
5.7.7 Port Status TLV	21
5.7.8 Interface Status TLV	21
5.8 Usage with diagnosis and alarms	21
5.9 Ring diagnosis	22
5.10 Multiple MRM in a single ring: Manager voting option.....	22
5.10.1 General	22
5.10.2 Basic principle of the manager voting process	23
5.10.3 The manager voting process.....	24
5.11 BLOCKED not supported (Option).....	26
5.12 Interconnection port.....	26
5.13 Media redundancy Interconnection Manager (MIM)	28
5.14 Media redundancy Interconnection Client (MIC)	30
5.15 Interconnection domain	31
5.16 Interconnection diagnosis	31
6 MRP Class specification	31
6.1 General.....	31
6.2 Template.....	32
6.2.1 Media redundancy template.....	32
6.2.2 Media redundancy Interconnection template	33
6.3 Attributes	34
7 MRP Service specification	38

7.1	Start MRM	38
7.2	Stop MRM.....	39
7.3	State Change.....	40
7.4	Start MRC.....	41
7.5	Stop MRC	42
7.6	Read MRM.....	43
7.7	Read MRC.....	45
7.8	Start MIM.....	46
7.9	Stop MIM	48
7.10	Interconnection State Change.....	49
7.11	Start MIC	49
7.12	Stop MIC.....	51
7.13	Read MIM	52
7.14	Read MIC	53
8	MRP protocol specification	55
8.1	PDU description.....	55
8.1.1	Basic data types	55
8.1.2	DLPDU abstract syntax reference	55
8.1.3	Coding of the DLPDU field SourceAddress	56
8.1.4	Coding of the DLPDU field DestinationAddress.....	56
8.1.5	Coding of the field TagControlInformation.....	56
8.1.6	Coding of the field LT	57
8.1.7	MRP APDU abstract syntax	57
8.1.8	Coding of the field MRP_TLVHeader	59
8.1.9	Coding of the field MRP_SubTLVHeader	59
8.1.10	Coding of the field MRP_Ed1Type and MRP_Ed1ManufacturerData	60
8.1.11	Coding of the field MRP_Version	60
8.1.12	Coding of the field MRP_SequenceID	60
8.1.13	Coding of the field MRP_OA	60
8.1.14	Coding of the field MRP_OtherMRMSA.....	61
8.1.15	Coding of the field MRP_Prio.....	61
8.1.16	Coding of the field MRP_OtherMRMPrio	61
8.1.17	Coding of the field MRP_PortRole	61
8.1.18	Coding of the field MRP_RingState.....	62
8.1.19	Coding of the field MRP_Interval	62
8.1.20	Coding of the field MRP_Transition.....	62
8.1.21	Coding of the field MRP_TimeStamp	62
8.1.22	Coding of the field MRP_Blocked.....	63
8.1.23	Coding of the field MRP_ManufacturerOUI	63
8.1.24	Coding of the field MRP_IECOUI	63
8.1.25	Coding of the field MRP_ManufacturerData	63
8.1.26	Coding of the field MRP_DomainUUID.....	63
8.1.27	Coding of the field MRP_InState	64
8.1.28	Coding of the field MRP_InID.....	64
8.1.29	Coding of the field MRP_LinkInfo.....	64
8.2	Protocol machines	64
8.2.1	MRM protocol machine	64
8.2.2	MRC protocol machine	75
8.2.3	MRA protocol machine.....	81

8.2.4	MRA, MRM and MRC functions.....	102
8.2.5	FDB clear timer	106
8.2.6	Topology change timer	106
8.2.7	MIM protocol machine.....	107
8.2.8	MIC protocol machine	115
8.2.9	MIM and MIC functions	122
8.2.10	Interconnection Topology Change timer.....	127
8.2.11	Interconnection Link Status Poll timer.....	127
9	MRP installation, configuration and repair.....	128
9.1	Ring port and Interconnection port parameters.....	128
9.2	Ring topology parameters	128
9.3	MRM parameters	129
9.4	MRC parameters and constraints	129
9.5	MRA compatibility to earlier Automanager protocol version	130
9.6	Interconnection topology parameters	130
9.7	MIM parameters.....	130
9.8	MIC parameters and constraints	131
9.9	Calculation of MRP ring recovery time	132
9.9.1	Overview	132
9.9.2	Deduction of formula	132
9.9.3	Worst-case calculation for recovery time of 10 ms.....	134
9.9.4	Worst-case calculation for 50 devices.....	135
9.10	Calculation of MRP Automanager voting time.....	135
9.11	Calculation of MRP Interconnection recovery time	135
10	MRP Management Information Base (MIB).....	137
10.1	General.....	137
10.2	MRP MIB with a monitoring view	137
10.3	MRP MIB with a management and monitoring view	151
Annex A (normative) Optional earlier version of the Automanager protocol		166
Annex B (informative) Timing considerations for 10 Mbit/s link speed		167
Annex C (informative) Using MRP together with scheduling and shaping mechanisms as defined in IEEE Std 802.3 and interspersing express traffic as defined in IEEE Std 802.3.....		169
C.1	General.....	169
C.2	Avoiding negative impact on the recovery time of an MRP ring	169
C.2.1	General	169
C.2.2	Interspersing express traffic.....	169
C.2.3	Enhancements for scheduled traffic	170
C.3	Configuration guidelines for increased performance of MRP	170
C.3.1	General	170
C.3.2	Interspersing express traffic.....	170
C.3.3	Enhancements for scheduled traffic	171
C.4	Calculation of MRP ring recovery time	171
C.4.1	Worst-case calculation for recovery time of 10 ms, using frame preemption	171
C.4.2	Worst-case calculation for 50 devices, using frame preemption	172
Annex D (informative) Advanced MRP and MRP Interconnection topologies		173
D.1	General.....	173
D.2	MRP Single Switch Multiple Rings (MRP-SSMR).....	173

D.3	Multiple MRP Interconnection	173
D.4	MRP Interconnection Dual Switch Multiple Couplings (MRP-I DSMC).....	174
	Bibliography.....	175
Figure 1	– Two MRP rings redundantly connected via MRP Interconnection	14
Figure 2	– MRP stack	16
Figure 3	– MRP ring topology with one manager and clients	17
Figure 4	– MRP open ring with MRM.....	18
Figure 5	– MRP ring with MRA at network startup	23
Figure 6	– MRP ring after the manager voting process.....	23
Figure 7	– Manager voting process	23
Figure 8	– MRA located outside the MRP ring.....	26
Figure 9	– MRP Interconnection topology.....	28
Figure 10	– MRP ring interconnection open	29
Figure 11	– MRP protocol machine for MRM.....	65
Figure 12	– MRP protocol machine for MRC	76
Figure 13	– MRP protocol machine for MRA.....	82
Figure 14	– MRP protocol machine for MIM in RC-mode and LC mode	107
Figure 15	– MRP protocol machine for MIC in RC-mode and LC mode.....	115
Figure D.1	– MRP Topologies	173
Figure D.2	– MRP Interconnection Topologies	174
Figure D.3	– MRP Interconnection Dual Switch Multiple Couplings Topology	174
Table 1	– Coding of the Maintenance Association ID (MAID).....	21
Table 2	– MRP Start MRM	38
Table 3	– MRP Stop MRM.....	40
Table 4	– MRP Change State.....	40
Table 5	– MRP Start MRC.....	41
Table 6	– MRP Stop MRC.....	42
Table 7	– MRP Read MRM.....	43
Table 8	– MRP Read MRC.....	45
Table 9	– MRP Start MIM.....	47
Table 10	– MRP Stop MIM	48
Table 11	– MRP Interconnection Change State.....	49
Table 12	– MRP Start MIC	50
Table 13	– MRP Stop MIC	51
Table 14	– MRP Read MIM	52
Table 15	– MRP Read MIC	54
Table 16	– MRP DLPDU syntax for ISO/IEC/IEEE 8802-3 (IEEE Std 802.3).....	55
Table 17	– MRP OUI.....	56
Table 18	– MRP MulticastMACAddress	56
Table 19	– MRP TagControlInformation.Priority field.....	57
Table 20	– MRP LT field	57
Table 21	– MRP APDU syntax	57

Table 22 – MRP Substitutions	58
Table 23 – MRP_TLVHeader.Type	59
Table 24 – MRP_SubTLVHeader.Type	59
Table 25 – MRP_Ed1Type and MRP_Ed1ManufacturerData	60
Table 26 – MRP_Ed1Type and MRP_Ed1ManufacturerData	60
Table 27 – MRP_Version	60
Table 28 – Coding of the field MRP_OtherMRMSA	61
Table 29 – MRP_Prio	61
Table 30 – Coding of the field MRP_OtherMRMPrio	61
Table 31 – MRP_PortRole	62
Table 32 – MRP_RingState	62
Table 33 – MRP_Interval	62
Table 34 – MRP_Transition	62
Table 35 – MRP_TimeStamp	63
Table 36 – MRP_Blocked	63
Table 37 – MRP_DomainUUID	63
Table 38 – MRP_InState	64
Table 39 – MRP_LinkInfo	64
Table 40 – MRP Local variables of MRM protocol machine	66
Table 41 – MRM State machine	67
Table 42 – MRP Local variables of MRC protocol machine	77
Table 43 – MRC state machine	77
Table 44 – MRP local variables of MRA protocol machine	83
Table 45 – MRA state machine	84
Table 46 – MRP functions and macros	102
Table 47 – MRP FDB clear timer	106
Table 48 – MRP topology change timer	107
Table 49 – MRP Local variables of MIM protocol machine	108
Table 50 – MIM State machine for LC-mode	109
Table 51 – MIM State machine for RC-mode	111
Table 52 – MRP Local variables of MIC protocol machine	116
Table 53 – MIC State machine for LC-mode	116
Table 54 – MIC State machine for RC-mode	120
Table 55 – MRP Interconnection functions	123
Table 56 – MRP Interconnection topology change timer	127
Table 57 – MRP Interconnection link status poll timer	128
Table 58 – MRP Network/Connection parameters	128
Table 59 – MRP MRM parameters	129
Table 60 – MRP MRC parameters	130
Table 61 – MRP MIM parameters	131
Table 62 – MRP MIC parameters	131
Table A.1 – Compatible mode MRP_Option for MRP_Test Substitutions	166
Table A.2 – Compatible mode MRP_Option frames MRP_TestMgrNAck and MRP_TestPropagate Substitutions	166

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
HIGH AVAILABILITY AUTOMATION NETWORKS –****Part 2: Media Redundancy Protocol (MRP)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publications"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as far as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 62439-2 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This third edition cancels and replaces the second edition published in 2016. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) improvements for the Continuity Check Protocol,
- b) introduction of further specifiers for the rings, the interconnection links, and the device roles,
- c) extensions and information on the use of baudrates smaller than 100 Mbit/s,
- d) information on using MRP together with scheduling and shaping mechanisms,
- e) introduction of an MRP Interconnection profile for a 30 ms reconfiguration time.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1118/FDIS	65C/1137/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

This International Standard is to be read in conjunction with IEC 62439-1.

A list of all parts of the IEC 62439 series, published under the general title *Industrial communication networks – High availability automation networks*, can be found on the IEC website.

This IEC standard includes Code Components i.e. components that are intended to be directly processed by a computer. Such content is any text found between the markers <CODE BEGINS> and <CODE ENDS>, or otherwise is clearly labeled in this standard as a Code Component.

The purchase of this IEC standard carries a copyright license for the purchaser to sell software containing Code Components from this standard directly to end users and to end users via distributors, subject to IEC software licensing conditions, which can be found at: <http://www.iec.ch/CCv1>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its content. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC/IEEE 8802-3 (IEEE Std 802.3™) compatible, reliable data communication, and preserve determinism of real-time data communication. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the typical Ethernet communication capabilities as used in the office world, so that the software involved remains applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching diverse application requirements. These solutions support different redundancy topologies and mechanisms which are introduced in IEC 62439-1 and specified in the other Parts of the IEC 62439 series. IEC 62439-1 also distinguishes between the different solutions, giving guidance to the user.

The IEC 62439 series follows the general structure and terms of the IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent. IEC takes no position concerning the evidence, validity, and scope of this patent right.

The holder of this patent right has assured IEC that s/he is willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from the patent database available at <http://patents.iec.ch>.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those in the patent database. IEC shall not be held responsible for identifying any or all such patent rights.

INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

Part 2: Media Redundancy Protocol (MRP)

1 Scope

1.1 General

The IEC 62439 series is applicable to high-availability automation networks based on the ISO/IEC/IEEE 8802-3 (IEEE Std 802.3) (Ethernet) technology.

This part of the IEC 62439 series specifies a recovery protocol based on a ring topology, designed to react deterministically on a single failure of an inter-switch link or switch in the network, under the control of a dedicated media redundancy manager node.

1.2 Code component distribution

Each Code Component is a ZIP package containing at least the electronic representation of the Code Component itself and a file describing the content of the package (IECManifest.xml).

The IECManifest contains different sections giving information on:

- the copyright notice;
- the identification of the code component;
- the publication related to the code component;
- the list of the electronic files which compose the code component;
- an optional list of history files to track changes during the evolution process of the code component.

The Code Components included in this IEC standard are a set of SNMP MIBs. The Code Component IEC-62439-2-MIB.mib is a file containing the MIB with the management and monitoring view. It will be available in a full version, which contains the MIB defined in this document with the documentation associated and access is restricted to purchaser of this document.

The Code Component (full version) is freely accessible on the IEC website for download at: https://www.iec.ch/sc65c/supportingdocuments/IEC_62439-2.MIB.{VersionStateInfo}.full.zip but the usage remains under the licensing conditions.

The life cycle of a code component is not restricted to the life cycle of the related publication. The publication life cycle goes through two stages, Version (corresponding to an edition) and Revision (corresponding to an amendment). Consequently, new release(s) of the Code Component(s) may be released, which supersede(s) the previous release, and will be distributed through the IEC website at: <https://www.iec.ch/sc65c/supportingdocuments>.

The latest version/release of the document will be found by selecting the file IEC_62439-2.MIB.{VersionStateInfo}.full.zip for the code component with the highest value for VersionStateInfo.

In case of any differences between the downloadable code and the IEC pdf published content, the downloadable code(s) is(are) the valid one; it may be subject to updates. See history files.