

INTERNATIONAL STANDARD

Mechanical structures for electrical and electronic equipment – Thermal management for cabinets in accordance with IEC 60297 and IEC 60917 series – Part 6: Air recirculation and bypass of indoor cabinets



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2020 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - webstore.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

INTERNATIONAL STANDARD

Mechanical structures for electrical and electronic equipment – Thermal management for cabinets in accordance with IEC 60297 and IEC 60917 series – Part 6: Air recirculation and bypass of indoor cabinets

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 31.240

ISBN 978-2-8322-8006-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Recirculation level	8
5 Determination of recirculation and bypass ratio	9
5.1 Cooling airflow in a cabinet	9
5.2 Recirculation ratio of a subrack.....	10
5.3 Recirculation ratio of a cabinet.....	11
5.4 Bypass ratio of a cabinet.....	11
6 Measurement of recirculation and bypass	11
6.1 Measurement of recirculation of a subrack	11
6.2 Measurement of recirculation of a cabinet.....	12
6.3 Measurement of bypass of a cabinet.....	12
6.4 Measurement methods of temperature	12
6.4.1 Intake air temperature of a subrack	12
6.4.2 Intake air temperature of a subrack group.....	13
6.4.3 Exhaust air temperature of a subrack	13
6.4.4 Exhaust air temperature of a subrack group.....	13
6.4.5 Intake air temperature of a cabinet	13
6.4.6 Exhaust air temperature of a cabinet.....	13
6.5 Measurement method of recirculation for an empty cabinet.....	14
Annex A (normative) Measurement method of recirculation with dummy thermal loads	15
A.1 Purpose	15
A.2 Specifications	15
A.2.1 DTL	15
A.2.2 Cabinet specifications.....	15
A.2.3 Measurement configurations	16
A.3 Environmental conditions	16
A.4 Measurement positions	16
A.4.1 Intake air temperature of DTL	16
A.4.2 Exhaust air temperature of DTL	16
A.4.3 Intake air temperature of a cabinet	16
A.4.4 Exhaust air temperature of a cabinet	16
A.4.5 Evaluation of recirculation ratio of a subrack.....	16
A.4.6 Evaluation of recirculation and bypass ratio of a cabinet.....	16
A.5 Case study.....	16
A.6 Relationship between recirculation ratio and intake temperature rise	19
Annex B (normative) Derivation of recirculation and bypass in a cabinet.....	21
B.1 General.....	21
B.2 Derivation of recirculation and bypass.....	21
Annex C (informative) Application of recirculation and bypass to outdoor cabinets.....	22
C.1 General.....	22
C.2 Application example.....	22
Bibliography.....	24

Figure 1 – Airflow in a cabinet.....	9
Figure 2 – Diagram of cabinet airflows	10
Figure A.1 – Outline drawings of DTL	17
Figure A.2 – Experimental setup of a cabinet and DTL.....	17
Figure A.3 – Measurement points of intake air temperature of DTL	18
Figure A.4 – Measurement points of exhaust air temperature of DTL	18
Figure A.5 – Measurement points of intake air temperature of a cabinet	18
Figure A.6 – Measurement points of exhaust air temperature of a cabinet.....	18
Figure A.7 – Recirculation ratio vs intake air temperature rise.....	20
Figure C.1 – Outdoor cabinet airflow schematic	23
Figure C.2 – Airflow diagram and air temperature in outdoor cabinet	23
Table 1 – Recirculation level.....	9
Table A.1 – Specifications of DTL	15
Table A.2 – Specifications of DTL	17
Table A.3 – Test result.....	19
Table A.4 – Recirculation and bypass ratio of a cabinet	19
Table C.1 – A case study of an outdoor cabinet	23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MECHANICAL STRUCTURES FOR ELECTRICAL AND ELECTRONIC
EQUIPMENT – THERMAL MANAGEMENT FOR CABINETS IN
ACCORDANCE WITH IEC 60297 AND IEC 60917 SERIES –**

Part 6: Air recirculation and bypass of indoor cabinets

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the most recent edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62610-6 has been prepared by subcommittee 48D: Mechanical structures for electrical and electronic equipment, of IEC technical committee 48: Electrical connectors and mechanical structures for electrical and electronic equipment.

The text of this International Standard is based on the following documents:

CDV	Report on voting
48D/700/CDV	48D/715/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62610 series, published under the general title *Mechanical structures for electrical and electronic equipment – Thermal management for cabinets in accordance with iec 60297 and iec 60917 series*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

Currently in preview, click buy full vers.

INTRODUCTION

The signal speed and component density of electrical and electronic equipment in the ICT field and the FA field, such as high performance servers, communications equipment, and electronic control equipment have been steadily increasing. As a result, the heat generation density of the integrated circuits, the power consumption of the equipment, and therefore the cooling task has also been increasing. In a computer room common in the ICT field, where many cabinets for mounting subrack and/or chassis-based equipment are installed and high availability is required, it is necessary to pay attention so that the equipment does not experience high temperature problems.

To prevent high temperature problems with the electronic equipment, it is important that the air conditioning installed in a computer room effectively contributes to the cooling of the cabinet for mounting subrack and/or chassis-based equipment. Indicators relating to airflow such as recirculation and bypass, are used to judge the effectiveness of the air conditioning system. Recirculation is the ratio at which the cabinets in the computer room suck in their own exhaust air, which affects the thermal problems of the equipment as it raises the intake air temperature. Bypass is the ratio at which the cooled supply air does not pass through the cabinets in the computer room, and affects the energy efficiency as it increases the air conditioning energy. If these ratios, especially the recirculation ratio, are kept low, the airflow of the computer room can be regarded as effectively cooling the cabinets. Conversely, if air recirculation or bypass occurs, the temperature of subracks and/or chassis-based equipment in the cabinet rises. Therefore it is necessary to provide similar indices to measure the effectiveness of the cooling airflow for the equipment in the cabinet.

The existing standard for forced air cooling, IEC 62610-2, introduces a method for determining the ideal airflow for a forced air cooled cabinet assembled with associated subrack and/or chassis-based equipment. The standard also defines qualitative guidelines for avoiding recirculation in such cabinets and a server (computer) room. However, concrete numerical values and the evaluation method of the recirculation have not been defined. It was impossible to judge in advance whether the cabinet for mounting subrack and/or chassis-based equipment satisfies the environmental conditions, or whether the empty cabinet has sufficient cooling when subrack and/or chassis-based equipment are mounted.

This document defines a method for easily measuring the recirculation ratio (RC) and the bypass ratio (BP) of the airflow in a cabinet and provides performance levels of recirculation on effectiveness of the cooling airflow in such cabinets. This can be regarded as the degree of conformity with respect to behaviour of the airflow in the cabinet in the computer room. Alternatively, even for a cabinet including a heat exchanger and an air conditioner, this method can be effectively utilized as an index for knowing the degree of airflow appropriately contributing to cooling the internal space in which the equipment is mounted.

The purpose of this document is to provide:

- for the equipment integrator and development designer of the cabinet the criteria for efficiently and correctly determining the specification, and
- for the supplier of the cabinet the measuring and classifying method for the airflow recirculation rate of the subrack and/or chassis-based equipment installed in the cabinet.

This document is addressed to the mechanical structures in accordance with IEC 60297 and IEC 60917 series.

MECHANICAL STRUCTURES FOR ELECTRICAL AND ELECTRONIC EQUIPMENT – THERMAL MANAGEMENT FOR CABINETS IN ACCORDANCE WITH IEC 60297 AND IEC 60917 SERIES –

Part 6: Air recirculation and bypass of indoor cabinets

1 Scope

This part of IEC 62610 which deals with thermal management for cabinets in accordance with IEC 60297 and IEC 60917 series, provides compatible measurement methods of recirculation ratio and bypass ratio which are indicators for defining quality of airflow in the forced air cooling that can be commonly applied to indoor cabinets for mounting subrack and/or chassis-based equipment.

NOTE 1 Both recirculation and bypass represent leakage airflows, i.e. detrimental phenomena in terms of cooling efficiency; their measurement is obviously aimed at their mitigation.

This document contains the following:

- the definition of recirculation and bypass flow rates in the cooling of the cabinet,
- the levels of the recirculation ratio RC ,
- the definition of the formula for the recirculation ratio RC_s of forced air cooling subrack and/or chassis-based equipment installed in the cabinet,
- the definition formula of recirculation ratio RC_r and bypass rate BP_r of the entire cabinet,
- the requirements of the measuring method of each temperature necessary for calculating the recirculation ratio RC_s , RC_r and bypass ratio BP_r .

NOTE 2 This document includes the definition of measuring bypass ratio, but excludes the definition of levels of bypass ratio.

The drawings used are not intended to indicate product design. They are only for explanatory indications for defining forced air cooling airflows.

The recirculation and bypass measurement methods dealt with in this document are assumed to be applied to a cabinet installed indoors. The cooling air inlet is at the front or the bottom of the cabinet and the heated air is exhausted to the rear or the top. These methods are also applicable to a cabinet that is installed outdoors and has a cooling device such as a heat exchanger or an air conditioner on the front or the back (see Annex C).

The recirculation ratio of a subrack or a cabinet is defined for each individual subrack or chassis-based equipment mounted in the cabinet or for the entire cabinet. The bypass ratio of a cabinet is defined for the entire cabinet.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60297-3-100, *Mechanical structures for electronic equipment – Dimensions of mechanical structures of the 482,6 mm (19 in) series – Part 3-100: Basic dimensions of front panels, subracks, chassis, racks and cabinets*