

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



**Residual current devices with or without overcurrent protection for
socket-outlets for household and similar uses**

**Dispositifs à courant différentiel résiduel (avec ou sans protection contre les
surintensités pour les socles de prises de courant destinés à des installations
domestiques et analogues**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

CONSOLIDATED VERSION

VERSION CONSOLIDÉE



**Residual current devices with or without overcurrent protection for
socket-outlets for household and similar uses**

**Dispositifs à courant différentiel résiduel (avec ou sans protection contre les
surintensités pour les socles de prises de courant destinés à des installations
domestiques et analogues**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50

ISBN 978-2-8322-2672-8

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

Currently in preview, click buy full version

REDLINE VERSION

VERSION REDLINE



**Residual current devices with or without overcurrent protection for
socket-outlets for household and similar uses**

**Dispositifs à courant différentiel résiduel avec ou sans protection contre les
surintensités pour les socles de prises de courant destinés à des installations
domestiques et analogues**

CONTENTS

FOREWORD.....	9
INTRODUCTION.....	11
1 Scope.....	12
2 Normative references	13
3 Terms and definitions	14
3.1 Definitions relating to currents flowing from live parts to earth	14
3.2 Definitions relating to the energization of a residual current device	15
3.3 Definitions relating to the operation and functions of the residual current device	15
3.4 Definitions relating to values and ranges of energizing quantities	17
3.5 Definitions relating to values and ranges of influencing quantities	19
3.6 Definitions relating to conditions of operation	20
3.7 Definitions relating to tests	21
3.8 Definitions relating to residual current devices in general	21
4 Classification.....	21
4.1 Classification according to behaviour resulting from failure of the line voltage	22
4.1.1 SRCD not opening automatically in case of failure of the line voltage	22
4.1.2 SRCD opening automatically in case of failure of the line voltage	22
4.2 Classification according to the design.....	22
4.2.1 SRCD consisting of an RCD incorporated in (a) fixed socket-outlet(s)	22
4.2.2 SRCD consisting of an RCD intended to be associated with fixed socket-outlets within the same mounting box or within two adjacent compatible boxes.....	22
4.2.3 SRCD consisting of an PCL incorporated in a connection unit intended to protect only one piece of fixed electrical equipment (e.g. hand dryer, water cooler, etc.) immediately adjacent to the SRCD	22
4.3 Classification according to behaviour in presence of d.c. components	22
4.4 Classification according to the provision for earthing	22
4.5 Classification according to the design of the cover plate.....	22
4.6 Classification according to the method of mounting	22
4.7 Classification according to the environmental conditions	23
4.7.1 Classification according to the degree of protection against ingress of solid foreign objects	23
4.7.2 Classification according to the degree of protection against harmful ingress of water	23
4.7.3 Classification according to the range of ambient air temperature	23
4.8 Classification according to the type of terminals	23
4.9 Classification according to overcurrent protection.....	23
5 Characteristics of SRCDs	23
5.1 Summary of characteristics	23
5.2 Characteristics common to all socket-outlet residual current devices	24
5.2.1 Rated current (I_n)	24
5.2.2 Rated residual operating current ($I_{\Delta n}$)	24
5.2.3 Rated residual non-operating current ($I_{\Delta n0}$)	24
5.2.4 Rated voltage (U_n).....	24
5.2.5 Rated frequency	24
5.2.6 Rated residual making and breaking capacity ($I_{\Delta m}$).....	24

5.2.7	Operating characteristics in case of residual current.....	24
5.3	Characteristics specific to SRCDs with overcurrent protection (see 4.9)	25
5.3.1	SRCDs classified according to 4.9 a), 4.9 b) and 4.9 c) 1)	25
5.3.2	Rated short-circuit capacity (I_{cn}) for SRCD classified according to 4.9 c) 2)	26
5.4	Preferred or standard values	26
5.4.1	Preferred values of rated voltage (U_n)	26
5.4.2	Standard values of rated current (I_n).....	26
5.4.3	Standard values of rated residual operating current ($I_{\Delta n}$)	26
5.4.4	Standard value of rated residual non-operating current ($I_{\Delta no}$)	26
5.4.5	Standard values of rated frequency	26
5.4.6	Standard values of the rated making and breaking capacity (I_m)	26
5.4.7	Standard values of the rated residual making and breaking capacity ($I_{\Delta m}$)	27
5.4.8	Standard values of the rated conditional short-circuit current (I_{nc})	27
5.4.9	Standard values of the rated conditional residual short-circuit current ($I_{\Delta c}$)	27
5.4.10	Standard values of the rated short-circuit capacity (I_{sc})	27
5.4.11	Standard values of break time	27
5.5	Standard ranges of overcurrent instantaneous tripping for SRCDs to 4.9 c) 2).....	28
6	Marking and other product information.....	28
6.1	General	28
6.2	Additional marking for screwless terminals	30
6.3	Additional marking for SRCDs with an FE connection	30
7	Standard conditions for operation in service and for installation.....	30
8	Requirements for construction and operation.....	31
8.1	General	31
8.2	Information and marking	31
8.3	Mechanical and electrical design	31
8.3.1	Mechanism	31
8.3.2	Clearance and creepage distances	32
8.3.3	Standing current in the FE	34
8.3.4	Screw current-carrying parts and connections.....	34
8.3.5	Terminals	35
8.4	Operating characteristics.....	35
8.4.1	Operation in response to the type of residual current.....	35
8.4.2	Operation in response to the presence of a residual current equal to or greater than $I_{\Delta n}$	36
8.5	Behaviour of SRCDs with feed through terminals in case of miswiring	36
8.6	Test device.....	36
8.7	Temperature rise	36
8.8	Resistance to humidity	37
8.9	Dielectric properties	37
8.10	EMC compliance and unwanted tripping	37
8.10.1	EMC	37
8.10.2	Resistance against unwanted tripping due to current surges caused by impulse voltages for SRCDs of $I_{\Delta n} \geq 0,010$ A	37
8.11	Behaviour of SRCDs in case of overcurrent conditions	37
8.11.1	For all SRCDs	37

8.11.2	Behaviour of SRCDs classified according to 4.9 c) in case of overcurrent conditions	38
8.11.3	Standard time-(over)current zone for SRCD according to 4.9 c) 1) and 4.9 c) 2)	38
8.12	Resistance of the insulation against impulse voltages	39
8.13	Mechanical and electrical endurance	39
8.14	Resistance to mechanical shock	39
8.15	Reliability	39
8.16	Protection against electric shock and degree of protection IP of the SRCD	39
8.16.1	Inaccessibility of live parts	40
8.16.2	Accessible knobs, operating means etc.	40
8.16.3	Accessible parts of SRCDs	40
8.16.4	Degree of protection IP of the SRCD	41
8.17	Resistance to heat	41
8.18	Resistance to abnormal heat and to fire	41
8.19	Behaviour of SRCDs within ambient temperature range	41
8.20	Resistance to temporary overvoltages	41
9	Tests	42
9.1	General	42
9.1.1	Test conditions	42
9.1.2	Characteristics of SRCDs	42
9.2	Marking and test of indelibility of marking	43
9.3	Verification of the trip-free mechanism	43
9.3.1	General test conditions	43
9.3.2	Test procedure	44
9.4	Test for the verification of electronic circuits	44
9.5	Requirements for capacitors and specific resistors and inductors	45
9.5.1	Capacitors	45
9.5.2	Resistors and inductors	45
9.6	Test of reliability of screws, current-carrying parts and connections	47
9.7	Screwed and screwless terminals	47
9.7.1	Screwed terminals for external copper conductors	47
9.7.2	Screwless terminals for external copper conductors	53
9.8	Verification of the operating characteristics of type AC and type A SRCDs	59
9.8.1	Test circuit	59
9.8.2	Verification of behaviour in the case of supply voltage failure	60
9.8.3	Off-load tests with residual sinusoidal alternating currents at the reference temperature of $(20 \pm 5) ^\circ\text{C}$	60
9.8.4	Verification of the correct operation with load at the reference temperature	61
9.8.5	Verification of the correct operation at the temperature limits with and without load	61
9.8.6	Additional tests for SRCDs fitted with an FE	62
9.8.7	Verification of correct operation of type A SRCDs with residual currents having a d.c. component	63
9.9	Verification of behaviour of SRCDs classified according to 4.2.1 b) in the case of miswiring	64
9.10	Verification of the test device	64
9.10.1	Verification of the simulated residual current	64
9.10.2	Verification of the operation of the test device	65

9.11	Verification of the limit of temperature rise	65
9.11.1	Test conditions	65
9.11.2	Ambient air temperature	66
9.11.3	Test procedure	66
9.11.4	Measurement of the temperature rise of different parts	66
9.12	Resistance to humidity	66
9.12.1	Preparation of the SRCD for test	66
9.12.2	Test conditions	66
9.12.3	Test procedure	67
9.12.4	Condition of the SRCD after the test	67
9.13	Test of dielectric properties	67
9.13.1	Insulation resistance of the main circuit	67
9.13.2	Dielectric strength of the main circuit	68
9.13.3	Capability of withstanding high d.c. voltages due to insulation measurements	68
9.14	EMC compliance and unwanted tripping	69
9.14.1	Electromagnetic compatibility (EMC)	69
9.14.2	Verification of resistance against unwanted tripping due to surge currents to earth resulting from impulse voltages for SRCDs of $I_{\Delta n} \geq 0,010$ A (ring wave test)	69
9.15	Verification of the behaviour of the SRCD under overcurrent conditions	69
9.15.1	List of the overcurrent tests	69
9.15.2	Short-circuit tests	70
9.15.3	Verification of the making and breaking capacity of the socket-outlet of the SRCD, classified according to 4.2.1	76
9.16	Verification of clearances of the SRCD with the impulse withstand voltage test	77
9.17	Mechanical and electrical endurance	78
9.17.1	Normal operation of socket-outlets of the SRCD	78
9.17.2	Test of the RCD part of the SRCD	78
9.18	Resistance to mechanical shock	80
9.18.1	General	80
9.18.2	Impact test apparatus	80
9.18.3	Surface type SRCD	83
9.18.4	Screwed glands	84
9.18.5	Shrouded SRCDs	84
9.19	Reliability	84
9.19.1	Climatic test	85
9.19.2	Test with temperature of 40 °C	86
9.20	Protection against electric shock and degree of protection IP of the SRCD	87
9.20.1	Protection against electric shock	87
9.20.2	Degree of protection IP of the SRCD	88
9.21	Resistance to heat	88
9.21.1	General	88
9.21.2	Conditioning	88
9.21.3	External parts of SRCDs	88
9.21.4	External Insulating parts	89
9.22	Resistance to abnormal heat and to fire – Glow-wire test	89
9.23	SRCDs with overcurrent protection	90

9.23.1	Verification of the operating characteristic under overcurrent conditions.....	90
9.23.2	Short-circuit tests for SRCDs according to 4.9 c) 2).....	91
9.23.3	Condition of the SRCD after tests.....	92
9.24	Verification of ageing of electronic components.....	92
9.25	Verification of the behaviour of the SRCD under temporary overvoltage conditions.....	93
9.26	Verification of the limiting value of FE/PE standing current.....	94
9.26.1	Verification of the limiting value of FE/PE standing current when the neutral is connected.....	94
9.26.2	Verification of the limiting value of FE/PE standing current when the neutral is not connected.....	94
Annex A	(normative) Test sequence and number of samples to be submitted for certification purposes.....	119
Annex B	(normative) Determination of clearances and creepage distances.....	124
Annex C	(informative) Approximate relationship between cross-sectional area in mm ² and AWG sizes.....	126
Annex D	(normative) Routine tests.....	127
Annex E	(informative) Methods of determination of short-circuit power-factor.....	128
Bibliography	130
Figure 1	– Standard test finger.....	95
Figure 2	– General test circuit.....	96
Figure 3	– Minimum creepage distances and clearances as a function of peak value of voltage.....	97
Figure 4	– Minimum creepage distances and clearances as a function of peak value of operating voltage.....	98
Figure 5	– Pillar terminals.....	99
Figure 6	– Screw terminals and stud terminals.....	100
Figure 7	– Saddle terminals.....	101
Figure 8	– Mantle terminals.....	101
Figure 9	– Arrangement for blocking damage to conductors.....	102
Figure 10	– Information for deflection test.....	103
Figure 11	– Example of a test circuit with current and voltage derived from separate sources.....	104
Figure 12	– Test cycle for low temperature test.....	104
Figure 13	– Measurement of the standing FE/PE current.....	105
Figure 14	– Test circuit for the verification of the correct operation of SRCDs, in the case of residual pulsating direct currents.....	106
Figure 15	– Test circuit for the verification of the correct operation of SRCDs, in the case of residual pulsating direct currents superimposed by a smooth direct current.....	107
Figure 16	– Damped oscillator current wave 0,5 μs/100 kHz.....	108
Figure 17	– Example of test circuit for the verification of resistance against unwanted tripping due to surge currents to earth resulting from impulse voltages for SRCDs.....	108
Figure 18	– Test circuit for the verification of the rated making and breaking capacity and of the coordination.....	109
Figure 19	– Test apparatus for the verification of the minimum I^2t and I_p values to be withstood by the SRCD (9.15.2.1 a).....	110

Figure 20 – Gauge for checking non-accessibility of live parts	111
Figure 21 – Impact-test apparatus	112
Figure 22 – Details of the striking element	113
Figure 23 – Mounting support for specimens.....	114
Figure 24 – Mounting block for flush-type SRCDs	114
Figure 25 – Reliability test cycle	115
Figure 26 – Ball-pressure test apparatus	116
Figure 27 – Sketches and table showing the application of the blows.....	117
Figure 28 – Diagrammatic representation of 9.22.....	118
Figure 29 – Test circuit for the verification of TOV withstand (9.25)	118
Figures B.1 to B.10 – Illustrations of the application of creepage distances	125
Table 1 – Standard values of maximum break time of SRCDs for a.c. residual current.....	27
Table 2 – Standard values of maximum break time of SRCDs for pulsating d.c. residual current.....	28
Table 3 – Ranges of overcurrent instantaneous tripping.....	28
Table 4 – Position of marking.....	29
Table 5 – Values of influencing quantities	31
Table 6 – Minimum clearances and creepage distances.....	33
Table 7 – Tripping current limits.....	35
Table 8 – Temperature-rise values.....	37
Table 9 – Time-(over)load operating characteristics.....	38
Table 10 – Instantaneous operating characteristics.....	38
Table 11 – Withstand values and duration of temporary overvoltages	41
Table 12 – Test copper conductors corresponding to the rated currents.....	42
Table 13 – List of type tests	43
Table 14 – Maximum permissible temperatures under abnormal conditions	46
Table 15 – Screw thread diameters and applied torques	47
Table 16 – Relationship between rated current and connectable nominal cross-sectional areas of copper conductors	48
Table 17 – Values for flexing under mechanical load test for copper conductors	50
Table 18 – Values for pull test for screw-type terminals	50
Table 19 – Composition of conductors	51
Table 20 – Tightening torques for the verification of the mechanical strength of screw-type terminals	52
Table 21 – Relationship between rated current and connectable cross-sectional areas of copper conductors for screwless terminals.....	54
Table 22 – Value for pull test for screwless-type terminals.....	56
Table 23 – Values for flexing under mechanical load test for copper conductors	56
Table 24 – Test current for the verification of electrical and thermal stresses in normal use for screwless terminals.....	57
Table 25 – Nominal cross-sectional areas of rigid copper conductors for deflection test of screwless terminals	59
Table 26 – Deflection test forces.....	59
Table 27 – Tripping current ranges for SRCDs in case of pulsating d.c. current	63

Table 28 – Tests to be applied for EMC	69
Table 29 – Tests to verify the behaviour of SRCDs under overcurrent conditions	70
Table 30 – Power factor ranges of the test circuit	72
Table 31 – Test voltage for verification of impulse withstand voltage between poles	77
Table 32 – Test voltage for verification of impulse withstand voltage with the metal support	78
Table 33 – Cross-sectional area for test conductors.....	79
Table 34 – Height of fall for impact tests	82
Table 35 – Torque test values for glands	84
Table A.1 – Test sequences.....	120
Table A.2 – Number of samples for full test procedure	122
Table A.3 – Number of samples for simplified test procedure	123

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**RESIDUAL CURRENT DEVICES WITH OR WITHOUT OVERCURRENT
PROTECTION FOR SOCKET-OUTLETS FOR
HOUSEHOLD AND SIMILAR USES**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 62640 bears the edition number 1.1. It consists of the first edition (2011-01) [documents 23E/706/FDIS and 23E/713/RVD] and its amendment 1 (2015-05) [documents 23E/866/CDV and 23E/901/RVC]. The technical content is identical to the base edition and its amendment.

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 62640 has been prepared by subcommittee 23E: Circuit-breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this standard, the following print types are used:

- Requirements proper: in roman type.
- *Test specifications: in italic type.*
- Explanatory matter: in smaller roman type.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC series 61008 and IEC 61009 are applicable to residual current devices having one to four poles used in any part of an electrical installation. These devices may be installed either at the origin of a whole installation or upstream of one or several circuits of a fixed installation or upstream of a circuit powering one or more socket-outlets, or be integrated in the same enclosure as a socket-outlet.

Such residual current devices are able to provide fault protection (protection against indirect contact), additional protection (protection against direct contact) if the rated residual current is equal to or less than 30 mA and protection against fire hazard due to a persistent earth leakage current without the operation of the overcurrent protection. Equipment meeting the requirements of the series IEC 61008 or IEC 61009 ensure isolation, withstand high levels of electromagnetic disturbances for household and similar applications and allow safe use of an electrical installation.

Although the series IEC 61008 and IEC 61009 may be applicable to “residual current devices integrated in socket-outlets” it is acknowledged that due to the specific use and location of a socket-outlet, at the boundary of the fixed installation and immediately upstream of electrical equipment powered through a plug inserted into the socket-outlet, these devices require different features.

The residual current device at socket-outlet level is normally intended to be installed by skilled or instructed persons. It can be operated several times per day. The isolation function is not necessary since pulling out the plug from the socket-outlet is recognized as providing effective isolation. The absence of permanently connected long conductors downstream of the RCD, together with a limited number of powered appliances, justifies reduced EMC levels. Residual current devices covered by this standard are intended for additional protection in case of direct contact only. These particular features having been considered, it was recognized that a dedicated standard for socket-outlet residual current devices (SRCDs) was necessary.

RESIDUAL CURRENT DEVICES WITH OR WITHOUT OVERCURRENT PROTECTION FOR SOCKET-OUTLETS FOR HOUSEHOLD AND SIMILAR USES

1 Scope

This International Standard applies to residual current-operated devices (RCD) incorporated in, or specifically intended for use with two pole socket-outlets, with or without earthing contact for household and similar uses (SRCD: socket-outlet residual current devices). SRCDs, according to this standard, are intended to be used in single phase systems such as phase to neutral or phase to phase or phase to earthed middle conductor.

SRCDs are only intended to provide additional protection downstream of the SRCD. SRCDs are intended for use in circuits where the fault protection (indirect contact protection) is already assured upstream of the SRCD.

NOTE 1 For example, fault protection (indirect contact protection) can be covered as follows:

- in TT systems, by upstream RCBOs or RCCBs according to IEC 61008-1 and IEC 61009-1;
- in a TN system, an overcurrent protective device can be used upstream.

NOTE 2 In the United States, there is no requirement for providing indirect contact protection upstream of an SRCD.

NOTE 3 In Switzerland these devices are not allowed for protective measures according to the national installation rules.

SRCDs are neither intended to provide an isolation function nor intended to be used in IT systems.

NOTE 4 For SRCDs intended to provide isolation or fault protection, or to be used in IT systems, IEC 61008-1 or IEC 61009-1 should be used, as applicable, in conjunction with IEC 60884-1.

NOTE 5 Requirements and testing for SRCDs intended to be used in IT systems are under consideration.

SRCDs are not used in distribution boards. They are not intended for the protection of a complete distribution circuit or a complete final circuit. These products are intended to be installed

- in boxes in compliance with IEC 60670-1,
- or in cable trunking systems in compliance with the IEC 61084 series,
- or in power track systems in compliance with the IEC 61534 series,
- or in boxes according to one of the above standards adjacent to socket-outlet boxes.

They are not intended to be used in enclosures or distribution boards in conformity with IEC 60670-24, IEC 61439-1 or IEC 60439-3.

RCDs for household and similar use not covered by the scope of this standard are covered by IEC 61008-1 or IEC 61009-1. SRCDs energized from batteries, or a circuit other than the one powering the loads, are not covered by this standard.

The residual current device incorporates the functions of detection of the residual current, of comparison of the value of this current with the residual operating value and of opening the protected circuit when the residual current exceeds this value.

The maximum rated residual operating current is 30 mA.