

FINAL VERSION

VERSION FINALE

Nuclear power plants – Instrumentation and control systems important to safety – Design and qualification of isolation devices

Centrales nucléaires de puissance – Systèmes d'instrumentation et de contrôle-commande importants pour la sûreté – Conception et qualification des appareils d'isolement

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Symbols and abbreviations.....	8
5 General principles for isolation devices.....	8
5.1 General.....	9
5.2 Isolation characteristics	9
5.3 Actuation priority.....	10
6 Isolation device design requirements	10
6.1 Requirements on isolation device application.....	10
6.1.1 Isolation device power	10
6.1.2 Maximum credible fault.....	10
6.1.3 Energy limiting devices	11
6.2 Requirements on isolation device design	11
6.2.1 Basic design requirements.....	11
6.2.2 Postulated faults.....	12
6.2.3 Physical component arrangement.....	12
6.3 Power isolation devices	13
6.3.1 General	13
6.3.2 Circuit breaker tripped by fault currents	13
6.3.3 Circuit breaker tripped by fault signals.....	13
6.3.4 Input current limiters.....	13
6.3.5 Fuses	13
7 Qualification test requirements.....	14
7.1 General.....	14
7.2 Requirements on the test method.....	14
7.2.1 Test specification.....	14
7.2.2 Testing energy limiting devices	14
7.2.3 Qualification test environment.....	14
7.3 Application specific testing.....	15
7.3.1 General	15
7.3.2 Isolation of safety circuits from lower class circuits	15
7.3.3 Isolation between redundant safety circuits.....	15
7.4 Documentation of test requirements and results.....	16
Bibliography.....	17
Figure 1 – Application of maximum credible fault	11
Figure 2 – Application of postulated fault	12

INTERNATIONAL ELECTROTECHNICAL COMMISSION

NUCLEAR POWER PLANTS – INSTRUMENTATION AND CONTROL SYSTEMS IMPORTANT TO SAFETY – DESIGN AND QUALIFICATION OF ISOLATION DEVICES

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

DISCLAIMER

This Consolidated version is not an official IEC Standard and has been prepared for user convenience. Only the current versions of the standard and its amendment(s) are to be considered the official documents.

This Consolidated version of IEC 62808 bears the edition number 1.1. It consists of the first edition (2015-05) [documents 45A/1004/FDIS and 45A/1019/RVD] and its amendment 1 (2018-05) [documents 45A/1192/FDIS and 45A/1204/RVD]. The technical content is identical to the base edition and its amendment.

Cette version Finale ne montre pas les modifications apportées au contenu technique par l'amendement 1. Une version Redline montrant toutes les modifications est disponible dans cette publication.

International Standard IEC 62808 has been prepared by subcommittee 45A: Instrumentation, control and electrical systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

Currently in preview, click buy full version.

INTRODUCTION

a) Technical background, main issues and organisation of the standard

I&C (instrumentation and control) systems important to safety in nuclear power plants need to tolerate the effects of plant / equipment faults as well as internal and external hazards. IEC 60709 provides requirements to establish independence between redundant portions of safety systems, and between safety systems and systems of a lower class. Among the techniques available to increase the level of tolerability of I&C systems to such effects is the provision of isolation devices where connections are made between redundant divisions of safety equipment, or between safety equipment and systems of a lower class. This standard provides technical requirements and recommendations for the design and qualification of isolation devices that are required by IEC 60709. This standard deals with the criteria and methods used to confirm that the design of isolation devices ensures that credible failure in the connected lower class system or redundant channels will not prevent the safety systems from meeting their required functions. Isolation devices may be required on power or signal interfaces within the system.

Guidance for other aspects of isolation device qualification (e.g. electromagnetic compatibility, environmental and seismic qualification) may be found in IEC 60780.

The object of this standard is:

- in Clause 5: to establish the basic criteria for acceptability of the design and application of isolation devices;
- in Clause 6: to establish design requirements on the selection and application of suitable isolation devices;
- in Clause 7: to establish requirements on qualification testing done to validate the adequacy of the isolation device design.

It is intended that the standard be used by operators of NPPs (utilities), designers of nuclear I&C system and equipment, systems evaluators and regulators.

b) Situation of the current standard in the structure of the IEC SC 45A standard series

IEC 62808 is the third level IEC SC 45A document tackling the issue of isolation devices.

IEC 60709 is directly referenced by IEC 61513 in regard to physical and electrical separation being required between subsystems of different safety trains of I&C systems important to safety, and between I&C systems important to safety and those that are not important to safety.

IEC 61226 establishes the principles of categorization of I&C functions, systems and equipment according to their level of importance to safety. It then requires that adequate separation be provided between functions of different categories. IEC 61226 refers to IEC 60709 as a normative standard regarding requirements of separation.

IEC 62808 is intended to provide requirements and recommendations relating to the design and qualification of isolation devices which are identified in IEC 60709 as a means of achieving independence between systems when signals are extracted from a system for use in lower class systems, or between independent subsystems of the same classes.

For more details on the structure of the IEC SC 45A standard series, see item d) of this introduction.

c) Recommendations and limitations regarding the application of this standard

IEC 60709 applies to I&C systems and equipment important to safety. It establishes requirements for physical and electrical separation as one means to provide independence between the functions performed in those systems and equipment. IEC 60709 requires the use of isolation devices where connections between independent systems must be made. IEC 62808 provides criteria for the analysis and qualification of the the isolation device.

A fundamental criterion for isolation devices is that they be included in, and designed to, the standards of the higher class system for which they provide protection against hazards. Additional requirements relating to design and qualification of an isolation device as an element of a safety system are not given in this standard.

d) Description of the structure of the IEC SC 45A standard series and relationships with other IEC documents and other bodies documents (IAEA, ISO)

The top-level document of the IEC SC 45A standard series is IEC 61513. It provides general requirements for I&C systems and equipment that are used to perform functions important to safety in NPPs. IEC 61513 structures the IEC SC 45A standard series.

IEC 61513 refers directly to other IEC SC 45A standards for general topics related to categorization of functions and classification of systems, qualification, separation of systems, defence against common cause failure, software aspects of computer-based systems, hardware aspects of computer-based systems, and control room design. The standards referenced directly at this second level should be considered together with IEC 61513 as a consistent document set.

At a third level, IEC SC 45A standards not directly referenced by IEC 61513 are standards related to specific equipment, technical methods or specific activities. Usually these documents, which make reference to second-level documents for general topics, can be used on their own.

A fourth level extending the IEC SC 45A standard series, corresponds to the Technical Reports which are not normative.

IEC 61513 has adopted a presentation format similar to the basic safety publication IEC 61508 with an overall safety life-cycle framework and a system life-cycle framework. Regarding nuclear safety, it provides the interpretation of the general requirements of IEC 61508-1, IEC 61508-2 and IEC 61508-4, for the nuclear application sector, regarding nuclear safety. In this framework IEC 60880 and IEC 62138 correspond to IEC 61508-3 for the nuclear application sector. IEC 61513 refers to ISO as well as to IAEA GS-R-3 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

The IEC SC 45A standards series consistently implements and details the principles and basic safety aspects provided in the IAEA code on the safety of NPPs and in the IAEA safety series, in particular the Requirements SSR-2/1, establishing safety requirements related to the design of Nuclear Power Plants, and the Safety Guide NS-G-1.3 dealing with instrumentation and control systems important to safety in Nuclear Power Plants. The terminology and definitions used by SC 45A standards are consistent with those used by the IAEA.

NOTE It is assumed that for the design of I&C systems in NPPs that implement conventional safety functions (e.g. to address worker safety, asset protection, chemical hazards, process energy hazards), international or national standards would be applied, that are based on the requirements of a standard such as IEC 61508.

NUCLEAR POWER PLANTS – INSTRUMENTATION AND CONTROL SYSTEMS IMPORTANT TO SAFETY – DESIGN AND QUALIFICATION OF ISOLATION DEVICES

1 Scope

This International Standard establishes requirements for the design, analysis and qualification of isolation devices used to ensure electrical independence of redundant safety system circuits, or between safety and lower class circuits, as specified in IEC 60709. This standard includes guidance on the determination of the maximum credible fault that is applied to the isolation devices. The maximum credible fault can be used as a basis for the test levels used in testing based on other standards (e.g. IEC TS 61000-6-5 or IEC 62003).

This standard does not address safety or CCF issues due to functional inter-dependencies and possible interferences or CCFs that may result from signal exchange or coupling between systems or sub-systems. It also does not address design or qualification issues related to digital or programmable logic in isolation devices. For isolation devices containing digital or programmable logic, additional design and qualification requirements must be considered; these requirements are outside the scope of this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60709, *Nuclear power plants – Instrumentation and control systems important to safety – Separation*

IEC TS 61000-6-5, *Electromagnetic compatibility (EMC) – Part 6-5: Generic standards – Immunity for power station and substation environments*

IEC 61513, *Nuclear power plants – Instrumentation and control important to safety – General requirements for systems*

IEC 62003, *Nuclear power plants – Instrumentation and control important to safety – Requirements for electromagnetic compatibility testing*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1 Barrier

device or structure interposed between redundant equipment or circuits important to safety, or between equipment or circuits important to safety and a potential source of damage to limit damage to the I&C system important to safety to an acceptable level

Note 1 to entry: The following definition is given in the IAEA Safety Glossary, edition 2007: “A physical obstruction that prevents or inhibits the movement of people, radionuclides or some other phenomenon (e.g. fire), or provides shielding against radiation”. The IAEA definition is more general and consistent with the definition given in this standard.