

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Mechanical structures for electrical and electronic equipment – Aisle
containment for it cabinets –
Part 1: Dimensions and mechanical requirements**

**Structures mécaniques pour équipements électriques et électroniques –
Confinement d'allées pour les baies informatiques –
Partie 1: Dimensions et exigences mécaniques**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2019 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 000 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Mechanical structures for electrical and electronic equipment – Aisle
containment for IT cabinets –
Part 1: Dimensions and mechanical requirements**

**Structures mécaniques pour équipements électriques et électroniques –
Confinement d'allées pour les baies informatiques –
Partie 1: Dimensions et exigences mécaniques**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 31.240

ISBN 978-2-8322-6614-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Design of a containment	8
4.1 Preferred arrangement setup of aisle containment	8
4.2 Optional arrangement set up of aisle containment.....	9
4.2.1 Arrangement of different sized cabinets for an aisle containment.....	10
4.2.2 Arrangement for an aisle containment with building structure element.....	10
4.2.3 Aisle containment at walls of buildings.....	11
4.3 Top cover elevation	12
4.4 Adaptation of air flow orientation.....	13
4.5 Air duct connection	13
5 Requirements of containment	14
5.1 Air tightness.....	14
5.2 Stability.....	15
5.3 Design of the ceiling of the aisle containment	15
6 Aisle containment dimensions.....	15
6.1 General.....	15
6.2 Width of the aisle	16
6.3 Dimensions of cabinets	16
6.4 Height of the elevated aisle top cover	17
Bibliography.....	18
Figure 1 – Examples of an aisle containment	6
Figure 2 – Preferred arrangement setup of an aisle containment.....	9
Figure 3 – Possible arrangement of an aisle containment	10
Figure 4 – Aisle containment with an integrated structural element	11
Figure 5 – Top view of aisle containment with an integrated structural element not in line with the cabinet front	11
Figure 6 – Aisle containment at a wall of a building.....	12
Figure 7 – Elevated aisle height.....	13
Figure 8 – Aisle containment with an air duct.....	14
Figure 9 – Dimensions at an aisle containment	16
Table 1 – Aisle widths	16
Table 2 – Cabinet height including plinth.....	17
Table 3 – Cabinet widths	17

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MECHANICAL STRUCTURES FOR
ELECTRICAL AND ELECTRONIC EQUIPMENT –
AISLE CONTAINMENT FOR IT CABINETS –**

Part 1: Dimensions and mechanical requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization, comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, issue to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62966-1 has been prepared by subcommittee 48D: Mechanical structures for electrical and electronic equipment, of IEC technical committee 48: Electrical connections and mechanical structures for electrical and electronic equipment.

The text of this International Standard is based on the following documents:

FDIS	Report on voting
48D/691/FDIS	48D/698/RVD

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62966 series, published under the general title *Mechanical structures for electrical and electronic equipment – Aisle containment for IT cabinets*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Cabinets of the IEC 60297 and IEC 60917 standard series are used as enclosures of electrical and electric equipment in many different fields of application. A wide field of application is represented by enclosures equipped with electronic information technology (IT) equipment. They are frequently set up in large numbers in server rooms and data centres. During their operation, the electronic equipment installed generates a considerable amount of heat that must be dissipated from the equipment by means of cooling air. Precise adjustment of the supply air temperature and a sufficient cooling air flow are indispensable prerequisites for the fail-safe operation of equipment in information technology.

Currently, it is common use in data centres and server rooms to set up cabinets in rows. The server cabinets along the rows are usually arranged in such a way that surfaces with cold supply air inlets face each other across an aisle, and surfaces with hot exhaust air outlets also face each other across an aisle. This row configuration is generally known as a hot aisle/cold aisle configuration. Moreover, air is supplied and discharged exclusively via the front and rear panels of the server cabinets, which are frequently perforated doors. It is assumed that inside the IT equipment, the cooling air is moved in horizontal direction, taking it in at the front and discharging it at the rear.

The required cooling air is provided by room air or row air conditioning. Warm exhaust air is moved by fans usually through a fluid/air heat exchanger that cools it.

In the arrangement described, considerable quantities of cooling air pass by the IT equipment, especially servers, which it is expected to cool, without having any cooling effect. Concurrently, recirculation within and outside the cabinet causes hot exhaust air to be absorbed as cooling air, which results in faulty operation. In order to minimize such recirculation, more cooling air than required needs to be supplied, this adversely affects the energy efficiency of the data centre.

The separation of air flows into enclosed air volumes consisting of either cold supply air or hot exhaust air precludes recirculation to the largest possible extent (see Figure 1). Such separation reduces the required cooling air flow because re-circulations are ruled out. Air flow separation can reduce power consumption by the fans in the cooling units once fan speed control fans are used.

Separation of the cold supply air from the hot exhaust air is achieved by covering the aisles of the same temperature level with top cover elements, adding doors or similar design elements to the end of the aisles, and all openings inside the cabinets at the front 482,6mm (19") rails shall be closed.

The installation of aisle containments in data centres and IT rooms shall not restrict the air intake demands for the correct usage and operation of servers or other IT equipment. Especially the required supply air temperature and the cooling air flow rate needed shall not be affected by the aisle containment. This can improve the energy efficiency as most of the cooling infrastructure has a higher efficiency with a higher difference between the air intake and the hot exhaust temperature.

The temperature difference between supply and exhaust air rises due to the reduced cooling air volume. As the supply air temperature of the cooling air is usually specified, thus being kept constant, an increase in the temperature difference results in an increase of the temperature of the warm exhaust air. This has a positive impact on the temperature difference to the temperature of ambient air, as the energy efficiency of the cooling of the building and infrastructure is improved by the raised temperature gradient.

The period during which system cooling is required to be supported by a mechanical cooling machine is reduced. Both the reduction of the cooling air flow and the reduction of times of mechanical cooling lead to considerable reduction in the consumption of electrical power. This effects significant savings in operating costs for data centres and server rooms. This results in

an environmentally-friendly use of resources, thereby relieving stress on the environment and slowing down global warming by reduced CO₂ emission.

Part 1 of the standard series defines geometric dimensions and mechanical properties ensuring undisturbed, energy-efficient and user-friendly operation of the data centre.

Part 2 defines characteristics and requirements of air separation, especially the air leakage rate, and determines the air leakage rate. Besides, operational parameters are determined, especially temperatures at which IT equipment in aisle containment are operated.

Part 3 deals with aspects of safely operating IT equipment in aisle containment, discussing special fire-protection and fire-fighting issues. It also provides required specifications of the doors for access to the aisle containment and possible access control.

In the past years, widely varying forms of aisle containment have been installed in server rooms and data centres. This document is intended to provide confidence by reflecting and structuring the currently most widely used solutions and catering for the energy-efficient operation of IT equipment. This document is also expected to solve probable uncertainties and problems concerning the containment technology




Figure 1 – Examples of an aisle containment

MECHANICAL STRUCTURES FOR ELECTRICAL AND ELECTRONIC EQUIPMENT – AISLE CONTAINMENT FOR IT CABINETS –

Part 1: Dimensions and mechanical requirements

1 Scope

This part of IEC 62966 defines the dimensions and mechanical requirements of aisle containment for information technology (IT) cabinets. The cabinets concerned are dealt with in the standard series IEC 60297 and IEC 60917. The objective of this document is to stipulate properties and requirements of aisle containment ensuring cost effective installation, energy-efficient and user-friendly operation of IT equipment in data centres and server rooms.

2 Normative references

The following documents are referred to in the text in such a way, that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61587-1, *Mechanical structures for electronic equipment – Tests for IEC 60917 and IEC 60297 series – Part 1: Environmental requirements, test set-up and safety aspects for cabinets, racks, subracks and chassis under indoor condition use and transportation*

IEC 61587-2, *Mechanical structures for electronic equipment – Tests for IEC 60917 and 60297 – Part 2: Seismic tests for cabinets and racks*

IEC 62966-2: *Mechanical structures for electrical and electronic equipment – Aisle containment for IT cabinets – Part 2: Details of air flow, air separation and air cooling requirements* (to be published)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

aisle containment

physical containment mainly formed of IT cabinets arranged in parallel rows with a centre aisle, a top cover across the aisle, doors or building structure at the ends of the aisle, and a floor

Note 1 to entry: The main purpose is the cooling air guidance to the IT equipment and the avoidance of bypass air and cooling air re-circulations.