



IEEE Guide for Batteries for Uninterruptible Power Supply Systems

IEEE Power Engineering Society

Sponsored by the
Stationary Battery Committee

1184TM

IEEE
3 Park Avenue
New York, NY 10016-5997, USA
29 September 2006

IEEE Std 1184TM-2006
(Revision of
IEEE 1184-1994)

Currently in preview, click buy full version

Recognized as an
American National Standard (ANSI)

IEEE Std 1184™-2006(R2011)
(Revision of
IEEE 1184-1994)

IEEE Guide for Batteries for Uninterruptible Power Supply Systems

Sponsor

Stationary Battery Committee
of the
IEEE Power Engineering Society

Approved 11 September 2006
American National Standards Institute

Approved 30 March 2006
Reaffirmed 7 December 2011
IEEE SA-Standards Board

Abstract: Various battery systems are discussed so that the user can make informed decisions on selection, installation design, installation, maintenance, and testing of stationary standby batteries used in uninterruptible power supply (UPS) systems. This guide describes how the UPS battery charging and converter components can relate to the selection of the battery systems. Design requirements of the UPS components are beyond the scope of this document. Battery back-up systems for dc-output rectifiers are also beyond the scope of this document. .

Keywords: battery system, Ni-Cd batteries (Ni-Cd), uninterruptible power supply, UPS, valve-regulated leadacid (VRLA), vented lead-acid batteries (VLA)

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 29 September 2006. Printed in the United States of America.

Second printing 22 February 2007. Equation 5 was corrected and cross references were corrected on pages 20, 22, and 34.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are both registered trademarks in the U.S. Patent & Trademark Office, owned by the National Fire Protection Association, Incorporated.

Print: ISBN 0-7381-4958-4 SH95533
PDF: ISBN 0-7381-4959-4 SS95533

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied **“AS IS.”**

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 1184-2006, IEEE Guide for Batteries for Uninterruptible Power Supply Systems.

Our society's increasing dependence on computerized information has resulted in the expanded use of uninterruptible power systems (UPS) to ensure the integrity of essential power systems. These systems require that stored energy be available to maintain operation. Although rotating inertia has at times been used to store this energy, batteries remain the preferred method of energy storage for this purpose. An array of battery designs and extensive technologies are available to the user.

This guide is intended to inform the user of the various battery technologies available and some of the design points to be considered when selecting a battery for UPS applications. Some of the battery design options that result in volumetric efficiency may also result in reduced life. This guide can help the user to become aware of which designs and operating procedures can result in optimum battery life. This guide is intended to be used along with IEEE Std 485™, IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stationary Applications; IEEE Std 484™, IEEE Recommended Practice for Installation Design and Installation of Vented Lead-Acid Batteries for Stationary Applications; IEEE Std 450™, IEEE Recommended Practice for Maintenance, Testing, and Replacement of Vented Lead-Acid Batteries for Stationary Applications; and IEEE Std 1106™, IEEE Recommended Practice for Installation, Maintenance, Testing, and Replacement of Vented Nickel-Cadmium Batteries for Stationary Applications.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

At the time this guide was completed, the Uninterruptible Power Supply (UPS) System working group had the following membership:

Bansi R. Patel, Chair

Curtis Ashton	Pete DeMar	Ed Rafter
Gary Balash	Richard Greco	Omi Samanta
Robert Beavers	Roger Johnson	Robert J. Schmitt
Richard T. Bolgeo	Wayne Johnson	M. A. (Sam) Shah
William Cantor	John Kopera	H. F. (Hal) Taylor
Jay Chamberlin	Jose A. Marrero	Richard Tressler
Bart Cotton	Stephen McCluer	Lesley Varga
Thomas G. Croda	Jim McDowall	Al Williamson

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Samuel Aguirre	Gary Engmann	Edward Kafter
James Anderson	Harold Epstein	Robert Kolinson
Curtis Ashton	Trilok Garg	Charles Rogers
Gary Balash	Jerry Goerz	Steven Sano
Robert Beavers	Richard Greco	Robert Seitz
Richard T. Bolgeo	Randall Groves	Edward Stallings
William Cantor	Joseph Jancauskas	James Stoner
Garth Corey	Alan Jensen	H. F. (Hal) Taylor
Stephen Dare	Jose A. Marrero	Richard Tressler
Matthew Davis	Stephen McCluer	Lesley Varga
Jerry DiSciullo	Jim McDowall	James Wilson
Neal Dowling	G. Michel	Edward Wirth
James Edmonds	Bansi R. Patel	Donald W. Zipse
		Ahmed Zobaa

When the IEEE-SA Standards Board approved this guide on 30 March 2006, it had the following membership:

Steven M. Mills, Chair

Richard H. Hulett, Vice Chair

D. Wright, Past Chair

Judith Gorman, Secretary

Mark D. Bowman	William B. Hopf	Greg Ratta
Dennis B. Brophy	Joseph L. Koepfinger*	Robby Robson
William R. Goldbach	David J. Law	Anne-Marie Sahazizian
Arnold M. Greenspan	Daleep C. Mohla	Virginia C. Sulzberger
Robert M. Grow	T. W. Olsen	Malcolm V. Thaden
Joanna N. Guenin	Glenn Parsons	Richard L. Townsend
Julian H. Heisterkamp	Ronald C. Petersen	Walter Weigel
Marie S. Hulpin	Tom A. Prevost	Howard L. Wolfman
Kenneth S. Hanus		

Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Alan H. Cookson, *NIST Representative*

Michelle D. Turner
IEEE Standards Program Manager, Document Development

Angela Ortiz
IEEE Standards Program Manager, Technical Program Development

Currently in preview, click buy full version

CONTENTS

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
2. Normative references.....	2
3. Definitions	2
4. Battery types.....	3
4.1 General	3
4.2 Performance considerations.....	4
4.3 Vented lead-acid (VLA) batteries.....	4
4.4 Valve-regulated lead-acid (VRLA) batteries	4
4.5 Vented Ni-Cd batteries	6
4.6 Sealed Ni-Cd batteries	7
5. Selection considerations	7
5.1 Design considerations.....	7
5.2 Battery footprint and floor loading	8
5.3 Battery life	8
5.4 Ventilation	9
6. Application considerations	11
6.1 Installation design.....	11
6.2 UPS operating consideration	13
6.3 Warranty considerations	14
7. Battery sizing.....	15
7.1 Voltage window design	15
7.2 Temperature.....	15
7.3 Design and aging considerations	17
7.4 Battery sizing calculations.....	17
7.5 Sample application for three-phase UPS.....	18
8. Commissioning.....	23
8.1 Design adherence.....	23
8.2 Installation adherence	23
8.3 Performance adherence.....	23
9. Maintenance and testing	23
9.1 General	23
9.2 Safety	24
9.3 Maintenance of lead-acid batteries	25
9.4 Maintenance requirements – Ni-Cd.....	29

9.5 Testing	31
9.6 Data analysis.....	33
9.7 Record retention	36
Annex A (informative) Bibliography	37
Annex B (normative) Seismic requirements.....	39
Annex C (normative) Lead-acid battery technology	40
Annex D (normative) Ni-Cd battery technology	47
Annex E (normative) Service life considerations	50
Annex F (normative) Commissioning	54
Annex G (normative) Maintenance and testing intervals	62

IEEE Guide for Batteries for Uninterruptible Power Supply Systems

1. Overview

1.1 Scope

This guide discusses various battery systems so that the user can make informed decisions on selection, installation design, installation, maintenance, and testing of stationary standby batteries used in uninterruptible power supply (UPS) systems. This guide describes how the UPS battery charging and converter components can relate to the selection of the battery systems. Design requirements of the UPS components are beyond the scope of this document. Battery back-up systems for dc-output rectifiers are also beyond the scope of this document. While this document applies to all UPS systems, it may be impractical to implement some of its guidance and recommendations with small, self-contained systems, such as products intended to back up individual personal computers.

This guide divides the available technologies into the following three main categories:

- Vented lead-acid batteries (VLA)
- Valve-regulated lead acid (VRLA)
- Ni-Cd batteries (Ni-Cd)

For each category, the technology and the design of the battery are described in order to facilitate user selection. The specific advantages for particular applications are also listed.

1.2 Purpose

This guide is intended to assist those involved with battery systems for uninterruptible power supply systems. Proper design, installation, and maintenance will enable the user to manage the battery system for optimum operation and results.