



BOOK™

142™

IEEE Recommended Practice for

**Grounding of
Industrial and
Commercial Power
Systems**

IEEE

Published by the
Institute of Electrical and
Electronics Engineers, Inc.

IEEE Std 142™-2007
(Revision of
IEEE Std 142-1991)

IEEE Std 142™-2007

(Revision of
IEEE Std 142-1991)

IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems

Sponsor

**Power Systems Engineering Committee
of the
IEEE Industry Applications Society**

Approved 7 June 2007

IEEE-SA Standards Board

Abstract: The problems of system grounding, that is, connection to ground of neutral, of the corner of the delta, or of the midtap of one phase, are covered. The advantages and disadvantages of grounded vs. ungrounded systems are discussed. Information is given on how to ground the system, where the system should be grounded, and how to select equipment for the ground of the neutral circuits. Connecting the frames and enclosures of electric apparatus, such as motors, switchgear, transformers, buses, cables, conduits, building frames, and portable equipment, to a ground system is addressed. The fundamentals of making the interconnection of a ground conductor system between electric equipment and the ground rods, water pipes, etc., are outlined. The problems of static electricity—how it is generated, what processes may produce it, how it is measured, and what should be done to prevent its generation or to drain the static charges to earth to prevent sparking—are treated. Methods of protecting structures against the effects of lightning are also covered. Obtaining a low-resistance connection to earth, use of ground rods, connections to water pipes, etc., are discussed. A separate chapter on electronic equipment is included.

Keywords: connection to earth, electronic equipment grounding, equipment grounding, lightning protection, static protection, system grounding

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2007 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 30 November 2007. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are both registered trademarks in the U.S. Patent & Trademark Office, owned by the National Fire Protection Association.

National Electrical Safety Code and NESC are both registered trademarks and service marks of the Institute of Electrical and Electronics Engineers, Inc.

National Lightning Detection Network (NLDN) is a registered trademark of Vaisala, Inc.

Print: ISBN 0-7381-5639-2 SH95700
PDF: ISBN 0-7381-5640-X SS95700

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
1000 Hillside Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 142-2007, IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems.

This book is a revision of IEEE Std 142-1991, the *IEEE Green Book*[™]. This recommended practice has served electrical engineers seeking electrical system grounding information since the first edition in 1956. It reflects the experience and sound judgment of a working group made up of engineers active in the design and operation of electrical systems for industrial and commercial power systems.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement a IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the Working Group had the following membership:

Elliot Rappaport, *Chair*
Daleep C. Mohla, *Vice Chair*

Chapter 1: System grounding—**Donald W. Zipse** and **Gene Strycula**, *Co-chairs*

Chapter 2: Equipment grounding—**Elliot Rappaport**, *Chair*

Chapter 3: Static and lightning protection grounding—**Donald McCullough II** and **Donald W. Zipse**, *Co-chairs*

Chapter 4: Connection to earth—**Ken Michaels**, *Chair*

Chapter 5: Electronic equipment grounding—**Thomas Baldwin**, *Chair*

Larry Ayer	Thomas M. Gruzs	Neil Nichols
V. Basch	M. Jerath	Melvin K. Sanders
Baldwin Bridger	Don O. Koval	Lynn F. Saunders
William Bush	T. David Mills	Srinivasa I.
M. Butkiewicz		Rebbapragada

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Marcos Andrade	Randall Groves	William Moylan
Richard Becker	Thomas M. Gruzs	Michael Newman
W. J. (Bill) Bergman	Paul Hamer	Neil Nichols
Thomas Blair	Robert Hood	Greg Nolan
William Bloethe	Darin Hunt	T. W. Olsen
Stuart Bouchey	Robert Singhani	Gregory Olson
Baldwin Bridger	David W. Jackson	Lorraine Padden
Frederick Brockhurst	Jedric Jancauskas	Kostas Pervolarakis
Mark Bushnell	Yuri Khersonsky	Paul Pillitteri
Keith Chow	Robert Konnik	Percy Pool
Donald Colaberardino	Don O. Koval	Louie Powell
Stephen P. Conrad	Saumen Kundu	Elliot Rappaport
Terry Conrad	Stephen R. Lambert	Radhakrishna
James Daly	Blane Leuschner	Rebbapragada
Stephen Dare	Jason Lin	Michael Roberts
Guru Dutt Dhingra	Michael Lowenstein	Melvin K. Sanders
Gary DiAntonio	Richard Loyd	Steven Sano
Gary Donner	Gregory Luri	Robert Schuerger
Randall E. Eaton	Keith Malmedal	Robert Seitz
Neal Dowling	William McCoy	Michael Shirven
Donald Dunn	Donald McCullough II	H. Jin Sim

Dan Evans
Jay Fischer
H. Landis Floyd II
Marcel Fortin
Carl Fredericks
Edgar Galyon
Travis Griffith

Mark McGranaghan
John Merando
James Michalec
Gary Michel
T. David Mills
James Mitchem
Charles Morse
Abdul Mousa

David Smith
Robert Smith
Devendra Soni
Peter Sutherland
James Wilson
Larry Young
Donald W. Zipse

When the IEEE-SA Standards Board approved this standard on 7 June 2007, it had the following membership:

Steve M. Mills, *Chair*
Robert M. Gown, *Vice Chair*
Don Wright, *Past Chair*
Judith Gorman, *Secretary*

Richard DeBlasio
Alex Gelman
William R. Goldbach
Arnold M. Greenspan
Joanna N. Guenin
Julian Forster*
Kenneth S. Hanus
William B. Hopf

Richard H. Hulett
Hermann Koch
Joseph L. Koepfinger*
John Kulick
David J. Law
Glenn Parsons
Ronald C. Petersen
Tom A. Prevost

Narayanan Ramachandran
Greg Ratta
Robby Robson
Anne-Marie Scharif
Virginia C. Sumner
Malcolm V. Thaden
Richard L. Townsend
Howard Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *IEEE Representative*
Alan H. Cohen, *IEEE T Representative*

Don Messina
IEEE Standards Program Manager, Document Development

Patricia A. Gerdon
IEEE Standards Program Manager, Technical Program Development

Contents

Chapter 1

System grounding	1
1.1 Introduction.....	1
1.2 Definitions.....	2
1.3 Purposes of system grounding	4
1.4 Methods of system neutral grounding.....	5
1.5 Obtaining the system neutral	22
1.6 Location of system grounding points.....	28
1.7 Grounding of industrial and commercial generators	38
1.8 Autotransformers	48
1.9 System grounding for uninterruptible power systems	53
1.10 Portable mining equipment supply systems.....	57
1.11 Creation of stray currents and potentials	60
1.12 Avoiding common-mode noise.....	62
1.13 Limiting transferred earth potentials.....	63
1.14 “Resonantly” produced voltages.....	64
1.15 Grounding of dc power systems	66
1.16 Normative references	70
1.17 Bibliography	73

Chapter 2

Equipment grounding.....	75
2.1 Basic objectives	75
2.2 Fundamental concepts.....	77
2.3 Equipment grounding as influenced by type of use.....	95
2.4 Outdoor open-frame substations	95
2.5 Unit substations.....	99
2.6 Installations serving heavy portable electric machinery	100
2.7 Interior wiring systems	104
2.8 Interior unit substations and switchgear centers.....	110
2.9 Utilization equipment.....	111
2.10 Normative references	114
2.11 Bibliography	116

Chapter 3

Static and lightning protection grounding.....	119
3.1 Introduction	119
3.2 Static grounding.....	119
3.3 Lightning protection grounding	140
3.4 Normative references	156
3.5 Bibliography	159

Chapter 4	
Connection to earth	161
4.1 Resistance to earth	161
4.2 Ground electrodes	169
4.3 Methods and techniques of construction.....	174
4.4 Measurement of resistance to earth.....	176
4.5 Normative references	182
Chapter 5	
Electronic equipment grounding.....	187
5.1 Introduction.....	187
5.2 Definitions.....	187
5.3 History of computer grounding.....	188
5.4 System or equipment to be grounded.....	190
5.5 Grounding electronic equipment.....	191
5.6 Effects of internal rectifiers in computers.....	200
5.7 Grounding of shields.....	201
5.8 Interference from radio frequencies	204
5.9 Case histories	205
5.10 Normative references	207
5.11 Bibliography	208
Index	211

IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems

Chapter 1 System grounding

1.1 Introduction

1.1.1 Overview

This chapter provides recommended procedures for the system grounding of industrial and commercial power systems, and the proper selection and application of grounding impedances. Special cases of system grounding are also addressed for generators, uninterruptible power supplies (UPS), portable mining equipment, and multi-voltage systems.

1.1.2 General

Grounding of an electrical system is a decision that must be faced sometime by most engineers charged with planning or modifying electrical distribution. Grounding in some form is generally recommended, although there are certain exceptions. Several methods and criteria exist for system grounding; each has its own purpose.

It is the intention of this chapter to assist the engineer in making decisions on the subject by presenting basic reasons for grounding or not grounding and by reviewing general practices and methods of system grounding.

The practices set forth herein are primarily applicable to industrial power systems that distribute and utilize power at medium or low voltage, usually within a smaller geographical area than covered by a utility.

Where distances or power levels may dictate circuitry and equipment similar to a utility, consideration of utility practices is warranted. However, restrictions of the National Electrical Code[®] (NEC[®]), NFPA 70¹ particular needs of service and the experience and training of the workforce should also be considered.

¹Information on references can be found in 1.16.

Where an industrial power system includes power-generating equipment, the reasons for grounding these components may be the same as those for grounding similar components of public utility systems. The methods of grounding would generally be similar under like conditions of service. However, in the industrial setting, conditions of service may be altered by the following:

- a) Location within the power system
- b) Individual generator characteristics
- c) Manufacturing process requirements

All of these may affect grounding decisions.

The NEC, sponsored by the National Fire Protection Association, contains regulations pertaining to system and equipment grounding applicable to industrial, commercial, and special occupancy facilities. These rules are considered minimum requirements for the protection of life and property and should be carefully reviewed during the course of system design. The recommended practices in this document are intended to supplement, and not negate, any of the requirements in the NEC.

1.2 Definitions

For the purposes of this document, the following terms and definitions apply. *The Authoritative Dictionary of IEEE Standards Terms* [B8]² and the NEC should be referenced for terms not defined in this subclause.

1.2.1 effectively grounded: Grounded through a sufficiently low impedance such that for all system conditions the ratio of zero-sequence reactance to positive-sequence reactance (X_0/X_1) is positive and not greater than 3, and the ratio of zero-sequence resistance to positive-sequence reactance (R_0/X_1) is positive and not greater than 1.

1.2.2 equipment grounding conductor (EGC): The conductor used to connect the non-current-carrying metal parts of the equipment, raceways, and other enclosures to the system grounded conductor, the grounding electrode conductor (GEC), or both, at the service equipment or at the source of a separately derived system.

1.2.3 ground: A conducting connection, whether intentional or accidental, between an electrical circuit or equipment and the earth, or to some other body that serves in place of the earth.

1.2.4 grounded: Connected to earth or to an extended conducting body that serves instead of the earth, whether the connection is intentional or accidental.

1.2.5 grounded system: A system in which at least one conductor or point (usually the middle wire or neutral point of transformer or generator windings) is intentionally grounded, either solidly or through an impedance.

²The numbers in brackets correspond to those of the bibliography in 1.17.

1.2.6 grounding system: A system that consists of all interconnected grounding connections in a specific power system and is defined by its isolation from adjacent grounding systems. The isolation is provided by transformer primary and secondary windings that are coupled only by magnetic means. Thus, the system boundary is defined by the lack of a physical connection that is either metallic or through a significantly high impedance.

1.2.7 high-resistance grounded: A resistance-grounded system designed to limit ground-fault current to a value that can be allowed to flow for an extended period of time, while still meeting the criteria of $R_0 < X_{co}$, so that transient voltages from arcing ground faults are reduced. The ground-fault current is usually limited to less than 10 A, resulting in limited damage even during prolonged faults.

1.2.8 low-resistance grounded: A resistance-grounded system that permits a higher ground-fault current to flow to obtain sufficient current for selective relay operation. Usually meets the criteria of R_0/X_0 less than or equal to 2. Ground-fault current is typically between 100 A and 1000 A.

1.2.9 per-phase charging current (I_{co}): The current (V_{ln}/X_{co}) that passes through one phase of the system to charge the distributed capacitance per phase-to-ground of the system; V_{ln} is the line-to-neutral voltage and X_{co} is the per-phase distributed capacitive reactance of the system.

1.2.10 reactance grounded: Grounded through an impedance, the principal element of which is inductive reactance.

1.2.11 resistance grounded: Grounded through an impedance, the principal element of which is resistance.

1.2.12 resonant grounded: A system in which the capacitive charging current is neutralized by an inductive current produced from a reactor connected between the system neutral and ground. By properly “tuning” the reactor (selecting the right tap), a low magnitude of fault current can be achieved. In general, when this occurs the arc will not maintain itself and the ground fault is extinguished or “quenched.” In a parallel circuit, consisting of L and C, this happens when,

$$\omega L = \frac{1}{\omega C} \quad \text{or} \quad f = \frac{1}{2\pi\sqrt{LC}}$$

1.2.13 R_n : The value of the resistance connected from the neutral to the ground of a resistance-grounded system. For high-resistance grounded systems where R_n is a major component of R_0 , the relationship $R_0 = 3R_n$ applies.

1.2.14 R_0 : The per-phase zero-sequence resistance of the system.

1.2.15 separately derived system: A wiring system whose power is derived from a generator, transformer, or converter windings and has no direct electrical connection,

including a solidly connected grounded circuit conductor, to supply conductors originating in another system.

1.2.16 solidly grounded: Connected directly through an adequate ground connection in which no impedance has been intentionally inserted.

1.2.17 static charge: The electricity generated when two dissimilar substances come into contact. Conveyor belts are active producers of static electricity.

1.2.18 switching surge: A transient wave of overvoltage in an electric circuit caused by the operation of a switching device interrupting current.

1.2.19 system charging current: The total distributed capacitive charging current ($3V_{ln}/X_{co}$) of a three-phase system.

1.2.20 three-phase, four-wire system: A system of alternating current supply comprising four conductors, three of which are connected as in a three-phase three-wire system, the fourth being connected to the neutral point of the supply or midpoint of one phase in case of delta-connected transformer secondary for the purpose of conducting load current.

1.2.21 three-phase, three-wire system: A system of alternating current supply comprising three conductors, between successive pairs of which are maintained alternating differences of potential successively displaced in phase by one third of a period.

1.2.22 transient overvoltage: The temporary overvoltage associated with the operation of a switching device, a fault, a lightning stroke, an arcing ground fault on an ungrounded system, or other instigating events.

1.2.23 ungrounded system: A system without an intentional connection to ground except through potential indicating or measuring devices or other very high-impedance devices.

1.2.24 X_{co} : The distributed per-phase capacitive reactance to ground of the system.

1.2.25 X_0 : Zero-sequence reactance of the system.

1.2.26 X_1 : Positive-sequence reactance of the system.

1.2.27 X_2 : Negative-sequence reactance of the system.

1.3 Purposes of system grounding

System grounding is the intentional connection to ground of a phase or neutral conductor for the purpose of:

- a) Controlling the voltage with respect to earth, or ground, within predictable limits, and

- b) Providing for a flow of current that will allow detection of an unwanted connection between system conductors and ground. Such detection may then initiate operation of automatic devices to remove the source of voltage from these conductors.

The NEC prescribes certain system grounding connections that must be made to be in compliance with the code. The control of voltage to ground limits the voltage stress on the insulation of conductors so that insulation performance can more readily be predicted. The control of voltage also allows reduction of shock hazard to persons who might come in contact with live conductors.

1.4 Methods of system neutral grounding

1.4.1 Introduction

Most grounded systems employ some method of grounding the system neutral at one or more points. These methods can be divided into two general categories: *solid grounding* and *impedance grounding*. Impedance grounding may be further divided into several subcategories: reactance grounding, resistance grounding, and *ground-fault neutralizer grounding*. Figure 1-1 shows examples of these methods of grounding.

Each method, as named, refers to the nature of the external circuit from system neutral to ground rather than to the degree of grounding. In each case the impedance of the generator or transformer whose neutral is grounded is in series with the external circuit. Thus a solidly grounded generator or transformer may or may not furnish effective grounding to the system, depending on the system source impedance.

Many of the concepts involved in defining system grounding types and levels are best explained in terms of symmetrical components or equivalent circuits. The reader who is not familiar with these analytical methods is referred to Chapter 2 of Beeman and to Chapter 3 of IEEE Std 399™ (*IEEE Brown Book™*) for guidance.

Molded-case circuit-breaker interrupting capabilities can be affected by the method of grounding. In addition, if other than solidly grounded wye systems are used, the circuit breakers' single-pole interrupting ratings should be evaluated for the application.

1.4.2 Ungrounded system (no intentional grounding)

In an ungrounded system, there is no intentional connection between the system conductors and ground. However, as shown in Figure 1-2, there always exists a capacitive coupling between one system conductor and another, and also between system conductors and ground. Consequently, the so-called *ungrounded* system is in reality a *capacitance grounded* system, by virtue of the distributed capacitance from the system conductors to ground. Since the capacitance between phases has little effect on the grounding characteristics of the system, it will be disregarded. For simplicity, the distributed capacitive reactance to ground, X_{CO} , is assumed to be balanced.