



# IEEE Standard for Performance of Adjustable Speed AC Drives Rated 375 kW and Larger

---

**IEEE Industry Applications Society**

Sponsored by the  
Petroleum and Chemical Industry Committee

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997, USA

7 June 2006

**IEEE Std 1566™-2005**

Currently in preview, click buy full version

Recognized as an  
American National Standard (ANSI)

IEEE Std 1566™-2005

# IEEE Standard for Performance of Adjustable Speed AC Drives Rated 375 kW and Larger

Sponsor

**Petroleum and Chemical Industry Committee  
of the  
IEEE Industry Applications Society**

Approved 15 May 2006

**American National Standards Institute**

Approved 6 December 2005

**IEEE-SA Standards Board**

**Abstract:** This standard is applied to ac adjustable speed drive (ASD) systems rated above 375 kW and above 750 V output voltage as used in petrochemical and similar applications. The performance requirements for an ASD system including, but not limited to, input transformer or reactor as required, power electronics, control interfaces, cooling system, switchgear, and motor are covered. Requirements for power quality, engineering analysis, start-up assistance, training, and spare parts are also included. Certain items such as the motor, switchgear, or transformer may be excluded from the scope of vendor supply if specified in the data sheets; any special requirements for the excluded equipment shall be given by the system vendor.

**Keywords:** adjustable speed, large drives

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 7 June 2006. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Inc. Incorporated.

National Electrical Code and NEC are registered trademarks in the U.S. Patent & Trademark Office, owned by The National Fire Protection Association.

Print: ISBN 0-7381-4866-0 SH95545  
PDF: ISBN 0-7381-4867-9 SS95545

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or recommending professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standard document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

**Interpretations:** Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

**NOTE—**Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std 1566-2005, IEEE Standard for Performance of Adjustable Speed AC Drives Rated 375 kW and Larger.

The need for a performance standard for adjustable speed drive systems was perceived, as a means to reduce confusion when specifying large drive systems for petrochemical and similar applications. Therefore, the work of this document was started in 2000. Input was received from users, manufacturers, and consultants in the industry.

## Notice to users

## Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

## Participants

At the time this standard was completed, the P1566 Working Group had the following membership:

**Bill Lockley, Chair**

**Bob Hanna, Vice Chair**

**Leo Berg, Secretary**

**Richard H. Hulett, PCIC Standards Liaison**

Nick Cicero  
Gabe D'Alleva  
John Dickin  
Frank DeWinter  
Bob Ellis  
Miles Griggs  
Greg Hartzo  
Mike Johnson  
Yuri Khersonsky

David Kiger  
John Kleinecke  
Hans Krattiger  
Mario Lanaro  
Roger Lawrence  
Victor Minak  
Justus Mylius

Richard Nailen  
Richard Paes  
David Rains  
John Rama  
Rob Robertson  
David Smith  
David Waddington  
Laszlo Veres  
Bruce Wood

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Paul Anderson  
Thomas Blair  
Dave Burns  
Keith Chow  
Gabe D'Alleva  
Roger Daugherty  
Frank DeWinter  
James Dymond  
Kimberly Eastwood  
C. James Erickson

Carl Fredericks  
Nirmal Ghai  
Travis Griffith  
Dennis Horwitz  
Darin Hucul  
Richard Hulett  
Yuri Khersonsky  
Bill Lockley  
Lisette Lucido  
Antonio J. Marques-Cardoso

Kenneth McClenahan  
Paul Myers  
Art Neubauer  
Lorraine Padden  
Iulian Profir  
David Rains  
James Ruggieri  
James Wilson  
Barry Wood  
Donald W. Zipse

When the IEEE-SA Standards Board approved this standard on 6 December 2005, it had the following membership:

**Steve M. Mills, Chair**

**Richard H. Hulett, Vice Chair**

**Don Wright, Past Chair**

**Judith Gorman, Secretary**

Mark D. Ewing  
Dennis B. Brodey  
Joseph Bruder  
Richard Cox  
Leo DeWinter  
Julian Forster\*  
Suzanna N. Guenin  
Mark S. Halpin  
Raymond Hapeman

William B. Hopf  
Lowell G. Johnson  
Herman Koch  
Joseph L. Koepfinger\*  
David J. Law  
Daleep C. Mohla  
Paul Nikolich

T. W. Olsen  
Glenn Parsons  
Ronald C. Petersen  
Gary S. Robinson  
Frank Stone  
Malcolm V. Thaden  
Richard L. Townsend  
Joe D. Watson  
Howard L. Wolfman

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*  
Richard DeBlasio, *DOE Representative*  
Alan H. Cookson, *NIST Representative*

Michelle D. Turner  
*IEEE Standards Project Editor*

Currently in preview, click buy full version

## Contents

1. Overview .....	1
1.1 Scope .....	1
1.2 Purpose .....	1
1.3 Application .....	1
2. Normative references.....	2
3. Definitions.....	3
4. Safety.....	3
4.1 General .....	3
4.2 ASD construction requirements.....	4
5. Unit construction .....	5
5.1 ASD structure .....	5
5.2 Insulation .....	6
5.3 Nameplate.....	6
5.4 Rectifier .....	6
5.5 DC link .....	7
5.6 Inverter .....	7
5.7 Modular system .....	7
6. Adjustable speed operation.....	8
6.1 Power supply .....	8
6.2 Harmonics.....	8
6.3 Capacity.....	8
6.4 Performance.....	8
6.5 Grounding.....	9
6.6 Rating of supply.....	9
6.7 Transient over voltages.....	9
6.8 Voltage sags.....	9
6.9 Loss of voltage.....	10
6.10 Three-phase voltage swells.....	10
6.11 Voltage distortion .....	10
6.12 Voltage unbalance .....	10
6.13 Common-mode voltage .....	10
6.14 Power-factor correction capacitors—Switching transients .....	10
6.15 Harmonic distortion.....	11
6.16 Electromagnetic interference and radio-frequency interference.....	11
6.17 Acoustic noise level.....	11

7. Control.....	11
7.1 General .....	11
7.2 Local control.....	12
7.3 Remote control (general).....	12
7.4 Bypass operation.....	13
8. Input transformer or reactor.....	14
8.1 Transformer .....	14
8.2 Reactor.....	14
9. Motor.....	15
9.1 Specification .....	15
9.2 Temperatures .....	15
9.3 Synchronous motor.....	16
9.4 Retrofit.....	16
10. Switchgear and starters.....	16
10.1 Requirements .....	16
10.2 Switchgear supply.....	16
11. Cooling system.....	17
11.1 Cooling system.....	17
11.2 Air cooling.....	17
11.3 Liquid cooling.....	17
12. System coordination.....	18
12.1 Responsibility .....	18
12.2 Compatibility .....	18
13. Engineering studies.....	18
13.1 General .....	18
13.2 Studies to determine process or driven equipment requirements.....	18
13.3 Power-system analysis to determine system response to ASD.....	18
13.4 Studies to determine the system mechanical constraints .....	19
13.5 Studies to determine the heating or cooling constraints .....	19
13.6 Reliability analysis .....	19
14. Inspection and factory tests.....	19
14.1 Records.....	19
14.2 Test plan .....	19
14.3 Motor tests.....	20
14.4 System test.....	20
14.5 Testing of synchronous motor applications.....	21

15. Commissioning and startup assistance .....	21
15.1 Commissioning plan .....	21
15.2 Field service.....	21
15.3 Results .....	22
15.4 Training .....	22
16. Spare parts .....	22
17. Data interchange.....	22
Annex A (normative) Technical data sheet (to be completed by the purchaser).....	23
Annex B (normative) Technical data sheet (to be completed by vendor).....	28
Annex C (informative) Engineering studies: Typical requirements (tutorial only).....	32
C.1 Process or driven equipment requirements .....	32
C.2 System response to ASD.....	32
C.3 Rotational dynamics.....	32
C.4 Studies to determine the heating or cooling requirements .....	34
Annex D (informative) Bibliography .....	35



# IEEE Standard for Performance of Adjustable Speed AC Drives Rated 375 kW and Larger

## 1. Overview

### 1.1 Scope

This standard applies to ac adjustable speed drive (ASD) systems rated above 375 kW and above 750 V output voltage as used in petrochemical and similar applications. It covers the performance requirements for an ASD system including, but not limited to, input transformer or reactor as required, power electronics, control interfaces, cooling system, switchgear, and motor. Requirements for power quality, engineering analysis, start-up assistance, training, and spare parts are also included. Certain items such as the motor, switchgear, or transformer may be excluded from the scope of vendor supply if specified in the data sheets; the system vendor shall specify any special requirements for the excluded equipment.

### 1.2 Purpose

The purpose of this standard is to assist users in defining the required performance of a drive system in clear terms. It is not intended to specify a particular technology that must be followed. It is intended to be used with the data sheets given in Annex A and Annex B.

### 1.3 Application

The drive system will be used to start, accelerate, and control the speed of a motor-driven load. When specified, the ASD shall be capable of achieving synchronization with the utility power system and connecting the motor directly to this system. The ASD supplier shall define the requirements for matching the motor and ASD to the load and the ASD, including input transformer if required, to the power system such that they operate as a system with no unsatisfactory transient, torsional, heating, or power-quality problems. The ASD system shall be suitable for the service conditions described in the data sheets, including the ambient temperature and humidity conditions; altitude; input power-supply voltage and minimum and maximum short-circuit capacities of the source; and auxiliary power-supply voltage.

Unless otherwise specified, the ASD and all related parts shall be suitable for a minimum of five years of continuous operation. The vendor shall identify any redundancy requirements necessary to meet this end. The vendor shall provide an expected mean time between failures (MTBF) and mean time to repair