



IEEE Guide to Select Terminations for Shielded Alternating-Current Power Cable Rated 5 kV – 46 kV

IEEE Power & Energy Society

Sponsored by the
Insulated Conductors Committee

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

5 May 2010

IEEE Std 1637™-2010

Currently in preview, click buy full version

IEEE Guide to Select Terminations for Shielded Alternating-Current Power Cable Rated 5 kV – 46 kV

Sponsor

**Insulated Conductors Committee
of the
IEEE Power & Energy Society**

Approved 2 February 2010

IEEE-SA Standards Board

Abstract: A step-by-step process for selecting an appropriate termination that is commensurate with a particular shielded power cable design is provided in this guide. Over the years, shielded power cables have been developed that employ many different insulating materials and many different shielding systems, such that, there are numerous issues to consider when selecting a termination for a particular cable design. Over the same period of time, many different termination methods and designs have been developed that serve the same purpose, but employ different application methodologies.

This guide does not attempt to cover every cable and termination design, and is generally restricted to single conductor underground residential distribution (URD) and shielded power cable that have a voltage rating from 5 kV – 46 kV, which includes some industrial cables. By nature, the terminations referred to in this guide are considered to be “live front,” in that the terminations comprise a transition from a shielded power cable system to an energized component or bus that is either bare or simply covered.

Keywords: power cable, shielded, termination

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2010 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 5 May 2010. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-6157-0 **STD96014**
Print: ISBN 978-0-7381-6158-7 **STDPD96014**

IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.
No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretation is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretation, should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 1637-2010, IEEE Guide to Select Terminations for Shielded Alternating-Current Power Cable Rated 5 kV – 46 kV.

This guide was developed within the IEEE Insulated Conductors Committee of the Power & Energy Society as an introduction to the process of selecting the appropriate termination for application on a particular cable design and within a particular environment. This guide is a new document that is intended as an introduction to the selection process. Feedback would be appreciated as this guide is gradually revised to serve a broader range of users.

In its current form, this guide is very general in nature and provides only a broad overview. Many factors can influence the selection of a particular termination for any given application, including user personal preferences. This guide is not intended to be exhaustive in covering the considerations necessary in making a termination selection. Consequently, the user should consult the expertise of knowledgeable individuals before making final choices.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include public use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this guide may require the use of subject matter covered by patent rights. By publication of this guide, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this guide are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this guide was submitted to the IEEE-SA Standards Board for approval, the B10W Working Group had the following members:

Robert Fulcomer, *Chair*
William Taylor, *Vice Chair*

Edwards Bradley
James A. Braun
Thomas Chammon
Jack Cherry
John DuPont
Robert Gear

Harry Hayes
W. B. Haverkamp
Roy Jazowski
Glenn Luzzi
John Makal

Michael Malia
Dennis Pratt
Greg Rampley
Michael Smalley
Frank Stepniack
Carl Wentzel

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Steven Alexanderson
Earle Bascom
Michael Bayer
William Bloethe
James A. Braun
Steven Brockschink
Chris Brooks
Kent Brown
Vern Buchholz
William Byrd
Thomas Champion
Weijen Chen
Tommy Cooper
John Densley
Gary L. Donner
Donald Dunn
Gary Engmann
Marcel Fortin
Robert Fulcomer
Robert Gear
Steven Graham
Randall Groves
Frank Di Guglielmo
Ajit Gwal
Richard Harp
Jeffrey Hartenberger

Wolfgang Haverkamp
Lauri Hiivala
Raymond Hill
David Horvath
R. Jackson
Edward M. Jankowich
A. S. Jones
Gael Kennedy
Joseph L. Koepfinger
Jim Kulchisky
Saumen Kundu
Chung-Yiu Lam
Benjamin Lanz
Albert Livshitz
Glenn Luzzi
Keith Malmedal
Williamn McBride
William McDermid
John Merando
Gary Michel
Michael Miller
Jerry Murphy
Arthur Neubauer
Michael S. Newman
Joe Nims
Bansi Patel
Christopher Petrola

Iulian Profir
Robert Puckett
Madan Rana
Robert Resuali
Michael Roberts
Bartien Sayogo
Charles Simmons
Michael Smalley
James E. Smith
Jerry Smith
John Spare
Nagu Srinivas
Paul Sullivan
S. Thamilarasam
Joseph Tumidajski
John Vergis
Martin Von Mettmann
Waldermar Von Miller
Carl Voll
Donald Wood
John Ware
Lee Welch
William Wilkens
James Wilson
Luis Zambrano
Dawn Zhao

When the IEEE-SA Standards Board approved this guide on 2 February 2010, it had the following membership:

Robert M. Grow, Chair
Steve M. Mills, Past Chair
John Gorman, Secretary

Karen Bartleson
Victor Berman
Ted Burse
Clint Chaplin
Andy Drozd
Alexander Gelman
Jim Hughes

Richard H. Hulett
Young Kyun Kim
Joseph L. Koepfinger*
John Kulick
David J. Law
Hung Ling
Oleg Logvinov
Ted Olsen

Ronald C. Petersen
Thomas Prevost
Jon Walter Rosdahl
Sam Sciacca
Mike Seavey
Curtis Siller
Don Wright

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Michelle D. Turner
IEEE Standards Program Manager, Document Development

Soo H. Kim
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
1.3 General	1
2. Normative references.....	2
3. Definitions	2
4. Termination	3
4.1 Termination theory	3
4.2 Parts of termination	5
5. Mounting	7
5.1 Riser pole mounting.....	7
5.2 Structure mounting	8
5.3 Enclosures.....	8
6. Operating environment	9
6.1 Indoor terminations.....	9
6.2 Outdoor terminations.....	9
6.3 Highly contaminated areas	9
6.4 Radiation Exposure.....	10
7. Sizing.....	10
8. Cable preparation.....	10
9. Grounding.....	11
9.1 Shield Type.....	11
9.2 Fault Current.....	11
9.3 Special Features.....	11
10. Termination types.....	12
10.1 Tape terminations	12
10.2 Cold-shrink terminations	12
10.3 Porcelain terminations	13
10.4 Heat-shrink terminations	13
10.5 Fore-fit slip-on molded termination	14
11. Summary of selecting a termination.....	14
Annex (informative) Bibliography	16

Currently in preview, click buy full version

IEEE Guide to Select Terminations for Shielded Alternating-Current Power Cable Rated 5 kV – 46 kV

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This guide will discuss the reasons why a termination is necessary on a shielded power cable. Included is a short tutorial on termination theory, a general discussion of design and materials and a selection flow chart.

1.2 Purpose

The purpose of this project is to guide the reader in selecting terminations for shielded-power cable 5 kV – 46 kV.

1.3 General

This guide provides the reader with guidance in selecting terminations for shielded-power cables rated 5 kV – 46 kV.