



IEEE Standard Method for Measuring the Effectiveness of Electromagnetic Shielding Enclosures

IEEE Electromagnetic Compatibility Society

Sponsored by the
Standards Development Committee

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

28 February 2007

IEEE Std 299™-2006
(Revision of IEEE Std 299-1997)

Currently in preview, click buy full version

*Recognized as an
American National Standard (ANSI)*

IEEE Std 299™-2006(R2012)

(Revision of
IEEE Std 299-1997)

IEEE Standard Method for Measuring the Effectiveness of Electromagnetic Shielding Enclosures

Sponsor

**Standards Development Committee
of the
IEEE Electromagnetic Compatibility Society**

Approved 29 December 2006

American National Standards Institute

Reaffirmed 8 June 2012

Approved 15 September 2006

IEEE-SA Standards Board

Abstract: Uniform measurement procedures and techniques are provided for determining the effectiveness of electromagnetic shielding enclosures at frequencies from 9 kHz to 18 GHz (extendable to 50 Hz and 100 GHz, respectively) for enclosures having all dimension greater than or equal to 2.0 m. The types of enclosures covered include, but are not limited to, single-shield or double-shield structures of various construction, such as bolted demountable, welded, or integral with a building; and made of materials such as steel plate, copper or aluminum sheet, screening, hardware cloth, metal foil, or shielding fabrics.

Keywords: electromagnetic shielding, screened rooms, shielded enclosures, shielded rooms, shielding, shielding effectiveness

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2007 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 28 February 2007. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

Print: ISBN 0-7381-5215-3 SH95568
PDF: ISBN 0-7381-5216-1 SS95568

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not fully reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comment. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 299-2006, IEEE Standard Method for Measuring the Effectiveness of Electromagnetic Shielding Enclosures.

This document provides a standard set of methods and procedures for determining the shielding effectiveness (SE) of shielding enclosures. The enclosures of concern include those used for testing groups of equipment, vehicles, computing systems, and smaller units whose electromagnetic (EM) emission and susceptibility require determination without disturbance from other sources. This standard incorporates the basic concepts of MIL-STD-285,^a the SE measurement reference for many years, which was cancelled by the U.S. Department of Defense in 1997. Those concepts have been expanded upon to increase the applicability of the measurement techniques to enclosures having a wide variety of applications and constructed from a large number of materials with varying methods of fabrication and assembly.

The basic premise of MIL-STD-285 is still in position: the shield effect is to provide an insertion loss to outside influence. IEEE Std 299-2006 offers testing based upon the performance specifications of the shield, rather than a fixed set of parameters that may not be applicable to the shield in question. The specific test procedures and frequency ranges are selected as appropriate for the enclosure being tested. The most important factor considered during the development of this revision was the concept that measurement of EM SE is a requirement not unique to walk-in sized enclosures. There are no widely accepted standards in use to describe test methods and techniques for measuring SE of physically small enclosures. The Standards Development Committee of the IEEE Electromagnetic Compatibility Society directed the current Working Group to plan for developing new parts of IEEE Std 299 for addressing the testing of these smaller enclosures. Thus, this document will continue to provide a standardized test method for EM shielded enclosures having all dimensions greater than or equal to 2 m. New parts of IEEE Std 299 will be developed soon to address these smaller enclosures.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

^a MIL publications are available from Customer Service, Defense Printing Service, 700 Robbins Ave., Bldg. 4D, Philadelphia, PA 19111-5094, USA.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

The many contributions to this standard by the members of the P299 Working Group are gratefully acknowledged. The support of the Vice Chairs, Norman Wehling (retired) and Dr. Croisant was invaluable, as were the editing efforts of Mark Bushnell and improvements to the figures by Joseph Weibler. Professor Sarto was also extremely helpful in clarifying many of the concepts and equations.

Special appreciation is extended to Don Sweeney who served as liaison from the EMC Society Standards Development Committee and “Angel” for the project.

At the time this standard was completed, the P299 Working Group had the following membership:

Dale G. Svetanoff, Chair

(July 1995 to present)

William Croisant, Vice Chair

(January 2001 to present)

Norman Wehling, Vice Chair

(July 1995 to December 2000)

Gianluca Arcari
Robert Bonsen
Ed Bronaugh
Mark Bushnell
Joe Butler
Nigel Carter
Johan Catrysse
Paul Cook
Frederick Eriksen
Ahmad Fallah

Robert Harriman
Michael Hatfield
L. O. “Bud” Heft
Christopher Holloway
D. Mark Johnson
Mark Kastrancha
James Klouda
Galen Koepke
David Larrabee
Andy Marvin
Michael McNerney

Ade Ogunsola
Jacques Rajade
Dale Reynolds
Peter Richeson
Maria Sabrina Sarto
Walter Scott
Doug Smith
James Whalen
Joseph Weibler
John Wyncott

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

David Baron
Stephen Berger
Mark Bushnell
J. J. Carr
Johan Catrysse
Richard Chow
Guru Dutt Dhingra

Tim Harrington
Werner Hoelzl
Daniel Hoolihan
Efthymios Karabetos
Yuri Khersonsky
Ronald Kollman
John Kraemer

Yeou-Song Lee
Li Li
Edward McCall
Kermit Phipps
Werner Schaefer
Dale G. Svetanoff
Donald Sweeney

When the IEEE-SA Standards Board approved this standard on 15 September 2006, it had the following membership:

Steve M. Mills, *Chair*
Richard H. Hulett, *Vice Chair*
Don Wright, *Past Chair*
Judith Gorman, *Secretary*

Mark D. Bowman
Dennis B. Brophy
William R. Goldbach
Arnold M. Greenspan
Robert M. Grow
Joanna N. Guenin
Julian Forster*
Mark S. Halpin

Kenneth S. Hanus
William B. Hopf
Joseph L. Koepfinger*
David J. Law
Daleep C. Mohla
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Tom A. Prevost

Greg Ratta
Robby Robson
Anne-Marie Sahazizian
Virginia Sulzberger
Malcolm V. Thaden
Richard L. Townsend
Walter Weigel
Howard L. Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Alan H. Cookson, *NIST Representative*

Don Messina
IEEE Standards Program Manager, Document Development

William Ash
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
1.3 Application	1
2. Normative references	2
3. Definitions	2
3.1 General terminology	2
3.2 Technical terminology	3
4. Preliminary procedures	3
4.1 Background	3
4.2 Test plan	4
4.3 Calibration	4
4.4 Reference level and dynamic range	4
4.5 Preliminary shield check procedures	4
4.6 Test/witness personnel	4
5. Detailed procedures	4
5.1 Background	4
5.2 Recommended standard measurement frequencies	5
5.3 Pass/fail requirements	6
5.4 Shielding effectiveness calculation	6
5.5 Preparation procedures	7
5.6 Low-frequency measurements (9 kHz to 20 MHz)	7
5.7 Resonant range measurements (20 MHz to 300 MHz)	11
5.8 High-frequency measurements (300 MHz to 18 GHz)	18
6. Quality assurance technical report	24
6.1 Abbreviated test report	24
6.2 Full test report	24
Annex A (informative) Rationale	26
A.1 Basis	26
A.2 Considerations pertinent to the objectives of 1.2	26
A.3 Cavity resonances	27
A.4 Measurement locations	30
A.5 Measurement equipment	30

Annex B (informative) Mathematical formulas.....	31
B.1 Specific mathematical formulations.....	31
B.2 Low-range (50 Hz to 20 MHz) shielding effectiveness	31
B.3 Resonant range (20 MHz to 300 MHz) shielding effectiveness.....	32
B.4 High-range (300 MHz to 100 GHz) shielding effectiveness.....	32
B.5 Nonlinear (logarithmic) calculations.....	32
B.6 Dynamic range considerations	33
Annex C (informative) Miscellaneous supporting information.....	34
C.1 Coplanar versus coaxial loops.....	34
C.2 Nonlinearity of high-permeability ferromagnetic enclosures.....	34
C.3 Selecting measurement frequencies	34
Annex D (informative) Guidelines for the selection of measurement techniques.....	37
D.1 Types of enclosures	37
D.2 Performance requirements	37
D.3 Equipment requirements.....	38
D.4 Regulatory agency conflicts.....	38
Annex E (informative) Preliminary measurements and repairs.....	39
E.1 Background	39
E.2 Frequencies for preliminary check	39
E.3 Preliminary check procedures	39

IEEE Standard Method for Measuring the Effectiveness of Electromagnetic Shielding Enclosures

1. Overview

1.1 Scope

This standard provides uniform measurement procedures for determining the effectiveness of electromagnetic (EM) shielding enclosures at frequencies from 9 kHz to 18 GHz (extendable down to 50 Hz and up to 100 GHz).

The owner of the shielding enclosure shall provide the frequencies at which the shield will be tested, and the shielding effectiveness (SE) limits for pass/fail. This standard suggests a range of test frequencies that would provide very high confidence in the effectiveness of the shield. This standard does not define SE limits for pass or fail.

1.2 Purpose

The purpose of this standard is to provide the following:

- a) A standard procedure for the measurement of the effectiveness of shielded enclosures, in a broad range of radio frequencies (RFs), including a minimum set of recommended frequencies
- b) Identical procedures applicable to frequencies other than the standard set
- c) An optional measurement technique to detect the nonlinear behavior of high-permeability ferromagnetic enclosures (see Annex C)

1.3 Application

The measurement procedures provided in this standard apply to any enclosure having a smallest linear dimension greater than or equal to 2.0 m. Separate methods, to be provided in the future, shall be used for enclosures with any dimension smaller than 2.0 m.

In the case of enclosures that are to be used in anechoic or semianechoic applications, this procedure shall apply prior to the installation of any RF absorber materials.