

IEEE Guide for Identification, Testing, and Evaluation of the Dynamic Performance of Excitation Control Systems

IEEE Power and Energy Society

Sponsored by the
Energy Development and Power Generation Committee

Currently in preview, click buy full version

IEEE Guide for Identification, Testing, and Evaluation of the Dynamic Performance of Excitation Control Systems

Sponsor

**Energy Development and Power Generation Committee
of the
IEEE Power and Energy Society**

Approved 27 March 2014

IEEE-SA Standards Board

Abstract: This guide includes criteria, definitions, and test procedures for evaluating the dynamic performance of excitation control systems for synchronous machines as applied by electric utilities.

Keywords: Closed-loop performance, dynamic performance, excitation control systems, excitation system specifications, IEEE Std 421.2™, large signal disturbances, model, small signal disturbances, stabilizer, synchronous machine

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2014 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 27 June 2014. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-9065-5 STD98620
Print: ISBN 978-0-7381-9066-2 STDPD98620

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official Statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on Standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws & Regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and the documents may not be construed as doing so.

Copyright

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards Documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE guide was completed, the Identification, Testing, and Evaluation of the Dynamic Performance of Excitation Control Systems Working Group had the following membership:

Les Hajagos, *Chair*
Robert Thornton-Jones, *Vice-chair*

J. C. Agee
Martin Aten
Matthias Baechle
Michael Basler
Katherine Doyon
Markus Egretzberger

Jim Feltes
Luc Gérin-Lajoie
Alexander Glaninger
Joe Hurlay
Kiyong Kim
Rudiger Kutzner
Leonardo Lima

Shawn Patterson
Rich Schaefer
Uwe Seeger
Dinemayer Silva
Paul Smulders
Jose Taborda

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman
J. C. Agee
Ali Al Awazi
George Bartok
Michael Basler
Wallace Binder
Thomas Blair
Steven Brockschink
Gustavo Brunello
Antonio Cardoso
James Case
Weijen Chen
Tommy Cooper
Luis Coronado
Matthew Davis
James Dymond
Ahmed ElSerafi
Gary Engmann
Robert Fenton
Jonathan Gardell
J. Travis Griffith

Robert Grondin
Randall Groves
James Gurney
Steve Hamilton
Ryusuke Hasegawa
Michael Henry
Gary Heuston
David Horvath
Dennis Horvitz
David Jacobson
Innocent Kimba
Jim McWhiskey
Santosh Kundu
James Lennon
William Lockley
Lawrence Long
William Lumpkins
Greg Luri
O. Malik
John Martin

Omar Mazzoni
Mark McGranaghan
Nigel Mcquin
James Michalec
Gary Michel
Charles Morse
Karl Mortensen
Jerry Murphy
Michael Newman
Nils Nilsson
Lorraine Padden
Shawn Patterson
Iulian Profir
Manfred Reimann
Frank Rocchio
Steven Sano
A. Schneider
William Terry
Malcolm Thaden
S. Thamilarsan
James Wilson

When the IEEE-SA Standards Board approved this guide on 27 March 2014, it had the following membership:

John Kulick, *Chair*
Jon Walter Rosdahl, *Vice-chair*
Richard H. Hulett, *Past Chair*
Konstantinos Karachalios, *Secretary*

Peter Balma
Farooq Bari
Ted Burse
Clint Chaplain
Stephen Dukes
Jean-Philippe Faure
Gary Hoffman

Michael Janezic
Jeffrey Katz
Joseph L. Koepfinger*
David Law
Hung Ling
Oleg Logvinov
Ted Olsen
Glenn Parsons

Ron Peterson
Adrian Stephens
Peter Sutherland
Yatin Trivedi
Phil Winston
Don Wright
Yu Yuan

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Don Messina,
IEEE-SA Content Publishing

Malia Zanetti,
IEEE-SA Standards Technical Community

Introduction

This introduction is not part of IEEE Std 421.2-2014, IEEE Recommended Practice for Overvoltage and Insulation Coordination of Transmission Systems at 1000 kV AC and Above.

This guide presents dynamic performance criteria, definitions, and test objectives for excitation control systems as applied by electric utilities. It should be specifically noted that the term *excitation control system* refers to the entire control system including the synchronous machine and power system as well as the excitation system.

The Working Group on Excitation Control System Dynamic Performance of the Excitation Systems and Controls Subcommittee of the Energy Development and Power Generation Committee adopted many definitions and performance criteria, which are common to all control systems, and derived others specifically related to excitation control systems. In doing this, the material in IEEE Std 421.1, IEEE Standard Definitions for Excitation Systems for Synchronous Machines and the now discontinued IEEE Std 100-1988, IEEE Standard Dictionary of Electrical and Electronics Terms (ANSI) was heavily used. Efforts were made not to conflict with existing definitions and criteria, but to clarify, supplement, and more fully define them as related specifically to excitation control systems. Definitions from these standards, which are reproduced in this standard, are included in Clause 3.

In preparing this guide, the working group recognized that both factory testing and field testing of excitation control systems and some of their components are costly and often impractical. Alternator-rectifier excitation systems in which the terminals of the exciter may not be available may preclude field testing of the exciter separately. Compound source excitation systems whose power is derived from the generator currents and voltages present special difficulties. Providing a load which reasonably duplicates the generator field characteristics, so that regulation effect and proper waveforms can be adequately simulated, may not be economically justifiable. Field testing on units under normal operating conditions are constrained to comply with the operating and security requirements of the power system, which often prohibit large excursions of the excitation control system variables. For many applications, it is necessary to devise practical test procedures for individual components and then by analytical means, to verify the total excitation system performance.

The need for models that accurately simulate the operation of excitation control systems during system disturbances demands effective test methods. However, the practical limitations on tests make it difficult to measure the parameters required for models. One solution is the collection of more complete data during system disturbances. Present instrumentation practices generally do not include the collection of data from enough excitation control system variables to permit the data to be used for model refinement. Improving the quantity and quality of data collected during system disturbances may be the only practical way to obtain the data required to significantly improve the accuracy of large signal models.

This revision incorporates a general introduction to the dynamic performance classification section to aid understanding and the effects of excitation limiters are introduced. Clarifications have been introduced where technology advancements have changed approaches in modelling, such as the introduction of integral control terms whereby open-loop steady-state gain is considered infinite. Additional and improved figures have been introduced and some typical parameters are shown. It is important to note that this document is part of the IEEE 421 series of guides on the various aspects of excitation control systems for synchronous generators and that the IEEE Excitation Systems and Controls Subcommittee has also produced a tutorial on Power System Stabilization via Excitation Control which provides substantial supplemental material.

Contents

| | |
|--|----|
| 1. Scope | 1 |
| 2. Normative references | 2 |
| 3. Definitions | 2 |
| 4. Dynamic performance classification | 4 |
| 4.1 Overall | 4 |
| 4.2 Large signal performance | 4 |
| 4.3 Small signal performance | 5 |
| 4.4 Effects of excitation limiters | 5 |
| 5. Large signal performance criteria | 6 |
| 5.1 General | 6 |
| 5.2 Ceiling current | 6 |
| 5.3 Ceiling voltage | 7 |
| 5.4 Excitation system voltage response time | 7 |
| 5.5 High initial response (HIR) | 8 |
| 5.6 Excitation system nominal response | 8 |
| 5.7 Large signal dynamic response | 9 |
| 6. Small signal performance criteria | 9 |
| 6.1 General | 9 |
| 6.2 Small signal dynamic response | 9 |
| 6.3 Frequency response characteristic (linear system) | 10 |
| 6.4 Complex frequency domain (s plane) | 12 |
| 6.5 Small signal performance indices | 15 |
| 7. Excitation control system effects on power system stability | 17 |
| 7.1 Types of synchronous machine oscillations | 18 |
| 7.2 Application of power system stabilizers | 21 |
| 8. Large signal performance testing | 25 |
| 8.1 General | 25 |
| 8.2 Factory testing | 25 |
| 8.3 Field testing | 26 |
| 8.4 Fault testing | 30 |
| 8.5 Power system disturbances | 30 |
| 9. Small signal performance testing | 31 |
| 9.1 General | 31 |
| 9.2 Excitation control system components | 31 |
| 9.3 Field testing | 33 |
| 9.4 Field testing with power system stabilizers | 35 |
| 9.5 Special considerations for digital systems | 37 |
| 9.6 Testing reactive load sharing and line drop compensation | 37 |
| 9.7 Testing power factor and var controllers | 38 |
| Annex A (informative) Bibliography | 39 |

| | |
|--|----|
| Annex B (informative) Basis underlying the concept of nominal response | 43 |
| B.1 Explanation | 43 |
| B.2 Nomenclature for Annex B | 44 |
| Annex C (informative) Frequency response characteristics of typical excitation control system elements | 46 |

IEEE Guide for Identification, Testing, and Evaluation of the Dynamic Performance of Excitation Control Systems

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Scope

This guide includes criteria, definitions, and test objectives for evaluating the dynamic performance of excitation control systems as applied by electric utilities. The term *excitation control system* (see Figure 1) is used to distinguish the combined performance of the synchronous machine, power system, and excitation system from that of the excitation system alone (see IEEE Std 421.1™). The primary purpose of this guide is to provide a basis for evaluating the closed-loop performance of excitation control systems, including synchronous machines, for both large and small signal disturbances. Confirming the adequacy of mathematical models for excitation control systems for use in analytical studies of power systems, identifying objectives for tests of excitation control systems and their components, and preparing excitation system specifications and additional standards will also be addressed (see IEEE Std 421.3™, IEEE Std 421.4™, and IEEE Std 421.5™). Portions of this guide will also serve as educational material for people who are becoming familiar with excitation control systems. This guide is applicable to excitation systems used on all sizes and types of synchronous machines including those in nuclear power facilities.

Traditionally, large signal performance (see 4.2) has been more closely associated with equipment specification and acceptance testing, while small signal performance (see 4.3) has been more closely associated with stability and model studies. Matching actual disturbance data with model simulations, however, requires that both large and small signal performance criteria be considered during design, specification, and acceptance testing.