

IEEE Recommended Practice for Excitation System Models for Power System Stability Studies

IEEE Power and Energy Society

Sponsored by the
Energy Development and Power Generation Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std 421.5™-2016
(Revision of
IEEE Std 421.5-2005)

IEEE Recommended Practice for Excitation System Models for Power System Stability Studies

Sponsor

**Energy Development and Power Generation Committee
of the
IEEE Power and Energy Society**

Approved 15 May 2016

IEEE-SA Standards Board

Abstract: Excitation system and power system stabilizer models suitable for use in large-scale system stability studies are presented. Important excitation limiters and supplementary controls are also included. The model structures presented are intended to facilitate the use of field test data as a means of obtaining model parameters. The models are, however, reduced order models and do not necessarily represent all of the control loops of any particular system. The models are valid for frequency deviations of $\pm 5\%$ from rated frequency and oscillation frequencies up to 3 Hz. These models would not normally be adequate for use in studies of subsynchronous resonance or other shaft torsional interaction behavior. Delayed protective and control features that may come into play in long-term dynamic performance studies are not represented. A sample set of data for each of the models, for at least one particular application, is provided.

Keywords: excitation limiter models, excitation systems models, IEEE 421.5™, power system stability, power system stabilizer models

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2016 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 26 August 2016. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-0855-4 STD20896
Print: ISBN 978-1-5044-0856-1 STDPD20896

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, make, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comment or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/Xplore/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity of any of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE recommended practice was completed, the Identification, Testing, and Evaluation of the Dynamic Performance of Excitation Control Systems Working Group had the following membership:

Les Hajagos, *Chair*
Robert Thornton-Jones, *Vice Chair*
Leonardo Lima, *Secretary*

Matthias Baechle
Michael Basler
Michael Faltas
James Feltes
Namal Fernando
Luc Gerin-Lajoie
Alexander Glaninger-Katschnig
Joseph Hurley
Chavdar Ivanov

Kiyong Kim
Ruediger Kutzner
Eric Lambert
Shawn McMullen
Richard Mummert
Shawn Patterson
Juan Sanchez-Gasca
Richard Schaefer

Alexander Schneider
Uwe Seeger
Jay Senthil
Dinemayer Silva
Paul Smulders
Kurt Sullivan
José Taborda
David Thumser
Stephane Venola

The following members of the individual balloting committee voted on the recommended practice. Balloters may have voted for approval, disapproval, or abstention.

Ali Al Awazi
Eugene Asbury
Matthias Baechle
Michael Basler
Andrew Bennett
William Bloethe
Gustavo Brunello
Luis Coronado
Matthew Davis
Gary Donner
Namal Fernando
Rostyslaw Fostiak
Alexander Glaninger-Katschnig
Randall Groves
James Gurney
Les Hajagos
Werner Hoelzl
Benjamin Hynes

Relu Ilie
Richard Jackson
Innocent Kamwa
Yuri Khersonsky
Jim Kulchisky
Andreas Kunkel
Ruediger Kutzner
Michael Lambert
Leonardo Lima
Orion Malik
Shawn McMullen
Charles Morse
Artnur Neubauer
Michael Newman
Pierre Ouellette
Lorraine Padden
Eli Pajuelo
Shawn Patterson

Howard Penrose
Christopher Petrola
Steven Sano
Richard Schaefer
Alexander Schneider
Uwe Seeger
Paul Smulders
Kurt Sullivan
José Taborda
Robert Thornton-Jones
David Thumser
James Timperley
Eric Toft
James Van De Ligt
Gerald Vaughn
John Vergis
Kenneth White
Jian Yu

When the IEEE-SA Standards Board approved this recommended practice on 15 May 2016, it had the following membership:

Jean-Philippe Faure, *Chair*
Ted Burse, *Vice Chair*
John D. Kulick, *Past Chair*
Konstantinos Karachalios, *Secretary*

Chuck Adams
Masayuki Ariyoshi
Stephen Dukes
Jianbin Fan
J. Travis Griffith
Gary Hoffman

Ronald W. Hotchkiss
Michael Janezic
Joseph L. Koepfinger*
Hung Ling
Kevin Lu
Annette D. Reilly
Gary Robinson

Mehmet Ulema
Yingli Wen
Howard Wolfman
Don Wright
Yu Yuan
Daidi Zhong

*Member Emeritus

Introduction

This introduction is not part of IEEE Std 421.5™-2016, IEEE Recommended Practice for Excitation System Models for Power System Stability Studies.

Excitation system models suitable for use in large-scale system stability studies are presented in this recommended practice. With these models, most of the excitation systems presently in widespread use on large, system-connected, synchronous machines in North America can be represented.

This recommended practice applies to excitation systems applied on synchronous machines, which include synchronous generators, synchronous motors, and synchronous condensers. Since most applications of this recommended practice involve excitation systems applied to synchronous generators, the term *generator* is often used instead of *synchronous machine*. Unless otherwise specified, use of the term *generator* in this document should be interpreted as applying to the synchronous machine in general, including motors and synchronous condensers.

In 1968, models for the systems in use at that time were presented by the Excitation Systems Subcommittee and were widely used by the industry. Improved models that reflected advances in equipment and better modeling practices were developed and published in the IEEE Transactions on Power Apparatus and Systems in 1981. These models included representation of more recently developed systems and some of the supplementary excitation control features commonly used with them. In 1992 the 1981 models were updated and presented in the form of the recommended practice IEEE Std 421.5. In 2005 this document was further revised to add information on reactive differential compensation, excitation limiters, power factor and var controllers, and new models incorporating proportional-integral-derivative (PID) control.

The model structures presented are intended to facilitate the use of field test data as a means of obtaining model parameters. The models are, however, reduced order models and do not necessarily represent all of the control loops of any particular system. The models are valid for frequency deviations of $\pm 5\%$ from rated frequency and oscillation frequencies up to 3 Hz. These models would not normally be adequate for use in studies of subsynchronous resonance or other shaft torsional interaction behavior. Delayed protective and control features that may come into play in long-term dynamic performance studies are not represented. A sample set of data for each of the models, for at least one particular application, is provided.

Contents

1. Overview	1
1.1 Scope	1
1.2 Background.....	1
1.3 Limitations.....	2
1.4 Summary of changes and equivalence of models	3
2. Normative references.....	6
3. Definitions	6
4. Representation of synchronous machine excitation systems in power system studies	7
5. Synchronous machine terminal voltage transducer and current compensation models.....	9
5.1 Terminal voltage sensing time constant.....	9
5.2 Current compensation.....	10
6. Type DC—Direct current commutator rotating exciter	13
6.1 General	13
6.2 Type DC1A excitation system model.....	14
6.3 Type DC1C excitation system model.....	14
6.4 Type DC2A excitation system model.....	16
6.5 Type DC2C excitation system model.....	16
6.6 Type DC3A excitation system model.....	17
6.7 Type DC4B excitation system model.....	18
6.8 Type DC4C excitation system model.....	18
7. Type AC—Alternator supplied rectifier excitation systems.....	20
7.1 General	20
7.2 Type AC1A excitation system model.....	21
7.3 Type AC1C excitation system model.....	21
7.4 Type AC2A excitation system model.....	22
7.5 Type AC2C excitation system model.....	22
7.6 Type AC3A excitation system model.....	23
7.7 Type AC3C excitation system model.....	24
7.8 Type AC4A excitation system model.....	24
7.9 Type AC4C excitation system model.....	25
7.10 Type AC5A excitation system model.....	25
7.11 Type AC5C excitation system model.....	26
7.12 Type AC6A excitation system model.....	26
7.13 Type AC6C excitation system model.....	26
7.14 Type AC7B excitation system model.....	27
7.15 Type AC7C excitation system model.....	28
7.16 Type AC8B excitation system model.....	30
7.17 Type AC8C excitation system model.....	30
7.18 Type AC9C excitation system model.....	32
7.19 Type AC10C excitation system model.....	35
7.20 Type AC11C excitation system model.....	39
8. Type ST—Static excitation systems.....	41
8.1 General	41
8.2 Type ST1A excitation system model.....	41

8.3 Type ST1C excitation system model	42
8.4 Type ST2A excitation system model	44
8.5 Type ST2C excitation system model	44
8.6 Type ST3A excitation system model	45
8.7 Type ST3C excitation system model	46
8.8 Type ST4B excitation system model	47
8.9 Type ST4C excitation system model	47
8.10 Type ST5B excitation system model	48
8.11 Type ST5C excitation system model	49
8.12 Type ST6B excitation system model	49
8.13 Type ST6C excitation system model	50
8.14 Type ST7B excitation system model	52
8.15 Type ST7C excitation system model	52
8.16 Type ST8C excitation system model	54
8.17 Type ST9C excitation system model	55
8.18 Type ST10C excitation system model	56
9. Type PSS—Power system stabilizers	59
9.1 General	59
9.2 Type PSS1A power system stabilizer model	60
9.3 Type PSS2A power system stabilizer model	60
9.4 Type PSS2B power system stabilizer model	61
9.5 Type PSS2C power system stabilizer model	61
9.6 Type PSS3B power system stabilizer model	63
9.7 Type PSS3C power system stabilizer model	63
9.8 Type PSS4B power system stabilizer model	64
9.9 Type PSS4C power system stabilizer model	64
9.10 Type PSS5C power system stabilizer model	66
9.11 Type PSS6C power system stabilizer model	66
9.12 Type PSS7C power system stabilizer model	68
10. Type OEL—Overexcitation limiters	70
10.1 General	70
10.2 Field winding thermal capability	70
10.3 OEL types	72
10.4 Type OEL1B overexcitation limiter model	72
10.5 Type OEL2C overexcitation limiter model	75
10.6 Type OEL3C overexcitation limiter model	77
10.7 Type OEL4C overexcitation limiter model	78
10.8 Type OEL5C overexcitation limiter model	79
11. Type UEL—Underexcitation limiters	81
11.1 General	81
11.2 Type UEL1 underexcitation limiter model	82
11.3 Type UEL2 Underexcitation limiter model	83
11.4 Type UEL2C underexcitation limiter model	84
12. Type SCL—Stator current limiters	87
12.1 General	87
12.2 Type SCL1C stator current limiter model	89
12.3 Type SCL2C stator current limiter model	90
13. Types PF and VAR—Power factor and reactive power controllers and regulators	94
13.1 General	94
13.2 Power factor input normalization	96
13.3 Voltage reference adjuster	100

13.4 Power factor controller Type 1	101
13.5 Var controller Type 1.....	102
13.6 Power factor controller Type 2	103
13.7 Var controller Type 2.....	104
14. Supplementary discontinuous excitation control.....	105
14.1 General	105
14.2 Type DEC1A discontinuous excitation control	106
14.3 Type DEC2A discontinuous excitation control	108
14.4 Type DEC3A discontinuous excitation control	108
Annex A (normative) Nomenclature	110
Annex B (normative) Per-unit system	111
Annex C (normative) Saturation function and loading effects	115
C.1 General.....	115
C.2 Generator saturation.....	115
C.3 Rotating exciter saturation	116
Annex D (normative) Rectifier regulation.....	119
Annex E (normative) Block diagram representations.....	122
E.1 General	122
E.2 Simple integrator.....	122
E.3 Simple time constant	123
E.4 Lead-lag block.....	124
E.5 Proportional-integral (PI) block	125
E.6 Proportional-integral-derivative (PID) block	126
E.7 Washout block.....	127
E.8 Filtered derivative block.....	128
E.9 Logical switch block	128
Annex F (informative) Avoiding computational problems by eliminating fast-feedback loops	130
F.1 General	130
F.2 Type AC3C excitation system model.....	130
F.3 Other Type AC excitation system models	133
Annex G (normative) Paths for flow of induced synchronous machine negative field current.....	135
G.1 General.....	135
G.2 No special provision for handling negative field current.....	136
Annex H (informative) Sample data.....	137
H.1 General.....	137
H.2 Type DC1C excitation system	138
H.3 Type DC2C excitation system	139
H.4 Type DC3A excitation system	140
H.5 Type DC4C excitation system	141
H.6 Type AC1C excitation system	142
H.7 Type AC2C excitation system	143
H.8 Type AC3C excitation system	144
H.9 Type AC4C excitation system	145
H.10 Type AC5C excitation system	145
H.11 Type AC6C excitation system	146
H.12 Type AC7C excitation system	148

H.13 Type AC8C excitation system	151
H.14 Type AC9C excitation system	152
H.15 Type AC10C excitation system	154
H.16 Type AC11C excitation system	155
H.17 Type ST1C excitation system	156
H.18 Type ST2C excitation system	159
H.19 Type ST3C excitation system	159
H.20 Type ST4C excitation system	162
H.21 Type ST5C excitation system	164
H.22 Type ST6C excitation system	165
H.23 Type ST7C excitation system	166
H.24 Type ST8C excitation system	167
H.25 Type ST9C excitation system	168
H.26 Type ST10C excitation system	169
H.27 Type PSS1A power system stabilizer	169
H.28 Type PSS2C power system stabilizer	169
H.29 Type PSS3C power system stabilizer	170
H.30 Type PSS4C power system stabilizer	170
H.31 Type PSS5C power system stabilizer	174
H.32 Type PSS6C power system stabilizer	175
H.33 Type PSS7C power system stabilizer	176
H.34 Type OEL1B overexcitation limiter	177
H.35 Type OEL2C overexcitation limiter	177
H.36 Type OEL3C overexcitation limiter	179
H.37 Type OEL4C overexcitation limiter	179
H.38 Type OEL5C overexcitation limiter	180
H.39 Type UEL1 underexcitation limiter	181
H.40 Type UEL2C underexcitation limiter	182
H.41 Type SCL1C stator current limiter	183
H.42 Type SCL2C stator current limiter	184
H.43 Power factor controller Type 1	186
H.44 Power factor controller Type 2	187
H.45 Var controller Type 1	187
H.46 Var controller Type 2	187
 Annex I (informative) Manufacturer model cross-reference	 188
 Annex J (informative) Bibliography	 191

IEEE Recommended Practice for Excitation System Models for Power System Stability Studies

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This document provides mathematical models for computer simulation studies of excitation systems and their associated controls for three-phase synchronous generators. The equipment modeled includes the automatic voltage regulator (AVR) as well as supplementary controls including reactive current compensation, power system stabilizers, overexcitation and underexcitation limiters, and stator current limiters. This revision is an update of the recommended practice and includes models of new devices which have become available since the previous revision, as well as updates to some existing models.

1.2 Background

When the behavior of synchronous machines is to be simulated accurately in power system stability studies, it is essential that the excitation systems of the synchronous machines be modeled in sufficient detail (see Byerly and Kimbark [B1], Kundur [B33]¹). The desired models should be suitable for representing the actual excitation equipment performance for large, severe disturbances as well as for small perturbations.

¹ The numbers in brackets correspond to those of the bibliography in Annex J.