

Recognized as an  
American National Standard (ANSI)

**IEEE Std 43-2000(R2006)**  
(Revision of  
IEEE Std 43-1974)

# IEEE Recommended Practice for Testing Insulation Resistance of Rotating Machinery

Sponsor

**Electric Machinery Committee**  
of the  
**IEEE Power Engineering Society**

Approved 12 October 2000

**American National Standards Institute**

Reaffirmed 30 March 2006

Approved 6 March 2000

**IEEE-SA Standards Board**

**Abstract:** This document describes the recommended procedure for measuring insulation resistance of armature and field windings in rotating machines rated 1 hp, 750 W or greater. It applies to synchronous machines, induction machines, dc machines, and synchronous condensers. Contained within this document is the general theory of insulation resistance (IR) and polarization index (P.I.), as well as factors affecting the results, test procedures, methods of interpretation, test limitations, and recommended minimum values.

**Keywords:** absorption current, conduction current, discharge current, geometric capacitive current, insulation resistance, polarization index, surface leakage current

The Institute of Electrical and Electronics Engineers, Inc.  
51 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2000 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 24 March 2000. Printed in the United States of America.

Print: ISBN 0-7381-1924-5 SH94806  
PDF: ISBN 0-7381-1925-3 SS94806

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

**Interpretations:** Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
P.O. Box 1331  
Piscataway, NJ 07054-1331  
USA

Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

IEEE is the sole entity that may authorize the use of certification marks, trademarks, or other designations to indicate compliance with the materials set forth herein.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; (978) 750-8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

(This introduction is not part of IEEE Std 43-2000, IEEE Recommended Practice for Testing Insulation Resistance of Rotating Machinery.)

Insulation resistance measurement has been recommended and used for more than half a century to evaluate the condition of electrical insulation. Whereas individual insulation resistance measurements may be of questionable value, the carefully maintained record of periodic measurements, accumulated over months and years of service, is of unquestioned value as a measure of some aspects of the condition of the electrical insulation. Originally, in 1950, this recommended practice was published by the AIEE as a guide to present the various facets associated with the measurement and understanding of electrical insulation resistance. The guide was revised in 1961 and again in 1974. During the 1970s, several changes were made to the type of insulation used in electric rotating machines. The insulation resistance characteristics of these newer insulation systems are different from the older systems, and therefore required this substantial revision to the standard for measuring insulation resistance. Other changes include the addition of further description of the testing theory and the removal of suggestions regarding maintenance dry-out procedures for older windings (previously Annex A). Recommendations for maintenance procedures are beyond the scope of this document. With this publication as a recommended practice, the IEEE is presenting and recommending electrical insulation resistance measurement as an important factor in monitoring the condition of electrical insulation in rotating machinery.

This recommended practice describes the theory, procedure, and interpretation of the insulation resistance test. It is intended for the following:

- Individuals or organizations who manufacture rotating machines
- Individuals or organizations who are responsible for the acceptance of new rotating machines
- Individuals or organizations who test and maintain rotating machines
- Individuals or organizations who operate rotating machines

This recommended practice is designed to help organizations and individuals

- Evaluate the condition of the electrical insulation used in rotating machines
- Determine if the electrical insulation of a rotating machine is suitable for return-to-service
- Determine if the electrical insulation of a rotating machine is suitable for high-potential testing

This recommended practice is intended to satisfy the following objectives:

- a) Promote consistency of insulation test procedures and interpretations
- b) Provide useful information on proper application of the insulation resistance test
- c) Provide useful information on the technical theory of insulation resistance testing

The revision to this recommended practice was prepared by a working group of the Materials Subcommittee of the Electrical Machinery Committee of the IEEE Power Engineering Society. Working group personnel were

William Bartley  
Thomas Bishop  
Robert Draper  
Guanzhong Gao  
Trilok C. Garg  
James Grant  
Gary Griffith  
Gary Heuston

**Vicki Warren, Chair**

Alan M. Iverson  
Ken Jackson  
Wayne Johnson  
Chaman L. Kaul  
Walter Martiny  
William McDermid  
Charles Millet  
Beant Nindra  
Madan Rana

Larry Rodland  
David Schump  
Susan Soergel  
Greg C. Stone  
George Stranovsky  
Chuck Wilson  
John Wilson  
Daniel I. Young\*

\*Chair Emeritus

The following members of the balloting committee voted on this recommended practice:

Vaino Aare  
Edwin Averill  
Roy L. Balke  
William H. Bartley  
Kevin D. Becker  
Karl W. Berger  
Thomas H. Bishop  
Paul G. Cummings  
Paul L. Dandeno  
James H. Dymond  
James S. Edmonds  
Franklin T. Emery  
Jorge Fernandez-Daher  
Guanzhong Gao  
Trilok C. Garg  
Nirmal K. Ghai  
Brian E. B. Gott  
James Grant  
Franklin H. Grooms  
Bal K. Gupta  
Howard B. Hamilton

Thomas J. Hammons  
Richard A. Huber  
Alan M. Iversen  
Chaman L. Kaul  
Rigsby Kavanaugh  
Tim Keck  
Stephen B. Kuznetsov  
Peter H. Landrieu  
Walter J. Martiny  
William R. McCown  
William McDermid  
Lloyd McSparran  
Edward J. Michaels  
J. R. Michalec  
Charles Millet  
Gerhard J. Neidhoefer  
Nils E. Nilsson  
Beant S. Nindra  
J. L. Oldenkamp  
James A. Oliver

William B. Penn  
Madan Rana  
Robert H. Rehder  
Laurence Rodland  
Charles M. Rowe  
David E. Schump  
Manoj R. Shah  
John Shea  
Jan Stein  
Ken Stenroos  
Greg C. Stone  
James E. Timperley  
Paul Vollmar  
Paul Dieter Wagner  
Vicki Warren  
Richard F. Waddell  
Charles A. Wilson  
John Wilson  
Edward J. Woods  
Daniel W. Young  
Mark Ziegen

The final conditions for approval of this standard were met on 6 March 2000. This standard was conditionally approved by the IEEE-SA Standards Board on 30 January 2000, with the following membership:

**Richard J. Holleman, *Chair***  
**Donald N. Heirman, *Vice Chair***  
**Judith Gorman, *Secretary***

Satish K. Aggarwal  
Dennis Bodson  
Mark D. Bowman  
James T. Carlo  
Gary R. Engmann  
Harold E. Epstein  
Jay Forster\*  
Ruben D. Garzon

James H. Gurney  
Lowell G. Johnson  
Robert J. Kennelly  
E. "Bill" Kener  
Joseph L. Koepfinger\*  
L. Bruce McClung  
Daleep C. Mohla  
Robert F. Munzner

Louis-François Pau  
Ronald C. Petersen  
Gerald H. Peterson  
John B. Posey  
Gary S. Robinson  
Akio Tojo  
Hans E. Weinrich  
Donald W. Zipse

\*Member Emeritus

Also included is the following nonvoting IEEE-SA Standards Board liaison:

Robert E. Hebner

Noelle D. Humenick  
*IEEE Standards Project Editor*

## Contents

1.	Overview.....	1
1.1	Scope.....	1
1.2	Purpose.....	1
2.	References.....	2
3.	Definitions.....	3
4.	Safety considerations.....	3
5.	Insulation resistance—general theory.....	4
5.1	Components of the measured direct current.....	4
5.2	Characteristics of the measured direct current.....	6
5.3	Insulation resistance readings.....	6
5.4	Polarization index readings.....	7
5.5	Discharge current.....	8
6.	Factors affecting insulation resistance.....	8
6.1	Effect of surface condition.....	8
6.2	Effect of moisture.....	9
6.3	Effect of temperature.....	9
6.4	Effect of test voltage magnitude.....	11
6.5	Effect of existing charge on winding resistance measurements.....	12
7.	Conditions for measuring insulation resistance.....	12
8.	Winding connections for insulation resistance tests.....	12
9.	Methods of measuring insulation resistance.....	13
9.1	Direct measurement.....	13
9.2	Calculated measurement.....	13
10.	Precautions.....	13
11.	Interpretation of insulation resistance and polarization index test results.....	14
11.1	Monitoring insulation condition.....	14
11.2	Suitability for operation or continued testing.....	14
11.3	Limitations of the insulation resistance test.....	15
12.	Recommended minimum value of polarization index and insulation resistance.....	15
12.1	Minimum values.....	15
12.2	Polarization index.....	15
12.3	Insulation resistance.....	16

Annex A (informative)—Variants in polarization index .....	18
Annex B (informative)—Direct versus alternating voltage testing .....	19
Annex C (informative)—Regulation in power supplies used for insulation resistance measurement.....	20

Currently in preview, click buy full version

# IEEE Recommended Practice for Testing Insulation Resistance of Rotating Machinery

## 1. Overview

### 1.1 Scope

This document describes a recommended procedure for measuring insulation resistance of armature and field windings in rotating machines rated 1 hp, 750 W or greater. It applies to synchronous machines, induction machines, dc machines, and synchronous condensers. It does not apply to fractional-horsepower machines.

The document also describes typical insulation resistance characteristics of rotating machine windings and how these characteristics indicate winding condition. It recommends minimum acceptable values of insulation resistance for ac and dc rotating machine windings.

Other IEEE standards that include information on insulation resistance measurement are listed in Clause 2.

### 1.2 Purpose

The purpose of this recommended practice is to

- a) Define insulation resistance and polarization index testing of the winding of a rotating machine.
- b) Review the factors that affect or change insulation resistance characteristics.
- c) Recommend uniform test conditions.
- d) Recommend uniform methods for measuring insulation resistance with precautions to avoid erroneous results.
- e) Provide a basis for interpreting insulation resistance test results to estimate winding suitability for service or for an overvoltage test. In particular, this standard describes typical insulation problems detected by the insulation resistance test.
- f) Present recommended minimum acceptable insulation resistance values and polarization indices for various types of rotating machines.

## 2. References

This recommended practice shall be used in conjunction with the following publications. When the following standards are superseded by an approved revision, the revision shall apply.

ASTM D257-99 Standard Test Methods for DC Resistance or Conductance of Insulating Materials.<sup>1</sup>

ASTM D1711-99 Standard Terminology Relating to Electrical Insulation.

ASTM F855-97e1 Standard Specifications for Temporary Protective Grounds to Be Used on De-energized Electric Power Lines and Equipment.

IEC 60085-1: 1984, Thermal evaluation and classification of electrical insulation.<sup>2</sup>

IEEE Std 56-1977 (Reaff 1991), IEEE Guide for Insulation Maintenance of Large Alternating-Current Rotating Machinery (10 000 kVA and Larger).<sup>3,4</sup>

IEEE Std 62-1995, IEEE Guide for Diagnostic Field Testing of Electric Power Apparatus—Part 1: Oil Filled Power Transformers, Regulators, and Reactors.

IEEE Std 67-1990 (Reaff 1995), IEEE Guide for Operation and Maintenance of Turbine Generators.

IEEE Std 95-1977 (Reaff 1991), IEEE Recommended Practice for Insulation Testing of Large AC Rotating Machinery With High Direct Voltage.<sup>5</sup>

IEEE Std 118-1978 (Reaff 1992), IEEE Standard Test Code for Resistance Measurements.

IEEE Std 432-1992 (Reaff 1998), IEEE Guide for Insulation Maintenance for Rotating Electric Machinery (5 hp to less than 10 000 hp).

IEEE Std 433-1974 (Reaff 1991), IEEE Recommended Practice for Insulation Testing of Large AC Rotating Machinery with High Voltage at Very Low Frequency.

IEEE Std 434-1973 (Reaff 1991), IEEE Guide for Functional Evaluation of Insulation Systems for Large High-Voltage Machines.

IEEE Std 492-1999 IEEE Guide for Operation and Maintenance of Hydro-Generators.

IEEE Std 510-1983 (Reaff 1992), IEEE Recommended Practices for Safety in High-Voltage and High-Power Testing.

<sup>1</sup>ASTM publications are available from the American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959, USA (<http://www.astm.org/>).

<sup>2</sup>IEC publications are available from the Sales Department of the International Electrotechnical Commission, Case Postale 131, 3, rue de Varembe, CH-1211, Genève 20, Switzerland/Suisse (<http://www.iec.ch/>). IEC publications are also available in the United States from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA.

<sup>3</sup>Presently under revision.

<sup>4</sup>IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA (<http://www.standards.ieee.org/>).

<sup>5</sup>Presently under revision.

### 3. Definitions

For the purposes of this recommended practice, the following terms and definitions apply. The IEEE Dictionary of Electrical and Electronics Terms should be referenced for terms not defined in this clause.

**3.1 absorption (polarization) current ( $I_A$ ):** A current resulting from molecular polarizing and electron drift, which decays with time of voltage application at a decreasing rate from a comparatively high initial value to nearly zero, and depends on the type and condition of the bonding material used in the insulation system.

**3.2 conduction current ( $I_G$ ):** A current that is constant in time, that passes through the bulk insulation from the grounded surface to the high-voltage conductor, and that depends on the type of bonding material used in the insulation system.

**3.3 electroendosmosis effect:** A phenomenon occasionally observed, more often on older windings, when, in the presence of moisture, different insulation resistance values may be obtained when the polarity of the tester leads are reversed. Typically for older wet windings, the insulation resistance for reverse polarity, where the ground lead is connected to the winding and the negative voltage lead to ground, is much higher than for normal polarity.

**3.4 insulation resistance ( $IR_t$ ):** The capability of the electrical insulation of a winding to resist direct current. The quotient of applied direct voltage of negative polarity divided by current across machine insulation, corrected to 40 °C, and taken at a specified time ( $t$ ) from start of voltage application. The voltage application time is usually 1 min ( $IR_1$ ) or 10 min ( $IR_{10}$ ), however, other values can be used. Unit conventions: values of 1 through 10 are assumed to be in minutes, values of 15 and greater are assumed to be in seconds.

**3.5 geometric capacitive current ( $I_C$ ):** A reversible current of comparatively high magnitude and short duration, which decays exponentially with time of voltage application, and which depends on the internal resistance of the measuring instrument and the geometric capacitance of the winding.

**3.6 polarization index ( $PI_{t_2/t_1}$ ):** Variation in the value of insulation resistance with time. The quotient of the insulation resistance at time ( $t_2$ ) divided by the insulation resistance at time ( $t_1$ ). If times  $t_2$  and  $t_1$  are not specified, they are assumed to be 10 min and 1 min, respectively. Unit conventions: values of 1 through 10 are assumed to be in minutes, values of 15 and greater are assumed to be in seconds (e.g.,  $PI_{60/15}$  refers to  $IR_{60s}/IR_{15s}$ ).

**3.7 surface leakage current ( $I_s$ ):** A current that is constant with time, and which usually exists over the surface of the end-turns of the stator winding or between exposed conductors and the rotor body in insulated rotor windings. The magnitude of the surface leakage current is dependent upon temperature and the amount of conductive material (i.e. moisture or contamination) on the surface of the insulation.

### 4. Safety Considerations

Insulation resistance testing involves the application of high direct voltages to machine windings. These windings have capacitive and inductive properties that can lead to hazards that may not be readily apparent. It is not possible to cover all safety aspects in this recommended practice and test personnel should consult IEEE Std 510-1983,<sup>6</sup> ASTM F855-97e1; manufacturers' instruction manuals; and union, company, and government regulations.

<sup>6</sup>Information on references can be found in Clause 2.