



IEEE Recommended Practice for Insulation Testing of AC Electric Machinery with High Voltage at Very Low Frequency

IEEE Power & Energy Society

Sponsored by the
Electric Machinery Committee

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

24 February 2010

IEEE Std 433™-2009
(Revision of
IEEE Std 433-1974)

Currently in preview, click buy full version

IEEE Recommended Practice for Insulation Testing of AC Electric Machinery with High Voltage at Very Low Frequency

Sponsor

**Electric Machinery Committee
of the
IEEE Power & Energy Society**

Approved 9 December 2009

IEEE-SA Standards Board

Acknowledgments

The Insulation Testing of AC Electric Machinery with High Voltage at Very Low Frequency Working Group especially acknowledges the contributions of Guy Halldorson, who passed away shortly before the publication of this recommended practice.

Abstract: This recommended practice describes very low frequency withstand and diagnostic tests that are performed on the stator windings of ac electric machines.

Keywords: ac electric machines, ac electric machine testing, diagnostic test, high-potential (hipotential) test, over potential test, proof testing, safety, very low frequency testing, VLF testing, withstand test

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2010 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 24 February 2010. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-6137-2 **STD96005**
Print: ISBN 978-0-7381-6138-9 **STDPD96005**

IEEE prohibits discrimination, harassment, and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.
No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretation is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretation, should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 433-2009, IEEE Recommended Practice for Insulation Testing of AC Electric Machinery with High Voltage at Very Low Frequency.

Voltage withstand tests, particularly in the field, are generally carried out with dc power sources, because in terms of weight, size, and cost they have a decided advantage. However the dc test data obtained on ac machines have a serious disadvantage in that the dc breakdown mechanism differs appreciably from that which occurs under ac conditions. In practice, it is found that the dc breakdown strength is substantially higher than the ac breakdown strength. The dc breakdown process is principally an electronic conduction mechanism, with the free electrons injected into the insulation from either sharp points or the electrode (where high field enhancement is created) or at space charge build-up sites within the dielectric. In contradistinction, the ac breakdown process involves a thermally controlled-type mechanism and results directly either from the thermal losses associated with the dielectric losses or from the partial discharge (PD) induced heating and physical erosion mechanism at the sites where repeated discharges can take place. Both of these are frequency- and voltage-dependent effects; also note that the dissipation factor at a given insulation site is determined by the dielectric losses of both the solid insulation and the power loss contribution from the repetitive PD pulses.

Evidently, it is more meaningful to evaluate the insulating systems of ac machines using ac voltage sources. For tests in the field, such ac voltage sources must be readily transportable, low weight, moderate size, and requiring lower amounts of power. This is accomplished by making use of low-frequency ac power supplies, which were first introduced in the 1950s for the purpose of high potential testing and insulation resistance and capacitance measurements (see Bhimani [B3], [B4]).^a Although since that time, the low-frequency source equipment has undergone substantial improvement, some uncertainties remain when it is attempted to relate the test data obtained at low frequencies to that at power frequencies. This becomes particularly apparent when one considers the dissipation factor and PD measurements at low frequencies with respect to those at the power frequency.

The dissipation factor may be expressed by the quotient, $\sigma/\omega\epsilon'$, where σ represents the conductivity, ϵ' represents the real permittivity (dielectric constant) of the dielectric, and ω is the frequency term. At power frequencies under constant ambient temperature, the conductivity is more or less constant and governed by the conduction losses of free-charge carriers. Since ϵ' is also relatively constant, then as the frequency ω is first decreased, the dissipation factor will exhibit an increase with falling frequency, ω . Once the falling frequency enters the space charge polarization region over the lower frequencies, the conductivity σ will commence increasing, thereby further augmenting the value of the dissipation factor. As a consequence, the low-frequency value of the dissipation factor will be substantially higher than that at the power frequencies (see *Engineering Dielectrics, Vol. IIB, Electrical Properties of Solid Insulating Materials: Measurement Techniques* [B5]).

When diagnostic measurements are carried out in terms of the dissipation factor to determine the dielectric loss behavior of an insulating system, it must be borne in mind that the measured $\tan\delta$ value is an indicator of the total loss in the insulating system. The PD contribution can be calculated in terms of the PD pulse-phase distribution at a given applied voltage and frequency or be measured using the pulse charge-voltage parallelogram technique (see *Engineering Dielectrics, Vol. I, Corona Measurement and Interpretation* [B6]). Both the dielectric loss component in the solid insulation of the ac machine can then be determined by subtracting the dissipation factor value due to the PD loss from that resulting from that of the overall insulation system loss.

^a The numbers in brackets correspond to those of the bibliography in Annex C.

The PD intensity at power frequencies is substantially greater than at 0.1 Hz, because there are more discharges occurring per unit time, i.e., per 1 s, at 60 Hz. However, it is most remarkable that studies, which have been carried out over an extended frequency range, indicate that as the frequency of the power source is reduced, the total PD pulse charge transfer per cycle is augmented as the number of PD pulses per cycle exhibits an increase with falling frequency (see Bartnikas and Morin [B2] and Radu et al. [B18]). It is likely that the observed behavior is due to the change in the rate of dielectric surface charging and discharging within the cavities. Nevertheless, the total PD energy dissipated over a 1 s period at the power frequency is appreciably higher than that at 0.1 Hz; if the ac breakdown strength at 60 Hz is a result of thermal instability and degradation caused by PDs, then it will be lower than that at 0.1 Hz, which in turn will be still lower than the dc breakdown strength.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to any applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this recommended practice may require use of subject matter covered by patent rights. By publication of this recommended practice, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this recommended practice are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this recommended practice was submitted to the IEEE-SA Standards Board for approval, the Insulation Testing of AC Electric Machinery with High Voltage at Very Low Frequency Working Group had the following membership:

Howard Sedding *Chair*
Stefano G. Bombe *Vice Chair*

Sabir Azizi
Ray Bartnikas
Martin Baur
Kevin Becker
William Chen
Sudhakar Cherukupalli
Douglas Conley
Alfredo Contin

Shawn Filliben
George Gao
Jim Grant
Vince Green
Bal Gupta
Gordon Hadzorsek†
Cory Heuston
Jeff Hubrig
Lou Little

Bill McDermid
Beant Nindra
Lori Rux
Mladin Sasic
Joe Williams
Chuck Wilson
Karim Younsi
Hugh Zhu

† Deceased

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman
Michael Adams
Ali Al Awazi
Paul Barnhart
David Baron
Martin Baur
William Bloethe
Stuart Borlase
Steven Brockschink
Chris Brooks
Andrew Brown
Thomas Callsen
Antonio Cardoso
Weijjen Chen
Danila Chernetsov
Tommy Cooper
John Crouse

Jorge Fernandez Daher
Matthew Davis
Gary L. Donner
Donald Dunn
Gary Engmann
Randall Groves
Ajit Gwal
Steve Hamilton
Gary Heuston
David Horvath
Joseph L. Koepfinger
Jim Kulchisky
Saumen Kundu
William Lockley
G. Luri
Omar Mazzoni
William McDermid
Nigel McQuin

G. Harold Miller
Kimberly Mosley
Michael S. Newman
Lorraine Padden
Iulian Profir
Michael Roberts
Dinesh Sankarakurup
Bartien Sayogo
Gregory Stone
Meredith Stranges
S. Thamilarasan
Martin Von Herrmann
Joe Watson
Chuck Wilson
James Wilson
Hugh Zhu
Ahmed Zol

When the IEEE-SA Standards Board approved this recommended practice on December 2009, it had the following membership:

Robert M. Grow, Chair
Thomas Prevost, Vice Chair
Steve M. Mills, Past Chair
Judith Gorman, Secretary

John Barr
Karen Bartleson
Victor Berman
Ted Burse
Richard DeBlasio
Andy Drozd
Mark Epstein

Alexander Gelman
Jim Hughes
Richard H. Lett
Young Kyun Kim
Joseph L. Koepfinger*
John Kulick

David J. Law
Ted Olsen
Glenn Parsons
Ronald C. Petersen
Narayanan Ramachandran
Jon Walter Rosdahl
Sam Sciacca

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Howard L. Wolfman, *TAB Representative*
Michael Janezic, *NIST Representative*
Satish Aggarwal, *NRC Representative*

Lisa Perry
IEEE Standards Program Manager, Document Development

Soo H. Kim
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
1.3 Background.....	2
2. Normative references.....	2
3. Definitions.....	3
4. Preparations for test.....	4
4.1 General	4
4.2 Air-cooled machines.....	4
4.3 Hydrogen-cooled machines	5
4.4 Liquid-cooled stator (armature) windings	5
4.5 Oil-cooled machines.....	5
4.6 Isolation of the winding from cables and auxiliary equipment	5
4.7 Sectionalizing the winding	6
4.8 Equipment clearances and area isolation	6
4.9 Grounding precautions.....	6
5. General test considerations.....	7
5.1 Possibility of failure to pass test.....	7
5.2 Condition of winding.....	7
5.3 Test voltage determination	7
6. Test equipment	8
6.1 Equipment specifications.....	8
6.2 Instrumentation.....	8
6.3 Protection of equipment and test specimen	8
6.4 Power source to the very low frequency test equipment	8
6.5 Operation checks.....	8
6.6 Ground connections.....	9
6.7 High-voltage test connections.....	9
7. Test procedure.....	9
7.1 Overpotential tests	9
7.2 Diagnostic tests.....	9
8. Test results.....	10
8.1 Interpretation	10
8.2 Suggested test record.....	10
8.3 Record comments regarding.....	10

Annex A (informative) Information on testing.....	11
Annex B (informative) Glossary	16
Annex C (informative) Bibliography.....	17

IEEE Recommended Practice for Insulation Testing of AC Electric Machinery with High Voltage at Very Low Frequency

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection in all circumstances. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This document describes very low frequency (VLF) testing of ac electric machines. It covers acceptance testing of new machines in the factory or on-site after erection. Also covered is the routine maintenance testing of machines that have been in service. In order to facilitate communication and comparison among investigators, this document recommends that the VLF used be $0.1 \text{ Hz} \pm 10\%$.

1.2 Purpose

The purposes of this recommended practice are as follows:

- a) To provide a uniform procedure for testing the stator (armature) insulation of ac electric machines with VLF voltage, in order to obtain consistent results
- b) To recommend constants for relating VLF tests to power-frequency and direct-voltage tests to obtain equally effective test levels
- c) To describe VLF test equipment and wave shape
- d) To define terms that have specific meaning in VLF testing