

# IEEE Standard for the Electrical Protection of Communications Facilities Serving Electric Supply Locations—General Considerations

IEEE Power and Energy Society

Sponsored by the  
Power System Communications Committee

Currently in preview, click buy full version

# **IEEE Standard for the Electrical Protection of Communications Facilities Serving Electric Supply Locations—General Considerations**

Sponsor

**Power System Communications Committee  
of the  
IEEE Power and Energy Society**

Approved 11 June 2015

**IEEE-SA Standards Board**

## Copyrights and permissions

Figure 15 reprinted with permission from CEA Technologies Inc. (CEATI).

Figure 16 reprinted with permission from Grcev et al. [B19].

Figure 17 reprinted with permission from Grcev et al. [B20].

**Abstract:** General considerations are presented for the electrical protection of telecommunications facilities serving electric supply locations. This standard contains material that is common to the IEEE 487™ family of standards (i.e., dot-series) including fundamental protection theory; basic electrical protection philosophy, concepts, and designs; protection apparatus; service types; reliability; service performance objective (SPO) classification; and transmission considerations. In general, special protective measures, handling procedures, and administrative procedures are necessary to provide electrical protection against damage to telecommunications facilities and equipment, maintain reliability of service, and ensure the safety of personnel.

**Keywords:** electric supply locations, high-voltage tower, IEEE 487™ power stations, protection, wire-line telecommunications

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10017-5997, USA

Copyright © 2015 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published July 2015. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Inc.

National Electrical Safety Code and NESC are both registered trademarks and service marks of The Institute of Electrical and Electronics Engineers, Inc.

National Fire Protection Code and NEC are both registered trademarks of the National Fire Protection Association, Inc.

Wi-Fi is a registered trademark of the Wi-Fi Alliance®

WiMAX is a registered trademark of the WiMAX Forum.

PDF: ISBN 978-0-7381-9782-1 STD20269  
Print: ISBN 978-0-7381-9783-8 STDPD20269

*IEEE prohibits discrimination, harassment, and bullying.*

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

## Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

### Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, make, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

### Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

## Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

## Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854 USA

## Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standards are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

## Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

## Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

## Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this standard was completed, the Wire-Line Working Group had the following membership:

**Percy E. Pool**, *Co-Chair and Technical Editor*  
**Larry S. Young**, *Co-Chair and Secretary*

Steven Blume  
Joe Boyles  
Timothy Conser  
Bhimesh Dahal  
Jean de Seve

Ernest Duckworth  
John Fuller  
Ernest Gallo  
Dave Hartmann  
Dan Jendek

Del Khomarlou  
Richard Knight  
Randall Mears  
Mark Tirio  
Thomas Vo

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman  
R. Baysden  
Steven Blume  
Gustavo Brunello  
William Byrd  
Robert Christman  
Timothy Conser  
Jerry Corkran  
Gary Donner  
Michael Dood  
Randall Dotson  
Ernest Duckworth  
Fredric Friend  
Frank Gerleve  
David Gilmer  
Mietek Glinkowski  
Jalal Gohari  
Randall Groves  
Jeffrey Helzer  
Lee Herron  
Werner Hoelzl

Yuri Khersonsky  
Richard Knight  
Jim Kulchisky  
Chung-Yiu Lam  
Robert Landman  
Lawrence Long  
Albert Martin  
William McCoy  
Joseph Mears  
Carl Moller  
H. Nerhood  
Michael Newman  
Joe Nims  
Gary Nims  
James O'Brien  
Carl Orje  
Ehsani Patel  
S. Patel  
Donald Platts  
Percy E. Pool

Richard Roberts  
Charles Rogers  
Thomas Rozek  
Daniel Sabin  
Steven Sano  
Bartien Sayogo  
Devki Sharma  
Mark Simon  
David Singleton  
Jerry Smith  
Michael Swearingen  
David Tepen  
Mark Tirio  
John Vergis  
Jane Verner  
Thomas Vo  
Daniel Ward  
Donald Wengerter  
Kenneth White  
James Wilson  
Larry S. Young

When the IEEE-SA Standards Board approved this standard on 11 June 2015, it had the following membership:

**John D. Kulick**, *Chair*  
**Jon Walter Rosdahl**, *Vice Chair*  
**Richard H. Hulett**, *Past Chair*  
**Konstantinos Karachalios**, *Secretary*

Masayuki Ariyoshi  
Ted Burse  
Stephen Dukes  
Jean-Philippe Faure  
J. Travis Griffith  
Gary Hoffman  
Michael Janezic

Joseph L. Koepfinger\*  
David J. Law  
Hung Ling  
Andrew Myles  
T. W. Olsen  
Glenn Parsons  
Ronald C. Petersen  
Annette D. Reilly

Stephen J. Shellhammer  
Adrian P. Stephens  
Yatin Trivedi  
Phillip Winston  
Don Wright  
Yu Yuan  
Daidi Zhong

\*Member Emeritus

## Introduction

This introduction is not part of IEEE Std 487™-2015, IEEE Standard for the Electrical Protection of Communications Facilities Serving Electric Supply Locations—General Considerations.

Telecommunications facilities serving electric supply locations often require special high-voltage protection (HVP) against the effects of fault-produced ground potential rise (GPR) or induced voltages, or both. Some of the telecommunications services are used for control and protective relaying purposes and may be called on to perform critical operations at times of power system faults. This requirement presents a major challenge in the design and protection of the telecommunications system because power system faults can result in the introduction of interfering voltages and currents into the telecommunications circuit at the very time when the circuit is most urgently required to perform its function. Even when critical services are not involved, special HVP may be required for both personnel safety and plant protection at times of power system faults. Effective protection of any telecommunications circuit requires coordinated protection on all circuits provided over the same telecommunications cable. Figure 24 provides an overview of a basic protection system.

Some electrical environments, collectively called *electric supply locations*, require the application of unique electrical protection techniques because of their special nature. One such environment is the electric power station or substation. Another is at or near power line transmission and distribution structures such as towers or poles. Such structures often provide a convenient site for the location of wireless, personal communications service, and cellular antennas and their associated electronic equipment that is served by a link to the wired telecommunications network.

This standard presents general considerations for the electrical protection of telecommunications facilities serving electric supply locations. This standard contains material that is common to the IEEE 487™ family of standards (i.e., dot-series) including fundamental protection theory and basic electrical protection concepts and designs. In general, special protective measures, handling procedures, and administrative procedures are necessary to provide electrical protection against damage to telecommunications facilities and equipment, maintain reliability of service, and ensure the safety of personnel. It is important to note that special HVP for the purpose of personnel safety and plant protection may be required even when critical services are not involved. For leased circuits, mutually agreeable methods for the installation of protective equipment owned by either party are presented.

This project is part of a reorganization of the IEEE 487 documentation in which the main document is broken down into a family of related documents segregated on the basis of technology:

- IEEE Std 487™ for general considerations
- IEEE Std 487.1™ for applications using on-grid isolation equipment involving metallic wire-line
- IEEE Std 487.2™ for applications consisting entirely of optical fiber cables
- IEEE Std 487.3™ for applications of hybrid facilities where part of the circuit is on metallic wire-line and the remainder of the circuit is on optical fiber cable
- IEEE Std 487.4™ for applications using neutralizing transformers (NTs)
- IEEE Std 487.5™ for applications using isolation transformers

This standard has been prepared by the Wire-Line Subcommittee (SC6) of the Power System Communications Committee of the IEEE Power and Energy Society, and it represents the consensus of both power and telecommunications engineers.

# Contents

1. Overview .....	1
1.1 Background.....	1
1.2 Scope .....	2
1.3 Purpose .....	2
1.4 Not covered .....	2
2. Normative references.....	2
3. Definitions, acronyms, and abbreviations .....	3
3.1 Definitions .....	3
3.2 Acronyms and abbreviations .....	5
4. High-voltage environment (HVE) .....	7
4.1 Overview .....	7
4.2 Coupling .....	7
4.3 Disturbances .....	8
5. Grounding considerations.....	23
5.1 Electric power stations.....	23
5.2 Typical grounding for sites immediately outside the grid .....	23
5.3 Typical grounding at power line structures such as towers or poles.....	24
5.4 Typical grounding requirements for base transceiver station (BTS) .....	25
5.5 Step, touch, and mesh voltages for BTSs located on power line transmission or distribution structures.....	25
5.6 Grounding for distributed antenna systems (DASs) .....	29
6. Protection apparatus .....	29
7. Service types, reliability, service performance objective (SPO) classifications, and transmission considerations .....	31
7.1 Overview .....	31
7.2 Service types.....	31
7.3 SPO classifications .....	32
7.4 Transmission considerations.....	34
8. Protection theory and philosophy .....	34
8.1 Overview .....	34
8.2 Concepts and concerns .....	35
8.3 Ownership.....	35
8.4 General-use telecommunications cable in the electric supply location GPR ZOI .....	35
8.5 Aerial cable installation .....	36
8.6 Conduit containing metallic members or tracing medium .....	36
9. Protection configurations.....	36
9.1 Overview .....	36
9.2 GPR plus induced voltage levels .....	37
9.3 Basic protection system.....	38
9.4 Protection configurations employing isolation devices .....	40
9.5 General isolation protection configuration .....	46
9.6 Specific protection configurations .....	47
9.7 Protection practices for electric supply locations services.....	48

10. Inspection considerations .....	48
11. Safety.....	49
11.1 General safety considerations .....	49
11.2 Safety considerations in equipment design.....	49
11.3 Safety considerations related to installation and maintenance.....	50
12. Summary .....	51
Annex A (informative) Bibliography .....	52
Annex B (informative) Characteristics of protection apparatus .....	56
Annex C (informative) Telecommunications cable in the electric supply location GPR ZOI.....	66
Annex D (informative) Protection of isolation, drainage, NTs, and other apparatus by surge arresters .....	71
Annex E (informative) Transmission characteristics and SPO requirements for various telecommunications channels.....	76
Annex F (informative) DC offset waveform development.....	77
Annex G (informative) High-dielectric optical fiber isolation systems.....	83
Annex H (informative) Theoretical verses actual field experience GPR and related ZOI profiles .....	85
Annex I (informative) Service request data.....	89

# IEEE Standard for the Electrical Protection of Communications Facilities Serving Electric Supply Locations—General Considerations

*IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.*

*This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.*

## 1. Overview

### 1.1 Background

Telecommunications facilities serving electric supply locations often require special high-voltage protection (HVP) against the effects of fault-produced ground potential rise (GPR) or induced voltages, or both. Some of the telecommunications services are used for control and protective relaying purposes and may be called on to perform critical operations at times of power system faults. This requirement presents a major challenge in the design and protection of the telecommunications system because power system faults can result in the introduction of interfering voltages and currents into the telecommunications circuit at the very time when the circuit is most urgently required to perform its function. Even when critical services are not involved, special HVP may be required for both personnel safety and plant protection at times of power system faults. Effective protection of any telecommunications circuit requires coordinated protection on all circuits provided over the same telecommunications cable.