

IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations Through the Use of On-Grid Isolation Equipment

IEEE Power and Energy Society

Sponsored by the
Power System Communications Committee

Currently in preview, click buy full version

IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations Through the Use of On-Grid Isolation Equipment

Sponsor

**Power System Communications Committee
of the
IEEE Power and Energy Society**

Approved 3 November 2014

IEEE-SA Standards Board

Abstract: Workable methods for protecting wire-line telecommunication circuits entering electric supply locations are presented. The electric supply location environment; protection apparatus; service types, reliability, service performance objective classifications, and transmission considerations; protection theory and philosophy; protection configurations; installation and inspection; and safety are covered in this document.

Keywords: electric supply locations, high-voltage tower, IEEE 487.1™, power stations, protection, wire-line telecommunication

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2014 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 7 November 2014. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Inc.

National Electrical Safety Code and NESC are both registered trademarks and service marks of The Institute of Electrical and Electronics Engineers, Inc.

PDF: ISBN 978-0-7381-9377-9 STD20001
Print: ISBN 978-0-7381-9378-6 STDPD20001

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, correctness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, make, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standards are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE standard was completed, the Wire-Line Working Group had the following membership:

Percy Pool, *Co-Chair and Technical Editor*
Larry Young, *Co-Chair and Secretary*

Joe Boyles
Steve Blume
Tim Conser
Bhimesh Dahal
Jean DeSeve

Ernest Duckworth
John Fuller
Ernest Gallo
Dave Hartmann

Dan Jendek
Richard Knight
Randall Mears
Mark Tirio
Thomas Vo

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman
R. Baysden
Joe Boyles
Gustavo Brunello
William Bush
Bhimesh Dahal
Douglas Dorr
Ernest Duckworth
John Fuller
Frank Gerleve
Jalal Gohari
Randall Groves

Noriyuki Ikeuchi
Yuri Khersonsky
Richard Knight
Jim Kulchisky
Lawrenc Long
Albert Martin
William McCoy
Joseph Mears
Jerry Murphy
Michael Newman
Gary Nissen

James O'Brien
Doraine Padden
Percy Pool
Charles Rogers
Bartien Sayogo
Mark Simon
Mark Tirio
John Vergis
Thomas Vo
John Wang
Kenneth White
Larry Young

When the IEEE-SA Standards Board approved this standard on 27 October 2014, it had the following membership:

John Kulick, *Chair*
Jon Walter Rosdahl, *Vice Chair*
Richard H. Hulett, *Past Chair*
Konstantinos Karachalios, *Secretary*

Peter Balma
Farooq Bari
Ted Burse
Clint Chaplin
Stephen Dukes
Jean-Luc Faure
Gary Hoffman

Michael Janezic
Jeffrey Katz
Joseph L. Koepfinger*
David J. Law
Hung Ling
Oleg Logvinov
T. W. Olsen
Glenn Parsons

Ron Petersen
Adrian Stephens
Peter Sutherland
Yatin Trivedi
Phil Winston
Don Wright
Yu Yuan

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Patrick Gibbons
IEEE-SA Content Publishing

Erin Spiewak
IEEE-SA Technical Community Programs

Currently in preview, click buy full version

Introduction

This introduction is not part of IEEE Std 487.1™-2014, IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations Through the Use of On-Grid Isolation Equipment.

Wire-line telecommunication facilities serving electric supply locations often require special high-voltage protection against the effects of fault-produced ground potential rise (GPR) or induced voltages, or both. Some of the telecommunication services are used for control and protective relaying purposes and may be called upon to perform critical operations at times of power-system faults. This requirement presents a major challenge in the design and protection of the telecommunication system because power-system faults can result in the introduction of interfering voltages and currents into the telecommunication circuit at the very time when the circuit is most urgently required to perform its function. Even when critical services are not involved, special high-voltage protection may be required for both personnel safety and plant protection at times of power-system faults. Effective protection of any wire-line telecommunication circuit requires coordinated protection on all circuits provided over the same telecommunication cable.

Some electrical environments, collectively called electric supply locations, require the application of unique electrical protection techniques because of their special nature. One such environment is the electric power station or substation. Another is at, or near, power line transmission and distribution structures such as towers or poles. Such structures often provide a convenient site for the location of wireless, personal communications service, and cellular antennas and their associated electronic equipment that is served by a link to the wired telecommunications network.

This standard presents workable methods for protecting wire-line telecommunication circuits entering electric supply locations. It is important to note that special high-voltage protection for the purpose of personnel safety and plant protection may be required even when critical services are not involved. In the case of leased circuits, mutually agreeable methods for the installation of protective equipment owned by either party are presented.

This project is part of a reorganization of IEEE Std 487™^a in which the main document is broken down into a family of related documents (i.e. dot-series), segregated on the basis of technology:

- IEEE 487™: general considerations
- IEEE 487.1™: for applications using on-grid isolation equipment involving metallic wire-line
- IEEE 487.2™: for applications consisting entirely of optical fiber cables
- IEEE 487.3™: for applications of hybrid facilities where part of the circuit is on metallic wire-line and the remainder of the circuit is on optical fiber cable
- IEEE 487.4™: for applications using neutralizing transformers
- IEEE 487.5™: for applications using isolation transformers

This standard covers the use of modular-type on-grid isolators, either transformer or optical, for the electrical protection of wire-line (metallic) telecommunications facilities serving electric supply locations. The use of discrete hard-wired isolation transformers is covered in IEEE Std 487.5 [B21]^b.

^a Information on references can be found in Clause 2.

^b The numbers in brackets correspond to those of the bibliography in Annex A.

This standard has been prepared by the Wire-Line Subcommittee of the Power System Communications Committee of the IEEE Power and Energy Society. This standard represents the consensus of both power and telecommunications engineers.

Contents

1. Overview	1
1.1 Background.....	1
1.2 Scope	2
1.3 Purpose	2
2. Normative references.....	2
3. Definitions, acronyms, and abbreviations	2
3.1 Definitions	2
3.2 Acronyms and abbreviations	4
4. High-voltage environment.....	5
4.1 Locations	5
4.2 Practical implications.....	5
4.3 Earth potential profile.....	6
4.4 Cables in high-voltage environments	7
5. Protection theory and philosophy	7
5.1 Background.....	7
5.2 Concepts and concerns	9
5.3 Service performance objective (SPO) classifications	10
5.4 Responsibilities for installation and maintenance.....	10
5.5 General-use telecommunication cable in the electric supply location GPR ZOI.....	10
5.6 Dedicated cable.....	11
5.7 Special wire-line protection design requirements.....	13
6. Protection configurations.....	14
6.1 Ground potential rise (GPR) plus induced voltage levels.....	14
6.2 Basic protection system	14
6.3 Protection configurations employing isolation devices	16
6.4 General isolation protection configuration	19
6.5 Protection configuration employing modular high dielectric and optic isolators	21
6.6 Protection practices for electric supply locations services.....	21
7. Periodic inspection considerations	26
8. Safety.....	27
8.1 General safety considerations	27
8.2 Safety considerations in equipment design.....	27
8.3 Safety considerations related to installation and maintenance.....	28
Annex A (informative) Bibliography	30
Annex B (informative) Telecommunications cable in the electric supply location GPR ZOI.....	32

IEEE Standard for the Electrical Protection of Communication Facilities Serving Electric Supply Locations Through the Use of On-Grid Isolation Equipment

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Background

Wire-line telecommunication¹ facilities serving electric supply locations often require special high-voltage protection against the effects of fault-produced ground potential rise (GPR), induced voltages, or both. Some of the telecommunication services are used for control and protective relaying purposes and may be called upon to perform critical operations at times of power-system faults. This requirement presents a major challenge in the design and protection of the telecommunication system because power-system faults can result in the introduction of interfering voltages and currents into the telecommunication circuit at the very time when the circuit is most urgently required to perform its function. Even when critical services are not involved, special high-voltage protection may be required for both personnel safety and plant protection at times of power-system faults. Effective protection of any wire-line telecommunication circuit requires coordinated protection on all circuits provided over the same telecommunication cable.

¹ In general, “wire-line telecommunication” will be referred to throughout this document as “telecommunication.”