

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

IEEE Power and Energy Society

Sponsored by the
Transmission and Distribution Committee

Currently in preview, click buy full version

IEEE Std 519™-2014

(Revision of
IEEE Std 519-1992)

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

Sponsor

**Transmission and Distribution Committee
of the
IEEE Power and Energy Society**

Approved 27 March 2014

IEEE-SA Standards Board

Abstract: Goals for the design of electrical systems that include both linear and nonlinear loads are established in this recommended practice. The voltage and current waveforms that may exist throughout the system are described, and waveform distortion goals for the system designer are established. The interface between sources and loads is described as the point of common coupling and observance of the design goals will reduce interference between electrical equipment.

This recommended practice addresses steady-state limitations. Transient conditions exceeding these limitations may be encountered. This document sets the quality of power that is to be provided at the point of common coupling. This document does not cover the effects of radio-frequency interference; however, guidance is offered for wired telephone systems.

Keywords: harmonics, IEEE 519™, power quality

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2014 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 11 June 2014. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-9005-1 STD98587
Print: ISBN 978-0-7381-9006-8 STDPD98587

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, correctness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, make, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comment or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standards are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE recommended practice was completed, the Harmonics Working Group had the following membership:

Mark Halpin, Chair

Reuben Burch
Jim Burke
Randy Collins
Doug Dorr
Russell Ehrlich
Thomas Gentile
David Gilmer
Daryl Hallmark
Dennis Hansen
Fred Hensley
Randy Horton
Bill Howe
John Kennedy
Albert Keri

Roberto Langella
Theo Laughner
Mike Lowenstein
Alex McEachern
Mark McGranaghan
Chris Melhorn
William Moncrief
Dave Mueller
Marty Page
Paulo Ribeiro
Daniel Sabin
Bob Saint
Surya Santoso

Ken Sedziol
Harish Sharma
Jeff Smith
Nicholas Smith
Mike Swearingen
Steve Tatum
Alfredo Testa
Rao Thallam
Timothy Unruh
Dan Ward
James Williams
Charlie Williams
Wilson Xu
Francis Zavadova

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman
Ali Al Awazi
Roy Alexander
Saleman Alibhay
Thomas Barnes
G. Bartok
David Bassett
Thomas Basso
Steven Bezner
Wallace Binder
Michael Bio
Thomas Bishop
William Bloethe
Frederick Brockhurst
Andrew Brown
Gustavo Brunello
Jeffrey Burnworth
William Bush
William Byrd
Brent Cain
Paul Cardin
Antonio Cardozo
Keith Chow
Robert Christman
Brian Coates
Gary Conrad
Stephen Conrad
Luis Coronado
Glenn Davis
Andrew Dettloff
Carlo Donati
Gary Donner
Neal Dowling

Robert Durham
Russell Ehrlich
Gearold O. H. Eidhi
Ahmed ElSerafi
C. Erven
Dan Evans
Jorge Fernandez Daler
William Finley
Carl Fredericks
Francis Friend
Ehab Galal
David Garrett
Thomas Gentile
Kenneth Gettman
David Gilmer
Mietek Glinkowski
Thomas Grebe
Randall Groves
Thomas Gruz
Erich Gunther
Ajit Gwal
Daryl Hallmark
Robert Hanna
Dennis Hansen
Edward Hare
Gregory Hartzo
James Harvey
Jeffrey Helzer
Werner Hoelzl
Robert Hoerauf
Randy Horton
Ronald Hotchkiss
John Houdek

Farris Jibril
Brian Johnson
Gerald Johnson
Lars Juhlin
Laszlo Kadar
Innocent Kamwa
Haran Karmaker
John Kay
Gael Kennedy
John Kennedy
Yuri Khersonsky
Chad Kiger
James Kinney
Stanley Klein
Joseph L. Koepfinger
Edwin Kramer
Jim Kulchisky
Asok Kumar
Senthil Kumar
Saumen Kundu
Chung-Yiu Lam
Thomas La Rose
Theo Laughner
Wei-Jen Lee
Steven Liggio
Kevin Little
Albert Livshitz
William Lockley
Lawrence Long
Greg Luri
Richard Marek
John McAlhane, Jr
William McBride

Kenneth McClenahan
Peter Megna
Dean Mehlberg
John Merando
T. David Mills
Daleep Mohla
William Moncrief
Kimberly Mosley
Jerry Murphy
Ryan Musgrove
Arun Narang
Dennis Neitzel
Arthur Neubauer
Michael Newman
David Nichols
Joe Nims
Gary Nissen
Tim Olsen
Gary Olson
Gregory Olson
Lorraine Padden
Richard Paes
Marty Page
Mirko Palazzo
Donald Parker
David Parman
Bansi Patel
S. Patel

Shawn Patterson
Wesley Patterson
K. James Phillips
Percy Pool
Iulian Profir
John Rama
Moises Ramos
Reynaldo Ramos
John Roach
Michael Roberts
Charles Rogers
Thomas Rozek
D. Daniel Sabin
Randall Safier
Bob Saint
Steven Sano
Bartien Sayogo
Colin Schauder
Robert Schuerger
Ken Sedziol
Robert Seitz
Nikunj Shah
Nigel Shore
Gil Shultz
Hyeong Sim
David Singleton
James Smith
Jeremy Smith

Jerry Smith
John Spare
Gary Stoedter
Raymond Strittmatter
K. Stump
Peter Sutherland
Michael Swearingen
Steve Tatum
Richard Taylor
Eric Udren
Timothy Unruh
John Vergis
Carl Wall
Daniel Ward
Karl Weber
Yingli Wen
Kenneth White
Matthew Wilkowski
George Wood
Wilson Xu
Edward Yonkers
Thomas Yonkers
Lan Yu
Lin Yu
Francisc Zavoda
James Ziebarth
Donald Zipse
Ahmed Zobaa

When the IEEE-SA Standards Board approved this recommended practice on 27 March 2014, it had the following membership:

John Kulick, Chair
Jon Walter Rosdahl, Vice Chair
Richard A. Hulett, Past Chair
Konstantinos Karachalios, Secretary

Peter Balma
Farooq Bari
Ted Burse
Clint Chaplain
Stephen Dukes
Jean-Phillippe Faure
Gary Hoffman

Michael Janezic
Jeffrey Katz
Joseph L. Koepfinger*
David J. Law
Hung Ling
Oleg Logvinov
Ted Olsen
Glenn Parsons

Ron Peterson
Adrian Stephens
Peter Sutherland
Yatin Trivedi
Phil Winston
Don Wright
Yu Yuan

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Catherine Berger
Senior Program Manager, IEEE-SA Content Publishing

Erin Spiewak
Program Manager, IEEE-SA Technical Community

Introduction

This introduction is not part of IEEE Std 519-2014, IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems.

The uses of nonlinear loads connected to electric power systems include static power converters, arc discharge devices, saturated magnetic devices, and, to a lesser degree, rotating machines. Static power converters of electric power are the largest nonlinear loads and are used in industry for a variety of purposes, such as electrochemical power supplies, adjustable speed drives, and uninterruptible power supplies. These devices are useful because they can convert ac to dc, dc to dc, dc to ac, and ac to ac.

Nonlinear loads change the sinusoidal nature of the ac power current (and consequently the ac voltage drop), thereby resulting in the flow of harmonic currents in the ac power system that can cause interference with communication circuits and other types of equipment. These harmonic currents also lead to increased losses and heating in numerous electromagnetic devices (motors, transformers, etc.). When reactive power compensation, in the form of power factor improvement capacitors, is used, resonant conditions can occur that may result in high levels of harmonic voltage and current distortion when the resonant condition occurs at a harmonic associated with nonlinear loads.

Common sources of harmonic currents in power systems include power electronic converters, arc furnaces, static VAR systems, inverters for distributed generation, ac phase controllers, cycloconverters, and ac-dc converters (rectifiers) commonly used in switched mode power supplies and pulse width modulated (PWM) motor drives. Each of these harmonic-producing devices can have fairly consistent harmonic current emission characteristics over time or each may present a widely varying characteristic depending on the control of the device, the characteristics of the system, and other variables. This recommended practice is to be used for guidance in the design of power systems with nonlinear loads. The limits set are for steady-state operation and are recommended for “worst case” conditions. Transient conditions exceeding these limits may be encountered. In any case, the limit values given in this document are recommendations and should not be considered binding in all cases. Because of the nature of the recommendations, some conservatism is present that may not be necessary in all cases.

This recommended practice should be applied at interface points between system owners or operators and users in the power system. The limits in this recommended practice are intended for application at a point of common coupling (PCC) between the system owner or operator and a user, where the PCC is usually taken as the point in the power system closest to the user where the system owner or operator could offer service to another user. Frequently, for service to industrial users (i.e., manufacturing plants) via a dedicated service transformer, the PCC is at the HV side of the transformer. For commercial users (office parks, shopping malls, etc.) supplied through a common service transformer, the PCC is commonly at the LV side of the service transformer.

The limits in this recommended practice represent a shared responsibility for harmonic control between system owners or operators and users. Users produce harmonic currents that flow through the system owner’s or operator’s system, which lead to voltage harmonics in the voltages supplied to other users. The amount of harmonic voltage distortion supplied to other users is a function of the aggregate effects of the harmonic current producing loads of all users and the impedance characteristics of the supply system.

Harmonic voltage distortion limits are provided to reduce the potential negative effects on user and system equipment. Maintaining harmonic voltages below these levels necessitates that

- All users limit their harmonic current emissions to reasonable values determined in an equitable manner based on the inherent ownership stake each user has in the supply system and
- Each system owner or operator takes action to decrease voltage distortion levels by modifying the supply system impedance characteristics as necessary.

In order to allow the system owner or operator to control the system impedance characteristics to reduce voltage distortion when necessary, users should not add passive equipment that affects the impedance characteristic in a way such that voltage distortions are increased. In effect, such actions by a user could amount to producing excessive voltage harmonic distortion. Such passive equipment additions (that lead to undesirable system impedance characteristics) should be controlled by the user in the same manner as current harmonic-producing devices operated by the user.

Contents

1. Overview	1
1.1 Scope	2
1.2 Purpose	2
2. Normative references.....	3
3. Definitions	3
4. Harmonic measurements	4
4.1 Measurement window width.....	4
4.2 Very short time harmonic measurements	5
4.3 Short time harmonic measurements.....	5
4.4 Statistical evaluation.....	5
5. Recommended harmonic limits	5
5.1 Recommended harmonic voltage limits.....	6
5.2 Recommended current distortion limits for systems nominally rated 120 V through 69 kV.....	6
5.3 Recommended current distortion limits for systems nominally rated above 69 kV through 161 kV ..	7
5.4 Recommended current distortion limits for systems nominally rated above 161 kV	8
5.5 Recommendations for increasing harmonic current limits	9
Annex A (informative) Interharmonic voltage limits based on flicker.....	11
Annex B (informative) Telephone influence factor (TIF).....	13
Annex C (informative) Limits on commutation notches	15
Annex D (informative) Bibliography	17

IEEE Recommended Practice and Requirements for Harmonic Control in Electric Power Systems

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

The uses of nonlinear loads connected to electric power systems include static power converters, arc discharge devices, saturated magnetic devices, and, to a lesser degree, rotating machines. Static power converters of electric power are the largest nonlinear loads and are used in industry for a variety of purposes, such as electrochemical power supplies, adjustable speed drives, and uninterruptible power supplies. These devices are useful because they can convert ac to dc, dc to dc, dc to ac, and ac to ac.

Nonlinear loads change the sinusoidal nature of the ac power current (and consequently the ac voltage drop), thereby resulting in the flow of harmonic currents in the ac power system that can cause interference with communication circuits and other types of equipment. These harmonic currents also lead to increased losses and heating in numerous electromagnetic devices (motors, transformers, etc.). When reactive power compensation, in the form of power factor improvement capacitors, is used, resonant conditions can occur that may result in high levels of harmonic voltage and current distortion when the resonant condition occurs at a harmonic associated with nonlinear loads.

Common sources of harmonic currents in power systems include power electronic converters, arc furnaces, static VAR systems, inverters for distributed generation, ac phase controllers, cycloconverters, and ac-dc converters (rectifiers) commonly used in switched mode power supplies and pulse width modulated (PWM) motor drives. Each of these harmonic-producing devices can have fairly consistent harmonic current emission characteristics over time or each may present a widely-varying characteristic depending on the control of the device, the characteristics of the system, and other variables.