

Recognized as an
American National Standard (ANSI)

IEEE Std 551™-2006

IEEE Recommended Practice for Calculating Short-Circuit Currents in Industrial and Commercial Power Systems

Sponsor

Power Systems Engineering Committee
of the
IEEE Industry Applications Society

Approved 9 May 2006

IEEE-SA Standards Board

Approved 2 October 2006

American National Standards Institute

Abstract: This recommended practice provides short-circuit current information including calculated short-circuit current duties for the application in industrial plants and commercial buildings, at all power system voltages, of power system equipment that senses, carries, or interrupts short-circuit currents. Equipment coverage includes, but should not be limited to, protective device sensors such as series trips and relays, passive equipment that may carry short-circuit current such as bus, cable, reactors and transformers as well as interrupters such as circuit breakers and fuses.

Keywords: available fault current, circuit breaker, circuit breaker applications, fuse, power system voltage, reactors, short-circuit applications guides, short-circuit duties

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5197, USA

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 7 November 2006. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are registered trademarks in the U.S. Patent & Trademark Office, owned by the National Fire Protection Association.

Print: ISBN 0-7381-4932-2 SH95520
PDF: ISBN 0-7381-4933-0 SS95520

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of the IEEE Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
 Piscataway, NJ 08854
 USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 551-2006, IEEE Recommended Practice for Calculating Short-Circuit Currents in Industrial and Commercial Power Systems.

This recommended practice is intended as a practical, general treatise for engineers on the subject of ac short-circuit currents in electrical power systems. The focus of this standard is the understanding and application of analytical techniques of short-circuit analysis in industrial and commercial power systems. However, the same engineering principles apply to all electrical power systems, including utilities and systems other than 60 Hz.

More than any other book in the IEEE Color Book[®] series, the “Violet Book” covers the basics of short-circuit currents. To help the reader, the same one-line diagram that is used in several of the other color books is used in sample calculations. Items covered in the Violet Book that are not covered in the other color book chapters on short-circuit currents are the contributions of regenerative SCR drives and capacitors to faults. The reference data chapter in this recommended practice is quite extensive and should be very useful for any type of power system analysis.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.htm>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

To many members of the working group who wrote and developed the chapters in this recommended practice, the Violet Book has been a labor of love and a long time coming. Over the years, some members have come and gone, but their efforts are sincerely appreciated. To all the members past and present, many thanks for your excellent contributions.

The following working group members of the Power System Analysis Subcommittee of the Power Systems Engineering Committee of the IEEE Industry Applications Society and some non-members contributed to the existence of the Violet Book:

Jason MacDowell, *Chair (2003-2006)*

S. Mark Halpin, *Chair (2000-2003)*

L. Guy Jackson, *Chair (1998-2000)*

Conrad R. St. Pierre, *Chair (1989-1998)*

Walter C. Huening, *Chair (1965-1989)*

Chapter authors:

Chet E. Davis	Walter C. Huening	Anthony J. Rodolakis
Richard L. Doughty	Douglas M. Kaarcher	Michael A. Slonim
M. Shan Griffith	Bal K. Mathur	David H. Smith
William R. Haack	Elliot Rappaport	Conrad R. St. Pierre
Timothy T. Ho	Alfred A. Regotti	Neville A. Williams

Chapter reviewers/contributors

Michael Aimone	Robert C. Hay, Sr.	Alfred A. Regotti
Jack Alacchi	Timothy T. Ho	Michael L. Reichard
William E. Anderson	Robert G. Hoerauf	Anthony J. Rodolakis
R. Gene Baggs	Walter C. Huening	William C. Roettger
Roy D. Boyer	Guy Jackson	Vincent Saporita
Reuben Burch	Douglas M. Kaarcher	George Schliapnikoff
Bernard W. Cable	Alton C. Knight	David D. Shipp
W. Fred Carden, Jr.	John A. Kriess	Farrokh Shokooch
Hari P. S. Cheema	William Lee	Charles A. Shrive
Norman R. Conte	Jason MacDowell	Michael A. Slonim
Chet E. Davis	Bal K. Mathur	David H. Smith
Robert J. Deaton	Richard H. McFadden	J. R. Smith
Phillip C. Doolittle	Steve Miller	Gary T. Smullin
Richard L. Doughty	William J. Moylan	Conrad R. St. Pierre
James W. Felten	Russell O. Olson	Peter Sutherland
Ken Fleischer	Laurie Opper	George A. Terry
Pradit Fuanfong	Norman Peach	Lynn M. Tooman
M. Shan Griffith	David J. Podobinski	S. I. Venugopalan
William R. Haack	Louie J. Powell	Donald A. Voltz
William Hall	Ralph C. Prichard	Claus Wiig
S. Mark Halpin	Elliot Rappaport	Neville A. Williams

Acknowledgment

Appreciation is expressed to the following companies and organizations for contributing the time and in some cases expenses of the working group members and their support help to make possible the development of this text.

AVCA Corporation
Brown & Root, Inc.
CYME International, Inc.
Electrical System Analysis
General Electric Company
ICF Kaiser Engineers
Jackson & Associates
Power Technologies, Inc.

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

David Aho	Randall Groves	William Moylan
Paul Anderson	Paul Hamer	Daniel Neeser
Dick Becker	Robert Hoerauf	Kenneth Nicholson
Behdad Biglar	Ronald Hotchkiss	Lorraine Padder
Stuart Bouchey	Darin Hucul	Gene Poletto
Reuben Burch	Walter C. Huening	Louie Powell
Donald Colaberardino	Robert Ingham	Madan K. P. S. Prasad
Stephen Conrad	David Jackson	James P. Ruggieri
Stephen Dare	L. Guy Jackson	Donald Ruffman
Robert Deaton	Brian Johnson	Vincent Scaporta
Guru Dutt Dhingra	Don Koval	Robert Schuerger
Matthew Dozier	Blane Leuschner	Michael Shirven
Donald Dunn	Jason Lin	W. Jin Sim
Thomas Ernst	Gregory Luri	Harinderpal Singh
Dan Evans	William Majeski	David Singleton
Jay Fischer	L. Bruce McClung	Robert Smith
Marcel Fortin	Jeff McElroy	Gary Smullin
Carl Fredericks	Mark McCannaghan	Jane Ann Verner
Edgar Galyon	James Michael	S. Frank Waterer
George Gregory	Gary Michael	Zhenxue Xu
	T. David Mills	

The final conditions for approval of this standard were met on 9 May 2006. This standard was conditionally approved by the IEEE-SA Standards Board on 30 March 2006, with the following membership:

Steve M. Mills, *Chair*
Richard H. Hulett, *Vice Chair*
Don Wright, *Past Chair*
Judith Gorman, *Secretary*

Mark D. Bowman
Dennis B. Brophy
William R. Goldbach
Arnold M. Greenspan
Robert M. Grow
Joanna N. Guenin
Julian Forster*
Mark S. Halpin

Kenneth S. Hanus
William B. Hopf
Joseph L. Koepfinger*
David J. Law
Daleep C. Mohla
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Tom A. Prevost

Greg Ratta
Robby Robson
Anne-Marie Sahazizian
Virginia C. Sulzberger
Malcolm V. Thaden
Richard L. Townsend
Walter Weigel
Howard L. Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Alan H. Cookson, *NIST Representative*

Michael Fisher
IEEE Standards Program Manager, Document Development

Contents

Chapter 1	
Introduction	1
1.1 Scope.....	1
1.2 Definitions	2
1.3 Acronyms and abbreviations	8
1.4 Bibliography	10
1.5 Manufacturers' data sources	11
Chapter 2	
Description of a short-circuit current	13
2.1 Introduction.....	13
2.2 Available short-circuit	13
2.3 Symmetrical and asymmetrical currents.....	14
2.4 Short-circuit calculations	17
2.5 Total short-circuit current	20
2.6 Why short-circuit currents are asymmetrical.....	22
2.7 DC component of short-circuit currents	22
2.8 Significance of current asymmetry	22
2.9 The application of current asymmetry information	23
2.10 Maximum peak current.....	24
2.11 Types of faults	31
2.12 Arc resistance.....	32
2.13 Bibliography	34
Chapter 3	
Calculating techniques	37
3.1 Introduction.....	37
3.2 Fundamental principles.....	37
3.3 Short-circuit calculation procedure	42
3.4 One-line diagram	43
3.5 Per-unit and ohmic manipulations	50
3.6 Network theorems and calculation techniques	52
3.7 Extending a three-phase short-circuit calculation procedures program to calculate short-circuit currents for single-phase branches.....	67
3.8 Representing transformers with non-base voltages	69
3.9 Specific time periods and variations on fault calculations.....	78
3.10 Determination of X/R ratios for ANSI fault calculations.....	81
3.11 Three winding transformers.....	81
3.12 Duplex reactor	82
3.13 Significant cable lengths.....	83
3.14 Equivalent circuits	84
3.15 Zero sequence line representation	85
3.16 Equipment data required for short-circuit calculations	86
3.17 Bibliography	94

Chapter 4	
Calculating short-circuit currents for systems without ac delay	95
4.1 Introduction.....	95
4.2 Purpose.....	95
4.3 ANSI guidelines.....	96
4.4 Fault calculations	97
4.5 Sample calculations	98
4.6 Sample computer printout.....	103
4.7 Conclusions.....	113
4.8 Bibliography	114

Chapter 5	
Calculating ac short-circuit currents for systems with contributions from synchronous machines	115
5.1 Introduction.....	115
5.2 Purpose.....	115
5.3 ANSI guidelines.....	115
5.4 Fault calculations	116
5.5 Nature of synchronous machine contributions	119
5.6 Synchronous machine reactances	119
5.7 One-line diagram data.....	121
5.8 Sample calculations	121
5.9 Sample computer printout.....	123
5.10 Sample computer printout for larger system calculation	124
5.11 Conclusions.....	126
5.12 Bibliography	126

Chapter 6	
Calculating ac short-circuit currents for systems with contributions from induction motors	127
6.1 Introduction.....	127
6.2 Purpose.....	127
6.3 ANSI guidelines.....	127
6.4 Fault calculations	129
6.5 Nature of induction motor contributions	129
6.6 Large induction motors with prolonged contributions	132
6.7 Data accuracy.....	133
6.8 Details of induction motor contribution calculations according to ANSI standard application guides.....	133
6.9 Recommended practice based on ANSI-approved standards for representing induction motors in multivoltage system studies	135
6.10 One-line diagram data.....	137
6.11 Sample calculations	138
6.12 Sample computer printout.....	142
6.13 Bibliography	145

Chapter 7	
Capacitor contributions to short-circuit currents	147
7.1 Introduction.....	147
7.2 Capacitor discharge current	147
7.3 Transient simulations	149
7.4 Summary	165
7.5 Bibliography	165
Chapter 8	
Static converter contributions to short-circuit currents.....	167
8.1 Introduction.....	167
8.2 Definitions of converter types.....	167
8.3 Converter circuits and their equivalent parameters	168
8.4 Short-circuit current contribution from the dc system to an ac short circuit.....	170
8.5 Analysis of converter dc faults	176
8.6 Short circuit between the converter dc terminals.....	177
8.7 Arc-back short circuits.....	187
8.8 Examples.....	19
8.9 Conclusions.....	1
8.10 Bibliography	197
Chapter 9	
Calculating ac short-circuit currents in accordance with ANSI-approved standards	199
9.1 Introduction.....	199
9.2 Basic assumptions and system modeling.....	199
9.3 ANSI recommended practice for ac decrement modeling.....	200
9.4 ANSI practice for dc decrement modeling	204
9.5 ANSI-conformable fault calculations	212
9.6 ANSI-approved standards and interrupting duties.....	214
9.7 One-line diagram layout and data	216
9.8 First cycle duty sample calculations	219
9.9 Interrupting duty sample calculations.....	223
9.10 Applying ANSI calculation to non-60 Hz systems	228
9.11 Normative references	229
9.12 Bibliography	230
Chapter 10	
Application of short-circuit interrupting equipment.....	231
10.1 Introduction	231
10.2 Purpose.....	231
10.3 Application considerations	231
10.4 Equipment data	233
10.5 Fully rated systems	234
10.6 Low voltage series rated equipment	234
10.7 Low voltage circuit breaker short-circuit capabilities less than rating	235
10.8 Equipment checklist for short-circuit currents evaluation.....	236

10.9 Equipment phase duty calculations	237
10.10 Equipment ground fault duty calculations.....	245
10.11 Capacitor Switching	245
10.12 Normative references	246
 Chapter 11	
Unbalanced short-circuit currents	249
11.1 Introduction	249
11.2 Purpose	249
11.3 ANSI guidelines	250
11.4 Procedure	251
11.5 Connection of sequence networks	257
11.6 Sample calculations	258
11.7 Conclusions	271
11.8 Bibliography	271
 Chapter 12	
Short-circuit calculations unser international standards	273
12.1 Introduction	273
12.2 System modeling and methodologies.....	273
12.3 Voltage factors	275
12.4 Short circuit currents per IEC 60909.....	275
12.5 Short circuits “far from generator”	276
12.6 Short circuits “near generator”	281
12.7 Influence of the motors.....	290
12.8 Fault calculations in complex systems.....	292
12.9 Comparing the ANSI-approved standards with IEC 909.....	292
12.10 Sample calculations.....	293
12.11 Normative references	299
12.12 Bibliography.....	300

IEEE Recommended Practice for Calculating Short-Circuit Currents in Industrial and Commercial Power Systems

Chapter 1 Introduction

1.1 Scope

Electric power systems in industrial plants and commercial and institutional buildings are designed to serve loads in a safe and reliable manner. One of the major considerations in the design of a power system is adequate control of short circuits or faults as they are commonly called. Uncontrolled short-circuits can cause service outage with accompanying production downtime and associated inconvenience, interruption of essential facilities or vital services, extensive equipment damage, personnel injury or fatality, and possible fire damage.

Short-circuits are caused by faults in the insulation of a circuit, and in many cases an arc ensues at the point of the fault. Such an arc may be destructive and may constitute a fire hazard. Prolonged duration of arcs, in addition to the heat released, may result in transient overvoltages that may endanger the insulation of equipment in other parts of the system. Clearly, the fault must be quickly removed from the power system, and this is the job of the circuit protective devices—the circuit breakers and fusible switches.

A short-circuit current generates heat that is proportional to the square of the current magnitude, I^2R . The large amount of heat generated by a short-circuit current may damage the insulation of rotating machinery and apparatus that is connected into the faulted system, including cables, transformers, switches, and circuit breakers. The most immediate danger involved in the heat generated by short-circuit currents is permanent destruction of insulation. This may be followed by actual fusion of the conducting circuit, with resultant additional arcing faults.

The heat that is generated by high short-circuit currents tends not only to impair insulating materials to the point of permanent destruction, but also exerts harmful effects upon the contact members in interrupting devices.

The small area common between two contact members that are in engagement depends mainly upon the hardness of the contact material and upon the amount of pressure by which they are kept in engagement. Owing to the concentration of the flow of current at the points of contact engagement, the temperatures of these points reached at the times of peak current are very high. As a result of these high spot temperatures, the material of which the contact members are made may soften. If, however, the contact material is caused to melt by excessive I^2R losses, there is an imminent danger of welding the contacts together rendering it impossible to separate the contact members when the switch or circuit breaker is called upon to open the circuit. Since it requires very little time to establish thermal equilibrium at the small points of contact engagement, the temperature at these points depends more upon the peak current than upon the rms current. If the peak current is sufficient to cause the contact material to melt, resolidification may occur immediately upon decrease of the current from its peak value.

Other important effects of short-circuit currents are the strong electromagnetic forces of attraction and repulsion to which the conductors are subjected when short-circuit currents are present. These forces are proportional to the square of the current and may subject any rotating machinery, transmission, and switching equipment to severe mechanical stresses and strains. The strong electromagnetic forces that high short-circuit currents exert upon equipment can cause deformation in rotational machines, transformer windings, and equipment bus bars, which may fail at a future time. Deformation in breakers and switches will cause alignment and interruption difficulties.

Modern interconnected systems involve the operation in parallel of large numbers of synchronous machines, and the stability of such an interconnected system may be greatly impaired if a short-circuit in any part of the system is allowed to prevail. The stability of a system requires short fault clearing times and can be more limiting than the longer time considerations imposed by thermal or mechanical effects on the equipment.

1.2 Definitions

For the purpose of this document, the following terms and definitions apply. *The Authoritative Dictionary of IEEE Standards Terms* [B3]¹ should be referenced for terms not defined in this clause.

1.2.1 30 cycle time: The time interval between the time when the actuating quantity of the release circuit reaches the operating value, and the approximate time when the primary arcing contacts have parted. The time period considers the ac decaying component of a fault current to be negligible.

¹The numbers in brackets correspond to those of the bibliography in 1.4.

1.2.2 arcing time: The interval of time between the instant of the first initiation of the arc and the instant of final arc extinction in all poles.

1.2.3 armature: The main current carrying winding of a machine, usually the stator.

1.2.4 armature resistance: R_a —The direct current armature resistance. This is determined from a dc resistance measurement. The approximate effective ac resistance is $1.2R_a$.

1.2.5 asymmetrical current: The combination of the symmetrical component and the direct current component of the current.

1.2.6 available current: The current that would flow if each pole of the breaking device under consideration were replaced by a link of negligible impedance without any change of the circuit or the supply.

1.2.7 breaking current: The current in a pole of a switching device at the instant of the arc initiation. Better known as *interrupting current*.

1.2.8 circuit breaker: A switching device capable of making, carrying, and breaking currents under normal circuit conditions and also making, carrying for a specified time, and breaking currents under specified abnormal conditions such as those of short circuit.

1.2.9 clearing time: The total time between the beginning of specified overcurrent and the final interruption of the circuit at rated voltage. In regard to fuses, it is the sum of the minimum melting time of a fuse plus tolerance and the arcing time. In regard to breakers under 1000 V, it is the sum of the sensor time, plus opening time and the arcing time. For breakers rated above 1000 V, it is the sum of the minimum relay time (usually 1/2 cycle), plus contact parting time and the arcing time. Sometimes referred to as *total clearing time* or *interrupting time*.

1.2.10 close and latch: The capability of a switching device to close (allow current flow) and immediately thereafter latch (remain closed) and conduct a specified current through the device under specified conditions.

1.2.10.1 close and latch duty: The maximum rms value of calculated short-circuit current for medium- and high-voltage circuit breakers during the first cycle with any applicable multipliers for fault current X/R ratio. Often the close and latching duty calculation is simplified by applying a 1.6 factor to the calculated breaker first cycle symmetrical ac rms short-circuit current. Also called first cycle duty (formerly, momentary duty).

1.2.10.2 close and latch rating: The maximum current capability of a medium or high-voltage circuit breaker to close and immediately thereafter latching closed for normal-frequency making current. The close and latching rating is 1.6 times the breaker rated maximum symmetrical interrupting current in ac rms amperes or a peak current that is 2.7 times ac rms rated maximum symmetrical interrupting current. Also called first cycle rating (formerly, momentary rating).

1.2.11 contact parting time: The interval between the time when the actuating quantity in the release circuit reaches the value causing actuation of the release and the instant when the primary arcing contacts have parted in all poles. Contact parting time is the numerical sum of release delay and opening time.

1.2.12 crest current: The highest instantaneous current during a period. *Syn:* **peak current.**

1.2.13 direct axis: The machine axis that represents a plane of symmetry in line with the no-load field winding.

1.2.14 direct axis subtransient reactance: X''_{dv} (saturated, rated voltage) is the apparent reactance of the stator winding at the instant short-circuit occurs with the machine at rated voltage, no load. This reactance determines the current flow during the first few cycles after short-circuit.

1.2.15 direct axis subtransient reactance: X''_{di} (unsaturated, rated current) is the reactance that is determined from the ratio of an initial reduced voltage open circuit condition and the currents from a three-phase fault at the machine terminals at rated frequency. The initial open-circuit voltage is adjusted so that rated current is obtained. The impedance is determined from the currents during the first few cycles.

1.2.16 direct axis transient reactance: X'_{dv} (saturated, rated voltage) is the apparent reactance of the stator winding several cycles after initiation of the fault with the machine at rated voltage, no load. The time period for which the reactance may be considered X'_{dv} can be up to a half (1/2) second or longer, depending upon the design of the machine and is determined by the machine direct-axis transient time constant.

1.2.17 direct axis transient reactance: X'_{di} (unsaturated, rated current) is the reactance that is determined from the ratio of an initial reduced voltage open circuit condition and the currents from a three-phase fault at the machine terminals at rated frequency. The initial open-circuit voltage is adjusted so that rated current is obtained. The initial high decrement currents during the first few cycles are neglected.

1.2.18 fault: A current that flows from one conductor to ground or to another conductor owing to an abnormal connection (including an arc) between the two. *Syn:* **short circuit.**

1.2.19 fault point angle: The calculated fault point angle ($\tan^{-1}(X/R$ ratio) using complex ($R + jX$) reactance and resistance networks for the X/R ratio.

1.2.20 fault point X/R : The calculated fault point X/R ratio using separate reactance and resistance networks.

1.2.21 field: The exciting or magnetizing winding of a machine.

1.2.22 first cycle duty: The maximum value of calculated short-circuit current for the first cycle with any applicable multipliers for fault current X/R ratio.

1.2.23 first cycle rating: The maximum current capability of a piece of equipment during the first cycle of a fault.

1.2.24 frequency: The rated frequency of a circuit.

1.2.25 fuse: A device that protects a circuit by melting open its current-carrying element when an overcurrent or short-circuit current passes through it.

1.2.26 high voltage: Circuit voltages over nominal 34.5 kV.

NOTE—ANSI standards are not unanimous in establishing the threshold of “high-voltage.”²

1.2.27 impedance: The vector sum of resistance and reactance in an ac circuit.

1.2.28 interrupting current: The current in a pole of a switching device at the instant of the arc initiation. Sometime referred to as *breaking current*.

1.2.29 interrupting time: The interval between the time when the actuating device “sees” or responds to a operating value, the opening time and arcing time. Sometimes referred to as *total break time* or *clearing time*.

1.2.30 low voltage: Circuit voltage under 1000 V.

1.2.31 maximum rated voltage: The upper operating voltage limit for a device.

1.2.32 medium voltage: Circuit voltage greater than 1000 V up to and including 34.5 kV.

NOTE—ANSI standards are not unanimous in establishing the threshold of “high-voltage.”

1.2.33 minimum rated voltage: The lower operating voltage limit for a device where the rated interrupting current is a maximum. Operating breakers at voltages lower than minimum rated voltage restricts the interrupting current to maximum rated interrupting current.

1.2.34 momentary current rating: The maximum rms current measured at the major peak of the first cycle, which the device or assembly is required to carry. Momentary rating was used on medium- and high-voltage breakers manufactured before 1965. See presently used terminology of **close and latch rating**.

1.2.35 momentary current duty: See presently used terminology of **close and latch duty**. Used for medium- and high-voltage breaker duty calculations for breakers manufactured before 1965.

1.2.36 negative sequence: A set of symmetrical components that have the angular phase lag from the first member of the set to the second and every other member of the set equal to the characteristic angular phase difference and rotating in the reverse direction of the

²Notes in text, tables, and figures are given for information only and do not contain requirements needed to implement the standard.

original vectors. For a three-phase system, the angular different is 120 degrees. *See also: symmetrical components.*

1.2.37 negative sequence reactance: X_{2v} (saturated, rated voltage). The rated current value of negative-sequence reactance is the value obtained from a test with a fundamental negative-sequence current equal to rated armature current (of the machine). The rated voltage value of negative-sequence reactance is the value obtained from a line-to-line short-circuit test at two terminals of the machine at rated speed, applied from no load at rated voltage, the resulting value being corrected when necessary for the effect of harmonic components in the current.

1.2.38 offset current: A current waveform whose baseline is offset from the ac symmetrical current zero axis.

1.2.39 opening time: The time interval between the time when the actuating quantity of the release circuit reaches the operating value, and the instant when the primary arcing contacts have parted. The opening time includes the operating time of an auxiliary relay in the release circuit when such a relay is required and supplied as part of the switching device.

1.2.40 peak current: The highest instantaneous current during a period.

1.2.41 positive sequence: A set of symmetrical components that have the angular phase lag from the first member of the set to the second and every other member of the set equal to the characteristic angular phase difference and rotating in the same phase sequence of the original vectors. For a three-phase system, the angular different is 120 degrees. *See also: symmetrical components.*

1.2.42 positive sequence machine resistance: R_1 is that value of rated frequency armature resistance that, when multiplied by the square of the rated positive-sequence armature current and by the number of phases, is equal to the sum of the copper loss in the armature and the load loss resulting from the flow of that current. This is **NOT** the resistance to be used for the machine in short-circuit calculations.

1.2.43 quadrature axis: The machine axis that represents a plane of symmetry in the field that produces no magnetization. This axis is 90 degrees ahead of the direct axis.

1.2.44 quadrature axis subtransient reactance: X''_{qv} (saturated, rated voltage) same as X''_{dv} except in quadrature axis.

1.2.45 quadrature axis subtransient reactance: X''_{qi} (unsaturated, rated current) same as X''_{di} except in quadrature axis.

1.2.46 quadrature axis transient reactance: X_q (unsaturated, rated current) is the ratio of reactive armature voltage to quadrature-axis armature current at rated frequency and voltage.

1.2.47 quadrature axis transient reactance: X'_{qv} (saturated, rated voltage) same as X'_{dv} except in q quadrature axis.

1.2.48 quadrature axis transient reactance: X'_{qi} (unsaturated, rated voltage) same as X'_{di} except in quadrature axis.

1.2.49 rating: The designated limit(s) of the operating characteristic(s) of a device. This data is usually on the device nameplate.

1.2.50 rms: The square root of the average value of the square of the voltage or current taken throughout one period. In this text, rms will be considered total rms unless otherwise noted.

1.2.51 rms ac: The square root of the average value of the square of the ac voltage or current taken throughout one period.

1.2.52 rms, single cycle: *See: single-cycle rms.*

1.2.53 rms, total: *See: total rms.*

1.2.54 rotor: The rotating member of a machine.

1.2.55 short circuit: An abnormal connection (including arc) of relative low impedance, whether made accidentally or intentionally, between two points of different potentials.
Syn: fault.

1.2.56 short-circuit duty: The maximum value of calculated short-circuit current for either first cycle current or interrupting current with any applicable multipliers for fault current X/R ratio or decrement.

1.2.57 single-cycle rms: The square root of the average value of the square of the ac voltage or current taken throughout one ac cycle.

1.2.58 stator: The stationary member of a machine.

1.2.59 symmetrical: That portion of the total current that, when viewed as a waveform, has equal positive and negative values over time such as is exhibited by a pure single-frequency sinusoidal waveform

1.2.60 symmetrical components: A symmetrical set of three vectors used to mathematically represent an unsymmetrical set of three-phase voltages or currents. In a three-phase system, one set of three equal magnitude vectors displaced from each other by 120 degrees in the same sequence as the original set of unsymmetrical vectors. This set of vectors is called the positive sequence component. A second set of three equal magnitude vectors displaced from each other by 120 degrees in the reverse sequence as the original set of unsymmetrical vectors. This set of vectors is called the negative sequence component. A third set of three equal magnitude vectors displaced from each other by 0 degrees. This set of vectors is called the zero sequence component.

1.2.61 synchronous reactance: Direct axis X_d (unsaturated, rated current) is the self reactance of the armature winding to the steady-state balanced three-phase positive-sequence current at rated frequency and voltage in the direct axis. It is determined from an initial open-circuit voltage and a sustained short circuit on the a synchronous machine terminals.

1.2.62 three-phase open circuit time constant: T_{a3} is the time constant representing the decay of the machine currents to a suddenly applied three-phase short-circuit to the terminals of a machine.

1.2.63 total break time: The interval between the time when the actuating quantity of the release circuit reaches the operating value, the switching device being in a closed position, and the instant of arc extinction on the primary arcing contacts. Total break time is equal to the sum of the opening time and arcing time. Better known as **interrupting time**.

1.2.64 total clearing time: *See:* **clearing time** or **interrupting time**.

1.2.65 total rms: The square root of the average value of the square of the ac and dc voltage or current taken throughout one period.

1.2.66 voltage, high: *See:* **high voltage**.

1.2.67 voltage, low: *See:* **low voltage**.

1.2.68 voltage, medium: *See:* **medium voltage**.

1.2.69 voltage range factor: The voltage range factor, K , is the range of voltage to which the breaker can be applied where EI equals a constant. K equals the maximum rated operating voltage divided by the minimum rated operating voltage.

1.2.70 X/R ratio: The ratio of rated frequency reactance and effective resistance to be used for short-circuit calculations. Approximately equal to $X_{2v}/1.2R_a$ or $2fT_{a3}$.

1.2.71 zero sequence: A set of symmetrical components that have the angular phase lag from the first member of the set to the second and every other member of the set equal to zero (0) degrees and rotating in the same direction as the original vectors. *See also:* **symmetrical components**.

1.3 Acronyms and abbreviations

The following are the symbols and their definitions that are used in this book.

- a symmetrical component operator = 120 degrees
- e instantaneous voltage
- e_0 initial voltage

INTRODUCTION

E	rms voltage
E_{\max}	peak or crest voltage
E_{LN}	rms line-to-neutral voltage
E_{LL}	rms line-to-line voltage
f	frequency in Hertz
i	instantaneous current
i_{dc}	instantaneous dc current
i_{ac}	instantaneous ac current
I	rms current
I_{\max}	peak or crest current
$I_{\max,s}$	symmetrical peak current
$I_{\max,ds}$	decaying symmetrical peak current
I'	rms transient current
I''	rms subtransient current
I'_{dd}	interrupting duty current
I''_{dd}	first cycle duty current
I_{SS}	rms steady state current
j	90 degree rotative operator, imaginary unit
L	inductance
Q	electric charge
R	resistance
R_a	armature resistance
t	time
T_{a3}	three-phase open-circuit time constant

X	reactance
X_d'	transient direct-axis reactance
X_d''	subtransient direct-axis reactance
X_q'	transient quadrature-axis reactance
X_q''	subtransient quadrature-axis reactance
X_{2v}	negative sequence rated voltage
Z	impedance: $Z = R + jX$
α	$\tan^{-1}(\omega L/R = \tan^{-1}(X/R)$
ϕ	phase angle
ω	angular frequency $\omega = 2\pi f$
τ	intermediate time
θ	phase angle difference

1.4 Bibliography

The IEEE publishes several hundred standards documents covering various fields of electrical engineering. Appropriate IEEE standards are routinely submitted to the American National Standards Institute (ANSI) for consideration as ANSI-approved standards. Standards that have also been submitted and approved by the Canadian Standards Association carry CSA letters. Basic standards of general interest include the following:

[B1] ANSI/IEEE Std 91TM-1984, IEEE Standard Graphic Symbols for Logic Diagrams.³

[B2] ANSI 268-1992, American National Standard Metric Practice.

[B3] IEEE 100, *The Authoritative Dictionary of IEEE Standards Terms*, Seventh Edition.^{4, 5}

³ANSI publications are available from the Sales Department, American National Standards Institute, 25 West 43rd Street, 4th Floor, New York, NY 10036, USA (<http://www.ansi.org/>).

⁴IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA (<http://standards.ieee.org/>).

⁵The IEEE standards or products referred to in this clause are trademarks of the Institute of Electrical and Electronics Engineers, Inc.

[B4] IEEE Std 260.1TM-2004, IEEE Standard Letter Symbols for Units of Measurement (SI Units, Customary Inch-Pound Units, and Certain Other Units).

[B5] IEEE Std 280TM-1985 (Reaff 2003), IEEE Standard Letter Symbols for Quantities Used in Electrical Science and Electrical Engineering.

[B6] IEEE Std 315TM-1975 (Reaff 1993)/ANSI Y32.2-1975 (Reaff 1989) (CSA Z99-1975), IEEE Standard for Graphic Symbols for Electrical and Electronics Diagrams.

The IEEE publishes several standards documents of special interest to electrical engineers involved with industrial plant electric systems, which are sponsored by the Power Systems Engineering Committee of the IEEE Industry Applications Society:

[B7] IEEE Std 141TM-1993, IEEE Recommended Practice for Electric Power Distribution of Industrial Plants (*IEEE Red Book*).

[B8] IEEE Std 142TM-1991, IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems (*IEEE Green Book*).

[B9] IEEE Std 241TM-1990, IEEE Recommended Practice for Electric Power Systems in Commercial Buildings (*IEEE Gray Book*).

[B10] IEEE Std 242TM-2001, IEEE Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems (*IEEE Buff Book*).

[B11] IEEE Std 399TM-1997, IEEE Recommended Practice for Power Systems Analysis (*IEEE Brown Book*).

[B12] IEEE Std 446TM-1995, IEEE Recommended Practice for Emergency and Standby Power Systems for Industrial and Commercial Applications (*IEEE Orange Book*).

[B13] IEEE Std 493TM-1997, IEEE Recommended Practice for the Design of Reliable Industrial and Commercial Power Systems (*IEEE Gold Book*).

[B14] IEEE Std 602TM-1996, IEEE Recommended Practice for Electric Systems in Health Care Facilities (*IEEE White Book*).

[B15] IEEE Std 739TM-1995, IEEE Recommended Practice for Energy Management in Industrial and Commercial Facilities (*IEEE Bronze Book*).

[B16] IEEE Std 1100TM-2005, IEEE Recommended Practice for Powering and Grounding Sensitive Electronic Equipment (*IEEE Emerald Book*).

1.5 Manufacturers' data sources

The last chapter in this reference book contains a collection of data from various manufacturers. While reasonable care was used compile this data, equipment with the

same identification and manufactured during different periods may have different ratings. The equipment nameplate is the best source of data and may require obtaining the serial number and contacting the manufacturer.

The electrical industry, through its associations and individual manufacturers of electrical equipment, issues many technical bulletins and data books. While some of this information is difficult for the individual to obtain, copies should be available to each major design unit. The advertising sections of electrical magazines contain excellent material, usually well-illustrated and presented in a clear and readable form, concerning the construction and application of equipment. Such literature may be promotional; it may present the advertiser's equipment or methods in a best light and should be carefully evaluated. Manufacturers' catalogs are a valuable source of equipment information. Some of the larger manufacturers' complete catalogs are very extensive, covering dozens of volumes; however, these companies may issue abbreviated or condensed catalogs that are adequate for most applications. Data sheets referring to specific items are almost always available from the sales offices. Some technical files may be kept on microfilm at larger design offices for use either by projection or by printing. Manufacturers' representatives, both sales and technical, can do much to provide complete information on a product.

Chapter 2

Description of a short-circuit current

2.1 Introduction

Electric power systems are designed to be as fault-free as possible through careful system and equipment design, proper equipment installation and periodic equipment maintenance. However, even when these practices are used, faults do occur. Some of the causes of faults are as follows:

- a) Presence of animals in equipment
- b) Loose connections causing equipment overheating
- c) Voltage surges
- d) Deterioration of insulation due to age
- e) Voltage or mechanical stresses applied to the equipment
- f) Accumulation of moisture and contaminants
- g) The intrusion of metallic or conducting objects into the equipment such as grounding clamps, fish tape, tools, jackhammers or pay-loaders
- h) A large assortment of “undetermined causes”

When a short-circuit occurs in a electric power distribution system, several things can happen, such as the following:

- 1) The short-circuit currents may be very high, introducing a significant amount of energy into the fault.
- 2) At the fault location, arcing and burning can occur damaging adjacent equipment and also possibly resulting in an arc-flash burn hazard to personnel working on the equipment.
- 3) Short-circuit current may flow from the various rotating machines in the electrical distribution system to the fault location.
- 4) All components carrying the short-circuit currents will be subjected to thermal and mechanical stresses due to current flow. This stress varies as a function of the magnitude of the current squared and the duration of the current flow (I^2t) and may damage these components.
- 5) System voltage levels drop in proportion to the magnitude of the short-circuit currents flowing through the system elements. Maximum voltage drop occurs at the fault location (down to zero for a bolted fault), but all parts of the power system will be subject to a voltage drop to some degree.

2.2 Available short-circuit current

The “available” short-circuit current is defined as the maximum possible value of short-circuit current that may occur at a particular location in the distribution system assuming that no fault related influences, such as fault arc impedances, are acting to reduce the fault current. The available short-circuit current is directly related to the size and capacity of the