

National Electrical Safety Code®

Secretariat

Institute of Electrical and Electronics Engineers, Inc.

Approved 15 March 1996

Institute of Electrical and Electronics Engineers, Inc.

Approved 6 June 1996

American National Standards Institute

1997 Edition

Abstract: This standard covers basic provisions for safeguarding of persons from hazards arising from the installation, operation, or maintenance of 1) conductors and equipment in electric supply stations, and 2) overhead and underground electric supply and communication lines. It also includes work rules for the construction, maintenance, and operation of electric supply and communication lines and equipment.

The standard is applicable to the systems and equipment operated by utilities, or similar systems and equipment, of an industrial establishment or complex under the control of qualified persons.

This standard consists of the introduction, definitions, grounding rules, list of referenced and bibliographic documents, and Parts 1, 2, 3, and 4 of the 1997 Edition of the National Electrical Safety Code.

Keywords: communications industry safety; construction of communication lines; construction of electric supply lines; electric supply stations, electric utility stations, electrical safety; high-voltage safety; operation of communications systems; operation of electric supply systems; power station equipment; power station safety; public utility safety; safety work rules; underground communication line safety; underground electric line safety

The Institute of Electrical and Electronics Engineers, Inc.
345 East 47th Street, New York, NY 10017-2394, USA

Copyright © 1996 by the
Institute of Electrical and Electronics Engineers, Inc.

All rights reserved. Published 1996
Printed in the United States of America

National Electrical Safety Code® and NESCC® are registered trademarks and
service marks of the Institute of Electrical and Electronics Engineers, Inc.
The NESCC logo is a trademark the Institute of Electrical and Electronics Engineers.

The National Electrical Code® and NEC® are registered trademarks of
the National Fire Protection Association.

ISBN 1-55937-715-1

*Public authorities are granted permission to republish the material
herein in laws, regulations, administrative orders, ordinances, or
similar documents. No other party may reproduce in any form, in an
electronic retrieval system or otherwise, any portion of this document,
without the prior written permission of the publisher.*

Recognized as an
American National Standard

An American National Standard implies a consensus of those substantially concerned with its scope and provisions. An American National Standard is intended as a guide to aid the manufacturer, the consumer, and the general public. The existence of an American National Standard does not in any respect preclude anyone, whether he has approved the standard or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standard. American National Standards are subject to periodic review and users are cautioned to obtain the latest editions.

Currently in preview, click buy full version

Dedication

Joseph M. Van Name, P. E.

2 January 1926—29 May 1995

This edition of the National Electrical Safety Code is dedicated to the memory of Joseph M. Van Name, P. E., Chair of NESC Subcommittee 8 for three Code editions, and pivotal contributor to electric power supply safety. Van Name is considered the father of modern live-line maintenance and working methods. His broad experience, great wisdom, and clear vision guided many areas of power industry standardization, education, development, and research. NESC colleagues and friends fondly acknowledge his profound and positive influence of electric power supply safety worldwide.

This dedication recognizes that the electrical standards community, electrical workers, and the public receive continuing benefit from the remarkable life and career of Joseph M. Van Name.

Currently in preview, click buy full version

Foreword

(This foreword is not a part of Accredited Standards Committee C2-1997, National Electrical Safety Code®.)

This publication consists of the parts of the National Electrical Safety Code® (NESC®) currently in effect. The former practice of designating parts by editions has not been practical for some time. In the 1977 Edition, Parts 1 and 4 were 6th Editions; Part 2 was a 7th Edition; Part 3, a revision of the 6th Edition; Part 2, Section 29, did not cover the same subject matter as the 5th Edition; and Part 3 had been withdrawn in 1970. In the 1987 Edition, revisions were made in all parts and revisions to all parts have been made in subsequent editions. It is therefore recommended that reference to the NESC be made solely by the year of the published volume and desired part number. Separate copies of the individual parts are not available.

Work on the NESC started in 1913 at the National Bureau of Standards (NBS), resulting in the publication of NBS Circular 49. The last complete edition of the Code (the 5th Edition, NBS Handbook H37) was issued in 1948, although separate portions had been available at various times starting in 1938. Part 2—*Definitions*, and the *Grounding Rules*, 6th Edition, were issued as NBS Handbook H81, ANSI C2.2-1960, in November 1961, but work on other parts was not actively in process again until 1970.

In 1970 the C2 Committee decided to delete the *Rules for the Installation and Maintenance of Electric Utilization Equipment* (Part 3 of the 5th Edition), now largely covered by the National Electrical Code (ANSI/NFPA 70), and the *Rules for Radio Installations* (Part 5 of the 5th Edition) from future editions. The Discussion of the NESC, issued as NBS Handbook H4 (1928 Edition) for the 4th Edition of the NESC, and as NBS Handbook H39 for Part 2 of the *Grounding Rules* of the 5th Edition, was not published for the 6th Edition.

The 1981 Edition included major changes in Parts 1, 2, and 3, minor changes in Part 4, and the incorporation of the rules common to all parts into Section 1. The 1984 Edition was revised to update all references and to list those references in a new Section 3. Rounded metric values, for information only, were added. Gender-related terminology was deleted. Sections 1—*Introduction*, 2—*Definitions*, 3—*References*, and 9—*Grounding Methods*, were made applicable to each of the Part 1, 2, 3, and 4.

The 1987 Edition was revised extensively. Definitions were changed or added. Requirements affecting grounding methods, electric supply stations, overhead line clearances and loading, underground lines, and work rules were revised.

The 1990 Edition included several major changes. General rules were revised. A significant change to the method for specifying overhead line clearance was made and the rationale added as Appendix A. Requirements for clearances of overhead lines from grain bins and an alternate method for determining the strength requirements for wood structures were added. Rules covering grounding methods, electric supply stations, underground lines, and work rules were changed.

In the 1993 Edition, changes were made in the rules applicable to emergency and temporary installations. In Section 9 and Parts 1, 2, and 3, rules were extended or clarified to include HVDC systems. The requirements for random separation of direct-buried supply and communication systems were modified for consistency and clarity, as was the rule in Part 4 on tagging electric supply circuits.

For 1997, several changes were made that affected all or several parts of the Code. The most significant of these, which is stated in Section 1, is to show numerical values in the metric (SI) system first, with the customary inch-foot-pound values (inside parentheses) following.

The second general change was the addition of NOTES referring to several ANSI standards on safety signs.

Finally, in order to reduce the probability of misinterpretation, words such as “minimize the possibility” or “prevent” were changed to “limit the likelihood” or similar language. One exception to this type of change is in Part 4.

In Section 2, definitions of several items related to worker safety, and a definition of limited access highways, were added. The definition of a generating station was changed and relocated as one type of an electric supply station.

The list of references in Section 3 was reorganized and revised so as to include only documents referred to in one or more sections of the Code.

In Section 9—*Grounding Methods*, changes were made in rules affecting the grounding of fences so as to state only the methods of grounding to be used when the grounding of fences is required by other parts of the Code. The wording of rules affecting Ampacity and Strength Underground Installations, Separation of Grounding Conductors, and Communication Apparatus was changed for clarity.

In Section 9 and Parts 1 and 2, rules were extended or clarified to include HVDC Systems.

In Part 1—*Electric Supply Stations*, requirements for a safety clearance zone for fences relative to exposed live parts were added. In most cases, requirements copied from the National Electrical Code[®], NFPA 70 were replaced by direct references to the applicable rules of the NEC document. A requirement for short circuit protection of power transformers was added.

In Part 2—*Overhead Lines*, changes were made to the clearance rules applicable to emergency and temporary installations to allow for the proper choice of methods for assuring safety. Footnotes to several tables regarding the requirements applicable to ungrounded guys and ungrounded portions of span guys were added, as were clearance requirements for unguarded rigid live parts over or near swimming pools. Clearance requirements between different facilities located on the same structure were changed. Strength requirements contained in Sections 24, 25, and 26 were revised completely.

In Part 3—*Underground Lines*, the requirements for random separation of direct-buried supply and communication cables were modified with respect to sequential marking of the identification symbol with other data on the cable. A requirement for a continuous metallic shield for some communication cables was added.

In Part 4—*Work Rules*, a requirement that warning signs and tags comply with the provisions of applicable ANSI standards, and extensive requirements for fall protection were added. The rule on tagging electric supply circuits was revised to clarify its application to Supervisory Control and Data Acquisition (SCADA) Systems.

A bibliography, Appendix B, was added to this edition, which consists of a list of resources identified in notes or recommendations. Only those sources identified in rules are included in the references of Section 3.

Substantive changes in the 1997 edition are identified by a bar in the left-hand margin. In several cases, rules have been relocated without substantive changes in the wording. In these cases, only the rule numbers have been indicated as having been changed.

The Institute of Electrical and Electronics Engineers, Inc. was designated as the administrative secretariat for C2 in January 1973, assuming the functions formerly performed by the National Bureau of Standards.

Comments on the rules and suggestions for their improvement are invited, especially from those who have experience in their practical application. In future editions every effort will be made to improve the rules, both in the adequacy of coverage and in the clarification of requirements. Comments should be addressed to:

Secretary
National Electrical Safety Code Committee
Institute of Electrical and Electronics Engineers, Inc.
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331

A representative Committee on Interpretations has been established to prepare replies to requests for interpretation of the rules contained in the Code. Requests for interpretation should state the rule in question as well as the conditions under which it is being applied. Interpretations are intended to clarify the intent of specific rules and are not intended to supply consulting information on the application of the Code. Requests for interpretation should be sent to the address above.

If the request is suitable for processing, it will be sent to the Interpretations Committee. After consideration by the committee, which may involve many exchanges of correspondence, the inquirer will be notified of its decision. Decisions are published regularly and may be ordered.

The NESC as written is a voluntary standard. However, some editions and some parts of the Code have been adopted, with and without changes, by some state and local jurisdictional authorities. To determine the legal status of the National Electrical Safety Code in any particular state or locality within a state, the authority having jurisdiction should be contacted.

Standards Committee Membership

At the time this Code was approved, Accredited Standards Committee C2 had the following membership:

O. Chuck Amrhyn, Chair

Frank A. Denbrock, Vice Chair

Susan L. Vogel, Secretary

| <i>Organization Represented</i> | <i>Name</i> |
|--|--|
| Alliance for Telephone Industry Solutions | R. E. Williams O. J. Gusella (Alt.) |
| American Insurance Services Group, Inc. | Edward S. Chaffey |
| American Public Power Association | Wayne B. Pelle K. J. Conner (Alt.) |
| American Public Transit Association | G. S. Pristach |
| Association of American Railroads | L. W. Etter |
| Association of Edison Illuminating Companies | J. J. Schlee, Jr. |
| Bonneville Power Administrations Department of Energy | Jerry L. Reding |
| Edison Electric Institute | Stephen A. Olinick Gary N. Miller (Alt.) John W. Troglia (Alt.) David G. Komassa (Alt.) |
| Electronic Industries Association | Percy Pool |
| Institute of Electrical and Electronics Engineers, Inc. | Frank A. Denbrock J. G. Hanson (Alt.) Vernon R. Lawson (Alt.) |
| International Association of Government Labor Officials | Bernard O'Neill Edward C. Lawry (Alt.) |
| International Brotherhood of Electrical Workers | James R. Tomaseski James M. Ozzello (Alt.) |
| International Municipal Signal Association | Warren Farrell |
| National Association of Regulatory Utility Commissioners | Lanny L. Smith |
| National Cable Television Association | James Kearney Wendell Bailey (Alt.) |
| National Electrical Contractors Association | O. L. Davis Brooke H. Stauffer (Alt.) |
| National Electrical Manufacturers Association | Chris K. Durland Lawrence F. Miller (Alt.) |
| National Safety Council | P. Schmidt |
| Rural Electrification Administration, US Department of Agriculture | G. J. Bagnall |
| Tennessee Valley Authority | C. L. Clem Nancy A. Burns (Alt.) |
| Western Area Power Administration, US Department of Energy | Henry J. Kientz Oliver W. Perkins (Alt.) |
| Individual Member | O. C. Amrhyn |
| Individual Member | A. L. Clapp |
| Liaison Representative to Canadian Electrical Code | Susan L. Vogel |
| Canadian Standards Association Liaison Representative | David Singleton |

Subcommittee 1
Purpose, Scope, Application, Definitions, and References
(Sections 1, 2, and 3)

Allen L. Clapp, Chair

Charles C. Bleakley, Secretary

| | | | |
|---------------------|--------|-------------------|-------------------|
| O. C. Amrhyh | (Main) | Donald E. Hooper | (Interpretations) |
| C. C. Bleakley | (SC7) | G. W. Horres, Jr. | (SC2) |
| F. W. Koch | (Alt.) | J. B. Dagenhart | (Alt.) |
| F. A. Denbrock | (SC5) | H. J. Kientz | (SC8) |
| Allen L. Clapp | (Alt.) | J. R. Tomaseski | (Alt.) |
| G. R. Engmann | (SC3) | W. B. Roelle | (SC4) |
| D. J. Christofersen | (Alt.) | R. H. Martineau | (Alt.) |

Subcommittee 2
Grounding Methods
(Section 9)

George W. Horres, Jr., Chair

John L. Dagenhart, Secretary

| | | | |
|-----------------|--------|-------------------|--------|
| J. Boksiner | ATIS | G. W. Horres, Jr. | EI |
| A. C. Channaiah | SEEX | W. J. ... | (Alt.) |
| J. B. Dagenhart | IEEE | N. Maxwell | NARUC |
| M. M. Dixon | EI | P. Pope | EIA |
| L. E. Gaunt | (Alt.) | E. Robeson | EI |
| G. R. Engmann | IEEE | J. R. Tomaseski | IBEW |
| C. B. Gustafson | AEIC | J. M. Ozzello | (Alt.) |
| T. Hiu | RUS | D. W. Zipse | IEEE |

Subcommittee 3
Electric Supply Stations
(Sections 10–19)

Gary R. Engmann, Chair

D. J. Christofersen, Secretary

| | | | |
|---------------------|------|-----------------|--------|
| W. Berg | WAPA | N. B. Lewis | SEEX |
| D. J. Christofersen | IEEE | K. C. Labbe | (Alt.) |
| A. L. Comans | AEIC | J. M. Ozzello | IBEW |
| G. R. Engmann | IEEE | J. R. Tomaseski | (Alt.) |
| C. C. Hamerla | EI | C. R. Pope | IEEE |
| A. E. Kollar | IEEE | G. P. Rahman | NECA |
| S. J. Kollmann | EI | G. E. Richey | EI |
| | | R. E. Sipler | NARUC |

ATIS—Alliance for Telephone Industry Solutions
 ASG—American Insurance Services Group, Inc.
 APWA—American Public Works Association
 APTA—American Public Transit Association
 AAR—Association of American Railroads
 AEIC—Association of Edison Illuminating Companies
 BPA—Bonneville Power Admin., US Dept. of Energy
 EEI—Edison Electric Institute
 EIA—Electronic Industries Association
 IAGLO—Int'l. Assoc. of Government Labor Officials
 IBEW—International Brotherhood of Electrical Workers

IEEE—Institute of Electrical and Electronics Engineers, Inc.
 IMSA—International Municipal Signal Association
 NARUC—National Association of Regulatory Utility Commissioners
 NCTA—National Cable Television Association
 NECA—National Electrical Contractors Association
 NEMA—National Electrical Manufacturers Association
 NSC—National Safety Council
 RUS—Rural Utilities Services, US Department of Agriculture
 SEEX—Southeastern Electric Exchange
 TVA—Tennessee Valley Authority
 WAPA—Western Area Power Administration, US Dept. of Energy

Subcommittee 4
Overhead Lines—Clearances
(Section 20, 21, 22, and 23)

Wayne B. Roelle, Chair

| | |
|--------------------|---------------|
| O. C. Amrhn | Self |
| R. J. Bednarz | Self |
| C. C. Bleakley | AEIC |
| M. B. Gunter | <i>(Alt.)</i> |
| J. L. Bohlk | RUS |
| J. S. Bottino | AAR |
| A. L. Clapp | Self |
| D. D. Davidchik | EIA |
| E. K. Engdahl | EI |
| J. Renowden | <i>(Alt.)</i> |
| D. E. Hooper | Self |
| H. N. Johnson, Jr. | SEEX |
| D. C. Young | <i>(Alt.)</i> |
| D. G. Komassa | EI |

Ronald H. Martineau, Secretary

| | |
|-----------------|---------------|
| R. H. Martineau | EI |
| J. M. Overton | US DOT |
| S. A. Olinick | EI |
| R. G. Oswald | IEEE |
| J. M. Ozzello | IBEW |
| J. R. Tomaseski | <i>(Alt.)</i> |
| O. W. Perkins | WAPA |
| J. L. Reding | EIA |
| W. B. Roelle | AEIC |
| J. Ruehl | NARUC |
| M. C. Schwarz | IEEE |
| R. H. Stevens | Self |
| B. J. Washburn | NARUC |
| R. E. Willis | ATIS |

Subcommittee 5
Overhead Lines—Strength and Loading
(Sections 24, 25, 26, and 27)

Frank A. Denbrock, Chair

| | |
|-----------------|---------------|
| N. G. Bingel | Self |
| A. L. Clapp | Self |
| D. D. Davidchik | EIA |
| F. A. Denbrock | IEEE |
| R. C. Peters | <i>(Alt.)</i> |
| F. B. Dewey | Self |
| W. F. Fuller | Self |
| D. Hanson | WAPA |
| E. Harrell | EI |

Allen L. Clapp, Secretary

| | |
|----------------|---------------|
| L. G. Caldwell | RUS |
| R. V. Hensel | IEEE |
| D. E. Hill | EI |
| W. D. Jones | IEEE |
| L. Kempner | BPA |
| R. Marsico | EI |
| T. A. Pinkham | IEEE |
| E. W. Shultz | SEEX |
| R. Corzine | <i>(Alt.)</i> |

Subcommittee 7
Underground Lines
(Sections 30–39)

C. C. Bleakley, Chair

| | |
|-----------------|---------------|
| O. C. Amrhn | Self |
| C. C. Bleakley | SEEX |
| M. B. Gunter | <i>(Alt.)</i> |
| D. C. Young | <i>(Alt.)</i> |
| D. E. Buchard | IEEE |
| J. L. Bohlk | RUS |
| R. M. Clapp | WAPA |
| G. Clemons | EI |
| R. Thiede | <i>(Alt.)</i> |
| O. L. Davis | NECA |
| R. A. Fernandez | EIA |

F. William Koch, Secretary

| | |
|-----------------|---------------|
| C. W. Forsberg | NEMA |
| W. E. Haug | EI |
| F. W. Koch | AEIC |
| J. D. Mars | EI |
| G. S. Pristach | APTA |
| G. P. Rahman | NECA |
| E. T. Robeson | EI |
| L. L. Smith | NARUC |
| J. R. Tomaseski | IBEW |
| J. M. Ozzello | <i>(Alt.)</i> |
| R. E. Willis | ATIS |

Subcommittee 8
Work Rules
(Sections 40–44)

Henry J. Kientz, Chair

Joseph M. Van Name, Chair (1987-1995)

J. M. Degen
 J. F. Doering
 C. W. Grose
 H. J. Kientz
 J. D. Mitchell
 H. J. Fox
 R. C. Mooney
 G. J. O’Neil
 J. A. Dahmer

ATIS
 Self
 IEEE
 WAPA
 IEEE
(Alt.)
 AEIC
 EEI
(Alt.)

R. D. Shores
 R. Thiede
 J. R. Tomaseski
 J. M. Ozzello
 G. Tootle
 S. Hadley
 D. M. Wallis
 J. E. Pipkin

EIA
 EEI
 IBEW
(Alt.)
 SFEX
(Alt.)
 OSHA
(Alt.)

James R. Tomaseski, Secretary

Executive Subcommittee

O. C. Amrhyn, Chair

O. C. Amrhyn
 E. S. Charkey
 F. A. Denbrock
 S. A. Olinick

Self
 AISG
 IEEE
 EEI

Frank A. Denbrock, Vice Chair

W. B. Roelle
 L.L. Smith
 J. R. Tomaseski
 R. E. Williams

APPA
 NARUC
 IBEW
 ATIS

Rochelle L. Stern
IEEE Standards Project Editor

Contents

| SECTION | PAGE |
|--|--------|
| Letter Symbols for Units..... | xxxiii |
| Sec. 1. Introduction to the National Electrical Safety Code | 1 |
| 010. Purpose | 1 |
| 011. Scope | 1 |
| 012. General Rules | 1 |
| 013. Application | 1 |
| A. New Installations and Extensions | 1 |
| B. Existing Installations | 1 |
| 014. Waiver | 2 |
| A. Emergency Installations | 2 |
| B. Temporary Overhead Installations | 2 |
| 015. Intent | 2 |
| 016. Effective Date | 2 |
| 017. Units of Measure | 2 |
| Sec. 2. Definitions of Special Terms | 4 |
| Sec. 3. References | 13 |
| Sec. 9. Grounding Methods for Electric Supply and Communications Facilities | 15 |
| 90. Purpose | 15 |
| 91. Scope | 15 |
| 92. Point of Connection of Grounding Conductor | 15 |
| A. Direct Current Systems That Are to Be Grounded | 15 |
| 1. 750 V and below | 15 |
| 2. Over 750 V | 15 |
| B. Alternating Current Systems That Are to Be Grounded | 15 |
| 1. 750 V and below | 15 |
| 2. Over 750 V | 15 |
| 3. Separate Grounding Conductor | 16 |
| C. Messenger Wires and Guys | 16 |
| 1. Messenger Wires | 16 |
| 2. Guys | 16 |
| 3. Common Grounding of Messengers and Guys on the Same Supporting Structure | 16 |
| D. Current in Grounding Conductor | 16 |
| E. Fences | 17 |
| 93. Grounding Conductor and Means of Connection | 17 |
| A. Composition of Grounding Conductors | 17 |
| B. Connection of Grounding Conductors | 18 |
| C. Ampacity and Strength | 18 |
| 1. System Grounding Conductors for Single-Grounded Systems | 18 |
| 2. System Grounding Conductors for Multi-grounded Alternating Current Systems | 18 |
| 3. Grounding Conductors for Instrument Transformers | 18 |
| 4. Grounding Conductors for Primary Surge Arresters | 18 |
| 5. Grounding Conductors for Equipment, Messenger Wires, and Guys | 18 |
| 6. Fences | 18 |
| 7. Bonding of Equipment Frames and Enclosures | 19 |
| 8. Ampacity Limit | 19 |

| SECTION | PAGE |
|--|------|
| 9. Strength | 19 |
| D. Guarding and Protection..... | 19 |
| E. Underground..... | 19 |
| F. Common Grounding Conductor for Circuits, Metal Raceways, and Equipment | 20 |
| 94. Grounding Electrodes..... | 20 |
| A. Existing Electrodes..... | 20 |
| 1. Metallic Water Piping System | 20 |
| 2. Local Systems | 20 |
| 3. Steel Reinforcing Bars in Concrete Foundations and Footings | 20 |
| B. Made Electrodes..... | 20 |
| 1. General | 20 |
| 2. Driven Rods | 21 |
| 3. Buried Wire, Strips, or Plates..... | 21 |
| 4. Pole-Butt Plates and Wire Wraps..... | 21 |
| 5. Concentric Neutral Cable..... | 22 |
| 6. Concrete-Encased Electrodes..... | 22 |
| 95. Method of Connection to Electrode | 22 |
| A. Ground Connections..... | 22 |
| B. Point of Connection to Piping Systems..... | 23 |
| C. Contact Surfaces..... | 23 |
| 96. Ground Resistance Requirements..... | 23 |
| A. Supply Stations..... | 23 |
| B. Single-Grounded (Unigrounded or Delta) Systems | 23 |
| C. Multi-grounded Systems | 23 |
| 97. Separation of Grounding Conductors..... | 23 |
| 98. Number 98 not used in this edition..... | 24 |
| 99. Additional Requirements for Communication Apparatus | 25 |
| A. Electrode..... | 25 |
| B. Electrode Connection | 25 |
| C. Bonding of Electrodes..... | 25 |

**Part 1. Rules for the Installation and Maintenance of Electric Supply
Stations and Equipment**

| | |
|--|----|
| Sec. 10. Purpose and Scope of Rules..... | 27 |
| 100. Purpose | 27 |
| 101. Scope | 27 |
| Sec. 11. Protective Arrangements in Electric Supply Stations | 28 |
| 110. General Requirements | 28 |
| A. Enclosure of Equipment | 28 |
| 1. Types of Enclosures | 28 |
| 2. Safety Clearance Zone | 28 |
| B. Rooms and Spaces..... | 28 |
| 1. Construction | 28 |
| 2. Use | 28 |
| 3. Ventilation..... | 28 |
| 4. Moisture and Weather..... | 28 |
| C. Electric Equipment..... | 30 |
| 111. Illumination | 30 |
| A. Under Normal Conditions | 30 |
| B. Emergency Lighting..... | 30 |
| C. Fixtures..... | 30 |
| D. Attachment Plugs and Receptacles for General Use | 30 |

Contents

| SECTION | PAGE |
|--|------|
| E. Receptacles in Damp or Wet Locations | 30 |
| 112. Floors, Floor Openings, Passageways, and Stairs | 30 |
| A. Floors | 30 |
| B. Passageways | 30 |
| C. Railings | 32 |
| D. Stair Guards | 32 |
| E. Top Rails | 33 |
| 113. Exits | 33 |
| A. Clear Exits | 33 |
| B. Double Exits | 33 |
| C. Exit Doors | 33 |
| 114. Fire-Extinguishing Equipment | 33 |
| Sec. 12. Installation and Maintenance of Equipment | 34 |
| 120. General Requirements | 34 |
| 121. Inspections | 34 |
| A. In-Service Equipment | 34 |
| B. Idle Equipment | 34 |
| C. Emergency Equipment | 34 |
| D. New Equipment | 34 |
| 122. Guarding Shaft Ends, Pulleys, Belts, and Suddenly Moving Parts | 34 |
| A. Mechanical Transmission Machinery | 34 |
| B. Suddenly Moving Parts | 34 |
| 123. Protective Grounding | 34 |
| A. Protective Grounding or Physical Isolation of Non-current-Carrying Metal Parts | 34 |
| B. Grounding Method | 34 |
| C. Provision for Grounding Equipment During Maintenance | 35 |
| D. Grounding Methods for Direct-Current Systems over 750 Volts | 35 |
| 124. Guarding Live Parts | 35 |
| A. Where Required | 35 |
| B. Strength of Guards | 35 |
| C. Types of Guards | 35 |
| 1. Location or Physical Isolation | 35 |
| 2. Shields or Enclosures | 35 |
| 3. Railings | 36 |
| 4. Mats | 36 |
| 5. Live Parts Below Supporting Surfaces for Persons | 36 |
| 6. Insulating Covering on Conductors or Parts | 36 |
| 125. Working Space About Electric Equipment | 44 |
| A. Working Space (600 Volts or Less) | 44 |
| 1. Clear Spaces | 44 |
| 2. Access and Entrance to Working Space | 44 |
| 3. Working Space | 44 |
| 4. Headroom Working Space | 44 |
| 5. Front Working Space | 44 |
| B. Working Space Over 600 Volts | 44 |
| 126. Equipment for Work on Energized Parts | 45 |
| 127. Classified Locations | 45 |
| A. Coal-Handling Areas | 45 |
| B. Flammable and Combustible Liquids | 45 |
| C. Flammable Liquid Storage Area | 46 |
| D. Loading and Unloading Facilities | 46 |

Contents

| SECTION | PAGE |
|--|------|
| E. Gasoline-Dispensing Stations | 46 |
| F. Boilers | 46 |
| G. Gaseous Hydrogen Systems for Supply Equipment | 46 |
| H. Liquid Hydrogen Systems | 47 |
| I. Sulfur | 47 |
| J. Oxygen | 47 |
| K. Liquefied Petroleum Gas (LPG) | 47 |
| L. Natural Gas (Methane) | 47 |
| 128. Identification | 47 |
| 129. Mobile Hydrogen Equipment..... | 47 |
| Sec. 13. Rotating Equipment | 48 |
| 130. Speed Control and Stopping Devices..... | 48 |
| A. Automatic Overspeed Trip Device for Prime Movers | 48 |
| B. Manual Stopping Devices | 48 |
| C. Speed Limit for Motors | 48 |
| D. Number 130D not used in this edition. | 48 |
| E. Adjustable-Speed Motors | 48 |
| F. Protection of Control Circuits | 48 |
| 131. Motor Control..... | 48 |
| 132. Number 132 not used in this edition..... | 48 |
| 133. Short-Circuit Protection..... | 48 |
| Sec. 14. Storage Batteries | 49 |
| 140. General | 49 |
| 141. Location | 49 |
| 142. Ventilation | 49 |
| 143. Racks | 49 |
| 144. Floors in Battery Areas | 49 |
| 145. Illumination for Battery Areas | 49 |
| 146. Service Facilities | 49 |
| 147. Number 147 not used in this edition. | 49 |
| Sec. 15. Transformers and Regulators | 50 |
| 150. Current-Transformer Secondary Circuits Protection When Exceeding 600 Volts | 50 |
| 151. Grounding Secondary Circuits of Instrument Transformers | 50 |
| 152. Location and Arrangement of Power Transformers and Regulators | 50 |
| A. Outdoor Installations | 50 |
| B. Indoor Installations | 50 |
| 153. Short-Circuit Protection of Power Transformers | 50 |
| Sec. 16. Conductors | 52 |
| 160. Application | 52 |
| 161. Electrical Protection | 52 |
| A. Overcurrent Protection Required | 52 |
| B. Grounded Conductors | 52 |
| C. Insulated Power Cables..... | 52 |
| 162. Mechanical Protection | 52 |
| 163. Isolation | 52 |
| 164. Conductor Terminations | 52 |
| A. Insulation | 52 |
| B. Metal-Sheathed or Shielded Cable | 52 |
| Sec. 17. Circuit Breakers, Reclosers, Switches, and Fuses | 53 |
| 170. Arrangement | 53 |

| SECTION | PAGE |
|--|------|
| 171. Application | 53 |
| 172. Circuit Breakers, Reclosers, and Switches Containing Oil | 53 |
| 173. Switches and Disconnecting Devices | 53 |
| A. Capacity | 53 |
| B. Provisions for Disconnecting | 53 |
| C. Visible Break Switch | 53 |
| 174. Disconnection of Fuses | 53 |
| Sec. 18. Switchgear and Metal-Enclosed Bus | 54 |
| 180. Switchgear Assemblies | 54 |
| A. General Requirements for All Switchgear | 54 |
| B. Metal-Enclosed Power Switchgear | 54 |
| C. Dead-Front Power Switchboards | 55 |
| D. Motor Control Centers | 55 |
| E. Control Switchboards | 55 |
| 181. Metal-Enclosed Bus | 55 |
| A. General Requirements for All Types of Bus | 55 |
| B. Isolated-Phase Bus | 55 |
| Sec. 19. Surge Arresters | 57 |
| 190. General Requirements | 57 |
| 191. Indoor Locations | 57 |
| 192. Grounding Conductors | 57 |
| 193. Installation | 57 |
| Part 2. Safety Rules for the Installation and Maintenance of Overhead Electric Supply and Communication Lines | |
| Sec. 20. Purpose, Scope, and Application of Rules | 59 |
| 200. Purpose | 59 |
| 201. Scope | 59 |
| 202. Application of Rules | 59 |
| Sec. 21. General Requirements | 60 |
| 210. Referenced Sections | 60 |
| 211. Number 211 not used in this edition. | 60 |
| 212. Induced Voltages | 60 |
| 213. Accessibility | 60 |
| 214. Inspection and Tests of Lines and Equipment | 60 |
| A. When In Service | 60 |
| 1. Initial Compliance With Rules | 60 |
| 2. Inspection | 60 |
| 3. Tests | 60 |
| 4. Record of Defects | 60 |
| 5. Remedying Defects | 60 |
| B. When Out of Service | 60 |
| 1. Lines Infrequently Used | 60 |
| 2. Lines Temporarily Out of Service | 60 |
| 3. Lines Permanently Abandoned | 60 |
| 215. Grounding of Circuits, Supporting Structures, and Equipment | 61 |
| A. Methods | 61 |
| B. Circuits | 61 |
| 1. Common Neutral | 61 |
| 2. Other Neutrals | 61 |
| 3. Other Conductors | 61 |
| 4. Surge Arresters | 61 |

Contents

| SECTION | PAGE |
|---|------|
| 5. Use of Earth as Part of Circuit | 61 |
| C. Non-current-Carrying Parts | 61 |
| 1. General | 61 |
| 2. Guys | 61 |
| 3. Multiple Messengers on the Same Structure | 61 |
| 216. Arrangement of Switches | 62 |
| A. Accessibility | 62 |
| B. Indicating Open or Closed Position | 62 |
| C. Locking | 62 |
| D. Uniform Position | 62 |
| 217. General | 62 |
| A. Supporting Structures | 62 |
| 1. Protection of Structures | 62 |
| 2. Climbing | 62 |
| 3. Identification | 63 |
| 4. Obstructions | 63 |
| 5. Decorative Lighting | 63 |
| B. Unusual Conductor Supports | 63 |
| 218. Tree Trimming | 63 |
| A. General | 63 |
| B. At Line Crossings, Railroad Crossings, and Limited-Access Highway Crossings | 63 |
| Sec. 22. Relations Between Various Classes of Lines and Equipment | 64 |
| 220. Relative Levels | 64 |
| A. Standardization of Levels | 64 |
| B. Relative Levels: Supply and Communication Conductors | 64 |
| 1. Preferred Levels | 64 |
| 2. Special Construction for Supply Circuits, the Voltage of Which Is 600 Volts or Less and Carrying Power Not in Excess of 5 Kilowatts | 64 |
| C. Relative Levels: Supply Lines of Different Voltage Classifications (as classified in Table 235-5) | 65 |
| 1. At Crossings or Conflicts | 65 |
| 2. On Structures Used Only by Supply Conductors | 65 |
| D. Identification of Overhead Conductors | 65 |
| E. Identification of Equipment on Supporting Structures | 65 |
| 221. Avoidance of Conflict | 65 |
| 222. Joint Use of Structures | 65 |
| 223. Communications Protective Requirements | 66 |
| A. Where Required | 66 |
| B. Means of Protection | 66 |
| 224. Communication Circuits Located Within the Supply Space and Supply Circuits Located Within the Communication Space | 66 |
| A. Communication Circuits Located in the Supply Space | 66 |
| B. Supply Circuits Used Exclusively in the Operation of Communication Circuits | 67 |
| 225. Electric Railway Construction | 67 |
| A. Trolley-Contact Conductor Fastenings | 67 |
| B. High-Voltage Contact Conductors | 67 |
| C. Third Rails | 67 |
| D. Prevention of Loss of Contact at Railroad Crossings at Grade | 67 |
| E. Guards Under Bridges | 68 |
| Sec. 23. Clearances | 69 |
| 230. General | 69 |

| SECTION | PAGE |
|---|------|
| A. Application | 69 |
| 1. Permanent and Temporary Installations | 69 |
| 2. Emergency Installations | 69 |
| B. Measurement of Clearance and Spacing | 69 |
| C. Supply Cables | 69 |
| D. Covered Conductors | 70 |
| E. Neutral Conductors | 70 |
| F. Fiber-Optic Cable | 70 |
| 1. Fiber-optic—supply cable | 70 |
| 2. Fiber-optic—communication cable | 70 |
| G. Alternating- and Direct-Current Circuits | 70 |
| H. Constant-Current Circuits | 71 |
| I. Maintenance of Clearances and Spacings | 71 |
| 231. Clearances of Supporting Structures From Other Objects | 71 |
| A. From Fire Hydrants | 71 |
| B. From Streets, Roads, and Highways | 71 |
| C. From Railroad Tracks | 71 |
| 232. Vertical Clearances of Wires, Conductors, Cables, and Equipment Above Ground, Roadway, Rail, or Water Surfaces | 72 |
| A. Application | 72 |
| B. Clearance of Wires, Conductors, Cables, and Equipment Mounted on Supporting Structures | 72 |
| 1. Clearance to Wires, Conductors, and Cables | 72 |
| 2. Clearance to Unguarded Rigid Live Parts of Equipment | 72 |
| 3. Clearance to Equipment Cases | 72 |
| 4. Street and Area Lighting | 72 |
| C. Additional Clearances for Wires, Conductors, Cables, and Unguarded Rigid Live Parts of Equipment | 72 |
| 1. Voltages Exceeding 22 Kilovolts | 72 |
| D. Alternate Clearances for Voltages Exceeding 98 Kilovolts Alternating Current to Ground or 139 Kilovolts Direct Current to Ground | 73 |
| 1. Sag Conditions of Line Conductors | 73 |
| 2. Reference Heights | 73 |
| 3. Electrical Component of Clearance | 73 |
| 4. Limit | 73 |
| 233. Clearances Between Wires, Conductors, and Cables Carried on Different Supporting Structures | 84 |
| A. General | 84 |
| 1. Conductor Movement Envelope | 84 |
| 2. Clearance Envelope | 84 |
| B. Horizontal Clearance | 88 |
| 1. Clearance Requirements | 88 |
| 2. Alternate Clearances for Voltages Exceeding 98 kV Alternating Current to Ground or 139 kV Direct Current to Ground | 88 |
| C. Vertical Clearance | 88 |
| 1. Clearance Requirements | 88 |
| 2. Voltages Exceeding 22 kV | 88 |
| 3. Alternate Clearances for Voltage Exceeding 98 Kilovolts Alternating Current to Ground or 139 Kilovolts Direct Current to Ground | 89 |
| 234. Clearance of Wires, Conductors, Cables, and Equipment From Buildings, Bridges, Rail Cars, Swimming Pools, and Other Installations | 94 |
| A. Application | 94 |
| 1. Vertical and Horizontal Clearances (No Wind Displacement) | 94 |
| 2. Horizontal Clearances (With Wind Displacement) | 94 |

| SECTION | PAGE |
|--|------|
| 3. Transition Between Horizontal and Vertical Clearances | 94 |
| B. Clearances of Wires, Conductors, and Cables From Other Supporting Structures | 94 |
| C. Clearances of Wires, Conductors, Cables, and Rigid Live Parts From Buildings, Signs, Billboards, Chimneys, Radio and Television Antennas, Tanks, and Other Installations Except Bridges | 97 |
| 1. Vertical and Horizontal Clearances | 97 |
| 2. Guarding of Supply Conductors | 97 |
| 3. Supply Conductors Attached to Buildings or Other Installations | 97 |
| 4. Communication Conductors Attached to Buildings or Other Installations | 102 |
| 5. Ladder Space | 102 |
| D. Clearance of Supply Wires, Conductors, Cables, and Rigid Live Parts From Bridges | 102 |
| 1. Vertical and Horizontal Clearances | 102 |
| 2. Guarding Trolley-Contact Conductors Located Under Bridges | 104 |
| E. Clearance of Wires, Conductors, or Cables Installed Over or Near Swimming Areas With No Wind Displacement | 104 |
| 1. Swimming Pools | 104 |
| 2. Beaches and Waterways Restricted to Swimming | 104 |
| 3. Waterways Subject to Water Skiing | 104 |
| F. Clearances of Wires, Conductors, Cables, and Rigid Live Parts From Grain Bins..... | 109 |
| 1. Grain Bins Loaded by Permanently Installed Augers, Conveyers, or Elevator Systems | 109 |
| 2. Grain Bins Loaded by Portable Augers, Conveyers or Elevators (With No Wind Displacement) | 109 |
| G. Additional Clearances for Voltages Exceeding 22 Kilovolts for Wires, Conductors, Cables, and Unguarded Rigid Live Parts of Equipment..... | 111 |
| H. Alternate Clearances for Voltages Exceeding 98 Kilovolts Alternating Current to Ground or 139 Kilovolts Direct Current to Ground | 111 |
| 1. Sag Conditions of Line Conductors | 111 |
| 2. Reference Distances | 111 |
| 3. Electrical Component of Clearance | 111 |
| 4. Limit | 112 |
| I. Clearance of Wires, Conductors, and Cables to Rail Cars | 112 |
| 1. Rules 232B1 and 232C1 | 112 |
| 2. Rule 232D | 112 |
| J. Clearance of Equipment Mounted on Supporting Structures..... | 112 |
| 1. Clearance to Unguarded Rigid Live Parts of Equipment..... | 112 |
| 2. Clearance to Equipment Cases..... | 112 |
| 235. Clearance for Wires, Conductors, or Cables Carried on the Same Supporting Structure | 115 |
| A. Application of Rule | 115 |
| 1. Multiconductor Wires or Cables | 115 |
| 2. Conductors Supported by Messengers or Span Wires | 115 |
| 3. Line Conductors of Different Circuits | 115 |
| B. Horizontal Clearance Between Line Conductors | 115 |
| 1. Fixed Supports | 115 |
| 2. Suspension Insulators | 119 |
| 3. Alternate Clearances for Different Circuits Where One or Both Circuits Exceed 98 Kilovolts Alternating Current to Ground or 139 Kilovolts Direct Current to Ground | 119 |
| C. Vertical Clearance Between Line Conductors | 119 |

Contents

| SECTION | PAGE |
|--|------|
| 1. Basic Clearance for Conductors of Same or Different Circuits | 120 |
| 2. Additional Clearances | 120 |
| 3. Alternate Clearances for Different Circuits Where One or Both Exceed 98 Kilovolts Alternating Current, or 139 Kilovolts Direct Current to Ground | 124 |
| D. Diagonal Clearance Between Line Wires, Conductors, and Cables Located at Different Levels on the Same Supporting Structure | 124 |
| E. Clearances in Any Direction From Line Conductors to Supports, and to Vertical or Lateral Conductors, Span or Guy Wires Attached to the Same Support | 124 |
| 1. Fixed Supports | 124 |
| 2. Suspension Insulators | 124 |
| 3. Alternate Clearances for Voltages Exceeding 98 Kilovolts Alternating Current to Ground or 139 Kilovolts Direct Current to Ground | 124 |
| F. Clearances Between Supply Circuits of Different Voltage Classifications on the Same Support Arm | 127 |
| G. Conductor Spacing: Vertical Racks | 128 |
| 236. Climbing Space | 129 |
| A. Location and Dimensions | 129 |
| B. Portions of Supporting Structures in Climbing Space | 129 |
| C. Support Arm Location Relative to Climbing Space | 129 |
| D. Location of Equipment Relative to Climbing Space | 129 |
| E. Climbing Space Between Conductors | 129 |
| F. Climbing Space on Buckarm Construction | 131 |
| G. Climbing Space Past Longitudinal Runs Not on Support Arms | 131 |
| H. Climbing Space Past Vertical Conductors | 131 |
| I. Climbing Space Near Ridge-Pin Conductors | 131 |
| 237. Working Space | 132 |
| A. Location of Working Spaces | 132 |
| B. Dimensions of Working Spaces | 132 |
| 1. Along the Support Arm | 132 |
| 2. At Right Angles to the Support Arm | 132 |
| 3. Vertically | 132 |
| C. Location of Vertical and Lateral Conductors Relative to Working Spaces | 132 |
| D. Location of Buckarms Relative to Working Spaces | 133 |
| 1. Standard Height of Working Space | 133 |
| 2. Reduced Height of Working Space | 133 |
| E. Guarding of Energized Equipment..... | 133 |
| F. Working Clearances From Energized Equipment..... | 133 |
| 238. Vertical Clearance Between Certain Communications and Supply Facilities Located on the Same Structure | 134 |
| A. Equipment | 134 |
| B. Clearances in General | 134 |
| C. Clearances for Span Wires or Brackets | 134 |
| D. Clearance of Drip Loops of Luminaire or Traffic Signal Brackets | 134 |
| 239. Clearance of Vertical and Lateral Facilities From Other Facilities and Surfaces on the Same Support | 136 |
| A. General | 136 |
| B. Location of Vertical or Lateral Conductors Relative to Climbing Spaces, Working Spaces, and Pole Steps | 136 |
| C. Conductors Not in Conduit | 136 |
| D. Guarding and Protection Near Ground | 136 |

Contents

| SECTION | PAGE |
|---|------|
| E. Requirements for Vertical and Lateral Supply Conductors on Supply Line Structures or Within Supply Space on Jointly Used Structures | 136 |
| 1. General Clearances | 136 |
| 2. Special Cases | 136 |
| F. Requirements for Vertical and Lateral Communication Conductors on Communication Line Structures or Within the Communication Space on Jointly Used Structures | 137 |
| 1. Clearances From Wires | 137 |
| 2. Clearances From Supporting Structure Surfaces | 137 |
| G. Requirements for Vertical Supply Conductors Passing Through Communication Space on Jointly Used Line Structures | 137 |
| 1. Guarding—General | 137 |
| 2. Cables and Conductors in Conduit or Covering | 138 |
| 3. Protection Near Trolley, Ungrounded Traffic Signal, or Ungrounded Luminaire Attachments..... | 138 |
| 4. Aerial Services | 138 |
| 5. Clearance From Through Bolts and Other Metal Objects | 138 |
| H. Requirements for Vertical Communication Conductors Passing Through Supply Space on Jointly Used Structures..... | 138 |
| 1. Metal-Sheathed Communication Cables..... | 138 |
| 2. Communication Conductors | 138 |
| 3. Communication Grounding Conductors | 138 |
| 4. Clearance From Through Bolts and Other Metal Objects | 139 |
| I. Operating Rods..... | 139 |
| J. Additional Rules for Standoff Brackets | 139 |
| Sec. 24 Grades of Construction | 142 |
| 240. General | 142 |
| 241. Application of Grades of Construction to Different Situations..... | 142 |
| A. Supply Cables..... | 142 |
| B. Order of Grades | 142 |
| C. At Crossings | 142 |
| 1. Grade of Upper Line | 142 |
| 2. Grade of Lower Line | 142 |
| 3. Multiple Crossings | 142 |
| D. Conflicts | 142 |
| 242. Grades of Construction for Conductors..... | 142 |
| A. Constant-Current Circuit Conductors..... | 143 |
| B. Railway Feeder and Trolley-Contact Circuit Conductors..... | 143 |
| C. Communication Circuit Conductors Located in the Supply Space..... | 143 |
| D. Fire-Alarm Circuit Conductors | 143 |
| E. Neutral Conductors of Supply Circuits..... | 143 |
| F. Surge-Protection Wires | 143 |
| 243. Grades of Construction for Line Supports..... | 147 |
| A. Structures..... | 147 |
| B. Crossarms and Support Arms..... | 147 |
| C. Pins, Armless Construction Brackets, Insulators, and Conductor Fastenings..... | 147 |
| Sec. 25. Loading for Grades B and C | 148 |
| 250. General Loading Requirements and Maps | 148 |
| A. General | 148 |
| B. Combined Ice and Wind Loading | 148 |
| C. Extreme Wind Loading | 148 |

| SECTION | PAGE |
|--|------|
| 251. Conductor Loading | 152 |
| A. General | 152 |
| B. Load Components | 152 |
| 1. Vertical Load Component | 152 |
| 2. Horizontal Load Component | 152 |
| 3. Total Load | 152 |
| 252. Loads Upon Line Supports | 153 |
| A. Assumed Vertical Loads | 153 |
| B. Assumed Transverse Loads | 153 |
| 1. Transverse Loads From Conductors and Messengers | 153 |
| 2. Wind Loads on Structures | 153 |
| 3. At Angles | 153 |
| 4. Span Lengths | 153 |
| C. Assumed Longitudinal Loading | 153 |
| 1. Change in Grade of Construction | 153 |
| 2. Jointly Used Poles at Crossings Over Railroads, Communication Lines, or Limited-Access Highways | 154 |
| 3. Deadends | 154 |
| 4. Unequal Spans and Unequal Vertical Loads | 154 |
| 5. Stringing Loads | 154 |
| 6. Longitudinal Capability | 154 |
| 7. Communication Conductors on Unguyed Supports at Railroad Crossings and Limited-Access Highways | 154 |
| D. Simultaneous Application of Loads | 154 |
| 253. Overload Factors for Structures, Crossarms, Guys, Foundations, and Anchors | 154 |
| Sec. 26. Strength Requirements | 157 |
| 260. General (see also Section 20) | 157 |
| A. Preliminary Assumptions | 157 |
| B. Application of Strength Factors | 157 |
| 261. Grades B and C Construction | 157 |
| A. Supporting Structures | 157 |
| 1. Metal, Prestressed-, and Reinforced-Concrete Structures | 157 |
| 2. Wood Structures | 157 |
| 3. Transverse-Strength Requirements for Structures Where Side Guying Is Required, But Can Only Be Installed at a Distance | 158 |
| 4. Longitudinal-Strength Requirements for Sections of Higher Grade in Lines of a Lower-Grade Construction | 158 |
| B. Strength of Foundations, Settings, and Guy Anchors | 159 |
| C. Strength of Guys and Guy Insulators | 159 |
| 1. Metal and Prestressed-Concrete Structures | 159 |
| 2. Wood and Reinforced-Concrete Poles and Structures | 159 |
| D. Crossarms and Braces | 159 |
| 1. Concrete and Metal Crossarms and Braces | 159 |
| 2. Wood Crossarms and Braces | 159 |
| 3. Crossarms and Braces of Other Materials | 160 |
| 4. Additional Requirements | 160 |
| E. Insulators | 160 |
| F. Strength of Pin-Type or Similar Construction and Conductor Fastenings | 160 |
| 1. Longitudinal Strength | 160 |
| 2. Double Pins and Conductor Fastenings | 161 |
| 3. Single Supports Used in Lieu of Double Wood Pins | 161 |
| G. Armless Construction | 161 |
| 1. General | 161 |

Contents

| SECTION | PAGE |
|---|------|
| 2. Insulating Material | 161 |
| 3. Other Components | 161 |
| H. Open Supply Conductors and Overhead Shield Wires | 161 |
| 1. Sizes of Supply Conductors | 161 |
| 2. Sags and Tensions | 161 |
| 3. Splices, Taps, and Dead-end Fittings | 162 |
| 4. Trolley-Contact Conductors | 162 |
| I. Supply Cable Messengers | 162 |
| J. Open-Wire Communication Conductors | 162 |
| K. Communication Cables | 162 |
| L. Paired Communication Conductors | 162 |
| 1. Paired Conductors Supported on Messenger | 162 |
| 2. Paired Conductors Not Supported on Messenger | 162 |
| M. Support Hardware | 163 |
| 262. Number 262 not used in this edition | 165 |
| 263. Grade N Construction | 165 |
| A. Poles | 165 |
| B. Guys | 165 |
| C. Crossarm Strength | 165 |
| D. Supply-Line Conductors | 165 |
| E. Service Drops | 165 |
| 1. Size of Open-Wire Service Drops | 165 |
| 2. Tension of Open-Wire Service Drops | 166 |
| 3. Cabled Service Drops | 166 |
| F. Trolley-Contact Conductors | 166 |
| G. Communication Conductors | 166 |
| H. Street and Area Lighting Equipment | 166 |
| I. Insulators | 166 |
| 264. Guying and Bracing | 167 |
| A. Where Used | 167 |
| B. Strength | 167 |
| C. Point of Attachment | 167 |
| D. Guy Fastenings | 167 |
| E. Guy Markers and Protection | 168 |
| F. Electrolysis | 168 |
| G. Anchor Rods | 168 |
| Sec. 27. Line Insulation | 169 |
| 270. Application of Rule | 169 |
| 271. Material and Marking | 169 |
| 272. Ratio of Flashover to Puncture Voltage | 169 |
| 273. Insulation Level | 169 |
| 274. Factory Tests | 169 |
| 275. Special Insulator Applications | 169 |
| A. Insulators for Constant-Current Circuits | 169 |
| B. Insulators for Single-Phase Circuits Directly Connected to Three-Phase Circuits | 170 |
| 276. Protection Against Arcing and Other Damage | 170 |
| 277. Mechanical Strength of Insulators | 170 |
| 278. Aerial Cable Systems | 170 |
| A. Electrical Requirements | 170 |
| B. Mechanical Requirements | 171 |
| 279. Guy and Span Insulators | 171 |
| A. Insulators | 171 |

| SECTION | PAGE |
|---|------|
| 1. Properties of Guy Insulators | 171 |
| 2. Use of Guy Insulators | 171 |
| 3. Corrosion Protection | 171 |
| B. Span-Wire Insulators | 171 |
| 1. Properties of Span-Wire Insulators | 171 |
| 2. Use of Span-Wire Insulators | 172 |
| Sec. 28 Section number 28 not used in this edition | 172 |
| Part 3. Safety Rules for the Installation and Maintenance of Underground Electric Supply and Communication Lines | |
| Sec. 30. Purpose, Scope, and Application of Rules | 173 |
| Sec. 31. General Requirements Applying to Underground Lines | 174 |
| 310. Referenced Sections | 174 |
| 311. Installation and Maintenance | 174 |
| 312. Accessibility | 174 |
| 313. Inspection and Tests of Lines and Equipment | 174 |
| A. When In Service | 174 |
| 1. Initial Compliance With Safety Rules | 174 |
| 2. Inspection | 174 |
| 3. Tests | 174 |
| 4. Record of Defects | 174 |
| 5. Remedying Defects | 174 |
| B. When Out of Service | 174 |
| 1. Lines Infrequently Used | 174 |
| 2. Lines Temporarily Out of Service | 174 |
| 3. Lines Permanently Abandoned | 174 |
| 314. Grounding of Circuits and Equipment | 174 |
| A. Methods | 174 |
| B. Conductive Parts to Be Grounded | 175 |
| C. Circuits | 175 |
| 1. Neutrals | 175 |
| 2. Other Conductors | 175 |
| 3. Surge Arresters | 175 |
| 4. Use of Earth as Part of Circuit | 175 |
| 315. Communications Protective Requirements | 175 |
| A. Where Required | 175 |
| B. Means of Protection | 175 |
| 316. Induced Voltage | 175 |
| Sec. 32. Underground Conduit Systems | 176 |
| 320. Location | 176 |
| A. Routing | 176 |
| 1. General | 176 |
| 2. Natural Hazards | 176 |
| 3. Highways and Streets | 176 |
| 4. Bridges and Tunnels | 176 |
| 5. Crossing Railroad Tracks | 176 |
| 6. Submarine Crossing | 176 |
| B. Separation From Other Underground Installations | 176 |
| 1. General | 176 |
| 2. Separations Between Supply and Communication Conduit Systems | 177 |
| 3. Sewers, Sanitary and Storm | 177 |
| 4. Water Lines | 177 |

Contents

| SECTION | PAGE |
|---|------|
| 5. Fuel Lines..... | 177 |
| 6. Steam Lines..... | 177 |
| 321. Excavation and Backfill | 177 |
| A. Trench..... | 177 |
| B. Quality of Backfill..... | 177 |
| 322. Ducts and Joints..... | 177 |
| A. General | 177 |
| B. Installation..... | 178 |
| 1. Restraint | 178 |
| 2. Joints | 178 |
| 3. Externally Coated Pipe..... | 178 |
| 4. Building Walls | 178 |
| 5. Bridges | 178 |
| 6. In Vicinity of Manholes | 178 |
| 323. Manholes, Handholes, and Vaults | 178 |
| A. Strength | 178 |
| B. Dimensions..... | 180 |
| C. Manhole Access | 180 |
| D. Covers..... | 180 |
| E. Vault and Utility Tunnel Access | 180 |
| F. Ladder Requirements | 181 |
| G. Drainage | 181 |
| H. Ventilation..... | 181 |
| I. Mechanical Protection..... | 181 |
| J. Identification | 181 |
| Sec. 33. Supply Cable | 182 |
| 330. General | 182 |
| 331. Sheaths and Jackets | 182 |
| 332. Shielding..... | 182 |
| A. General | 182 |
| B. Material | 182 |
| 333. Cable Accessories and Joints..... | 182 |
| Sec. 34. Cable in Underground Structures..... | 183 |
| 340. General | 183 |
| 341. Installation | 183 |
| A. General | 183 |
| B. Cable in Manholes and Vaults | 183 |
| 1. Supports | 183 |
| 2. Clearance..... | 183 |
| 3. Identification | 184 |
| 342. Grounding and Bonding | 184 |
| 343. Fireproofing..... | 184 |
| 344. Communication Cables Containing Special Supply Circuits..... | 184 |
| Sec. 35. Direct-Buried Cable | 186 |
| 350. General | 186 |
| 351. Location and Routing | 186 |
| A. General | 186 |
| B. Natural Hazards..... | 187 |
| C. Other Conditions | 187 |
| 1. Swimming Pools | 187 |
| 2. Buildings and Other Structures..... | 187 |
| 3. Railroad Tracks | 187 |

| SECTION | PAGE |
|--|------|
| 4. Highways and Streets..... | 188 |
| 5. Submarine Crossings..... | 188 |
| 352. Separations From Other Underground Structures | 188 |
| A. Horizontal Separation..... | 188 |
| B. Crossings | 188 |
| C. Parallel Facilities | 188 |
| D. Thermal Protection..... | 188 |
| 353. Installation | 188 |
| A. Trenching | 188 |
| B. Plowing..... | 188 |
| C. Boring..... | 189 |
| D. Depth of Burial..... | 189 |
| 354. Random Separation—Additional Requirements | 189 |
| A. General | 189 |
| B. Supply Cables or Conductors..... | 189 |
| C. Communication Cables or Conductors | 189 |
| D. Supply and Communication Cables or Conductors | 189 |
| 1. General | 189 |
| 2. Grounded Bare or Semiconducting Jacketed Neutral Supply Cables..... | 190 |
| 3. Insulating Jacketed Grounded Neutral Supply Cables..... | 190 |
| 4. Insulating Jacketed Grounded Neutral Supply Cables in Nonmetallic Duct..... | 191 |
| Sec. 36. Risers..... | 192 |
| 360. General | 192 |
| 361. Installation | 192 |
| 362. Pole Risers—Additional Requirements..... | 192 |
| 363. Pad-Mounted Installations..... | 192 |
| Sec. 37. Supply Cable Terminations..... | 193 |
| 370. General | 193 |
| 371. Support at Terminations | 193 |
| 372. Identification..... | 193 |
| 373. Clearances in Enclosures or Vaults | 193 |
| 374. Grounding..... | 193 |
| Sec. 38. Equipment | 194 |
| 380. General | 194 |
| 381. Design..... | 194 |
| 382. Location in Underground Structures | 195 |
| 383. Installation | 195 |
| 384. Grounding..... | 195 |
| 385. Identification..... | 195 |
| Sec. 39. Installation in Tunnels..... | 196 |
| 390. General | 196 |
| 391. Environment | 196 |
| Part 4. Rules for the Operation of Electric Supply and Communications Lines and Equipment | |
| Sec. 40. Purpose and Scope | 197 |
| 400. Purpose | 197 |
| 401. Scope | 197 |
| 402. Referenced Sections | 197 |
| Sec. 41. Supply and Communications Systems—Rules for Employers..... | 198 |

Contents

| SECTION | PAGE |
|---|------|
| 410. General Requirements | 198 |
| A. General | 198 |
| B. Emergency Procedures and First Aid Rules | 198 |
| C. Responsibility | 198 |
| 411. Protective Methods and Devices | 198 |
| A. Methods | 198 |
| B. Devices and Equipment | 199 |
| C. Inspection and Testing of Protective Devices | 199 |
| D. Warning Signs | 199 |
| E. Identification and Location | 199 |
| F. Fall Protection | 199 |
| Sec. 42. General Rules for Employees | 200 |
| 420. Personal General Precautions | 200 |
| A. Rules and Emergency Methods | 200 |
| B. Qualifications of Employees | 200 |
| C. Safeguarding Oneself and Others | 200 |
| D. Energized or Unknown Conditions | 200 |
| E. Ungrounded Metal Parts | 201 |
| F. Arcing Conditions | 201 |
| G. Liquid-Cell Batteries | 201 |
| H. Tools and Protective Equipment | 201 |
| I. Clothing | 201 |
| J. Ladders and Supports | 201 |
| K. Fault Protection | 201 |
| L. Fire Extinguishers | 202 |
| M. Machines or Moving Parts | 202 |
| N. Fuses | 202 |
| O. Cable Reels | 203 |
| P. Street and Area Lighting | 203 |
| 421. General Operating Routines | 203 |
| A. Duties of a First-Level Supervisor or Person in Charge | 203 |
| B. Area Protection | 203 |
| 1. Areas Accessible to Vehicular and Pedestrian Traffic | 203 |
| 2. Areas Accessible to Employees Only | 203 |
| 3. Locations With Crossed or Fallen Wires | 203 |
| C. Escort | 203 |
| 422. Overhead Line Operating Procedures | 204 |
| A. Setting, Moving, or Removing Poles In or Near Energized Electric Supply Lines | 204 |
| B. Checking Structures Before Climbing | 204 |
| C. Installing and Removing Wires or Cables | 204 |
| 423. Underground Line Operating Procedures | 204 |
| A. Guarding Manhole and Street Openings | 204 |
| B. Testing for Gas in Manholes and Unventilated Vaults | 204 |
| C. Flames | 205 |
| D. Excavation | 205 |
| E. Identification | 205 |
| F. Operation of Power-Driven Equipment | 205 |
| Sec. 43. Additional Rules for Communications Employees | 206 |
| 430. General | 206 |
| 431. Approach to Energized Conductors or Parts | 206 |
| 432. Joint-Use Structures | 206 |
| 433. Attendant on Surface at Joint-Use Manhole | 206 |
| 434. Sheath Continuity | 206 |
| Sec. 44. Additional Rules for Supply Employees | 207 |
| 440. General | 207 |

Contents

| SECTION | PAGE |
|---|------|
| 441. Energized Conductors or Parts | 207 |
| A. Approach Distance to Live Parts | 207 |
| 1. General | 207 |
| 2. Precautions for Approach—Voltages from 51 V to 300 V | 207 |
| 3. Precaution for Approach—Voltages from 301 V to 72.5 kV | 207 |
| 4. Transient Overvoltage Control Above 72.5 kV | 208 |
| 5. Altitude Correction | 208 |
| 6. Calculation of Approach Distances | 208 |
| B. Additional Approach Requirements | 215 |
| C. Live-Line Tool Clear Insulation Length | 216 |
| 1. Clear Live-Line Tool Length | 216 |
| 2. Live-Line Conductor Support Tool Length | 216 |
| 442. Switching Control Procedures | 216 |
| A. Designated Person | 216 |
| B. Specific Work | 216 |
| C. Operations at Stations | 216 |
| D. Re-energizing After Work | 217 |
| E. Tagging Electric Supply Circuits Associated With Work Activities | 217 |
| F. Restoration of Service After Automatic Trip | 217 |
| G. Repeating Oral Messages | 217 |
| 443. Work on Energized Lines and Equipment | 217 |
| A. General Requirements | 217 |
| B. Requirement for Assisting Employee | 218 |
| C. Opening and Closing Switches | 218 |
| D. Working Position | 218 |
| E. Protecting Employees by Switches and Disconnectors | 218 |
| F. Making Connections | 218 |
| G. Switchgear | 219 |
| H. Current Transformer Secondaries | 219 |
| I. Capacitors | 219 |
| J. Gas-Insulated Equipment | 219 |
| K. Attendant on Surface | 219 |
| L. Unintentional Grounds on Delta Circuits | 219 |
| 444. De-energizing Equipment or Lines to Protect Employees | 219 |
| A. Application of Rule | 219 |
| B. Employee’s Request | 220 |
| C. Operating Switches, Disconnectors, and Tagging | 220 |
| D. Employee’s Protective Grounds | 220 |
| E. Proceeding With Work | 220 |
| F. Reporting Clear—Transferring Responsibility | 220 |
| G. Removal of Tags | 220 |
| H. Sequence of Re-energizing | 221 |
| 445. Protective Grounds | 221 |
| A. Installing Grounds | 221 |
| 1. Current-Carrying Capacity of Grounds | 221 |
| 2. Initial Connections | 221 |
| 3. Test for Voltage | 221 |
| 4. Completing Grounds | 221 |
| B. Removing Grounds | 221 |
| 446. Live Work | 221 |

Contents

| FIGURES | RULE | PAGE |
|-----------------|--|------------------|
| Figure D-1. | Sag and Apparent Sag..... | Sec. 2 10 |
| Figure 110-1 | Safety Clearance to Electric Supply Station Fences..... | 110A2 29 |
| Figure 124-1. | Clearance From Live Parts | 124A1 36 |
| Figure 124-2. | Railing Used as Guards | 124C3 43 |
| Figure 233-1. | Use of Clearance Envelope and Conductor Movement Envelopes to Determine Applicable Clearance | 233A 85 |
| Figure 233-2. | Conductor Movement Envelope..... | 233A 1a 86 |
| Figure 233-3. | Clearance Envelope | 233B 88 |
| Figure 234-1(a) | Clearance Diagram for Building..... | 234A3 95 |
| Figure 234-1(b) | Clearance Diagram for Other Structures | 234A3 95 |
| Figure 234-1(c) | Transitional Clearance When H is Greater Than V..... | 234 96 |
| Figure 234-2. | Clearances of Service Drop Terminating on Support Mast..... | 234C3d(1)(b) 103 |
| Figure 234-3. | Swimming Pool Clearances..... | 234E3 104 |
| Figure 234-4(a) | Clearance Envelope for Grain Bins Filled by Permanently Installed Augers, Conveyors, or Elevators..... | 234F2c 109 |
| Figure 234-4(b) | Clearance Envelope for Grain Bins Filled by Portable Augers, Conveyors, or Elevators..... | 234F2a 110 |
| Figure 234-5 | Rail Car Clearances | 234I 113 |
| Figure 235-1. | Clearance Diagram for Energized Conductor..... | 235D 124 |
| Figure 236-1. | Rule 236G, Exception 3..... | 236G 132 |
| Figure 237-1. | Obstruction of Working Space by Buckarm..... | 237D1 133 |
| Figure 250-1. | General Loading Map of United States With Respect to Loading of Overhead Lines | 250B 149 |
| Figure 250-2. | Basic Wind Speed (miles per hour)..... | 250C 151 |
| Figure 323-1. | Roadway Vehicle Load..... | 323A1 179 |
| Figure 323-2. | Wheel Load Area..... | 323A1 179 |
| Figure 350-1. | Symbols for Identification of Buried Cables | 350G 187 |
| TABLES | | |
| Table 111-1. | Illumination Levels | 111A 31 |
| Table 124-1. | Clearance From Live Parts..... | 124A1 37 |
| Table 125-1. | Working Space..... | 125A3 44 |
| Table 232-1. | Vertical Clearance of Wires, Conductors, and Cables Above Ground, Roadway, Rail, or Water Surfaces | 232B1 74 |
| Table 232-2. | Vertical Clearance of Equipment Cases and Unguarded Rigid Live Parts Above Ground or Roadway Surfaces | 232B2 80 |
| Table 232-3. | Reference Heights | 232D2 82 |
| Table 232-4. | Electrical Component of Clearance in Rule 232D3a | 232D3a 83 |
| Table 233-1. | Vertical Clearance Between Wires, Conductors, and Cables Carried on Different Supporting Structures | 233C1 90 |
| Table 233-2. | Clearance Between Supply Wires, Conductors, and Cables in Rule 233C3b(1)..... | 233C3b(1) 92 |
| Table 233-3. | Reference Heights | 233C3a 93 |

Contents

| TABLES | RULE | PAGE |
|---------------|--|------------------|
| Table 234-1. | Clearance of Wires, Conductors, Cables, and Unguarded Rigid Live Parts Adjacent but Not Attached to Buildings and Other Installations Except Bridges..... | 234C1a 99 |
| Table 234-2. | Clearance of Wires, Conductors, Cables, and Unguarded Rigid Live Parts From Bridges | 234D1a 105 |
| Table 234-3. | Clearance of Wires, Conductors, Cables or Unguarded Rigid Live Parts Over or Near Swimming Pools | 234E1 107 |
| Table 234-4. | Electrical Component of Clearance of Buildings, Bridges, and Other Installations | 234H3a 114 |
| Table 234-5. | Reference Distances..... | 234H2 115 |
| Table 235-1. | Horizontal Clearance Between Wires, Conductors, or Cables at Supports..... | 235B1a 116 |
| Table 235-2. | Horizontal Clearances Between Line Conductors Smaller Than AWG No. 2 at Supports, Based on Sags..... | 235B1b(1) 117 |
| Table 235-3. | Horizontal Clearances Between Line Conductors AWG No. 2 or Larger at Supports, Based on Sags..... | 235B1b(2) 118 |
| Table 235-4. | Electrical Clearances in Rule 235B3a(1) | 235B3a(1) 121 |
| Table 235-5. | Vertical Clearance Between Conductors at Supports | 235C1 122 |
| Table 235-6. | Clearance in Any Direction From Line Conductors to Supports and to Vertical or Lateral Conductors, Span, or Guy Wires Attached to the Same Support..... | 235E1 125 |
| Table 235-7. | Clearance in Any Direction From Line Conductors to Supports | 235E3b 128 |
| Table 236-1. | Horizontal Clearance Between Conductors Bounding the Climbing Space | 236E 130 |
| Table 238-1. | Vertical Clearance Between Supply Conductors and Communications Equipment, Between Communication Conductors and Supply Equipment, and Between Supply and Communications Equipment..... | 238B 135 |
| Table 238-2. | Vertical Clearance of Span Wires and Brackets From Communication Lines | 238C 135 |
| Table 239-1. | Clearance of Open Vertical and Lateral Conductors | 239E1 140 |
| Table 239-2. | Clearance Between Open Vertical Conductors and Pole Center | 239E2a(1) 141 |
| Table 242-1. | Grades of Construction for Supply Conductors Alone, at Crossing, or on the Same Structures With Other Conductors | 242 144 |
| Table 242-2. | Grades of Construction for Communication Conductors Alone, or in Upper Position of Crossing or on Joint Poles | 242 146 |
| Table 250-1. | Ice, Wind, and Temperature..... | 250C 150 |
| Table 250-2. | Horizontal Wind Pressures on Cylindrical Surfaces..... | 250C 150 |
| Table 251-1. | Temperatures and Constants | 251B3 152 |
| Table 253-1. | Overload Factors for Structures, Crossarms, Guys, Foundation, and Anchors to Be Used with the Strength Factors of Table 261-1A | 253 155 |
| Table 253-2. | Alternate Overload Factors for Wood and Reinforced (Not Prestressed) Concrete Structures to Be Used with the Strength Factors of Table 261-1B..... | 253 156 |
| Table 261-1A. | Strength Factors for Structures, Crossarms, Guys, Foundations, and Anchors for Use with Overload Factors of Table 253-1 | 261M 163 |
| Table 261-1B. | Strength Factors for Structures and Crossarms for Use with Overload Factor of Table 253-2..... | 261D2 164 |
| Table 261-2 | Dimensions of Crossarm Cross Section of Select Southern Pine | |

Contents

| TABLES | RULE | PAGE |
|--------------|--|---------------|
| | and Douglas Fir | 261D2 164 |
| Table 261-3 | Conductor Sizes | 261H1 164 |
| Table 261-4. | Communication Wire Sizes with Respect to Loading District and Span Length | 263E1a(2) 165 |
| Table 263-1. | Sizes for Grade N Supply Line Conductors (AWG for Copper and Aluminum, Stl WG for Steel)..... | 263D1 166 |
| Table 263-2. | Sizes of Service Drops of 750 V or Less | 263E1a(1) 167 |
| Table 273-1. | Insulation Level Requirements | 273 170 |
| Table 341-1. | Clearance Between Supply and Communications Facilities in Joint-Use Manholes and Vaults | 341B2b(5) 184 |
| Table 353-1. | Supply Cable or Conductor Burial Depth | 353D2 190 |
| Table 431-1. | Overhead Supply Lines and Equipment Approach Distances to Exposed Energized Parts | 431 206 |
| Table 441-1. | AC Live Work Minimum Approach Distance | 441A4 209 |
| Table 441-2. | AC Live Work Minimum Approach Distance With Transient Overvoltage Factor..... | 441A4 210 |
| Table 441-3. | AC Live Work Minimum Approach Distance With Transient Overvoltage Factor..... | 441A4 212 |
| Table 441-4. | DC Live Work Minimum Approach Distance With Transient Overvoltage Factor..... | 441A1 214 |
| Table 441-5. | Altitude Correction Factor | 441A4 215 |

| APPENDIX | PAGE |
|---|--|
| Appendix A | Uniform System of Clearances Adopted in the 1990 Edition |
| | Introduction 223 |
| | Clearance Rules and Tables Prior to 1990 224 |
| | Clearance Values Prior to 1990 228 |
| | Summary—Prior Editions 228 |
| | Clearances Subcommittee Activities 228 |
| | The 1990 Changes 228 |
| | Summary 233 |
| Appendix B | Bibliography 234 |
| APPENDIX FIGURES | |
| Figure A1. | Basic Clearance 225 |
| Figure A2. | Additional Clearance Required for High-Temperature Operation 226 |
| Figure A3. | Additional Clearance Required for Long-Span Construction 227 |
| Figure A4. | Clearance at Maximum Sag 232 |
| APPENDIX TABLES | |
| Table A-1. | 229 |
| Table A-2a. | Reference Components of Rule 232 230 |
| Table A-2b. | Reference Components of Rule 234 231 |
| Index | 237 |
| Revision Procedures | 259 |
| Form for Change Proposal | 261 |
| Time Schedule | 262 |
| Working Group Assignments | 263 |
| Tentative Interim Amendments | 265 |

Letter Symbols for Units

This code uses standard symbols for units. They have the following meanings:

| | |
|-------------------|----------------------------|
| A | ampere |
| c | centi (10^{-2}) |
| cm | centimeter |
| cm ³ | cubic centimeter |
| C | degree Celsius |
| ft | foot |
| g | gram |
| g/cm ³ | grams per cubic centimeter |
| ha | hectare |
| Hz | hertz |
| h | hour |
| h | hecto (10^2) |
| in | inch |
| J | joule |
| k | kilo (10^3) |
| kV | kilovolt (1000 volts) |
| kvar | kilovar |
| kVA | kilovoltampere |
| kW | kilowatt |
| l | liter |
| lm | lumen |
| m | meter |
| m | milli (10^{-3}) |
| mA | milliampere |
| mg | milligram |
| mi | mile (statute) |
| mV | millivolt |
| min | minute (time) |
| N | newton |
| Pa | pascal |
| lb | pound |
| s | second (time) |
| ft ² | square feet |
| in ² | square inch |
| var | var |
| V | volt |
| VA | voltampere |
| W | watt |

Section 1. Introduction to the National Electrical Safety Code®

010. Purpose

The purpose of these rules is the practical safeguarding of persons during the installation, operation, or maintenance of electric supply and communication lines and associated equipment.

These rules contain the basic provisions that are considered necessary for the safety of employees and the public under the specified conditions. This code is not intended as a design specification or as an instruction manual.

011. Scope

These rules cover supply and communication lines, equipment, and associated work practices employed by a public or private electric supply, communications, railway, or similar utility in the exercise of its function as a utility. They cover similar systems under the control of qualified persons, such as those associated with an industrial complex or utility interactive system.

NESC® rules do not cover installations in mines, ships, railway rolling equipment, aircraft, or automotive equipment, or utilization wiring except as covered in Parts 1 and 3. For building utilization wiring requirements, see the National Electrical Code® (NEC®), NFPA 70-1993.¹

012. General Rules

- A. All electric supply and communication lines and equipment shall be designed, constructed, operated, and maintained to meet the requirements of these rules.
- B. The utilities, authorized contractors, or other entities, as applicable, performing design, construction, operation, or maintenance tasks for electric supply or communication lines or equipment covered by this code shall be responsible for meeting applicable requirements.
- C. For all particulars not specified in these rules, construction and maintenance should be done in accordance with accepted good practice for the given local conditions known at the time by those responsible for the construction or maintenance of the communication or supply lines and equipment.

013. Application

- A. New Installations and Extensions
 1. These rules shall apply to all new installations and extensions, except that they may be waived or modified by the administrative authority. When so waived or modified, safety shall be provided in other ways.

EXAMPLE: Alternative working methods, such as the use of barricades, guards, or other electrical protective equipment, may be implemented along with appropriate alternative working clearances as a means of providing safety when working near energized conductors.
 2. Types of construction and methods of installation other than those specified in the rules may be used experimentally to obtain information, if done where qualified supervision is provided.
- B. Existing Installations
 1. Where an existing installation meets, or is altered to meet, these rules, such installation is considered to be in compliance with this edition and is not required to comply with any previous edition.
 2. Existing installations, including maintenance replacements, that currently comply with prior editions of the Code, need not be modified to comply with these rules except as may be required for safety reasons by the administrative authority.

¹Information on references can be found in Section 3.